

June 15, 2026

VIA ELECTRONIC FILING

Docket # 2025 NODI

Patrick Doherty
Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Patrick.Doherty@energysafety.ca.gov

RE: PacifiCorp's Response to Notice of Data Inaccuracy – PAD_PC_IAG_20251009_1231

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the Notice of Data Inaccuracy “NODI_PAD_PC_IAG_20251009_1231” (NODI) issued by the Office of Energy Infrastructure Safety (Energy Safety) on May 14, 2026. On October 9, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California.

Energy Safety found the following Data Inaccuracy:

Data Inaccuracy 1. Energy Safety observed that in On Grid Hardening ID 8077661 at coordinates 41.43052973495417, -122.38938973187061, the inspector observed that PC failed to adhere to data accuracy. The data inaccuracy identified in this notice could make it appear as though PC reached the target set in its WMP initiative related to expulsion fuse replacements when it has not. If PC does not address this data inaccuracy and includes the inaccurate data in PC's reporting regarding its WMP initiative related to expulsion fuse replacements, PC may be found to fail to achieve the target for that WMP initiative. This failure may be raised in future NON or in Energy Safety's 2025 Annual Report on PC's WMP Performance.

PacifiCorp Response:

For assets and recent grid hardening work completed near the location identified in the NODI (coordinates 41.43052973495417, -122.38938973187061), PacifiCorp reviewed its 2025 Quarterly Data Report (QDR) and as-built construction records, and conducted a field inspection on May 21, 2026. PacifiCorp discovered that Grid Hardening ID 8077661 was incorrectly reported as an expulsion fuse replacement in the Q2 of the 2025 QDR. The work conducted at the location associated with Grid Hardening ID 8077661 (coordinates 41.430723, -122.389535) actually involved removing a pole as part of an undergrounding project, and no expulsion fuse existed on

June 15, 2026


Page 2

that pole prior to removal. Instead, it appears an expulsion fuse was removed at a nearby location when an overhead transformer was replaced with a pad mounted transformer at coordinates 41.43106, -122.3895, and that fuse removal was erroneously reported under Grid Hardening ID 8077661.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NODI_PAD_PC_IAG_20251009_1231.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,



Carrie Laird
Vice President, Wildfire Mitigation and Emergency Operations

cc: assetperformance@energysafety.ca.gov
Shannon.Greene@energysafety.ca.gov
Yana.Loginova@energysafety.ca.gov
Babak.Kaviani@energysafety.ca.gov
Samuel.Isaiah@energysafety.ca.gov
Ivan.Garcia@energysafety.ca.gov
Patrick.Doherty@energysafety.ca.gov