



June 17, 2026

Crystal Bertolini  
Sr. Supervisor, Wildfire Mitigation Program Compliance  
San Diego Gas & Electric Company (SDG&E)  
8316 Century Park Court, CP32F  
San Diego, CA 92123

## NOTICE OF DATA INACCURACY

Ms. Bertolini:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by San Diego Gas & Electric Company (SDG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues SDG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy may lead to a Notice of Non-Performance (NON) if the inaccuracy causes SDG&E to miss a WMP target or prevents Energy Safety from ensuring that SDG&E performed the targets and statements made in SDG&E's 2025 WMP.

On April 8, 2026, Energy Safety conducted an inspection of San Diego Gas & Electric Company's WMP initiatives in the vicinity of the city of Valley Center, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID P519983, Grid Hardening ID 300000596492\_P519983\_92431 at coordinates 33.329414, -117.104047, the inspector observed that covered conductor was installed on the reported pole; however, no lightning arrester was observed to have been upgraded or installed.

The data inaccuracy identified in this notice could make it appear as though SDG&E reached the target set in its WMP initiative related to equipment inspections, maintenance, and repair when it has not. If SDG&E does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to equipment inspections, maintenance, and repair, SDG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on SDG&E's WMP performance.

Within 30 days from the issuance date of this NODI, SDG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,<sup>1</sup> and the associated file name(s) must begin with the NODI identification number.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

Cc:

Jonathan Woldemariam, SDG&E

[Jwoldemariam@sdge.com](mailto:Jwoldemariam@sdge.com)

Kari Kloberdanz, SDG&E

[kkloberdanz@sdge.com](mailto:kkloberdanz@sdge.com)

Shewit Woldegiorgis, SDG&E

[swoldegiorgis@sdge.com](mailto:swoldegiorgis@sdge.com)

Laura Fulton, SDG&E

[Lfulton@sdge.com](mailto:Lfulton@sdge.com)

Kimberly Siebenthal, SDG&E

[KSiebenthal@sdge.com](mailto:KSiebenthal@sdge.com)

Mary Innamorato, SDG&E

[MInnamorato@sdge.com](mailto:MInnamorato@sdge.com)

WM Compliance Box, SDG&E

[WildfireMitigationCompliance@sdge.com](mailto:WildfireMitigationCompliance@sdge.com)

Yana Loginova, Energy Safety

[Yana.Loginova@energysafety.ca.gov](mailto:Yana.Loginova@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

[AssetPerformance@energysafety.ca.gov](mailto:AssetPerformance@energysafety.ca.gov)

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



# INSPECTION REPORT

Electrical Corporation:	San Diego Gas & Electric Company
Report Number:	PAD_SDGE_SIS_20260408_0959
Date of Inspection:	April 08, 2026
City and/or County of Inspection:	Valley Center, San Diego County
Inspector:	Samuel Isaiah
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 3 (Q3)
Inspection Selection:	Energy Safety viewed the contents of the Q3 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.4.6 – Lightning Arrester Removal and Replacement (WMP.550)
Inspection Purpose:	Assess the accuracy of San Diego Gas & Electric Company’s QDR data, completeness of its work, and performance of WMP requirements.

## WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	P519983	300000596492_P5 19983_92431	33.329414, - 117.104047	Tier 2	8.1.4.6 – Lightning Arrester Removal and Replacement (WMP.550)	Inaccurate data provided on Lighting Arrester Removal and Replacement (Upgrade)

# Observations

On Pole ID P519983, Grid Hardening ID 300000596492\_P519983\_92431 at Valley Center, CA, 92082, 33.329414, -117.104047, the inspector observed that covered conductor was installed, but no lightning arresters were replaced (or upgraded) at the reported pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A. Photo numbers Asset Image 1 and Asset Image 2 depict that no lightning arresters were replaced or upgraded on the pole.

Energy Safety concludes that there are inaccurate data because of these facts:

1. SDG&E reported in the 2025 Q3 QDR that work on WMP Initiative 8.1.4.6 – Lightning Arrester Removal and Replacement (WMP.550) was done at the reported pole.
2. The inspector did not observe any lightning arresters at this pole.



This observation indicates that the data regarding Lightning Arrester Removal and Replacement were not accurate. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

# Exhibits

Exhibit A: Photo Log

**Structure ID:** P519983

Data Inaccuracy 1

 A photograph showing a tall wooden utility pole with multiple cross-arms and power lines. The pole is situated in a dry, hilly landscape under a clear blue sky.	 A close-up photograph of the utility pole. It features a white warning sign with a lightning bolt icon and the text: "WARNING Hazardous voltage above. KEEP OFF! Can shock, burn, or cause death." Below the sign is a yellow vertical label with the structure ID "P519983" and a yellow horizontal band at the bottom.
<p><b>General Image1:</b> Overall structure</p>	<p><b>General Image2:</b> Structure ID</p>



**Asset Image 1:** Lighting arresters not present



**Asset Image 2:** Lighting arresters not present