



June 17, 2026

Daniel Kushner  
Senior Director, Electric Risk & Compliance  
Pacific Gas and Electric Company  
300 Lakeside Drive  
Oakland, CA 94612

## **NOTICE OF DATA INACCURACY**

Mr. Kushner:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by Pacific Gas and Electric Company (PG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PG&E to miss a WMP target or prevents Energy Safety from ensuring that PG&E performed the targets and statements made in PG&E's 2025 WMP.

On November 5, 2025, Energy Safety conducted an inspection of Pacific Gas and Electric Company's WMP initiatives in the vicinity of the city of Cool, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 121901742, Grid Hardening ID 35305310 at coordinates 38.8989112519005, -120.947950005085, the inspector observed that PG&E failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PG&E reached the target set in its WMP initiative related to covered conductor when it has not. If PG&E does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to covered conductor, PG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on PG&E's WMP performance.

Within 30 days from the issuance date of this NODI, PG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,<sup>1</sup> and the associated file name(s) must begin with the NODI identification number.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

Cc:

Mandy Knockaert, PG&E

[ARKN@pge.com](mailto:ARKN@pge.com)

Rahima Manderola, PG&E

[R12W@pge.com](mailto:R12W@pge.com)

Savannah Torres, PG&E

[S6KZ@pge.com](mailto:S6KZ@pge.com)

Electric Data Requests

[ElectricDataRequests@pge.com](mailto:ElectricDataRequests@pge.com)

WS Compliance, PG&E

[WSComplianceMailbox@pge.com](mailto:WSComplianceMailbox@pge.com)

Babak Kaviani, Energy Safety

[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

[AssetPerformance@energysafety.ca.gov](mailto:AssetPerformance@energysafety.ca.gov)

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



## INSPECTION REPORT

Electrical Corporation:	Pacific Gas and Electric Company
Report Number:	PAD_PGE_BKA_20251105_1239
Date of Inspection:	November 5, 2025
City and/or County of Inspection:	Cool, El Dorado County
Inspector:	Babak Kaviani
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 2 (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.1 – Covered Conductor Installation – Distribution
Inspection Purpose:	Assess the accuracy of Pacific Gas and Electric Company’s QDR data, completeness of its work, and performance of WMP requirements.

## WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	121901742	35305310	38.8989112519005, -120.947950005085	Tier 2	8.1.2.1 – Covered Conductor Installation – Distribution	Inaccurate data provided on covered conductor installation.

# Observations

On Pole ID 121901742, Grid Hardening ID 35305310 at Mile 4.1 State Hwy 193 E, Cool, CA, 95614, USA, 38.8989112519005, -120.947950005085, the inspector observed no covered conductor installation on the middle phase on the west side of the pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there are inaccurate data because of these facts:

1. PG&E reported in the 2025 Q2 QDR that work on WMP initiative 8.1.2.1 – Covered Conductor Installation – Distribution was completed at this location.
2. The inspector did not observe covered conductor installation on the middle phase on the west side of the Pole ID 121901742.
3. The inspector observed bare conductor on the middle phase on the west side of the Pole ID 121901742.

This observation indicates that the data regarding Covered Conductor Installation – Distribution were not accurate. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

# Exhibits

Exhibit A: Photo Log

Structure ID: 121901742

Data Inaccuracy 1

 A photograph showing a wet asphalt road with a double yellow line. In the background, there are utility poles with power lines and some trees under an overcast sky.	 A close-up photograph of a dark grey utility pole. The pole has two yellow reflective bands near the bottom. A small yellow label with the number '121901742' is attached to the pole. The background shows some greenery and trees.
<p><b>G1mg1:</b> Overall area</p>	<p><b>G1mg2:</b> Structure ID</p>



**IA1Img1:** Close up view of pole 121901742 showing a bare conductor on the west side of the middle phase



**IA1Img2:** Close up view of pole 121901742 showing a bare conductor on the west side of the middle phase