



May 14, 2026

Daniel Kushner  
Senior Director, Electric Risk & Compliance  
Pacific Gas and Electric Company  
300 Lakeside Drive  
Oakland, CA 94612

## **NOTICE OF NON-PERFORMANCE**

Mr. Kushner:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by Pacific Gas and Electric Company (PG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of non-performance requiring correction. Energy Safety therefore issues PG&E a Notice of Non-Performance (NON), identifying non-performance with its approved WMP.

On February 25, 2026, Energy Safety conducted an inspection of PG&E's WMP initiatives in the vicinity of the city of Angwin, California. The inspection report is enclosed herewith. Energy Safety found the following deficiencies:

Deficiency 1. Energy Safety observed that in implementing 2025 WMP initiative 8.1.2.10.5 – Non-Exempt Expulsion Fuses, PG&E failed to complete the installation of non-exempt expulsion fuses on Pole ID 110500257, Grid Hardening ID 31742800 at coordinates 38.5649660898935, -122.439116400552. Energy Safety considers this non-performance to be in the Minor risk category. PG&E must complete a corrective action for this deficiency by 12 months of this notice.

Within 30 days from the issuance date of this NON, the electrical corporation must provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified deficiency or deficiencies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NON Docket,<sup>1</sup> and the associated file name(s) must begin with the NON identification number.

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NON>

Prior to its response, the electrical corporation may request an informal conference with Energy Safety for the purpose of disputing any issues raised in this NON no later than 10 business days before the response deadline.<sup>2</sup> Requests for informal conference with Energy Safety must be e-mailed to [AssetPerformance@energysafety.ca.gov](mailto:AssetPerformance@energysafety.ca.gov), with a copy sent to all Energy Safety staff identified in the NON.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

Cc:

Mandy Knockaert, PG&E

[ARKN@pge.com](mailto:ARKN@pge.com)

Rahima Manderola, PG&E

[R12W@pge.com](mailto:R12W@pge.com)

Savannah Torres, PG&E

[S6KZ@pge.com](mailto:S6KZ@pge.com)

Electric Data Requests

[ElectricDataRequests@pge.com](mailto:ElectricDataRequests@pge.com)

WS Compliance, PG&E

[WSComplianceMailbox@pge.com](mailto:WSComplianceMailbox@pge.com)

Romeo Marroquin Ajcac, Energy Safety

[Romeo.MarroquinAjcac@energysafety.ca.gov](mailto:Romeo.MarroquinAjcac@energysafety.ca.gov)

Babak Kaviani, Energy Safety

[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

[assetperformance@energysafety.ca.gov](mailto:assetperformance@energysafety.ca.gov)

---

<sup>2</sup> Energy Safety Performance Guidelines, p. 4



# INSPECTION REPORT

## Overview

### Inspection Categories

The Office of Energy Infrastructure Safety (Energy Safety) conducts inspections to verify the work performed by an electrical corporation as reported in an approved Wildfire Mitigation Plan (WMP) or subsequent filing, and to assess general conditions of electrical infrastructure that may adversely affect an electrical corporation’s wildfire risk.

A Notice of Non-Performance (NON) is issued for any deficiencies discovered during an inspection related to an electrical corporation’s performance of its WMP.

### Correction Timelines

Deficiencies must be corrected in a timely manner. Energy Safety may prescribe a timeframe for resolution of a deficiency.<sup>3</sup> If Energy Safety assigns a risk category to a deficiency, an electrical corporation must correct the deficiency as required per the timelines provided in Table 1.<sup>4</sup>

**Table 1. Risk Category and Correction Timelines**

Risk Category	Deficiency correction timeline
Severe	<ul style="list-style-type: none"><li>• Immediate resolution</li></ul>
Moderate	<ul style="list-style-type: none"><li>• 2 months (in High Fire Threat District (HFTD) Tier 3)</li><li>• 6 months (in HFTD Tier 2)</li><li>• 6 months (if relevant to worker safety; not in HFTD Tiers 2 or 3)</li></ul>
Minor	<ul style="list-style-type: none"><li>• 12 months or resolution scheduled in WMP update</li></ul>

---

<sup>3</sup> Gov. Code section 15475.2(a)(2)

<sup>4</sup> Energy Safety Performance Guidelines, p. 4



# Inspection Summary

Table 2 provides a summary of the selection of the WMP inspection location and initiative. Table 3 provides a summary of the deficiency or deficiencies found during the inspection. Details regarding the inspection that identified the deficiency or deficiencies are provided in the Inspections Details Section below.

***Table 2: Inspection Location and Initiative Summary***

Electrical Corporation:	Pacific Gas and Electric Company
Report Number:	PAD_PGE_RMA_20260225_1347
Inspector:	Romeo Marroquin Ajcac
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 3 (Q3)
Inspection Selection:	Energy Safety viewed the contents of the Q3 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.10.5 - Non-Exempt Expulsion Fuses
Date of Inspection:	February 25, 2026
City and/or County of Inspection:	Angwin, Napa County
Inspection Purpose:	Assess the accuracy of Pacific Gas and Electric Company’s QDR data, completeness of its work, and performance of WMP requirements.

***Table 3: WMP Inspection Deficiencies***

Deficiency #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Severity	Deficiency Description
Deficiency 1	110500257	31742800	38.5649660898935, -122.439116400552	Tier 3	8.1.2.10.5 - Non-Exempt Expulsion Fuses	Minor	Failure to complete work on non-exempt expulsion fuses.

# Inspection Details

## Deficiency 1

### **Relevant Requirement:**

PG&E's WMP states the following regarding initiative number 8.1.2.10.5:

1. "This program reduces the consequence of potential ignitions by replacement and/or removal of non-exempt fuses. In general, the risk of ignition associated to a fuse on a line is reduced through the complete removal and/or replacement of non-exempt equipment with exempt equipment."<sup>5</sup>

PG&E's states in their job aid TD-2908P-01-JA230 Replacing High Voltage Fuses:

1. "Do not leave outdoor fused cutouts, including 44H and 63H-type cutouts, hanging in open position for more than 1 week."

### **Findings:**

In the 2025 Q3 Quarterly Data Report submission, PG&E reported that work on WMP initiative 8.1.2.10.5 – Non-Exempt Expulsion Fuses was completed at Pole ID 110500257, Grid Hardening ID 31742800 at 1-91 Cold Springs Rd, Angwin, CA, 94508, USA, 38.5649660898935, -122.439116400552. At this location, the inspector observed that an exempt fuse was left in the open position in its cutout. The inspector's observation is documented in Deficiency 1 photographs, which are attachments to this report. Photo numbers IA1Img1 and IA1Img2 depict an exempt fuse in the open position in its cutout.

Energy Safety concludes that there is a deficiency because of these facts:

1. The inspector observed an exempt fuse in the open position in its cutout.

---

<sup>5</sup> Pacific Gas & Electric Company, "PG&E 2023-25 Approved Wildfire Mitigation Plan R8," February 13, 2025, p. 465. [Online]. Available: <https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=57976&shareable=true>

# Exhibits

Exhibit A: Photo Log

Structure ID: 110500257

Deficiency 1



**G1mg1:** Overall Structure



**G1mg2:** Structure ID



**IA1mg1:** Exempt fuse in the open position in its cutout.



**IA1mg2:** Exempt fuse in the open position in its cutout (close view).