

June 5, 2026

Patrick Doherty, Program Manager
Performance Assessment Division
Office of Energy Infrastructure Safety
California Natural Resources Agency
715 P Street 20th Floor
Sacramento, CA 95814

BY ENERGY SAFETY E-FILING

SUBJECT: Southern California Edison Company's Response to Notice of Non-Performance (NON_PAD_SCE_BKA_20260128_1023)

Dear Mr. Doherty:

Southern California Edison Company (SCE) appreciates the opportunity to provide this response to the finding identified in the Notice of Non-Performance –

NON_PAD_SCE_BKA_20260128_1023 which SCE received on **May 19, 2026 (Notice)**, based on the Office of Energy Infrastructure Safety's (Energy Safety) field inspections conducted in SCE's service area on **January 28, 2026**. SCE appreciates Energy Safety's efforts to identify, communicate and work together to resolve potential wildfire risks.

If you have any questions, or require additional information, please contact Liz Leano at 626-302-3662 or Elizabeth.Leano@sce.com.

Sincerely,

//s//

Brandon Tolentino
Vice President of Wildfire and Business Resiliency
Southern California Edison

SCE Response

Finding:

Notice	#	Structures
NON_PAD_SCE_BKA_20260128_1023	1	4452209E

Summary of Findings:

Energy Safety's Notice states that in implementing 2025 WMP initiative 8.1.2.1.1 – Covered Conductor, SCE failed to complete work on covered conductor on Pole ID 4452209E, Grid Hardening ID TD2121066-4452209E at coordinates 34.4212494435061, -118.48600214025.

Energy Safety states that it “considers this non-performance to be in the Minor risk category.”¹

Response:

SCE confirms that covered conductor installation was completed on structure 4452209E in accordance with the 2025 Wildfire Mitigation Plan initiative 8.1.2.1.1 – Covered Conductor, as previously reported in SCE's Quarterly Data Report.

During a subsequent inspection conducted on May 22, 2026, wildlife covers on structure 4452209E were identified as dislodged. This condition likely resulted from weather or other environmental factors following the covered conductor installation.

SCE has created notification #415360275 to remediate the dislodged wildfire covers, with an estimated completion date of November 22, 2026.

¹ Notice, p. 1.