



June 11, 2026

BY ENERGY SAFETY E-FILING

Elizabeth McAlpine

Supervisory Environmental Scientist | Environmental Science

Division Office of Energy Infrastructure Safety

Elizabeth.McApline@energysafety.ca.gov

Docket: 2025 NON

Subject: Bear Valley Electric Service, Inc. Response to Notice of Performance-
NON_ESD_BVES_RGA_20260505_1247

Dear Ms. McAlpine:

Bear Valley Electric Service, Inc. (BVES) is providing a response to the Notice of Performance- NON_ESD_BVES_RGA_20260505_1247. The enclosed response describes corrective actions taken by BVES to remedy the findings identified in the above notice.

If you have any questions, or require additional information, please contact Jared Hennen at 909-255-2948 or Jared.Hennen@bvesinc.com.

Sincerely,

//s//

Jared Hennen

Wildfire Mitigation and Reliability

Engineer Bear Valley Electric Service, Inc.

BVES RESPONSE

Notice of Non-Performance: NON_ESD_BVES_RGA_20260505_1247

Finding: Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) conducted inspections of work completed by Bear Valley Electric Service, Inc. (BVES) in accordance with its 2025 Wildfire Mitigation Plan (WMP). During the inspections, Energy Safety determined the existence of non-performance requiring correction. Energy Safety therefore issues BVES a Notice of Non-Performance (NON).

On May 5, 2026, Energy Safety conducted an inspection of BVES's WMP initiatives in the vicinity of Big Bear City, California in High Fire Threat District (HFTD) Tier 2 and State Responsibility Area (SRA). The inspection report is enclosed herewith. Energy Safety found the following deficiency:

Deficiency 1. Energy Safety observed that BVES failed to implement its 2025 WMP initiative 8.2.3.4 Fall-in Mitigation, by not removing a dead, rotten or diseased tree near coordinates 34.26713531028709, -116.84599287356302. Energy Safety considers this non-performance to be in the Moderate risk category. BVES must complete a corrective action for this non-performance by six months from the date of this notice.

Response: BVES received NON_ESD_BVES_RGA_20260505_1247 on May 12, 2026 regarding a dead tree located at 945 Sierra Ave, Big Bear City. BVES dispatched a vegetation management crew to remove the tree. The work was completed the same day, and all wood and debris were removed from the site. Please see the photographs below for before and after images of the tree, labeled "1".



P.O. Box 1547, 42020 Garstin Drive, Big Bear Lake, California, 92315
Tel: (909) 866-4678 * Fax (909) 866-5056

Before.



Before.

P.O. Box 1547, 42020 Garstin Drive, Big Bear Lake, California, 92315
Tel: (909) 866-4678 * Fax (909) 866-5056



After work was completed.