



**CALIFORNIA UNDERGROUND SAFETY BOARD
INVESTIGATION DIVISION**

INVESTIGATION REPORT

Date: June 24, 2026

Case No.: N2425571

Violation:

Steven L Raffaelli Construction
Government Code § 4216.2(b):

Excavating without first notifying the regional
notification center of intent to excavate.

Executive Summary:

On August 14, 2024, Steven L. Raffaelli Construction dug with a shovel to install a fence post without first contacting the regional notification center and damaged an ½-inch plastic natural gas installation. In the emergency response to the incident, the San Bernardino County Fire Department notified the surrounding homeowners to shelter in place. No one was injured and no equipment, other than the ½-inch plastic natural gas installation, was damaged.

Reporting Party Information:

Southern California Gas Company
555 West 5th Street
Los Angeles, California 90013

Date of Incident:

August 14, 2024

Location of the Incident:

590 Lanes End Trail
Crestline, California 92325

Operator:

Southern California Gas Company
555 West 5th Street
Los Angeles, California 90013

Excavator:

Steven L. Raffaelli Construction
24600 Albrun Drive
Crestline, California 92325

Subsurface Installation Type Damaged:

1/2 inch plastic natural gas installation

Notification of the Incident

On September 11, 2024, Southern California Gas Company (SoCalGas) submitted a notification of an incident to the California Underground Safety Board. The notification stated, "Raffaelli Construction while excavating for fence post struck 1/2" plastic service with No USA." (Exh. 1.)

On November 21, 2024, Investigator emailed SoCalGas' Pipeline Safety & Compliance team to clarify the date and time of when it was notified of this incident. (Exh. 2.) On December 5, 2024, Carlos R. Chavez with SoCalGas' Pipeline Safety & Compliance emailed stating that it was notified of the incident on August 14, 2024, at 10:39 a.m. (Exh. 3.)

Location of the Incident

Luis Robles, Damage Prevention Analyst for SoCalGas, stated on the damage notification that the damage occurred at 590 Lanes End in Fontana and included a "USB Damage Report Form Raffaelli.docx" attachment with their damage notification that shows the damage occurring at 590 Lanes End Tri in Crestline. (Exh. 1.) The emergency response report states the location is 5908 Lanes End Trail in Valley of Enchantment. (Exh. 10.) An audio file provided by the San Bernardino County Fire Department states the cross street is Seeley Way. (Exh. 10, WAV File 3.) The investigator used Google Maps to confirm the incident location was in the city of Crestline using the Lanes End Trail and the cross street of Seeley Way. Google Maps shows the street name as Lane's End Trail. Various reports submitted show the street name without the

apostrophe.




Photo 1: Google Map image of the incident created by the investigator depicting the location of the address of 590 Lane's End Trail.

Excavation and Damage

Government Code section 4216(g) defines “excavation” to be the use of tools or equipment to move or displace earth, rock, or other material in the ground.

On November 7, 2024, Investigator had a telephone conversation with Nori Day (Day), Office Manager of Steven L. Raffaelli Construction, after she called concerning the Board's Questionnaire. She said that her boss told her to deal with this, so she would prefer to talk it through since she wasn't too familiar with it. (Exh. 4.)

Day stated that Steven L. Raffaelli had been a contractor for 25 years and that Steven L. Raffaelli Construction had been hired to dig and install fence posts at 590 Lanes End Trail, Crestline, California 92325, from August 13, 2024, to August 16, 2024. Day said their employee, Carlos, had been digging with a shovel for a fence post on August 14, 2024, when he hit something. Day stated they were only digging 16 to 18 inches and damaged a ½-inch gas line. (Exh. 5.)

Excavation and Identity of the Excavator

Government Code section 4216(h) defines an excavator to be “any person, firm, contractor or subcontractor, owner, operator, utility, association, corporation, partnership, business trust, public agency, or other entity that, with their own employees or equipment, performs any excavation.”

Steven L. Raffaelli Construction was licensed, as of November 4, 2024, by the Contractors State License Board, holding license number 670334, with C33 – Painting and Decorating, B –

General Building, C39 – Roofing, C-61/D24 - Metal Products, and C36 - Plumbing Classifications. (Exh. 6.)

Steven L. Raffaelli Construction Did Not Contact the Regional Notification Center Before Excavating

Government Code section 4216.2(b) states that an excavator planning to excavate shall notify the appropriate regional notification center of the excavator's intent to excavate at least two working days, and not more than 14 calendar days, before beginning that excavation.

Steven L. Raffaelli Construction did not notify the regional notification center prior to digging with a shovel for a fence post on August 14, 2024. Day stated the reason that Steven L. Raffaelli Construction did not contact the regional notification center prior to digging was that the gas lines are buried at twenty-four inches, and they were only digging 16 to 18 inches. (Exh. 5.)

On November 4, 2024, Investigator emailed Amber Dahl, Safety Awareness Director at DigAlert, requesting ticket information for 590 Lane's End Trail, Crestline, California 92325, for July 14, 2024, through August 30, 2024. (Exh. 7.)

Director Dahl emailed its response on November 5, 2024, confirming that a ticket did not exist at 590 Lane's End Trail, Crestline, California 92325, on August 14, 2024. (Exh. 8.)

Steven L. Raffaelli Construction Did Call 911 Emergency Services Upon Gas Escape

Government Code section 4216.4(c)(1) requires an excavator to call 911 emergency services upon discovering or causing damage to a gas or hazardous liquid pipeline subsurface installation in which the damage results in the escape of any flammable, toxic, or corrosive gas or liquid.

On August 14, 2024, Steven L Raffaelli Construction was digging with a shovel for a fence post and damaged a ½-inch gas line. Someone from Steven L. Raffaelli Construction called 911. (Exh. 5.)

On August 14, 2024, the San Bernardino County Fire Department responded to the 911 call for a gas leak at 590 Lanes End Trail, Valley of Enchantment, CA 92325 at 10:30 a.m. The San Bernardino County Fire Department notified the surrounding homeowners to shelter in place. (Exh. 10)

Finding:

1. Steven L. Raffaelli Construction failed to contact the regional notification center before beginning excavation on August 14, 2024, at 590 Lanes End Trail, Crestline, California 92325, where it had been digging with a shovel to install fence posts.

Investigator	Supervisor
Angel Barton	Anona Bonner
Signature	Signature
/s/ Angel Barton	/s/ Anona Bonner

Exhibit List:

Exhibit No.	Description	Date	Received From
1.	Incident report submitted to the Underground Safety Board	Received on 9/11/2024	Southern California Gas Company
2.	Investigator's email to SoCalGas requesting clarification on dates and times of the underlying incident	Emailed on 11/21/2024	
3.	Email from SoCalGas providing the correct dates and times of the incident	Received on 12/5/2024	Carlos R. Chavez Pipeline Safety & Compliance SoCalGas
4.	Report of Interview with Office Manager, Nori Day, prepared by Angel Barton	Telephone Interview conducted by Angel Barton on 11/7/2024	
5.	Report of Interview with Office Manager, Nori Day, prepared by Angel Barton	Telephone Interview conducted by Angel Barton on 11/13/2024	
6.	Contractor's license detail for License No. 670334 obtained from the Contractors State License Board's website	Downloaded on 11/4/2024	Contractors State License Board's website at https://www.cslb.ca.gov/onlineservices/checklicense/checklicense.aspx
7.	Investigator's email to DigAlert requesting	Emailed on 11/4/2024	

	ticket information on the underlying job to this incident		
8.	Email from DigAlert stating there was no valid ticket for the underlying job to this incident	Received on 11/5/2024	Amber Dahl Safety Awareness Director DigAlert
9.	Email to San Bernardino County Fire Department stating no records were found for the public records request	Emailed on 1/24/2025	
10.	Email from San Bernardino County Fire Department stating no records were found for the public records request	Received on 1/29/2025	San Bernardino County Fire Department

Exhibit 1

No-Ticket Damage Reporting Form

Submitted: September 11, 2024 12:46 PM

Reporter Information

Provide the names, titles, phone numbers, and email addresses of all individuals who are involved in reporting this damage or contributing to the answers to these questions

Full Name

Luis Robles

Title

Damage Prevention Analyst

Phone Number

657-724-9205

E-mail address

LRobles@socalgas.com

Company

Provide the name, address, phone number, email address, and, if applicable, the Regional Notification Center (member code for your company).

Company Name

Socal Gas

Address

555 W 5th St., Los Angeles , 90013

Phone Number

562-202-0687

Email Address

SCGDamagePrevention@socalgas.com

Regional Notification Center member code

Other Contacts

Is the photographer same as the primary reporter named above?

Yes

Incident Information

What was the date and approximate time of the incident?

August 14, 2024 10:43 AM

What is the address where your facility was damaged on 8/14/2024?

Damage Street Address

590 Lanes End

Damage County

San Bernardino

Damage City

Fontana

Damage Cross Street 1

HWY 38

Damage Cross Street 2

Other Damage location description

Does Socal Gas own, operate or maintain the facility damaged on 8/14/2024?

Yes

What type of excavation did you observe on 8/14/2024 at that address?

Fencing

Describe the excavation activity you identified.

excavation with pole hole digger with no USA

What excavation companies did you observe on 8/14/2024?

Company Name

Raffaelli Construction

Company Address

PO Box 102, Rimforest , 92378

Phone Number

909-908-5423

Email Address

sraffaelli@raffaelliconstruction.com

Did this company damage the facility?

Yes

Provide the name, title, phone number, and email address for at least one contact for each excavation company working at or near incident address on date of incident. If you have more than one contact, please provide all of them. Email addresses are required for submission of this form.

Personnel Name

Steve Raffaelli

Title

CEO

Phone Number

909-908-5423

Email Address

sraffaelli@raffaelliconstruction.com

Notification Details

Was Socal Gas notified of the proposed excavation by the Regional Notification Center before 8/14/2024?

No

What date and time did you learn of the damage to the facility?

August 14, 2024 10:43 AM

How did Socal Gas learn of the damage to the facility?

intercompany email notification

Facility Damaged

What kind of facility was damaged on 8/14/2024?

Natural Gas

Natural Gas

What type of material was the damaged facility?

Plastic

Facility diameter (inches)?

0.5

Incident Details

What kinds of excavation equipment did you observe at the location of the damaged facility?

Other hand tools

Do you know what equipment damaged the facility?

Yes

What equipment damaged the facility?

Other hand tools

What information are you relying on regarding damage to the facility?

Photographs, Interview with excavator

Did Socal Gas contact the Regional Notification Center before repairing the damaged facility?

No

Provide any other relevant information about the damage on 8/14/2024.

Raffaelli Construction while excavating for fence post struck 1/2" plastic service with No USA.

Damages

Were there any injuries to any personnel or bystanders due to the damage to your facility on 8/14/2024?

No

Was any property damaged other than the damaged facility?

No

Was there a fire caused by this damage on 8/14/2024?

No

Was there an evacuation of any nearby homes or businesses caused by this damage on 8/14/2024?

No

Provide an estimate of the number of your customers whose service was interrupted by this damage on 8/14/2024.

1

Conclusions

What date and time were repairs completed to the damaged facility?

August 14, 2024 1:00 PM

Please explain why you think the facility was damaged on 8/14/2024?

1/2" plastic gas service was damaged with gas escape.

Is there any other information which you feel is important to share about this incident?

Not counting your answers to these questions, did Socal Gas create an investigatory or incident report pertaining to the damage on 8/14/2024?

Yes

Please attach investigatory or incident report here.

USB Damage Report Form Raffaelli.docx, 0.03MB

Have your answers to these questions and or the documents you are sending today been reviewed, changed or amended by anyone?

No

Files

Please attach all Facility Repair Orders.

Please attach all Photos.



Date and time photographed

August 14, 2024 12:30 PM

Photographer Name

Luis Robles



Date and time photographed

August 14, 2024 12:30 PM

Photographer Name

Luis Robles



Date and time photographed

August 14, 2024 12:30 PM

Photographer Name

Luis Robles



Date and time photographed

August 14, 2024 12:30 PM

Photographer Name

Luis Robles



Date and time photographed
August 14, 2024 12:30 PM

Photographer Name
Luis Robles



Date and time photographed

August 14, 2024 12:30 PM

Photographer Name

Luis Robles

Additional Records

Business cards, photo of company vehicles onsite, etc.

Image _47_.jpg, 0.18MB

Reference Number

N2425571

Incident Time: 10:43PM_____

Incident Date: _08/14/2024_____

Incident Location:

City/County: _____Crestline/San Bernardino_____

Address/Location: 590 Lanes End Tri_____

Incident Cause: _____Excavating without a USA ticket_____

Gas Equipment Affected: _____Main_____

Material: _____Plastic_____ Pipe size: _____1 / 2 "_____

Dig In Information:

USA notification required: **Yes / No**

USA notified: **Yes / No** USA # _____

Facilities properly marked: **Yes / No**

Name of Excavator: _____Raffaelli Construction_____

Excavator Contact Person: _____Steve Raffaelli_____

Phone: _____909-908-5423_____

On Scene:	Date	Time
Company Personnel on Scene	_____08/14/24_____	_____10:54PM_____
Gas Flow Stopped	_____08/07/24_____	_____1:00PM_____

Customer Outages (Quantity) _____1_____

Summary of incident: Raffaelli Construcion hit 1/2" plastic service with a post hole digger. They did not have a valid USA ticket



DEPARTMENT OF CONSUMER AFFAIRS
CONTRACTORS
STATE LICENSE BOARD



Consumers



Licensees



Applicants



Online Services



Media



Resources

[Home](#) | [Online Services](#) | [License Details](#)

Contractor's License Detail for License # 670334

DISCLAIMER: A license status check provides information taken from the CSLB license database. Before relying on this information, you should be aware of the following limitations.

- ▶ CSLB complaint disclosure is restricted by law ([B&P 7124.6](#)) If this entity is subject to public complaint disclosure click on link that will appear below for more information. Click [here](#) for a definition of disclosable actions.
- ▶ Only construction related civil judgments reported to CSLB are disclosed ([B&P 7071.17](#)).
- ▶ Arbitrations are not listed unless the contractor fails to comply with the terms.
- ▶ Due to workload, there may be relevant information that has not yet been entered into the board's license database.

Business Information

STEVEN L RAFFAELLI CONSTRUCTION
P O BOX 102
RIMFOREST, CA 92378
Business Phone Number: [\(909\) 273-7662](#)

Entity Sole Ownership
Issue Date 04/29/1993
Expire Date 04/30/2026

License Status

This license is current and active.

All information below should be reviewed.

Classifications

- ▶ [C33 - PAINTING AND DECORATING](#)
- ▶ [B - GENERAL BUILDING](#)
- ▶ [C39 - ROOFING](#)
- ▶ [C31 - METAL PRODUCTS](#)

Online Services Quick Hits

- ▶ [Check a License or HIS Registration](#)
- ▶ [Find My Licensed Contractor](#)
- ▶ [Frequently Asked Questions](#)
- ▶ [Forms and Applications](#)
- ▶ [Guides and Publications](#)
- ▶ [CSLB Laws and Regulations](#)
- ▶ [List of All CSLB Fees](#)
- ▶ [License Classifications](#)
- ▶ [Contractor Newsletter](#)
- ▶ [Application Status](#)
- ▶ [Application Status \(Secured\)](#)
- ▶ [Application Status by Personnel Name](#)
- ▶ [Application Status by Business Name](#)
- ▶ [CSLB Email Login](#)

Online Services



Exhibit 2

Barton, Angel@EnergySafety

From: Barton, Angel@EnergySafety
Sent: Thursday, November 21, 2024 3:43 PM
To: es-pscscg@semprautilities.com
Cc: Alcantar, Daysi@EnergySafety
Subject: Requesting Verification for Reference Number N2425571 - Underground Safety Board
Attachments: No-Ticket Damage Reporting Form.pdf; USB Damage Report Form.pdf

Follow Up Flag: Follow up
Flag Status: Completed

Good afternoon Southern California Gas Company,

I am requesting verification for a no-ticket damage that was reported to our office on September 11, 2024, reference number N2425571. The incident address is 590 Lanes End, Fontana, San Bernardino, near Highway 38 according to the No-Ticket Damage Reporting Form.

I have attached the documents as reference and need verification on the chronological dates and times of the following:

- On the USB Damage Report Form it states the date of August 14, 2024, with an incident time of 10:43 pm., the scene time of 10:54 pm., and a gas flow stoppage on August 7, 2024, was at 1:00 pm.
- On the No-Ticket Damage Reporting Form it states the date of August 14, 2024, with an incident time of 5:43 pm., the time SCG learned about the damage was at 5:43 pm., and the time of completed repairs was at 8:00 pm.

Please clarify and confirm, the correct dates and times.

Cordially,

Angel Barton

Investigator

Underground Infrastructure Directorate

Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list.](#)

No-Ticket Damage Reporting Form

Submitted: September 11, 2024

Reporter Information

Provide the names, titles, phone numbers, and email addresses of all individuals who are involved in reporting this damage or contributing to the answers to these questions

Full Name

Luis

Title

Damage Prevention Analyst

Phone Number

657-724-9205

E-mail address

LRobles@socalgas.com

Company

Provide the name, address, phone number, email address, and, if applicable, the Regional Notification Center (member code for your company).

Company Name

Socal Gas

Address

555 W 5th St.

Phone Number

562-202-0687

Email Address

SCGDamagePrevention@socalgas.com

Regional Notification Center member code

Other Contacts

Is the photographer same as the primary reporter named above?

Yes

Incident Information

What was the date and approximate time of the incident?

August 14, 2024 5:43 PM

What is the address where your facility was damaged on 8/14/2024?

Damage Street Address

590 Lanes End

Damage County

San Bernardino

Damage City

Fontana

Damage Cross Street 1

HWY 38

Damage Cross Street 2

Other Damage location description

Does Socal Gas own, operate or maintain the facility damaged on 8/14/2024?

Yes

What type of excavation did you observe on 8/14/2024 at that address?

Fencing

Describe the excavation activity you identified.

excavation with pole hole digger with no USA

What excavation companies did you observe on 8/14/2024?

Company Name

Raffaelli Construction

Company Address

PO Box 102

Phone Number

909-908-5423

Email Address

sraffaelli@raffaelliconstruction.com

Did this company damage the facility?

Yes

Provide the name, title, phone number, and email address for at least one contact for each excavation company working at or near incident address on date of incident. If you have more than one contact, please provide all of them. Email addresses are required for submission of this form.

Personnel Name

Steve

Title

CEO

Phone Number

909-908-5423

Email Address

sraffaelli@raffaelliconstruction.com

Notification Details

Was Socal Gas notified of the proposed excavation by the Regional Notification Center before 8/14/2024?

No

What date and time did you learn of the damage to the facility?

August 14, 2024 5:43 PM

How did Socal Gas learn of the damage to the facility?

intercompany email notification

Facility Damaged

What kind of facility was damaged on 8/14/2024?

Natural Gas

Natural Gas

What type of material was the damaged facility?

Plastic

Facility diameter (inches)?

0.5

Incident Details

What kinds of excavation equipment did you observe at the location of the damaged facility?

Other hand tools

Do you know what equipment damaged the facility?

Yes

What equipment damaged the facility?

Other hand tools

What information are you relying on regarding damage to the facility?

Photographs, Interview with excavator

Did Socal Gas contact the Regional Notification Center before repairing the damaged facility?

No

Provide any other relevant information about the damage on 8/14/2024. Raffaelli Construction while excavating for fence post struck 1/2" plastic service with No USA.

Damages

Were there any injuries to any personnel or bystanders due to the damage to your facility on 8/14/2024?

No

Were there any fatalities?

Was any property damaged other than the damaged facility?

No

Was there a fire caused by this damage on 8/14/2024?

No

Was there an evacuation of any nearby homes or businesses caused by this damage on 8/14/2024?

No

Provide an estimate of the number of your customers whose service was interrupted by this damage on 8/14/2024.

1

Conclusions

What date and time were repairs completed to the damaged facility?

August 14, 2024 8:00 PM

Please explain why you think the facility was damaged on 8/14/2024?

1/2" plastic gas service was damaged with gas escape.

Is there any other information which you feel is important to share about this incident?

Not counting your answers to these questions, did Socal Gas create an investigatory or incident report pertaining to the damage on 8/14/2024?

Yes

Please attach investigatory or incident report here.

USB Damage Report Form Raffaelli.docx, 0.03MB

Have your answers to these questions and or the documents you are sending today been reviewed, changed or amended by anyone?

No

Files

Please attach all Facility Repair Orders.

Please attach all Photos.



Date and time photographed

August 14, 2024 7:30 PM

Photographer Name

Luis Robles



Date and time photographed

August 14, 2024 7:30 PM

Photographer Name

Luis Robles



Date and time photographed

August 14, 2024 7:30 PM

Photographer Name

Luis Robles



Date and time photographed
August 14, 2024 7:30 PM

Photographer Name
Luis Robles



Date and time photographed
August 14, 2024 7:30 PM

Photographer Name
Luis Robles



Date and time photographed

August 14, 2024 7:30 PM

Photographer Name

Luis Robles

Additional Records

Business cards, photo of company vehicles onsite, etc.

Image _47_.jpg, 0.18MB

Reference Number
N24255

Incident Time: 10:43PM_____

Incident Date: _08/14/2024_____

Incident Location:

City/County: Crestline/San Bernardino

Address/Location: 590 Lanes End Tri

Incident Cause: Excavating without a USA ticket

Gas Equipment Affected: Main

Material: Plastic Pipe size: 1 / 2 "

Dig In Information:

USA notification required: **Yes / No**

USA notified: **Yes / No** USA # _____

Facilities properly marked: **Yes / No**

Name of Excavator: Raffaelli Construction

Excavator Contact Person: Steve Raffaelli

Phone: 909-908-5423

On Scene:	Date	Time
Company Personnel on Scene	<u>08/14/24</u>	<u>10:54PM</u>
Gas Flow Stopped	<u>08/07/24</u>	<u>1:00PM</u>

Customer Outages (Quantity) 1

Summary of incident: Raffaelli Construcion hit 1/2" plastic service with a post hole digger. They did not have a valid USA ticket

Exhibit 3

Barton, Angel@EnergySafety

From: Chavez, Carlos R <CChavez@socalgas.com>
Sent: Thursday, December 5, 2024 1:58 PM
To: Barton, Angel@EnergySafety; ES-PSC SCG
Cc: Alcantar, Daysi@EnergySafety
Subject: RE: Requesting Verification for Reference Number N2425571 - Underground Safety Board

Some people who received this message don't often get email from cchavez@socalgas.com. [Learn why this is important](#)

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hello Angel,

Please see our responses below in red.

Thank you,

Carlos R Chavez
Pipeline Safety & Compliance
213-264-6814



From: Barton, Angel@EnergySafety <Angel.Barton@energysafety.ca.gov>
Sent: Thursday, November 21, 2024 3:43 PM
To: ES-PSC SCG <ES-PSCSCG@semprautilities.com>
Cc: Alcantar, Daysi@EnergySafety <Daysi.Alcantar@energysafety.ca.gov>
Subject: [EXTERNAL] Requesting Verification for Reference Number N2425571 - Underground Safety Board

Good afternoon Southern California Gas Company,

I am requesting verification for a no-ticket damage that was reported to our office on September 11, 2024, reference number N2425571. The incident address is 590 Lanes End, Fontana, San Bernardino, near Highway 38 according to the No-Ticket Damage Reporting Form.

I have attached the documents as reference and need verification on the chronological dates and times of the following:

- On the USB Damage Report Form it states the date of August 14, 2024, with an incident time of 10:43 pm., the scene time of 10:54 pm., and a gas flow stoppage on August 7, 2024, was at 1:00 pm.
Incident date and time – Company was notified August 14, 2024 10:39a
Scene arrival date and time - August 14, 2024 10:43a
Gas under control date and time – August 14, 2024 12:13p

- On the No-Ticket Damage Reporting Form it states the date of August 14, 2024, with an incident time of 5:43 pm., the time SCG learned about the damage was at 5:43 pm., and the time of completed repairs was at 8:00 pm.

Incident date and time – Company was notified August 14, 2024 10:39a

Notification date and time - August 14, 2024 10:39a

Repair Completion date and time – August 14, 2024 1:30p

Please clarify and confirm, the correct dates and times.

Cordially,

Angel Barton

Investigator

Underground Infrastructure Directorate

Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list](#) [public.govdelivery.com].

This email originated outside of Sempra. Be cautious of attachments, web links, or requests for information.

Exhibit 4



**CALIFORNIA UNDERGROUND SAFETY BOARD
INVESTIGATION DIVISION
RECORD OF CONVERSATION**

REPORT DATE: November 07, 2024

CASE NO: N2425571

DATE AND TIME OF CONVERSATION: November 07, 2024, at 2:20 p.m.

LOCATION OF CONVERSATION: Phone

INVESTIGATOR: Angel Barton

NAME, TITLE, AND COMPANY OF CALLER: Nori, Unknown, Raffaelli Construction

CALLER PHONE NUMBER: 909 273 7716

MAIN REASON FOR CALLING: Schedule an Interview

THE CONVERSATION:

Caller: Called

Investigator: Answered with greeting

Caller: Called in regard to the email and is wondering if they are able to talk about it over the phone

Investigator: Stated that we are able to have the conversation, it will be very similar to the survey questions. And relayed benefits of taking the survey online instead

Caller: Said that her boss told her to deal with this, so will prefer talking it through since she is not too familiar with it

Investigator: Asked if tomorrow she had availability

Caller: Stated that she does, and that she gets in around 10 a.m.

Investigator: Told her that 10:30 a.m. will work and to block off at least 30 minutes for the interview, and asked for the spelling of her name

Caller: Agreed on the time, and N-O-R-I

Investigator: Reiterated the time, their phone number, questions will be similar to the survey, and the amount of time to have available to interview

Caller: Understood and stated that she much prefers to talk over the phone to answer the questions

END OF CONVERSATION

Exhibit 5



**CALIFORNIA UNDERGROUND SAFETY BOARD
INVESTIGATION DIVISION
INTERVIEW REPORT**

REPORT DATE: November 19, 2024

CASE NO: N2425571

DATE AND TIME OF INTERVIEW: November 13, 2024, at 11:00a.m.

LOCATION OF INTERVIEW: Phone

INTERVIEWER: Angel Barton

NAME, TITLE, AND COMPANY OF INTERVIEWEE: Nori Day, Office Manager, Raffaelli Construction

INTERVIEW:

1. Provide your name, title, phone number, and email address.

Nori Day, Office Manager, 909 273 7716, norigrl01@gmail.com

2. Please provide the identifying information for your company. Company Name, CSLB, Physical Address, Mailing Address, Phone Number, and Email.

Steven L Raffaelli Construction, CSLB- 670334, 24600 Albrun DR, Crestline CA, 92325.
Mailing- PO BX 102 RimForest CA 92378, 909 273 7662, StevenLRaffaelli@gmail.com,

3. Did Raffaelli Construction excavate and damage a ½" plastic gas facility at 590 Lane's End Trail., Crestline CA, on August 14, 2024?

Yes

4. At approximately what time did the damage happen?

10 am

5. Was Raffaelli Construction at Lane's End Trail., Crestline CA when the facility was damaged? Y/N

Yes

6. To the best of your knowledge, did Raffaelli Construction ever perform work at Lane's End Trail., Crestline CA, the location where the facility was damaged? Y/N

Yes

7. When did Raffaelli Construction work at the Lane's End Trail., Crestline CA? (Date and Time)

More than one day, August 13th through August 16th, 2024

8. Were there any other companies at or near Lane's End Trail., Crestline CA on August 14, 2024? Y/N

No

9. Did someone in Raffaelli Construction, or anyone else, contact the Regional Notification Center on August 14, 2024? Y/N

No

If the answer to the previous question is No:

10. Is Raffaelli Construction aware that it needed to contact the Regional Notification Center prior to excavating? Y/N

Yes, reasons that they didn't was because the gas lines are 24in buried, and that they were only digging 16-18 inches, that's why they didn't call

11. Did the Regional Notification Center create an 811-ticket for 590 Lane's End Trail., Crestline CA that Raffaelli Construction worked? Y/N

No contact with them

12. If no one at Raffaelli Construction worked, or anyone else, contacted the Regional Notification Center before excavating, why not?
- a. Excavation occurred in an emergency situation
 - b. Excavation occurred under a prime contractor's 811 ticket
 - c. Excavation was to remove asphalt and you knew there was no facility buried in the asphalt
 - d. Other

Other

If the answer to the previous question is 'd':

13. Explain why Raffaelli Construction did not obtain an 811 ticket?

They didn't was because the gas lines are 24in buried, and that they were only digging 16-18 inches, that's why they didn't call

14. Has Raffaelli Construction ever obtained an 811 ticket, either by calling 811 or using the Regional Notification Center's website? Y/N

Yes, when digging trenches

15. The damage notification indicated that a facility was damaged at 590 Lane's End Trail., Crestline CA on August 14, 2024. Is that correct? Y/N

Yes

16. Provide the names, phone numbers, and if applicable, their email address for all your personnel who were at 590 Lane's End Trail., Crestline CA when the facility was damaged.

a. Name, Title, Phone Number, Email

Carlos Sanchez, 760 704 3898, Carpenter – but does a variety of different type of work for them, does not keep employee email records, only worker there

17. Which one of the individuals you identified in the previous questions was the foreman on the project when the facility was damaged?"

Carlos

Facility Damage

18. Was a facility damaged on August 14, 2024? (Select One) Y/N

Yes

19. Describe the damaged facility.

Half inch gas line

20. Identify the type of material damaged.

Plastic

21. Explain how the facility was damaged?

Digging with a hand shovel for a fence post, hit something, and called 911 after smelling gas

22. What equipment did Raffaelli Construction use on August 14, 2024?

- a. Auger/vertical bore
- b. Backhoe/trackhoe/excavator
- c. Bulldozer/front loader
- d. Horizontal drilling or boring equipment
- e. Farm equipment
- f. Shovel
- g. Pick
- h. Other hand tools
- i. Trencher
- j. Air/water knife
- k. Clay spade
- l. Jackhammer (90+ pound hammer)
- m. Powered hammer drill
- n. Powered hand-held other
- o. Explosives
- p. Surface milling equipment
- q. Grading equipment
- r. Saw cutting
- s. Other

Shovel

23. What type of equipment damaged the facility?

Shovel

24. Who was operating the equipment that damaged the facility on August 14, 2024?

Carlos

25. Specify if Raffaelli Construction owns that equipment? Y/N

Yes

Emergency Response

26. How did Raffaelli Construction learn that the SoCalGas facility was damaged on August 14, 2024?

Carlos smelled gas

27. Did anyone with Raffaelli Construction call 911 on August 14, 2024, after the damage had occurred? Y/N

Yes

28. Was there an emergency response to the incident from the fire department, a law enforcement department, or an ambulance on August 14, 2024?

Fire department

29. Were there any injuries to any personnel or bystanders on August 14, 2024? Y/N

No

30. Were there any fatalities on August 14, 2024 or afterwards, due to the damage at 590 Lane's End Trail., Crestline CA? Y/N

No

31. Was there property damage on August 14, 2024, excluding the facility damage? Y/N

No

32. Was there a fire on August 14, 2024 as a result of the damage to the facility? Y/N

No

33. Was there an evacuation of any homes or businesses on August 14, 2024 as a result of the damage to the facility? Y/N

No

34. Are you aware of anyone else that called 911?

No

35. Did anyone at Raffaelli Construction contact the Regional Notification Center after the damage on August 14, 2024? Y/N

No

36. Did anyone at Raffaelli Construction contact SoCalGas after the damage? Y/N

No

37. Who at Raffaelli Construction contacted the SoCalGas?

Nobody

38. What is the name of the person at the SoCalGas that was contacted?

N/A

39. What steps, if any, have Raffaelli Construction taken to prevent a similar damage in the future?

Call dig alert before digging in the future

40. Is there any other information you want to share about this damage?

No, just want to reiterate that the reason that they did not call was because they were not digging to the depth of 24 inches where the gas lines are supposed to be, only 16-18 inches.

Steven L. Raffaelli has been a Contractor for 25 years

No addition documents, photographs, nor procedures to submit.

Exhibit 6



CONTRACTORS STATE LICENSE BOARD

Contractor's License Detail for License # 670334

DISCLAIMER: A license status check provides information taken from the CSLB license database. Before relying on this information, you should be aware of the following limitations.

- ▶ CSLB complaint disclosure is restricted by law (B&P 7124.6) If this entity is subject to public complaint disclosure click on link that will appear below for more information. Click [here](#) for a definition of disclosable actions.
- ▶ Only construction related civil judgments reported to CSLB are disclosed (B&P 7071.17).
- ▶ Arbitrations are not listed unless the contractor fails to comply with the terms.
- ▶ Due to workload, there may be relevant information that has not yet been entered into the board's license database.

Data current as of 11/4/2024 3:51:27 PM

Business Information

STEVEN L RAFFAELLI CONSTRUCTION
P O BOX 102
RIMFOREST, CA 92378
Business Phone Number:(909) 273-7662

Entity Sole Ownership
Issue Date 04/29/1993
Expire Date 04/30/2026

License Status

This license is current and active.

All information below should be reviewed.

Classifications

- ▶ C33 - PAINTING AND DECORATING
- ▶ B - GENERAL BUILDING
- ▶ C39 - ROOFING
- ▶ C-61 / D24 - METAL PRODUCTS
- ▶ C36 - PLUMBING

Bonding Information

Contractor's Bond

This license filed a Contractor's Bond with [AMERICAN CONTRACTORS INDEMNITY COMPANY](#).

Bond Number: 100754915

Bond Amount: \$25,000

Effective Date: 04/15/2023

[Contractor's Bond History](#)

Workers' Compensation

This license has workers compensation insurance with the [CAROLINA CASUALTY INSURANCE COMPANY](#)

Policy Number: BNUWC0163347

Effective Date: 08/04/2024

Expire Date: 08/04/2025

[Workers' Compensation History](#)

Exhibit 7

811 ticket request N2425571

From Barton, Angel@EnergySafety <Angel.Barton@energysafety.ca.gov>
Date Mon 11/4/2024 2:16 PM
To Amber Dahl <amber@digalert.org>
Cc Alcantar, Daysi@EnergySafety <Daysi.Alcantar@energysafety.ca.gov>

Good afternoon Amber,

Please provide a copy of all tickets, revisions, and electronic positive responses at about 590 Lane's End Trail Crestline CA, from cross-streets Highway 138 to Seeley Way, for July 14, 2024 to August 30, 2024.

If there is not a ticket at this location for any of these dates, please confirm that finding.

Cordially,

Angel Barton

Investigator

Underground Infrastructure Directorate

Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list](#).

Exhibit 8



Underground Service Alert

of Southern California™

November 5, 2024

Angel Barton
Underground Safety Board

File Number: N2425571

Dear Angel,

After searching our records from 7/14/24 through 8/30/24, we were unable to find any DigAlert tickets for the location at or near 590 Lane's End Trail in Crestline. I hope this information will be helpful.

If we can be of further assistance, please call us at 951-808-8100.

Sincerely,

Amber Dahl
Safety Awareness Director

From: [Amber Dahl](#)
To: [Barton, Angel@EnergySafety](mailto:Barton,Angel@EnergySafety)
Cc: [Alcantar, Daysi@EnergySafety](mailto:Alcantar,Daysi@EnergySafety)
Subject: File N2425571
Date: Tuesday, November 5, 2024 12:10:40 PM
Attachments: [N2425571.pdf](#)

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Thank you,



Amber Dahl, Safety Director
Underground Service Alert of Southern California
PO BOX 77070 Corona, CA 92877
P: 951-808-8115 F: 951-808-8101
E: amber@digalert.org W: www.digalert.org



This e-mail message may contain confidential or legally privileged information and is intended only for the use of the intended recipient(s). Any unauthorized disclosure, dissemination, distribution, copying or the taking of any action in reliance on the information herein is prohibited. E-mails are not secure and cannot be guaranteed to be error free as they can be intercepted, amended, or contain viruses. Anyone who communicates with us by e-mail is deemed to have accepted these risks. Underground Service Alert of Southern California is not responsible for errors or omissions in this message and denies any responsibility for any damage arising from the use of e-mail. Any opinion and other statement contained in this message and any attachment are solely those of the author and do not necessarily represent those of the company.

Exhibit 9

Breaux, Angel@EnergySafety

From: Barton, Angel@EnergySafety
Sent: Friday, January 24, 2025 10:43 AM
To: countyfirereports@sbcfire.org; mcamargo@sbcfire.org
Cc: Alcantar, Daysi@EnergySafety
Subject: 911 Public records request - Case N2425571

Good morning San Bernardino County Fire Protection District,

This is a request for an electronic copy of all fire dispatch call logs, 911 audio recordings, and any incident reports from responding emergency personnel surrounding the possible gas leak of an underground natural gas service facility at 590 Lane's End Trail, Crestline, California 92325 on August 14, 2024. If no records exist, confirm that finding.

We are currently investigating the incident per California Government Code TITLE 1 – GENERAL - DIVISION 5 - PUBLIC WORK AND PUBLIC PURCHASES - CHAPTER 3.1 - Protection of Underground Infrastructure - ARTICLE 2 - Regional Notification Center System Section 4216.19.

Any information received will be beneficial to our investigation. If you have any questions, feel free to contact the undersigned.

Cordially,

Angel Barton

Investigator

Underground Infrastructure Directorate

Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list](#).

Exhibit 10

FW: 911 Public records request - Case N2425571 Inc. #24-202340

From County Fire Reports <countyfirereports@sbcfire.org>

Date Wed 1/29/2025 10:47 AM

To Barton, Angel@EnergySafety <Angel.Barton@energysafety.ca.gov>

 6 attachments (2 MB)

Request-A-081424-Lanes End-24-202340-N2425571.pdf; A-081424-Lanes End-24-202340-N2425571-DOR.pdf; A-081424-Lanes End-24-202340-N2425571-Redacted Personnel ID.pdf; 2024-08-14 MI#24-202340 590 Lanes End Trl 2CMD1.wav; 2024-08-14 MI#24-202340 590 Lanes End Trl 2DISP1.wav; 2024-08-14 MI#24-202340 590 Lanes End Trl 911.wav;

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning,

Attached is the requested record and audio. If you have any questions do not hesitate to reach out.

Thank you,

Lissa Camargo, Office Assistant II
San Bernardino County Fire District
Division 10, EMS/Records Clerk
Fax Phone: 909.387-5542

James 1:22

But be doers of the word and not hearers only, deceiving yourselves.



County of San Bernardino Confidentiality Notice: This communication contains confidential information sent solely for the use of the intended recipient. If you are not the intended recipient of this communication, you are not authorized to use it in any manner, except to immediately destroy it and notify the sender.

From: Barton, Angel@EnergySafety <Angel.Barton@energysafety.ca.gov>
Sent: Friday, January 24, 2025 10:43 AM
To: County Fire Reports <countyfirereports@sbcfire.org>; Camargo, Melissa <mcamargo@SBCFire.org>
Cc: Alcantar, Daysi@EnergySafety <Daysi.Alcantar@energysafety.ca.gov>
Subject: 911 Public records request - Case N2425571

Good morning San Bernardino County Fire Protection District,

This is a request for an electronic copy of all fire dispatch call logs, 911 audio recordings, and any incident reports from responding emergency personnel surrounding the possible gas leak of an underground natural gas service facility at 590 Lane's End Trail, Crestline, California 92325 on August 14, 2024. If no records exist, confirm that finding.

We are currently investigating the incident per California Government Code TITLE 1 – GENERAL - DIVISION 5 - PUBLIC WORK AND PUBLIC PURCHASES - CHAPTER 3.1 - Protection of Underground Infrastructure - ARTICLE 2 - Regional Notification Center System Section 4216.19.

Any information received will be beneficial to our investigation. If you have any questions, feel free to contact the undersigned.

Cordially,

Angel Barton
Investigator
Underground Infrastructure Directorate
Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list.](#)



NFIRS-1 Basic

A

36193	CA	08	14	2024		24-202340	0
FDID	State	Month	Day	Year	Station	Number	Exposure

B Location Type

Census tract:

- ☒ Street Address
☐ Intersection
☐ In Front Of
☐ Rear Of
☐ Adjacent To
☐ Directions
☐ US National Grid

590		LANES END	TRL-Trail	
Number	Prefix	Street or Highway	Street Type	Suffix

	Valley of Enchantment	CA	92325
Apt./Suite/Room	City	State	Zip Code

Cross Street

C

Incident Type

412-Gas leak (natural gas or LPG)

D

Aid Given Or Received

- ☐ 1 Mutual Aid Received
☐ 2 Auto. Aid Received
☐ 3 Mutual Aid Given
☐ 4 Auto. Aid Given
☐ 5 Other Aid Given
☒ None

Their FDID	Their State
Their Incident Number	

E1 Dates and Times

Alarm 08 14 2024 10:30

Arrival 08 14 2024 10:50

Controlled

Last Unit Cleared 08 14 2024 12:25

E2 Shifts and Alarms

A		
Shift or Platoon	Alarms	District

E3 Special Studies

ID#	Value

F

Actions Taken

55-Establish safe area

Primary Action Taken

82-Notify other agencies.

Additional Action Taken

G1

Resources

- ☒ Apparatus or Personnel Module is used.

	Apparatus	Personnel
Suppression	1	3
EMS	0	0
Other	0	0

- ☐ Resource counts include aid received resources.

G2

Estimated Dollar Losses and Values

Losses: Required for all fires if known. Optional for all non-fires. None

Property: \$ None ☒

Contents: \$ None ☒

Pre-Incident Values: Optional None

Property: \$ None ☒

Contents: \$ None ☒

Completed Modules ☐ 2 - Fire ☐ 3 - Structure Fire ☐ 4 - Civilian Fire Cas. ☐ 5 - Fire Service Cas. ☐ 6 - EMS ☐ 7 - HazMat ☐ 8 - Wildland Fire ☐ 9 - Apparatus ☐ 10 - Personnel ☐ 11 - Arson	H1 Casualties ☒ None <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"></td> <td style="width: 35%; text-align: center;">Deaths</td> <td style="width: 35%; text-align: center;">Injuries</td> </tr> <tr> <td>Fire Service</td> <td style="text-align: center;"> 0 </td> <td style="text-align: center;"> 0 </td> </tr> <tr> <td>Civilian</td> <td style="text-align: center;"> 0 </td> <td style="text-align: center;"> 0 </td> </tr> </table>		Deaths	Injuries	Fire Service	0	0	Civilian	0	0	H3 Hazardous Materials Release ☐ 1 - Natural Gas ☐ 2 - Propane Gas ☐ 3 - Gasoline ☐ 4 - Kerosene ☐ 5 - Diesel Fuel / Fuel Oil ☐ 6 - Household Solvents ☐ 7 - Motor Oil ☐ 8 - Paint ☐ 0 - Other ☒ None	I Mixed Use Property ☐ Not Mixed ☐ 10 - Assembly Use ☐ 20 - Education Use ☐ 33 - Medical Use ☐ 40 - Residential Use ☐ 51 - Row Of Stores ☐ 53 - Enclosed Mall ☐ 58 - Business and Residential ☐ 59 - Office Use ☐ 60 - Industrial Use ☐ 63 - Military Use ☐ 65 - Farm Use ☐ 00 - Other Mixed Use
	Deaths	Injuries										
Fire Service	0	0										
Civilian	0	0										
H2 Detector Required for Confined Fires ☐ 1 - Detector Alerted Occupants ☐ 2 - Detector Did Not Alert Them ☐ 3 - Unknown												

J Property Use ☐ None Structures 131 ☐ Church, Place of Worship 161 ☐ Restaurant or Cafeteria 162 ☐ Bar/Tavern or Nightclub 213 ☐ Elementary School, Kindergarten 215 ☐ High School, Junior High 241 ☐ College, Adult Education 311 ☐ Nursing Home 331 ☐ Hospital	341 ☐ Clinic, Clinic-Type Infirmary 342 ☐ Doctor/Dentist Office 361 ☐ Prison or Jail, Not Juvenile 419 ☒ 1- or 2-Family Dwelling 429 ☐ MultiFamily Dwelling 439 ☐ Rooming/Boarding House 449 ☐ Commerical Hotel or Motel 459 ☐ Residential, Board and Care 464 ☐ Dormitory/Barracks 519 ☐ Food and Beverage Sales	539 ☐ Household Goods, Sales, Repairs 571 ☐ Gas or Service Station 579 ☐ Motor Vehicle/Boat Sales/Repairs 599 ☐ Business Office 615 ☐ Electric-Generating Plant 629 ☐ Laboratory/Science Laboratory 700 ☐ Manufacturing Plant 819 ☐ Livestock/Poultry Storage (Barn) 882 ☐ Non-Residential Parking Garage 891 ☐ Warehouse
---	---	--

Outside 124 ☐ Playground or Park 655 ☐ Crops or Orchard 669 ☐ Forest (Timberland) 807 ☐ Outdoor Storage Area 919 ☐ Dump or Sanitary Landfill 931 ☐ Open Land or Field 936 ☐ Vacant Lot	938 ☐ Graded/Cared for Plot of Land 946 ☐ Lake, River, Stream 951 ☐ Railroad Right-of-Way 960 ☐ Other Street 961 ☐ Highway/Divided Highway 962 ☐ Residential Street/Driveway 981 ☐ Construction Site 984 ☐ Industrial Plant Yard	Property Use: Description Look up and enter a Property Use code and description only if you have NOT checked a Property Use box.
---	---	--

K2				
Owner				
Local Option	Person/Entity Type	Business Name (if applicable)	Phone Number	
Mr., Ms., Mrs.	First Name	MI	Last Name	Suffix
Number	Prefix	Street or Highway	Street Type	Suffix
Post Office Box	Apt./Suite/Room		City	
State	Zip Code			

L	Remarks: ME26 AOS of confirmed gas leak. ME26 established safe area and notified surrounding homeowners to shelter in place. ME26 deployed hoseline and stood by for gas company. Gas company AOS and mitigated the hazard without incident.
----------	--

M **Authorization**

	C8150			10/10/2024
Officer In Charge ID	Signature	Position or Rank	Assignment	Date
	C8150			10/10/2024
Member Making Report ID	Signature	Position or Rank	Assignment	Date

NFIRS-9 Apparatus or Resources

A

36193	CA	08	14	2024		24-202340	0
FDID	State	Month	Day	Year	Station	Number	Exposure

B

Apparatus/Resource

Dates/Times

Sent

Number
of People

Apparatus Use

Actions Taken

ID:

ME26

Dispatch:

08/14/2024

10:30

☒ Sent

3

☒ Suppression

☐ EMS

☐ Other

Type:

11-Engine

Arrival:

08/14/2024

10:50

Clear:

08/14/2024

12:25

NFIRS-10 Personnel

A

36193		CA		08		14		2024		24-202340		0	
FDID		State		Month		Day		Year		Station		Number	Exposure

B

Apparatus/Resource	Dates/Times	Sent	Number of People	Apparatus Use	Actions Taken
ID: ME26 Type: 11-Engine	Dispatch: 08/14/2024 10:30 Arrival: 08/14/2024 10:50 Clear: 08/14/2024 12:25	☒ Sent	3	☒ Suppression ☐ EMS ☐ Other	☐
Personnel ID	Name	Rank	Role	Attend	Actions Taken
[REDACTED]	Arnold, Richard			☐	☐
[REDACTED]	Atkinson, Daniel			☐	☐
[REDACTED]	Godinez, Nathan			☐	☐

NFIRS-1S Supplemental

A

36193	CA	08	14	2024		24-202340	0
FDID	State	Month	Day	Year	Station	Number	Exposure

Additional Narrative (#1 of 1):

08/14/2024 10:29:05SYS [1] WPH2 LAT:34.24266815 LON:-117.294845 METERS:5 %:090 | 08/14/2024 10:29:05SYS
 [2] ELV 1405 UNC 0 | 08/14/2024 10:29:05SYS [3] Validity of address cannot be determined:23407 CREST FOREST DR. |
 08/14/2024 10:29:53G8723 [4] GAS LINE HIT AT END OF STREET | 08/14/2024 10:33:42J4622 [5] ME26 CONFIRM
 GAS IS ER | 08/14/2024 10:36:53J4622 [6] ***GAS COMPANY REQUESTED*** SOCAL GAS #1328342708 ETA 30 MINS OR
 LESS | 08/14/2024 10:36:56G8723 [7] CONSTRUCTION CREW REMODELING HOUSE AND HIT GAS LINE | 08/14/2024
 11:00:12ME26 [8] GAS CO ONSCENE [TC, ME26] | 08/14/2024 12:05:24ME26 [9] UPDATE - STILL ONSCENE
 AWAITING RESPONSE TEAM TO CLAMP GAS LINE [TC, ME26]

Camargo, Melissa

From: Barton, Angel@EnergySafety <Angel.Barton@energysafety.ca.gov>
Sent: Friday, January 24, 2025 10:43 AM
To: County Fire Reports; Camargo, Melissa
Cc: Alcantar, Daysi@EnergySafety
Subject: 911 Public records request - Case N2425571

Good morning San Bernardino County Fire Protection District,

This is a request for an electronic copy of all fire dispatch call logs, 911 audio recordings, and any incident reports from responding emergency personnel surrounding the possible gas leak of an underground natural gas service facility at 590 Lane's End Trail, Crestline, California 92325 on August 14, 2024. If no records exist, confirm that finding.

We are currently investigating the incident per California Government Code TITLE 1 – GENERAL - DIVISION 5 - PUBLIC WORK AND PUBLIC PURCHASES - CHAPTER 3.1 - Protection of Underground Infrastructure - ARTICLE 2 - Regional Notification Center System Section 4216.19.

Any information received will be beneficial to our investigation. If you have any questions, feel free to contact the undersigned.

Cordially,

Angel Barton

Investigator

Underground Infrastructure Directorate

Phone: (916) 216-0251

www.energysafety.ca.gov



OFFICE OF ENERGY
INFRASTRUCTURE
SAFETY

Stay connected and informed by signing up for the [Underground Safety Board's subscriber list](#).



SAN BERNARDINO COUNTY FIRE PROTECTION DISTRICT

2824 "W" Street • San Bernardino, CA 92408 • (909) 501.0602 • Fax (909) 501.0605

EMS, Special Ops & Training
Headquarters
sbcfire.org

Daniel R. Munsey
Fire Chief/Fire Warden

Mike O'Bier
Interim Division Chief

01/29/2025

OFFICE OF ENERGY
INFRASTRUCTURE SAFETY +
715 P Street, 20th Floor
Sacramento, CA 95814

To Whom It May Concern:

I, the undersigned, being the duly authorized Custodian of Records for the San Bernardino County Fire District, declare that I am qualified to testify as to the preparation and maintenance of the records and having the authority to certify records sought and having the authority to certify records sought by the request declare the following:

All records called for in the attached request are true and correct copies of the original documents.

Miranda Mulhall
Privacy Officer
Emergency Medical Services Division
San Bernardino County Fire

BOARD OF SUPERVISORS

Col. Paul Cook (Ret.)
First District

Jesse Armendarez
Second District

Dawn Rowe
Vice Chair
Third District

Curt Hagman
Chairman
Fourth District

Joe Baca, Jr
Vice-Chair
Fifth District

Luther Snoke
Chief Executive Officer



WAV File 1



WAV File 2



WAV File 3