



OFFICE OF ENERGY INFRASTRUCTURE SAFETY

715 P Street, 20th Floor | Sacramento, CA 95814
916.902.6000 | www.energysafety.ca.gov

Caroline Thomas Jacobs, Director

September 22, 2021

To Wildfire Mitigation Plan stakeholders:

Enclosed is the Final Action Statement on the 2021 Wildfire Mitigation Plan (WMP) Update of Pacific Gas and Electric Company (PG&E).

The evaluation of 2021 WMP Updates began at the California Public Utilities Commission's (CPUC) Wildfire Safety Division (WSD). Consistent with statute, the WSD, along with all its functions, transitioned to the Office of Energy Infrastructure Safety (Energy Safety) under the California Natural Resources Agency on July 1, 2021.¹

On August 9, 2021, a draft of this Action Statement was filed in the 2021 WMPs Docket (#2021-WMPs) and served to the service list of the CPUC's Rulemaking 18-10-007 for public review and comment. Comments on the Draft Action Statement were due on August 30, 2021, and considered in the final evaluation.

This Action Statement is the Office of Energy Infrastructure Safety's approval of PG&E's 2021 WMP Update.

Sincerely,

Lucy Morgans
Acting Program Manager, Safety Policy Division
Office of Energy Infrastructure Safety

¹ See Assembly Bill 111, Stats. of 2019, Ch 81, Sec. 7.



**OFFICE OF ENERGY INFRASTRUCTURE SAFETY'S
FINAL EVALUATION OF 2021 WILDFIRE
MITIGATION PLAN UPDATE
PACIFIC GAS AND ELECTRIC**



Contents

- Introduction and Background 3
- 1. Summary of Key Findings 7
 - 1.1 Areas of Significant Progress 7
 - 1.2 Revision Notices 8
 - 1.3 Key Areas for Improvement and Remedies 11
 - 1.4 Maturity Model Evaluation 19
- 2. Wildfire Safety Advisory Board Input 20
- 3. Public and Stakeholder Comment 23
- 4. Discussion 25
 - 4.1 Introductory Sections of the WMP 25
 - 4.2 Actuals and Planned Spending for Mitigation Plan 26
 - 4.3 Lessons Learned and Risk Trends 30
 - 4.4 Inputs to the Plan and Directional Vision for WMP 33
 - 4.5 Metrics and Underlying Data 35
- 5. Mitigation initiatives and maturity evaluation 38
 - 5.1 Risk Assessment and Mapping 40
 - 5.2 Situational Awareness and Forecasting 49
 - 5.3 Grid Design and System Hardening 53
 - 5.4 Asset Management and Inspections 63
 - 5.5 Vegetation Management and Inspections 71
 - 5.6 Grid Operations and Operating Protocols, Including PSPS 90
 - 5.7 Data Governance 93
 - 5.8 Resource Allocation Methodology 96
 - 5.9 Emergency Planning and Preparedness 106
 - 5.10 Stakeholder Cooperation and Community Engagement 109
- 6. Public Safety Power Shutoff (PSPS), including directional vision for PSPS 112
- 7. Next steps 121
- 8. Consultation with cal fire has occurred 123
- 9. Conclusion 128
- 10. Appendix 1
 - 10.1 Complete Table of 2021 Key Areas for Improvement and Remedies 1
 - 10.2 Status of 2020 WMP Deficiencies 21
- 11. Attachments 1
 - Attachment 1: PG&E’s 2021 Maturity Survey 1
 - Attachment 2: Definition of Initiatives by Category 59
 - Attachment 3: Glossary of Terms 70



INTRODUCTION AND BACKGROUND

This Action Statement represents the assessment of the Office of Energy Infrastructure Safety (Energy Safety)¹ on the 2021 Wildfire Mitigation Plan Update (WMP or Plan) of Pacific Gas and Electric Corporation (PG&E or the utility). This Plan is an update for the comprehensive 2020-2022 plan submitted by PG&E in 2020. PG&E submitted its 2021 WMP Update on February 5, 2021, in response to guidelines provided by the California Public Utilities Commission’s (CPUC) Wildfire Safety Division (WSD).² Assembly Bill (AB) 1054³ mandates that Energy Safety complete its evaluation of WMPs within three months of submission, unless Energy Safety issues an extension.⁴ On May 4, 2021, WSD issued a Revision Notice to PG&E to address critical issues within its WMP Update. That notice also contained a notice of extension for the review timeline. PG&E responded on June 3, 2021. For additional information see below in Section 1.2.

PG&E’s 2021 WMP Update is approved.

In its 2021 WMP Update, PG&E demonstrates an improved understanding of the underlying risks it faces, a more targeted approach to addressing those risks, and a foundational change in its organization structure and systems, including data governance, that will better position it to improve over time.

Notwithstanding these improvements, Energy Safety finds that PG&E is spending more money per mitigation initiative and yet making less progress than its peer utilities. Energy Safety expects PG&E to demonstrate that it is reducing the risk of wildfire in line with its peers. PG&E must provide an update to Energy Safety on the 29 key areas of improvement outlined in this Action Statement in its November 1, 2021, Progress Report.

1. Legal Authority

In 2018, following the devastating wildfires in 2016 and 2017, the California Legislature passed several bills increasing oversight of the electrical corporations’ efforts to reduce utility-related

¹ Pursuant to Public Utilities Code Section 326(b), on July 1, 2021, the Wildfire Safety Division (WSD) transitioned from the Commission into the Office of Energy Infrastructure Safety (Energy Safety) under the California Natural Resources Agency. Energy Safety “is the successor to” and “is vested with all of the duties, powers, and responsibilities of the Wildfire Safety Division” (Government Code Section 15475), including, but not limited to, jurisdiction for evaluating and approving or denying electrical corporations’ WMPs and evaluating compliance with regulations related to the WMPs. The Commission and the newly formed Energy Safety will adhere to all statutory requirements pertaining to the WMP process. WSD is used to describe the work of the WSD prior to July 1, 2021. Energy Safety is used to describe the work of Energy Safety beginning on July 1, 2021. Any references to WSD action post July 1, 2021, or to Energy Safety action prior to July 1, 2021, are inadvertent and should be interpreted as the actions of WSD or Energy Safety as appropriate.

² The Commission approved 2021 WMP guidelines in Resolution WSD-011.

³ Stats. of 2019, Ch. 79.

⁴ Pub. Util. Code Section 8386.3(a).



wildfires.⁵ AB 1054 created the WSD at the CPUC and tasked it with reviewing annual WMPs submitted by electrical corporations under the CPUC’s jurisdiction.

As of July 1, 2021, the WSD transitioned into the Office of Energy Infrastructure Safety (Energy Safety) under the California Natural Resources Agency (CNRA) vested with all the powers, duties, and responsibilities of the WSD established pursuant to Section 15475 of the Government Code.⁶ Section 10 of the associated Resolution provides further detail on the transition of the WSD to Energy Safety. In this Action Statement, “WSD” is used to describe the work of the WSD prior to July 1, 2021, and “Energy Safety” is used to describe the work of Energy Safety beginning on July 1, 2021. Any references to WSD action post July 1, 2021, or to Energy Safety action prior to July 1, 2021, are inadvertent and should be interpreted as the actions of WSD or Energy Safety as appropriate. Any references herein to WSD actions that post-date this transition should be interpreted as actions taken by Energy Safety or for which Energy Safety will take responsibility.

The main regulatory vehicle for Energy Safety to evaluate electrical corporations’ wildfire risk reduction efforts is the WMP, which was first introduced in Senate Bill (SB) 1028⁷ and further defined in SB 901,⁸ AB 1054, and AB 111. Investor-owned electrical corporations (hereafter referred to as “utilities”) are required to submit WMPs assessing their level of wildfire risk and providing plans for wildfire risk reduction. The CPUC evaluated the utilities’ first WMPs under the SB 901 framework in 2019.⁹

AB 1054 and AB 111 transferred responsibility for evaluation and approval or denial of WMPs to Energy Safety; AB 1054 provides, “After approval by the division, the commission shall ratify the action of the division.” Energy Safety must ensure utility wildfire mitigation efforts sufficiently address increasing utility wildfire risk. To support its efforts, Energy Safety developed a long-term strategic roadmap, Reducing Utility-Related Wildfire Risk (2020).¹⁰ This strategic roadmap informs Energy Safety’s work in updating the WMP process and guidelines and Energy Safety’s evaluation of the WMPs.

2. Multi-Year Plan Process

In February of 2020, the utilities¹¹ submitted their three-year 2020-2022 WMPs. The WSD conducted its evaluation and either approved, conditionally approved, or denied the Plans. In

⁵ In this document “utility” should be understood to mean “electrical corporation.”

⁶ See AB 111, Stats. of 2019, Ch. 81.

⁷ Stats. of 2016, Ch. 598.

⁸ Stats. of 2018, Ch. 626.

⁹ See Rulemaking (R.) 18-10-007.

¹⁰ The Office of Energy Infrastructure’s strategic roadmap Reducing Utility-Related Wildfire Risk (2020) (accessed July 29, 2021): <https://energysafety.ca.gov/who-we-are/strategic-roadmap/>.

¹¹ Pacific Gas and Electric Company, Southern California Edison Company, San Diego Gas and Electric, Liberty Utilities, PacifiCorp, Bear Valley Electric Service, Trans Bay Cable, and Horizon West Transmission.



the case of conditional approval, the WSD identified items missing or incomplete in the Plans on a scale of severity, with Class A Deficiencies representing issues that required resolution through a Remedial Compliance Plan (RCP).¹² The 2020 Class B Deficiencies required resolution through Quarterly Reports,¹³ and Class C Deficiencies were to be resolved in the 2021 WMP Update.

In 2020, the WSD issued a conditional approval of PG&E's WMP. PG&E submitted its RCP¹⁴ to resolve Class A Deficiencies on July 27, 2020.¹⁵ The WSD released its evaluation of PG&E's RCP on December 30, 2020, and provided direction to address "insufficient" responses in PG&E's updated 2021 Plan. PG&E submitted its first Quarterly Report on September 9, 2020, to resolve 2020 Class B Deficiencies.¹⁶ The WSD released its evaluation of PG&E's Quarterly Report on January 8, 2021, and also issued direction to address "insufficient" responses in its 2021 WMP Update.¹⁷ Appendix 10.2 of this report provides a list of the deficiencies found in the 2020 WMP and their current status.

3. 2021 Evaluation Process

On November 16, 2020, the CPUC adopted updated WMP requirements (Guidelines) and procedures for the 2021 WMP Plan Year pursuant to Public Utilities Code section 8389(d).¹⁸ The updates to the 2021 WMP Guidelines are intended to streamline the reporting and evaluation process. Pursuant to the adopted Guidelines, large utilities submitted 2021 WMP Updates on February 5, 2021; small and multi-jurisdictional utilities (SMJUs) and independent transmission operators (ITOs) submitted 2021 WMP Updates on March 5, 2021.

The 2021 WMP submissions are updates of the 2020-2022 WMPs and are intended to show progress since 2020 and report changes from the 2020 WMP. Importantly for 2021, Energy Safety amended its review process and will no longer issue conditional approvals. Instead,

¹² An RCP "must present all missing information and/or articulate the electrical corporation's plan, including proposed timeline, to bring the electrical corporation's WMP into compliance." See Resolution WSD-002 at 17.

¹³ "Class B issues are of moderate concern and require reporting on a quarterly basis by the electrical corporation to provide missing data or update its progress in a quarterly report." See Resolution WSD-002 at 18.

¹⁴ PG&E's 2020 RCP can be found here (accessed July 18, 2021): <https://energysafety.ca.gov/what-we-do/wildfire-mitigation-and-safety/wildfire-mitigation-plans/2020-wmp/>.

¹⁵ WSD's evaluation of PG&E's 2020 RCP can be found here (accessed July 18, 2021):

<https://energysafety.ca.gov/what-we-do/wildfire-mitigation-and-safety/wildfire-mitigation-plans/2020-wmp/>.

¹⁶ PG&E's 2020 QR can be found here (accessed July 18, 2021): <https://energysafety.ca.gov/what-we-do/wildfire-mitigation-and-safety/wildfire-mitigation-plans/2020-wmp/>. Subsequent Quarterly Reports addressing conditions requiring ongoing reporting will be evaluated as part of utilities' 2021 WMP Updates.

¹⁷ WSD's Evaluation of PG&E's First Quarterly Report from January 8, 2021

(accessed July 30, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/pge-qr-action-statement.pdf>. The WSD issued an extension to the large investor-owned utilities to respond to insufficient Quarterly Reports until February 26, 2021.

¹⁸ See <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf> for adopted 2021 WMP Guidelines (accessed July 29, 2021).



where Energy Safety found critical issues with 2021 submissions, it issued a Revision Notice requiring the utility to remedy such issues prior to completion of the 2021 WMP Update evaluation. Upon receipt of the utility's response to the Revision Notice, Energy Safety could determine that the response was sufficient to warrant approval, although additional ongoing reporting or other conditions may be required, or the response was insufficient such that denial of the WMP is warranted due to the utility inadequately reducing wildfire risk and its potential impact to public safety.

Energy Safety evaluated 2021 WMP Updates according to the following factors:

- **Completeness:** The WMP is complete and comprehensively responds to the WMP statutory requirements and WMP Guidelines.
- **Technical feasibility and effectiveness:** Initiatives proposed in the WMP are technically feasible and are effective in addressing the risks that exist in the utility's service territory.
- **Resource use efficiency:** Initiatives are an efficient use of utility resources and focus on achieving the greatest risk reduction at the lowest cost.
- **Demonstrated year-over-year progress:** The utility has demonstrated sufficient progress on objectives and program targets reported in the prior annual WMP.
- **Forward-looking growth:** The utility demonstrates a clear action plan to continue reducing utility-related wildfires and the scale, scope, and frequency of Public Safety Power Shutoff (PSPS) events.¹⁹ In addition, the utility is sufficiently focused on long-term strategies to build the overall maturity of its wildfire mitigation capabilities while reducing reliance on shorter-term strategies such as PSPS and vegetation management.

To conduct its assessment, Energy Safety relied upon PG&E's WMP submission and subsequent update, responses to Revision Notices, input from California Department of Forestry and Fire Protection (CAL FIRE), input from the Wildfire Safety Advisory Board (WSAB), public comments, responses to the WSD's data requests, utility-reported data, and utility responses to the Utility Maturity Survey.

Upon completion of its review, Energy Safety determined whether each utility's 2021 WMP Update should either be:

- Approved (approval may include the requirement to address certain issues in the utility's subsequent WMP and/or through existing ongoing reporting processes), or,
- Denied (the utility does not have an approved WMP for 2021 and must reapply for approval in 2022).

¹⁹ A Public Safety Power Shutoff (PSPS) event, also called a de-energization event, is when a utility proactively and temporarily cuts power to electric lines that may fail in certain weather conditions in specific areas to reduce electric facility-caused fire risk.



4. Cost Recovery

This document does not approve costs attributable to WMPs, as statute requires electrical corporations to seek cost recovery and prove all expenditures are just and reasonable at a future time in their General Rate Cases (GRC) or an appropriate application. Nothing in this Action Statement nor CPUC’s Resolution should be construed as approval of any WMP-related costs.²⁰

1. SUMMARY OF KEY FINDINGS

Pursuant to Public Utilities Code (Pub. Util. Code) Section 8386.3(a), this Action Statement is the totality of Energy Safety’s review of PG&E’s 2021 WMP Update. PG&E’s 2021 WMP Update is approved.

1.1 Areas of Significant Progress

Energy Safety finds that PG&E has made significant progress over the past year and/or has matured in its mitigation strategies for future years in the following areas:

- PG&E redesigned its 2021 Wildfire Distribution Risk Model that includes vegetation probability of ignition, equipment probability of ignition, and fire consequence models. The updated model informs which circuit segments PG&E considers highest risk and enables PG&E to prioritize circuit segments for mitigation based on risk.
- PG&E has updated its Vegetation Risk Model for 2021 in a manner it claims allows it to prioritize work with more granularity at the level of circuit protection zones (CPZs).²¹ The model’s outputs are used to prioritize work for PG&E’s EVM program.
- PG&E established a new system hardening program decision-making framework. The new decision-making framework provides a consistent approach for evaluating the optimal mitigation measure for each circuit segment that PG&E selects for mitigation, with a focus on reducing catastrophic wildfire risk. The new decision-making framework provides a more comprehensive and targeted approach than PG&E presented in its

²⁰ Energy Safety’s approval and the Commission’s ratification do not relieve the electrical corporation from any and all otherwise applicable permitting, ratemaking, or other legal and regulatory obligations.

²¹ CPZs are portions of a circuit that can be isolated from the rest of the system.

https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/vegetation-management.page (accessed July 12, 2021).



2020 WMP and represents a significant improvement to PG&E’s initiative selection process.^{22, 23}

- PG&E provided 10 times more risk-spend efficiency (RSE) estimates for mitigation initiatives than it did in its 2020 WMP, helping remedy a concern raised in connection with the 2020 WMP that PG&E was combining initiatives for its RSE calculations. These combinations made the RSEs less valuable because they did not allow comparison across initiatives to determine whether certain initiatives had a more favorable RSE than others.
- PG&E improved its inspection process to identify particular issues based on its Failure Modes and Effects Analysis and ignition risk analysis to move away from its previous “run to failure” methodology. This process targets known failures that present higher ignition risk and aims to repair or mitigate them prior to failure occurring.
- PG&E improved its capability to analyze circuit segments across multiple initiatives, including vegetation management and system hardening, and developed plans to avoid conducting vegetation management where system hardening is occurring and vice versa. PG&E is working to tailor its initiative selections to the optimal solution for each CPZ instead of choosing overarching initiatives that may overlap in benefits and therefore not provide the most efficient use of resources.
- PG&E has been working toward consolidating the data collection tools for various vegetation management (VM) activities into a new geographic information system (GIS)-based vegetation management system it calls “One Vegetation Management.”²⁴ A consolidated system will enable PG&E to improve planning, scheduling, and reporting and improve coordination between its numerous VM programs. It is important that PG&E keep track of its various VM programs in a consolidated manner to avoid situations where work done as part of one of its programs is not available to workers handling other VM programs. Anytime VM personnel – regardless of the program on which they work – needs data about a particular tree or trees, the data should be available regardless of which VM resulted in the gathering of the data.

1.2 Revision Notices

A Revision Notice was issued to PG&E on May 4, 2021, to resolve six critical issues in its 2021 WMP Update. PG&E responded to the Revision Notice on June 3, 2021. Table 1 below lists the critical issues contained in the Revision Notice, a brief overview of PG&E’s response, and whether Energy Safety deems the response to be sufficient to support approval of the 2021

²² While these processes were not developed at the time of PG&E’s initial submission of its 2021 WMP Update, PG&E presented the changes made to its decision-making process in a presentation given to Wildfire Safety Division on May 21, 2021. Given that this process is now in-place and was developed by the time PG&E refiled its 2021 WMP Update as part of the Revision Notice Response, Energy Safety is including the updates as part of its overall 2021 WMP review.

²³ Energy Safety is seeking more information from PG&E regarding its July 21, 2021, announcement of its plans to underground 10,000 miles of power lines to determine if that plan will impact the decision-making framework presented in PG&E’s 2021 WMP Update.

²⁴ PG&E 2021 WMP Update Revision - Clean, p. 807.



WMP Update. All critical issues were addressed by PG&E in its Revision Notice Response. However, in some instances residual issues remain, and Energy Safety includes new remedies in the relevant sections of this Action Statement, as indicated in Table 1 below.

Table 1: Critical issues.

| Critical issue | Description | Utility response | Energy Safety evaluation |
|--|---|--|--|
| RN-PG&E-01 Omission of Quantitative Targets for Reduction in PSPS Scale, Scope, and Frequency | PG&E omitted inclusion of quantitative targets for reducing the scale, scope, and frequency of PSPS events; it does not fully explain how its programmatic commitments over the next WMP cycle will reduce PSPS events; and it projects an increase in customer planned outage hours for 2021 and 2022 despite the implementation of mitigation measures over this time period. | PG&E responded to each required remedy, including: 1) description of changes to its PSPS protocols, 2) quantitative targets for reducing scale, scope, and frequency of PSPS, 3) description of PSPS target methodology, 4) expected quantitative reduction of PSPS scale, scope, and/or frequency from programmatic commitments, 5) detail of how major programs are factored into PSPS projections, and 6) explanation of why its projected customer outage hours for 2021 and 2022 are an increase over recorded customer outage hours in 2020. | PG&E’s response sufficiently addresses each required remedy; however, PG&E states that its PSPS approach will likely change in August 2021 and the new approach may be “substantially” ²⁵ different than PG&E’s current approach. ²⁶ Energy Safety recognizes the need to continually refine and improve PSPS protocols, but significant changes to PSPS protocols could result in significant changes to PSPS commitments. As soon as practicable, PG&E must provide an update, including showing how its new PSPS protocols affect targets. See key area for improvement PG&E-21-29 below. |
| RN-PG&E-02 Inadequate Justification of Significant Changes to High Priority Circuit Segments | PG&E does not adequately justify its significant re-prioritization of circuit segments targeted for mitigation. PG&E relies on the results of its 2021 Wildfire Distribution Risk Model (“2021 Risk Model”) to justify these changes. However, PG&E does not provide adequate validation of its 2021 Risk Model. | PG&E provided its internal validation report, its third-party review and validation, and other available supporting materials that reviewed and/or validated its 2021 Risk Model. PG&E provided an explanation and timeline for how and when it intends to address all recommendations provided by these reports, reviews, and validations. PG&E provided detailed descriptions of and | PG&E provided the required information. However, additional remedies are required. Third-party evaluation findings provided recommendations for improving PG&E’s risk models, including further integration between PG&E’s risk model and PSPS model, a need for a stronger connection between SMEs and the model, and the need for a roadmap for further development of the models. To provide transparency, as well as ensure that PG&E is addressing the third-party’s findings, PG&E must provide updates on its progress for |

²⁵ PG&E Revision Notice response, section 2 “2021 PSPS Protocols,” page 983.

²⁶ In its Revision Notice response, PG&E labels its current PSPS protocols, in effect from May 2021 through August 2021, as “2020 PSPS Protocols Plus Tree Overstrike Potential and Priority Tags.”



| Critical issue | Description | Utility response | Energy Safety evaluation |
|--|--|--|---|
| | | justification for modeling assumptions, choice of inputs, and accuracy of outputs. | implementing the recommended changes. This issue is addressed in key area for improvement PG&E-21-06. See Section 5.1 for additional details. |
| RN-PG&E-03 Unacceptable Aggregation of System Hardening Risk-Spend Efficiencies (RSEs) | PG&E does not provide individual RSE estimates for its system hardening initiatives and instead provides one RSE for distribution system hardening. | PG&E provided the detailed costs, miles treated, RSE estimates, and other relevant information and data for each of the following mitigations: covered conductor installation, undergrounding, and remote grid. PG&E submitted this information as a revised Table 12. | PG&E addressed the critical issue by providing the costs, miles treated, and RSE estimates for covered conductor installation, undergrounding, and remote grid. Additional discussion on RSEs can be found in Section 5.8. Related issues and key areas for improvement regarding RSEs include PG&E-21-26 through 28. |
| RN-PG&E-04 Equivocating Language in Asset Inspection QA/QC Process Descriptions | PG&E continues to use vague, noncommittal, and equivocating language to describe its processes for quality assurance and quality control (QA/QC) of distribution and transmission asset inspections. | PG&E revised its 2021 WMP Update to describe its QA/QC processes for its asset inspections using specific, measurable, quantifiable, and verifiable language and described its internal plans to address QA/QC issues related to asset inspections. | PG&E’s response was complete and this issue is resolved. See additional discussion in Section 5.4 on key areas of improvement for QA/QC in PG&E-21-17. |
| RN-PG&E-05 Unresolved Discrepancies in Vegetation Management Expenditure Data and Their Effect on the WMP | PG&E continues to provide inconsistent data for its vegetation management program since 2019. | PG&E submitted a revised Table 12 and explained in full and complete detail why spend information was so drastically different from previous submissions and what quality controls it has in place. | PG&E provided the required information, including a revised Table 12. However, Energy Safety remains concerned about the inconsistency of data and supports PG&E’s proposal to hire a “business liaison” for each major WMP initiative category.” ²⁷ See additional discussion in Section 5.5. |
| RN-PG&E-06 Contradictory Reduction in Expenditure Allocation for Critical Vegetation Management Initiatives | PG&E significantly reduces budget allocations for initiatives considered critical to effective execution of its vegetation management programs. | PG&E explained how it is ensuring it is still meeting its risk reduction targets from vegetation contact considering its modified percentage allocation and expenditure reduction, as compared to the 2020 WMP. PG&E also provided requested details on its | PG&E’s response was complete. However, the details PG&E provided regarding initiatives 7.3.5.13, QA/QC of vegetation inspections, and 7.3.5.14, recruiting and training of vegetation management personnel, raise additional concerns. See Section 5.5 for additional discussion on future |

²⁷ PG&E 2021 WMP Update Revision – Clean, p. 417.



| Critical issue | Description | Utility response | Energy Safety evaluation |
|----------------|-------------|--------------------------------|---|
| | | vegetation management program. | remedies required in the 2022 WMP Update. |

Additional discussion of Energy Safety’s evaluation of PG&E’s Revision Notice Response can be found in the following sections:

- On Revision Notice Issue RN-PG&E-01: Section 6.0
- On Revision Notice Issue RN-PG&E-02: Section 5.1
- On Revision Notice Issue RN-PG&E-03: Section 5.8
- On Revision Notice Issue RN-PG&E-04: Section 5.4
- On Revision Notice Issue RN-PG&E-05: Section 5.5
- On Revision Notice Issue RN-PG&E-06: Section 5.5

1.3 Key Areas for Improvement and Remedies

Energy Safety evaluated the 2021 WMP Updates with a particular focus on how the utility’s chosen mitigations and strategies will drive down the risk of utility-related wildfires as well as the scale, scope, and frequency of PSPS events. Energy Safety approves PG&E’s 2021 WMP Update; however, Energy Safety finds that PG&E must focus over the next year on the areas summarized in Table 2 below. While continued progress toward maturity is important in all areas of a utility’s WMP, Energy Safety finds these areas to be key for PG&E to continue to drive down utility-related wildfire risk. Energy Safety expects PG&E to take action to address these key areas²⁸ and report on progress made over the year in a Progress Report due by 5:00 p.m. on November 1, 2021, and in its 2022 WMP Update. Energy Safety will closely monitor progress in each of these areas over the coming year.

Table 2 provides a summary of the key areas for improvement and remedies and has been edited for length. A version of this table containing the full text of the key areas for improvement and remedies is contained in Appendix 10.1.

In addition to the table below summarizing key areas for improvement, each key focus area and any required follow-up are denoted by a table in the respective detailed evaluation section.

²⁸ PG&E must address the complete key areas for improvement and associated remedies which can be found in the corresponding initiative section and Appendix 10.1 of this Action Statement.

Table 2: Summary of key areas for improvement and remedies.

| Risk Assessment and Mapping (Section 5.1) | | |
|---|---|---|
| Utility-# and title | Summary of issue description | Summary of remedies required and alternative timeline if applicable |
| PG&E-21-01 Unclear inclusion of future climate data into planning | PG&E’s 2021 WMP Update does not include PG&E’s climate resilience team’s evaluation of High Fire Risk Areas (HFRA) ²⁹ map initiatives in order to validate that the maps are consistent with climate projections. | PG&E must explain how it incorporates components of its climate resilience team’s report into its own risk assessment. |
| PG&E-21-02 Lack of consistency in approach to wildfire risk modeling across utilities | The utilities do not have a consistent approach to wildfire risk modeling. They face similar enough circumstances that there should be some level of consistency in statewide approaches to wildfire risk modeling. | The utilities ³⁰ must collaborate through a working group facilitated by Energy Safety to develop a more consistent statewide approach to wildfire risk modeling. A working group will allow for collaboration among the utilities, stakeholder and academic expert input, and increased transparency. |
| PG&E-21-03 Inadequate speed of improvements made to risk modeling | PG&E self-reported a low risk assessment score in the Maturity Model with slower growth in comparison to the other two large investor-owned utilities (IOUs). Thus, PG&E fails to demonstrate growth at an adequate speed in regard to its risk assessment. | PG&E must demonstrate that it is applying automation as quickly as possible, explaining any constraints on progress, and supply its workplan to enhance its modeling efforts. |
| PG&E-21-04 PG&E does not adequately justify the wind speed inputs it uses in its Probability of Ignition Models. | PG&E’s Outage Producing Winds (OPW) Model finds a correlation between equipment failure and high wind speed. Despite the correlation, PG&E does not use peak wind speed as part of its input data set for its Equipment Probability of Ignition Model. | PG&E must demonstrate that it appropriately accounts for wind speed in its Probability of Ignition Models’ input data sets and addresses discrepancies between its input data sets and those of its peer utilities. |
| PG&E-21-05 Lack of PSPS consequence model at a circuit-segment level | PG&E does not describe any specific efforts or progress regarding the development of the PSPS risk model. The incorporation of PSPS consequence risk into the total risk reduction of a mitigation initiative is crucial to the selection process. | PG&E must provide a detailed update on the functionality of its PSPS consequence model at a circuit-segment level; and quantitative targets for any remaining work or future developments. |

²⁹ PG&E 2021 WMP Update at p. 85. PG&E identified areas of increased fire risk that are not currently included in the CPUC-designated HFTD and defined these as High Fire Risk Areas.

³⁰ Here “utilities” refers to SDG&E and Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), PacifiCorp, Bear Valley Electric Service, Inc. (BVES), and Liberty Utilities; although this may not be the case every time “utilities” is used through the document.



| | | |
|---|---|--|
| <p>PG&E-21-06</p> <p>Insufficient transparency for modifications to Wildfire Risk Models and circuit segment prioritization</p> | <p>In response to RN-PG&E-02, PG&E provided justification for its reprioritization of circuit segments and also provided the third-party review of its 2021 Wildfire Distribution Risk Model. The third-party’s analysis included recommendations for PG&E to improve its Wildfire Risk Models. PG&E must continue to update its models and report its progress in implementing the third-party’s evaluation recommendations.</p> | <p>PG&E must provide an update on progress made on each of the third-party’s recommendations and an updated timeline for addressing the recommendations. PG&E must detail what changes have been made to its 2021 risk models since the submission of its 2021 WMP Update and describe changes it has made to its circuit segment prioritization since the submission of its 2021 WMP Update.</p> |
| <p>Situational Awareness and Forecasting (Section 5.2)</p> | | |
| <p>Utility-# and title</p> | <p>Summary of issue description</p> | <p>Summary of remedies required and alternative timeline if applicable</p> |
| <p>PG&E-21-07</p> <p>PG&E’s DFA and EFD technology pilot outcome is lacking justification for the scope of installment</p> | <p>Following PG&E’s 2020 pilot project for Distribution Fault Anticipation (DFA) and Early Fault Detection (EFD) technology, PG&E determined to ramp up deployment to 600-800 circuits. However, PG&E lacks details and performance metrics on the pilot outcome and how PG&E made the decision to ramp up deployment.</p> | <p>PG&E must provide details and performance metrics on the outcome of the 2020 DFA and EFD technology pilot program and explain how the determination was made to increase deployments of DFA/EFD technology across HFTD areas.</p> |
| <p>PG&E-21-08</p> <p>Weather station program target not met</p> | <p>PG&E’s 2021 WMP Update originally reported installation of 404 weather stations in 2020, surpassing its program target of 400. However, in PG&E’s revised 2021 WMP Update the weather station installations changed to 378 in 2020, falling short of its target without explanation.</p> | <p>PG&E must provide details on why PG&E did not meet the targeted 400 weather station installs in 2020 and explain why weather station installation totals in the original 2021 WMP Update differ from the revised 2021 WMP Update.</p> |
| <p>Grid Design and System Hardening (Section 5.3)</p> | | |
| <p>Utility-# and title</p> | <p>Summary of issue description</p> | <p>Summary of remedies required and alternative timeline if applicable</p> |
| <p>PG&E-21-09</p> <p>Limited evidence to support the effectiveness of covered conductor</p> | <p>The rationale to support the selection of covered conductor as a preferred initiative to mitigate wildfire risk lacks consistency among the utilities. The utilities have not demonstrated a full understanding of the long-term risk reduction, cost-effectiveness, and field performance of covered conductor, and fail to provide adequate comparison to other initiatives’ ability to reduce PSPS risk.</p> | <p>The utilities must coordinate to develop a consistent approach to evaluating the long-term risk reduction and cost-effectiveness of covered conductor deployment (including the effectiveness of covered conductor in the field in comparison to alternative initiatives) and to determining how covered conductor installation compares to other initiatives in its potential to reduce PSPS risk.</p> |
| <p>PG&E-21-10</p> | <p>The pace of PG&E’s current program for expulsion fuse replacements is not</p> | <p>PG&E must demonstrate that it is replacing expulsion fuses with fuses that reduce wildfire risk at a speed that adequately addresses risk;</p> |



| | | |
|--|---|--|
| Insufficient pace of expulsion fuse replacement plan | proportional to those of SDG&E and SCE. ³¹ The slower pace is especially problematic given PG&E’s larger service territory. | explain current limits or constraints on the scope of PG&E’s expulsion fuse replacement program; and increase the pace of its expulsion fuse replacement program, provided reasonable constraints do not limit such expansion. |
| PG&E-21-11 Insufficient detail regarding installation of expulsion fuses in HFTD areas | PG&E continues to install non-exempt expulsion fuses, which are considered to be fire hazards, in HFTD areas. PG&E does not detail whether the non-exempt expulsion fuses it installed in the HFTD in 2019 and 2020 were installed under allowable circumstances. | PG&E must explain the circumstances under which it installed non-exempt expulsion fuses in HFTD areas; and clarify if any of the new expulsion fuses it is installing in the HFTD in 2021 and beyond are non-exempt fuses. |
| PG&E-21-12 Failure to adequately track copper conductor replacements and insufficient detail regarding targeting replacements to highest risk areas | PG&E identified that copper conductor poses a high risk due to its high incidence of failure yet does not currently track completed copper reconductoring projects nor provide sufficient evidence that its copper reconductoring plan targets the highest risk circuits. | PG&E must develop a workplan to target and track copper reconductoring projects; and demonstrate that it is targeting its copper reconductoring projects to its highest risk circuits, including justification for any projects outside of the HFTD. |
| PG&E-21-13 Failure to demonstrate that system hardening plan targets highest risk circuit segments | A small percentage of circuit-segments in PG&E’s distribution system pose a high percentage of PG&E’s wildfire risk. ³² However, PG&E does not clearly demonstrate that its system hardening plan targets these segments. | PG&E must fully demonstrate that its system hardening mitigation efforts efficiently target reducing wildfire risk and PSPS events, including a description of how PG&E determines the order in which circuit segments are scheduled for mitigation. |
| PG&E-21-14 Inadequate transparency of | PG&E provides limited detail regarding its short-term system hardening plan and does not include its long-term system hardening plan. Additionally, PG&E’s July 21, 2021, press release ³³ regarding its intention to | PG&E must provide additional detail on its short-term system hardening plans; provide its long-term system hardening plan; explain how, if at all, PG&E’s recently announced undergrounding plan changes its decision- |

³¹ Cal Advocates’ Comments state at p. 36: “PG&E has approximately 22,000 expulsion fuses in HFTDs and forecasts replacing about five percent of them in 2021” which is approximately 1,100 fuses. At this rate, it will take PG&E nearly two decades to remove all the expulsion fuses from the HFTD. By comparison, BVES replaced 2,200 in 2020, which is more expulsion fuses than PG&E in 2020, although PG&E’s service territory is two thousand times larger than BVES. In 2021, SDG&E replaced “3,179 (with a focus in Tiers 3 and 2 of the HFTD), bringing the total replaced to 5,669 out of the 11,000 total populations of such fuses in the HFTD” (according to SDG&E’s 2021 WMP Update, p. 197). SCE is replacing “13,000 locations by the end of 2022 (cumulative from the inception of the program in 2018)” (according to SCE’s 2021 WMP Update, p. 216).

³² “2021 Wildfire Mitigation Plan Workshop Grid Design and System Hardening” presented February 23, 2021, p. 4.

³³ “PG&E Announces Major New Electric Infrastructure Safety Initiative to Protect Communities From Wildfire Threat,” July 21, 2021: <https://investor.pgecorp.com/news-events/press-releases/press-release-details/2021/PGE-Announces-Major-New-Electric-Infrastructure-Safety-Initiative-to-Protect-Communities-From-Wildfire-Threat/default.aspx> (accessed July 28, 2021).



| system hardening plan | underground 10,000 miles of power lines indicates that the system hardening plan and initiative selection process that PG&E presents in its 2021 WMP Update may change. | making framework for initiative selection; and provide an update on its system hardening efforts. Additionally, if PG&E is moving forward with its stated intention to underground 10,000 miles of power lines, PG&E must provide detail in its 2022 WMP Update on the decision to underground and its plans for such undergrounding. |
|--|---|---|
| Asset Management and Inspections (Section 5.4) | | |
| Utility-# and title | Summary of issue description | Summary of remedies required and alternative timeline if applicable |
| PG&E-21-15 Insufficient detail regarding covered conductor maintenance | PG&E does not provide sufficient detail on its covered conductor maintenance requirements. PG&E does not explain or justify its spend projections for covered conductor maintenance, which decrease from 2021 to 2022 despite the constant projected line miles. | PG&E must provide its procedures for determining when covered conductor maintenance is required and explain why PG&E’s cost projections decrease from 2021 to 2022 despite line mile projections remaining the same. |
| PG&E-21-16 Insufficient evidence of effective covered conductor maintenance program | PG&E does not have a separate covered conductor maintenance program. | PG&E must either provide all supporting material to demonstrate that its maintenance programs effectively maintain its covered conductor or enhance its current operations and explain how the enhancements will effectively maintain its covered conductor. |
| PG&E-21-17 Insufficient evidence of QA/QC for work performed by contractors | Several PG&E internal audits revealed contractors that failed to follow procedures. PG&E’s response to these issues was insufficient. | PG&E must demonstrate that it is tracking the quality of contractor work; describe how it is addressing underperforming contractors; and describe how it is expanding quality control of work performed by contractors. |
| Vegetation Management and Inspections (Section 5.5) | | |
| Utility-# and title | Summary of issue description | Summary of remedies required and alternative timeline if applicable |
| PG&E-21-18 Minimally planned maturity of VM program | PG&E has increased the scale of its VM program but does not foresee maturing five of six VM Maturity Model capabilities. PG&E must create a long-term VM maturation strategy and establish clear goals and targets to prioritize work and monitor progress toward its risk-reduction goals. | PG&E must clearly define goals and targets to reach each level of maturity for Maturity Model capabilities 21-26 and include a timeline for completion of the goals and targets from. PG&E must also provide a long-term vision for each VM initiative in Subsection 5 “Future improvements to the initiative” (or similar) including any relevant timelines. |



| | | |
|---|--|--|
| <p>PG&E-21-19</p> <p>Delays in achieving mutually agreeable environmental mitigation</p> | <p>PG&E cites delays in reaching mutually agreeable environmental and community impact mitigation efforts that “in certain situations,”³⁴ result in PG&E seeking court orders.³⁵ These delays, judicial or otherwise, can compromise working relationships between the community and state and local environmental agencies and cause further delays to WMP initiatives.</p> | <p>PG&E must show progress on achieving environmental and community impact mitigation agreements with agencies, local governments, and tribal governments. PG&E must consider the development of Operations and Maintenance Plans and Memorandums of Understandings with relevant federal, state,³⁶ and local land managing agencies to facilitate agreed-upon review times of permits and/or vegetation management activities. PG&E must document the outcomes of these efforts and any lessons learned.</p> |
| <p>PG&E-21-20</p> <p>Non-inclusion of fire damage attributes in hazard tree assessments</p> | <p>It is unclear whether PG&E uses its Tree Assessment Tool (TAT) to perform hazard tree assessments in post-wildfire response circumstances or uses no tool or standard for this purpose.</p> | <p>PG&E must clarify what tool or standard it and its contractors use in post-wildfire response circumstances for hazard tree assessments for post-fire specifics. If PG&E does not currently use any such tool (including TAT), PG&E must develop a tool or standard for this purpose.</p> |
| <p>PG&E-21-21</p> <p>Unknown environmental impact and efficacy of PG&E’s Preventative Fire Retardant Program (PFRP)</p> | <p>PG&E plans to undertake an environmental review of fire-retardant chemicals ahead of the 2021 wildfire season to pilot under its Utility Defensible Space (UDS) program “pre-treat[ing] Right of Ways (ROWs) and around equipment in select locations to limit a spark from causing an ignition.” In PG&E’s 2021 WMP Update, it had not determined a long-term plan for this initiative and had no set targets. However, Energy Safety has since been informed that PG&E has been applying fire-retardant to “81 pilot [circuit] miles”³⁷ as part of its PFRP. The efficacy and environmental impact of PG&E’s PFRP are unknown.</p> | <p>PG&E must provide its review of fire-retardant to Energy Safety; a report on its 2021 applications; any plans for 2022 applications; quarterly reports regarding the deployment of fire retardant to the Compliance Division of Energy Safety per CPUC-approved Compliance Operational Protocols;³⁸ and an RSE value for its PFRP.</p> |
| <p>PG&E-21-22</p> <p>Incomplete identification of</p> | <p>PG&E must ensure proper identification of species so that the “regional species risk values”³⁹ put into its TAT are updated and accurate. While PG&E does not currently prescribe tree work based on specific</p> | <p>PG&E must use scientific names in its reporting, add genus and species designation input capabilities into its systems that track vegetation, and identify the genus and species of any tree that has caused an outage⁴⁰ or</p> |

³⁴ PG&E 2021 WMP Update Revision – Clean, p. 691.

³⁵ PG&E 2021 WMP Update Revision – Clean, p. 691.

³⁶ This does not include the CPUC nor any environmental review processes already required by the CPUC.

³⁷ Presentation to the Office of Energy Infrastructure Safety and the CPUC’s Safety Enforcement Division from PG&E titled “Public Safety Measures: Addressing Extreme Drought”, August 6, 2021.

³⁸ Wildfire Safety Division – Compliance Operational Protocols, issued February 16, 2021, p. 5-7.

³⁹ PG&E 2021 WMP Update, p. 667.

⁴⁰ WSD GIS Data Reporting Standard Version 2, Transmission Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.5 & Distribution Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.7.



| vegetation species and record keeping | species, it may choose to do so in the future; in this case, accurate species recordkeeping is essential. | ignition ⁴¹ in the Quarterly Data Reports (QDRs). |
|--|---|---|
| PG&E-21-23 Inadequate joint plan to study the effectiveness of enhanced clearances | RCP Action-PGE-35 ⁴² (Class A) required PG&E, SCE, and SDG&E to “submit a joint, unified plan” to begin a study of the effectiveness of extended vegetation clearances. PG&E, SCE, and SDG&E presented the “joint, unified” plan to WSD on February 18, 2021. While it was apparent the three large utilities had discussed a unified approach, each utility presented differing analyses that would be performed to measure the effectiveness of enhanced clearances. | PG&E, SCE, and SDG&E will participate in a multi-year vegetation clearance study. Energy Safety will confirm the details of this study in due course. The objectives of this study are to: establish uniform data collection standards create a cross-utility database of tree-caused risk events (i.e., outages and ignitions caused by vegetation contact); incorporate biotic and abiotic factors into the determination of outage and ignition risk caused by vegetation contact; and assess the effectiveness of enhanced clearances |
| PG&E-21-24 Need for quantified vegetation management compliance targets | In Table 12, PG&E only defines quantitative targets for six of 20 VM initiatives. Energy Safety will audit PG&E when a “substantial portion” of PG&E’s VM work is complete and needs quantification in this task. | PG&E must define quantitative targets for all VM initiatives. If PG&E contends quantitative targets are not applicable to an initiative, PG&E must fully justify its position, define goals within that initiative, and include a timeline in which it expects to achieve those goals. |
| Grid Operations and Operating Protocols, Including PSPS (Section 5.6) | | |
| Utility-# and title | Summary of issue description | Summary of remedies required and alternative timeline if applicable |
| PG&E-21-25 Lack of specificity regarding how increased grid hardening will change system operations, change PSPS thresholds, and reduce PSPS events | PG&E does not commit to changes in its PSPS thresholds for increased grid hardening. PG&E does not specify how increased grid hardening will change system operations. | For each mitigation alternative, including pilot program initiatives, PG&E must provide quantitative analysis on: changes in system operations; changes in PSPS thresholds; and estimated changes in the frequency, duration, and number of customers impacted by PSPS events. |
| Resource Allocation Methodology (Section 5.8) | | |
| Utility-# and title | Summary of issue description | Summary of remedies required and alternative timeline if applicable |

⁴¹ WSD GIS Data Reporting Standard Version 2, Ignition (Feature Class), Section 3.4.3

⁴² Wildfire Safety Division Evaluation of Pacific Gas and Electric Company’s Remedial Compliance Plan can be found here (accessed August 2, 2021):

<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/pge-rcp-action-statement-20201230.pdf>



| | | |
|---|--|---|
| <p>PG&E-21-26</p> <p>Inadequate discussion on impact of Risk Spend Efficiencies (RSE) in initiative selection</p> | <p>PG&E does not clearly explain how RSE estimates impact its initiative selection process. RSE estimates provide a pathway to assess the relative benefit provided by the mitigation initiatives and must play an integral role in the selection process. Energy Safety understands the dynamic nature of initiative selection due to work management efficiencies, operational realities, resource constraints, and other factors. However, a clear description of how RSE estimates impact the selection process must be provided to ensure consistency across initiatives.</p> | <p>PG&E must provide an overview of its decision-making framework to include a clear explanation of how RSE estimates impact decision making for initiative selection. The overview must show the rankings of the relative decision-making factors (e.g., planning and execution lead times, resource constraints, etc.) and pinpoint where quantifiable risk reductions and RSE estimates are considered in the initiative selection process. Energy Safety recommends a cascading, dynamic “if-then” style flowchart to effectively demonstrate this prioritization process and satisfy this requirement.</p> |
| <p>PG&E-21-27</p> <p>Lack of methodology to verify RSE estimates</p> | <p>PG&E’s response to capability 41c of the 2021 Maturity Survey showed that there is no RSE verification process in place. In order to rely on RSEs to select mitigation initiatives, PG&E must have high confidence that the calculated RSEs are accurate. PG&E must develop a methodology to assess the accuracy of its RSE estimates.</p> | <p>PG&E must provide a detailed RSE verification plan with attainable benchmarks and timeline.</p> |
| <p>PG&E-21-28</p> <p>RSE values vary across utilities</p> | <p>Energy Safety raises a concern that there are stark variances in RSE estimates, sometimes on several orders of magnitude, for the same initiatives calculated by different utilities. There are also significant discrepancies between the utilities’ inputs and assumptions, which further support the need for exploration and alignment of these calculations.</p> | <p>The utilities must collaborate through a working group facilitated by Energy Safety to develop a more standardized approach to the inputs and assumptions used for RSE calculations. After Energy Safety completes its evaluation of the 2021 WMP Updates, it will provide additional detail on the specifics of this working group.</p> |
| <p>Public Safety Power Shutoff (PSPS), Including Directional Vision for PSPS (Section 6)</p> | | |
| <p>Utility-# and title</p> | <p>Summary of issue description</p> | <p>Summary of remedies required and alternative timeline if applicable</p> |
| <p>PG&E-21-29</p> <p>PSPS targets and projections set to expire</p> | <p>PG&E will update its PSPS approach and the PSPS targets and projections presented in its WMP Update and Revision Notice response will become obsolete.</p> | <p>After PG&E updates its PSPS approach, PG&E must submit a Change Order Report describing its updated PSPS protocols and show how its new PSPS protocols affect PSPS projections and targets.</p> |

In addition to the key areas for improvement listed in Table 2 above, Energy Safety lists additional issues for continued improvement to increase the maturity of PG&E’s wildfire mitigation capabilities in the evaluation sections below. These additional issues are denoted by



bullet points. Energy Safety expects PG&E to take action to address these issues and report on progress made over the year in its 2022 WMP Update.

1.4 Maturity Model Evaluation

The WSD introduced a maturity model (the Utility Wildfire Mitigation Maturity Model) in 2020, providing a method to assess utility wildfire risk reduction capabilities and examine the relative maturity of individual wildfire mitigation programs. In 2020, the utilities completed a survey setting a baseline for maturity as well as anticipated progress over the three-year plan period. In 2021, the utilities again completed the survey, enabling Energy Safety to monitor progress and ascertain potential improvements to maturity based on progress to date.

The ten maturity and mitigation initiative categories are listed below in Section 5. Each capability within a category was assigned a level, from 0 – 4 range, with 0 being the lowest and 4 the highest. The levels were calculated using an “all or nothing” binary approach. Thus, to reach a specific maturity level, an electrical corporation would have to meet 100 percent of the threshold requirements for that level. Refer to Attachment 11.1 of this Action Statement for more details.

Energy Safety makes the following key findings regarding PG&E’s maturity progress in 2021:

- PG&E currently rates its own highest maturity in the areas of
 - Situational Awareness & Forecasting (1.4)
 - Grid Operations & Protocols (1.3)
 - Stakeholder Cooperation & Community Engagement (1.4)
- The two areas where PG&E anticipates the most maturity growth by the end of the 2020-22 WMP cycle are:
 - Data Governance (from 0.3 to 2.8)
 - Emergency Planning & Preparedness (from 0.4 to 3.6)
- PG&E’s overall maturity ranks considerably behind both SCE and SDG&E in several significant categories:
 - Grid Design & System Hardening (0.8)
 - Asset Management & Inspections (0.8)
 - Vegetation Management & Inspections (0.7)
 - Data Governance (0.8)
 - Resource Allocation Methodology (0.8)
 - Emergency Planning & Preparedness (2.0)
- PG&E does not foresee maturing five of six VM Maturity Model capabilities.⁴³

⁴³ PG&E does not foresee maturing in the following VM related capabilities: vegetation inspection cycle (capability 22), vegetation inspection effectiveness (capability 23), vegetation grow-in mitigation (capability 24), vegetation fall-in mitigation (capability 25), and QA/QC for vegetation management (capability 26). See PG&E’s 2021 response to the Maturity Survey (accessed July 18, 2021):

<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/pge-2021-survey.pdf>



- PG&E rates its current Vegetation Management & Inspections maturity at only 0.7 and only foresees improvement to 1.0. By comparison, SCE foresees improving from 2.0 to 3.0 across the WMP cycle, and SDG&E foresees improvement from 2.7 to 3.3.
 - PG&E reported maturity thresholds of zero for both current and cycle-end estimates for capability 24 (Vegetation Grow-In Mitigation) and capability 25 (Vegetation Fall-In Mitigation). These scores reflect PG&E’s reported length of time in removing vegetation from rights of way.
- PG&E estimates that its resource allocation methodology maturity will increase from 0.2 to 1.5 across the WMP cycle. By comparison, SCE anticipates improvement from 0.8 to 2.7; SDG&E from 1.0 to 2.5. Much of this disparity appears to stem from PG&E’s lack of methodology for verifying its risk-spend estimates.
 - For capability 40a of the 2021 Maturity Survey PG&E selected “Utility has accurate relative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate.” This selection is at odds with capability 41c, for which PG&E selected “Utility does not verify RSE estimates” for the WMP cycle 2020 – 2023.
 - PG&E self-reported a low score in risk modeling automation, with slower growth than its peer utilities.⁴⁴ PG&E overhauled its modeling efforts between the 2020 and 2021 WMP submissions. However, PG&E fails to demonstrate growth at a rate comparable to its peers in its risk modeling automation. (For additional information on this issue see Section 5.1 “Risk Assessment and Mapping.”)

2. WILDFIRE SAFETY ADVISORY BOARD INPUT

The Wildfire Safety Advisory Board (WSAB) provided recommendations on the WMP Updates of PG&E, Southern California Edison Company (SCE), and San Diego Gas & Electric Company (SDG&E) on April 16, 2021. Energy Safety has considered the WSAB’s recommendations and incorporates its input throughout this Action Statement. The WSAB’s recommendations focused on the following areas:

Risk Assessment, Mapping and Resource Allocation

- All three utilities are now creating their own in-house models and using models created by other vendors. The WSAB is concerned that the assumptions, algorithms, and outcomes of the models are not being closely and transparently reviewed by independent experts to ensure they meet scientific standards.

⁴⁴ Within the responses to the Maturity Survey, for capabilities 1 and 2, PG&E rated itself as not automated for its climate scenario modeling for both current and end of 2023 and ranked its ignition risk automation as currently not automated, expecting to move to partially automated (<50 percent) in 2023. In comparison, SCE rated itself as partially automated for climate scenario modeling for both current and end of 2023 and expects to move from partially automated to mostly automated (>50 percent) for ignition risk. SDG&E rated itself as mostly automated for climate scenario modeling for both current and end of 2023 and expects to move from partially automated to mostly automated for ignition risk.



- The WSAB is concerned that while PG&E does appear to be making great progress in developing its risk models its WMP Update does not report outcomes or how the outcomes have influenced decision-making and prioritization.
- The WMP Updates of all three utilities would benefit from specific examples of how mitigation measures were prioritized based on these models.⁴⁵
- Without undergoing a transparent peer review process, neither Energy Safety nor the public can verify the accuracy of these models. Verifying the accuracy of the models is an essential step in reviewing the rationale for determining priorities. Further, these models must be vetted to ensure the prudent use of ratepayer funds.
- The utilities should not maintain confidential modeling methods or implementation because the public safety of Californians depends upon our ability to reduce or eliminate utility-caused ignitions and wildfires.
- While the WSAB appreciates the sensitive and confidential nature of the data collected, there are ways to anonymize data so that it may be shared with the scientific community for peer review.

Vegetation Management: Inspections, Strategies, and Pilots

- Energy Safety should consider the impact of the utilities' vegetation management and tree removal practices on the environment, climate change, and wildfire risk. Energy Safety should consider whether the utilities have a tree replacement program and have consulted with ecologists regarding each tree removal.
- PG&E, SCE, and SDG&E should explore creating a statewide database so all incidents can be recorded, with the information to benefit all. This database could also track how species characteristics vary along different environmental gradients. Plants and trees are still being referred to by their genus, within which are hundreds of species. This database could serve as a repository to start narrowing the information and traits of these species.
- The WSAB is very concerned about the instances where PG&E has been cited in violation of environmental regulations by different State of California agencies.⁴⁶ The WSAB is troubled by the environmental impacts that are described therein such as discharges in waterways that are deleterious to fish and wildlife, and soil erosion from tree removal.

⁴⁵ SCE's 2021 WMP Update, pp. 83-86.

⁴⁶ These violations include:

- Department of Forestry, and Fire Protection (CAL FIRE) Notices of Violation #1-5 between – CZU Lightning Fire Utility Work 1-20NON-00122-SCR October 30, 2020 and February 8, 2020;
- Central Coast Regional Water Quality Control Board December 15, 2020 Notice of Violation for Unauthorized Discharges No. 7019 0700 0001 7649 7673; and
- California Coastal Commission Notice of Violation v-3-20-0089 for Tree Removal in Santa Cruz Mountains.



System Design and Management: Grid Hardening, Operations, Inspections, and Emerging Technology

- The WSAB is impressed with new technologies that are being piloted and deployed including PG&E’s distribution fault anticipation and fault current limiting technology. This technology significantly reduces the size of the arcs in the event of a fault which increases worker safety and decreases the risk of ignition. If an ignition does occur, the risk of a high-consequence fire is reduced because the intensity of the arc is shorter, and the size of the arc is smaller.
- The WSAB is concerned about PG&E’s reduced system hardening commitment from 342 line-miles in 2020 in HFTD to 180 line-miles in 2021.⁴⁷ PG&E has the largest service area of the three IOUs and has the greatest number of lines to harden.
- Energy Safety should request that the IOUs evaluate the risk involved in keeping idle lines or equipment energized versus disconnecting completely when not in use. Energy Safety should require the IOUs remove or de-energize lines and equipment that are not being used, which would lower the risk of those assets failing and causing a fire. PG&E indicates that it addresses idle lines and takes them out of service.⁴⁸ However, PG&E’s WMP Update does not describe its protocols for the de-energization of idle lines and equipment.
- The WSAB is concerned that none of the utilities’ WMP Updates describe their protocols to ensure the safety of their workforce when introducing new technologies or equipment, implementing new work practices, or during the removal, installation, and repair of equipment.

Public Safety Power Shutoffs: Reducing the Scale, Scope and Frequency

- During the WSD workshop held on August 11, 2020, the WSAB presented the System Hardening for Electric Utility Resiliency (SHEUR) threshold.⁴⁹ The utilities should develop a methodology (such as the SHEUR threshold) for reducing the risk of both wildfires and PSPS events, and systematically prioritizing grid hardening measures through risk spend efficiency calculations that treat wildfires and PSPS events as risks for the utilities to reduce the scale, scope, and frequency of PSPS.
- Both SCE and PG&E are in the process of developing more robust and adaptive predictive models in this area.

Emergency Planning and Communication: Emergency Preparedness, Stakeholder Cooperation, and Community Engagement

⁴⁷ PG&E 2021 WMP Update, p 9.

⁴⁸ Board member Mader presented this idea at the August 11, 2020, WSD workshop.

⁴⁹ The WSAB presented recommendations to the WSD during the August 11, 2020, WSD Workshop. See also the WSAB Recommendations on the 2021 WMP Guidelines (June 24, 2020), available at the WSAB’s website: <https://energysafety.ca.gov/who-we-are/wildfire-safety-advisory-board/> (accessed July 30, 2021).



- The WSAB acknowledges the increased maturity level of the utilities in the capabilities of emergency planning and preparedness, stakeholder cooperation, and community engagement.
- Each utility offers data to quantify its outreach efforts and how it interacts with the affected populations (e.g., social media outreach, PSPS information workshops, specific customer contacts).⁵⁰

3. PUBLIC AND STAKEHOLDER COMMENT

The following individuals and organizations submitted comments by March 29, 2021, and reply comments by April 13, 2021, on PG&E's 2021 WMP Update:

- Acton Town Council (ATC)
- California Farm Bureau Federation (CFBF)
- Green Power Institute (GPI)
- Joint Local Governments (JLG)
- Kevin Collins
- Mussey Grade Road Alliance (MGRA)
- Professor Catherine Sandoval, Santa Clara University School of Law (SCU Law)
- Protect Our Communities Foundation (PCF)
- Public Advocates Office at the California Public Utilities Commission (Cal Advocates)
- Rural County Representatives of California (RCRC)
- Santa Clara County (SCC)
- Small Business Utility Advocates (SBUA)
- The Utility Reform Network (TURN)
- Valley Women's Club for the San Lorenzo Valley
- Will Abrams

Comments were also provided on PG&E's response to its Revision Notice. The following individuals and organizations submitted comments by June 10, 2021, and reply comments by June 16, 2021, on PG&E's response to its 2021 Revision Notice:

- Green Power Institute (GPI)
- Mussey Grade Road Alliance (MGRA)
- Public Advocates Office at the California Public Utilities Commission (Cal Advocates)

Energy Safety has evaluated comments and concurs with the following stakeholder input on PG&E's 2021 WMP Update and PG&E's 2021 WMP Revision, as reflected in this Action Statement:

⁵⁰ SCE's 2021 WMP Update describes its regional prioritization and its monthly survey to capture awareness and perception metrics across a sample of its customers. See SCE's 2021 WMP Update, pp. 326-327.



- There should be a coordinated approach to the calculation of risk-spend efficiency values across the utilities (MGRA, TURN, Cal Advocates). In particular, there should be a coordinated approach to looking at the costs and risk-spend efficiency of covered conductor installation across the utilities (MGRA, TURN, Cal Advocates).
- There should also be a coordinated approach to the utilities' risk modeling efforts, supported by an Energy Safety-led technical working group (Cal Advocates). The risk models should be subject to verification (MGRA).
- Utilities should explain how post PSPS inspection data informs lessons learned, with the goal for utilities to re-evaluate PSPS thresholds and/or explore alternative solutions (RCRC, GPI, ATC).
- Utilities provided limited analyses on the estimated impacts from pilot programs on PSPS thresholds (PCF, SBUA).
- The utilities need to make more progress on their joint plan to begin a study of the effectiveness of extended vegetation clearances (MGRA).
- The utilities should prioritize wildfire mitigation measures that address ignitions that have external drivers (like high wind) and are likely to occur under the worst possible conditions (i.e., likely to lead to catastrophic fires) (MGRA).
- Use of fire retardant on vegetation as a pre-emptive measure for wildfire prevention could have long-lasting environmental impacts and needs to be studied with rigorous peer and public review before expanding the pilot (RCRC, CFBF, JLG, Cal Advocates).
- The utilities should report in their WMPs every instance of catastrophic wildfire and the lessons they learned (ATC, Will Abrams, Cal Advocates).
- PG&E's enhanced vegetation management is producing large amounts of biomass residue at the clearance site which could serve as dry fuel for future fires (GPI, RCRC, Cal Advocates). Large biomass is also left behind in PG&E's post-fire restoration work (JLG).
- PG&E has poor record-keeping of its contractors which reduces vegetation and asset management quality assurance and quality control (Prof. Sandoval [SCU Law], Cal Advocates).
- PG&E has not addressed its shortcomings in training its personnel and contractors and in tracking ongoing mitigation implementation quality (Cal Advocates, TURN, JLG, Will Abrams, RCRC).
- Despite costly mitigations, PG&E forecasts equal or more frequent use of PSPS in the coming decade. Sectionalization and other grid hardening efforts appear to have had little effect on PSPS risk (MGRA, Valley Women's Club for the San Lorenzo Valley, TURN, Cal Advocates, GPI, SCC, Prof. Sandoval [SCU Law], Kevin Collins, ATC, RCRC).
- PG&E calls for a PSPS even when strong winds are not present – PG&E should explicitly call out PSPS events that are called as a result of poor asset and vegetation management (Will Abrams, ATC, MGRA).
- Weather forecasting and monitoring supports short-term PSPS reduction but does not address long-term grid issues (GPI, RCRC). PG&E's system hardening programs have not



demonstrated a material impact on PSPS scale, scope, or frequency (Cal Advocates, MGRA).

- PG&E and SCE’s pilots on Rapid Earth Fault Current Limiters (REFCLs) have shown promise as a potential low-cost alternative to address ignition risks such as vegetation contact and wire downs. (MGRA, TURN).
- A significant percent of PG&E’s work verification inspections from 2019 and 2020 have findings that are still unaddressed and do not have a timeline to be addressed (Cal Advocates).
- PG&E needs to continue improving how it targets its system hardening and enhanced vegetation management initiatives to the areas that reduce the most risk (Cal Advocates, TURN).

4. DISCUSSION

The following sections discuss in detail PG&E’s 2021 WMP Update, including progress over the past year, issues, and remedies to address by the next annual submission.

4.1 Introductory Sections of the WMP

The first two sections of the WMP Guidelines⁵¹ require the utility to report basic information regarding persons responsible for executing the plan and adherence to statutory requirements. Section 1 requires contact information (telephone and email) for the executive with overall responsibility and the specific program owners. In addition, all experts consulted in preparation of the WMP must be cited by name and include their relevant background/credentials. Contact information and names may be submitted in a redacted file.

Section 2 requires the utility to specify where each of the 22 requirements from Pub. Util. Code section 8386(c) are satisfied. Each utility shall both affirm that the WMP addresses each requirement AND cite the section and page number where it is more fully described.

PG&E minimally satisfied all 22 requirements from Pub. Util. Code section 8386(c).

⁵¹ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 14-21 (accessed May 27, 2021):

<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

Issues and Remedies

While Energy Safety did not identify key areas for improvement in this competency, Energy Safety finds the following issues and directs associated remedies. Energy Safety expects PG&E to take action to address these issues and report on progress made over the year in its 2022 WMP Update.

- ISSUE: (All requirements.) The requested intent of Table 2-1 was to direct readers of the WMP to the section and page where the requirement was addressed. PG&E provided only the section reference.
 - REMEDY: Provide section *and* page number(s) in this table.
- ISSUE: (Requirement 11) According to the WMP Guidelines, PG&E must provide a “list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks.” PG&E did not provide this list and instead included a footnote that referenced a list. This list was later provided via a data request (see Appendix 10.2).
 - REMEDY: Provide a table with a prioritized list of wildfire risks and drivers and the rationale for prioritization.

4.2 Actuals and Planned Spending for Mitigation Plan

The WMP Guidelines⁵² require utilities to report a summary of WMP expenditures, planned and actual, for the current WMP cycle.

This requirement also includes an estimated annual increase in costs to the ratepayer due to utility-related wildfires and wildfire mitigation activities. The WMP Guidelines require that ratepayer impact calculations are clearly shown to demonstrate how each value was derived. Nothing in the request for such information should be construed as approval of any such expenditure, which is left to the CPUC pursuant to Pub. Util. Code section 8386.4(b).

PG&E provided all required information regarding expenditures. However, PG&E’s reported spend numbers differed with subsequent data request responses and phone conversations, making it difficult for Energy Safety to confirm the final expenditures. Further detail is explained in the “Issues and Remedies” section below.

See Figure 4.2.a for the comparison of the total WMP actual and planned spends of the three large electrical utilities.

- Comparing the planned spend of the three utilities, PG&E plans to spend the most in the WMP three-year cycle, but SDG&E plans to spend the most territory-wide per overhead circuit mile.

⁵² WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 22-24 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



- Comparing the planned spend of the three utilities, PG&E plans to spend the most in the WMP three-year cycle in HFTDs, but SCE plans to spend the most per overhead HFTD circuit mile.
- Like the other utilities, PG&E plans to spend the most in 2022 within the WMP three-year cycle, including about 4.6% more than the projected spending for 2021 (or \$5.117 billion).
- 56 percent of PG&E’s total WMP cycle spend is on Grid Design and System Hardening.
- PG&E’s highest-spend initiative for the total WMP cycle is 7.3.5.2 “Detailed inspections of vegetation around distribution electric lines and equipment” (\$3.186 billion total WMP cycle planned spend).
- PG&E shows an increase of 2 percent between its 2020 planned and 2020 actual spend (\$4.725 billion to \$4.821 billion).

PG&E’s net changes in spend at the WMP Category level show that initiatives were added, removed or had expenditures reallocated. Planned total WMP cycle spend as reported 2020 WMP vs. 2021 WMP (\$M) shows the following:

Spend increased in the following categories:

- Grid Design and System Hardening by \$768.6M (+10.31%)
- Vegetation Management and Inspections by \$103.7M (+2.41%)
- Data Governance by \$229.7M (+124.63%)
- Situational Awareness and Forecasting by \$22.1M (+17.46%)
- Stakeholder Cooperation and Community Engagement by \$37.6M (+31.89%)
- Resource Allocation Methodology by \$14.3M (+216.67%)
- Risk Assessment and Mapping by \$2.8M (+16.09%)

Spend decreased in the following categories:

- Asset Management and Inspections by \$413.9M (-33.89%)
- Grid Operations and Operating Protocols by \$205.6M (-27.01%)
- Emergency Planning and Preparedness by \$54.1M (-41.42%)

PG&E’s planned total WMP three-year cycle expenditures allocation by category in the 2021 WMP Update are (\$M and % of total):

- Grid Design and System Hardening \$8,225M (56%)
- Vegetation Management and Inspections \$4,409M (30%)
- Asset Management and Inspections \$808M (5%)
- Grid Operations and Operating Protocols \$556M (4%)
- Data Governance \$414M (3%)
- Stakeholder Cooperation and Community Engagement \$155M (1%)
- Situational Awareness and Forecasting \$149M (1%)
- Emergency Planning and Preparedness \$76M (0.5%)


- Resource Allocation Methodology \$21M (0.1%)
- Risk Assessment and Mapping \$20M (0.1%)

Energy Safety requested additional information and clarification from PG&E on their overall spend as described below, under “Issues and Remedies” for this section.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:

Planned and actual spending (\$M), territory-wide spend




Source: Tables 8 and 12 of utility 2021 WMPs, Tables 21-30 of utility 2020 WMPs, subsequent data requests and SCE and PGE Revision Notices
 1. SCE had initiatives that were reported in the 2020 WMP but not in the 2021 WMP; those initiatives are included in its 2020 plan totals
 2. In SCE's most recent data request response on 3/09/2021, SCE provided total territory spend but not annual territory-wide cycle spend as reported in 2020. The 2020 planned spend (1.68) is calculated from SCE's 2020 WMP submission
 3. SDG&E did not provide 2020-reported spend data for certain initiatives in their Feb 18 data request, as HFTD vs non HFTD split was not possible for those initiatives. Thus spend numbers from SDG&E's 2020 WMP were used for those specific initiatives.

Figure 4.2.a: Overview of total WMP spend across utilities, territory-wide spend.

As Figure 4.2.a shows, PG&E has the highest spend of the three large electrical utilities but is significantly lower than SDG&E in terms of spend per circuit mile.

Planned and actual spending (\$M), HFTD-only spend



Source: Tables 8 and 12 of utility 2021 WMPs, Tables 21-30 of utility 2020 WMPs, subsequent data requests, SCE and PGE Revision Notices
 1. PG&E and SCE had initiatives that were reported in the 2020 WMP but not in the 2021 WMP; those initiatives are included in their 2020 plan totals
 2. SDG&E did not provide 2020-reported spend data for certain initiatives in their Feb 18 data request, as HFTD vs non-HFTD split was not possible for those initiatives. Thus spend numbers from SDG&E's 2020 WMP were used for those specific initiatives.

Figure 4.2.b: Overview of total WMP spend across utilities, HFTD-only spend.

Figure 4.2.b provides a comparison of the high fire threat district actual and planned spends of the three large electrical utilities. As with total overhead circuits in Figure 4.2.a, PG&E's spend for HFTD circuit miles also falls between those of SCE and SDG&E.

Issues and Remedies

While Energy Safety did not identify key areas for improvement in this competency, Energy Safety finds the following issues and directs the associated remedies. Energy Safety expects PG&E to take action to address these issues and report on progress made over the year in its 2022 WMP Update.

- ISSUE: Explanations and amounts of large expenditure shifts in mitigation categories and individual initiatives (2020 actual vs. 2021 planned) were difficult to pin down across a number of phone conversations and data requests.

PG&E initially showed a marked increase in its total WMP-cycle spend as reported in 2021, compared to that reported in 2020; this apparent increase was due to an inconsistency in reporting, whereby in 2020 PG&E had only reported its spend in the HFTD. In response to data request WSD-006, Q1,⁵³ PG&E amended its territory-wide cycle spend, anticipated as of 2020. Thus amended, PG&E's planned territory-wide WMP-cycle spend in 2020 was reported to be \$15.160B. Territory-wide cycle spend as reported in 2021 was \$15.015B, a decrease in planned cycle spend of approximately 1

⁵³ Data request WSD-006, Question 1, can be found here (accessed July 22, 2021): https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan-discovery-data-requests.page.



percent from its 2020 plan to its 2021 plan. This change comprises decreased spend in Vegetation Management and Inspections initiatives and increases in Grid Design and System Hardening.

Then, in response to a Revision Notice issued by WSD on May 4, 2021, PG&E again amended its planned WMP cycle spend as reported for 2020 to 14.3B, and its plan as of 2021 to \$14.8B (see Appendix 10.3). These newer numbers included a range of estimates in spend on covered conductor and undergrounding, so the exact increase in planned spend will vary based on PG&E's covered conductor and undergrounding resource allocation. Issues in resource allocation are further discussed in the "Resource Allocation Methodology" mitigation initiatives and maturity evaluation.

- REMEDY: PG&E must report all wildfire mitigation-related activity spend in its 2022 and subsequent WMP updates, using the Energy Safety classification scheme required in the upcoming 2022 WMP Update Guidelines. PG&E must provide accurate spend information for its 2022 WMP Update upon initial submission. Any follow-up corrections must be fully explained and justified, with all calculations and underlying data reported to Energy Safety.

4.3 Lessons Learned and Risk Trends

This section of the WMP Guidelines⁵⁴ requires utilities to report how their plans have evolved since the 2020 WMP based on lessons learned, current risk trends, and research conducted. This section also requires utilities to report on potential future learnings through proposed and ongoing research.

Utilities must describe how the utility assesses wildfire risk in terms of ignition probability and estimated wildfire consequence using Commission adopted risk assessment requirements (for large electrical corporations) from the General Rate Case (GRC) Safety Model and Assessment Proceeding (S-MAP) and Risk Assessment Mitigation Phase (RAMP) Proceeding at a minimum. The utility may additionally include other assessments of wildfire risk. The utility must:

1. Describe how it monitors and accounts for the contribution of weather and fuel to ignition probability and wildfire consequence.
2. Identify any areas where the Commission's HFTD should be modified.
3. Explain any "high fire threat" areas the utility considers that differ from Commission-adopted HFTD, and why such areas are so classified.
4. Rank trends anticipated to have the greatest impact on ignition probability and wildfire consequence.

⁵⁴ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 24-29 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



PG&E provided all required information on lessons learned, current risk trends, and research conducted.

Energy Safety finds that PG&E has made the following progress over the past year:

- PG&E reports it is installing weather and fire monitoring devices across HFTD areas to provide early warning of high fire risk conditions and real-time identification of emerging wildfires, which enable faster action by first responders and more proactive system operations to avert fire ignition and spread. PG&E reports it is nearing the completion of long-term goals for the deployment of weather stations (1,300 by the end of 2021) and HD cameras (600 by the end of 2022).⁵⁵
- PG&E reports it has established a 24/7 meteorology operations and a Wildfire Safety Operations Center (WSOC). These two entities work together to support day-to-day gas and electric system operations broadly as well as support emergency responses and preparation activities. Each has the technology and analytical capabilities to forecast wildfire threat conditions, identify and track actual fires, and support rapid fire response.⁵⁶
- PG&E states that it has substantially updated its wildfire risk modeling and risk assessment tools for the 2021 WMP. PG&E's wildfire risk models produce a quantified risk value that is the product of two terms — the ignition probability and the wildfire consequence at each location. PG&E provides a summary of its models in Table PG&E-4.5-1, which includes the following:⁵⁷
 - Enterprise Risk Model
 - 2021 Wildfire Distribution Risk Model
 - Vegetation Probability of Ignition Model
 - Equipment Probability of Ignition Model
 - Wildfire Consequence Model
 - Vegetation Risk Model
 - Conductor Risk Model
 - Large Fire Probability Model (Distribution) or LFPd Model
 - Large Fire Probability Model (Transmission) or LFPt Model
 - Dead Fuel Moisture Model
 - Live Fuel Moisture Model
 - Transmission Operability Assessment Model or OA Model
 - Outage Producing Wind Model or OPW Model
 - Fire Potential Index Model or FPI Model or Utility FPI Model
- PG&E explains that it uses two forms of models that can be used to address wildfire risk:⁵⁸
 - Planning models which support annual workplans and are based on either worst-case conditions such as weather and fuels or cumulative probabilities of failure or

⁵⁵ PG&E 2021 WMP Update, p. 14.

⁵⁶ PG&E 2021 WMP Update, p. 15.

⁵⁷ PG&E 2021 WMP Update, p.121.

⁵⁸ PG&E 2021 WMP Update, p.130.



ignition. The 2021 Wildfire Distribution Risk Model is a planning model for the Electric Distribution system.

- Operational models, such as those used for PSPS events, use real-time weather, fuels data, and asset conditions as reflected by maintenance tags or recently completed asset hardening. The Large Fire Probability Model (Distribution) or LFPD Model is an example of an operational model.
- PG&E reports it has also modeled PSPS consequences to customers at a program level and is currently developing a more granular, circuit level model, to assess the impacts of PSPS de-energizations. PG&E indicates it currently plans to complete this analysis in collaboration with Energy Safety and the other California utilities by September 30, 2021.⁵⁹
- In 2020, PG&E identified areas of increased fire risk that are not currently included in the CPUC-designated HFTD and defined these as High Fire Risk Areas (HFRA).⁶⁰ It also completed the first version of the HFRA map, which identified approximately 115 areas that are not included in HFTD areas to be included in its PSPS scope. These HFRA map areas vary from small boundary adjustments (i.e., 0.25 acres) to larger areas (i.e., hundreds of square miles) where ignitions could lead to catastrophic fires during offshore wind events. Many of the larger areas do not contain high numbers of customers or PG&E assets as they are in rural, hard to access locations where a fire could grow and spread rapidly. PG&E provided a map and a high-level summary table depicting the following information:⁶¹
 - Polygons⁶² added: 115
 - Customers added to PSPS scope: 3,000
 - Distribution Circuit Miles within polygons: 620
 - Transmission Circuit Miles within polygons: 230
- PG&E provides detail in Table PG&E-4.2-9⁶³ identifying macro trends. It discusses change in ignition probability and estimated consequence due to:
 - climate change (warmer winters, extremely dry and wet years have become more common)
 - relevant species, such as bark beetles (invasive insect species can exacerbate forest health concerns and result in hazardous tree conditions that require repetitious monitoring and mitigation by utilities)
 - other drivers of change in fuel density and moisture (forests are becoming denser with decreased presence of large trees and significant tree mortality over the last decade)

⁵⁹ PG&E 2021 WMP Update, p. 139.

⁶⁰ PG&E 2021 WMP Update, p. 85.

⁶¹ PG&E 2021 WMP Update at p. 86 TABLE PG&E-4.2-8: HIGH LEVEL SUMMARY OF ADDITIONS TO HFTD AREAS.

⁶² <https://desktop.arcgis.com/en/arcmap/latest/analyze/arcpy-classes/polygon.htm> A Polygon object is a closed shape defined by a connected sequence of x, y coordinate pairs.

⁶³ PG&E 2021 WMP Update at p. 90 TABLE PG&E-4.2-9: MACRO TRENDS IGNITION PROBABILITY AND/OR WILDFIRE CONSEQUENCE.



- population changes that could be impacted by utility ignition (with projection of upward population trends continuing, it is likely that populations in the Wildland Urban Interface (WUI) and/or the HFTD areas will relatedly increase)
- population changes in HFTD that could be impacted by utility ignition (population growth in HFTD areas may exceed, at least in some areas, population growth in non-HFTD areas)
- population changes in the WUI that could be impacted by utility ignition (given the overall area of the WUI as a percentage of PG&E’s service territory, it is likely that population growth in WUI will not be an exception to anticipated trends)
- Utility infrastructure location in HFTD vs non-HFTD (PG&E anticipates limited net-addition of utility assets in the near future)
- utility infrastructure location in urban vs rural vs highly rural areas (trends impacting urban vs. rural are largely similar to those impacting HFTD vs non-HFTD)
- PG&E describes how the utility’s plan has evolved since 2020, focusing on the primary gaps identified and lessons learned from 2020 and 2019, including risk prioritization of Enhanced Vegetation Management (EVM) work, prioritizing the scheduling and execution of system inspections, and the quality of vegetation management activities.⁶⁴

4.4 Inputs to the Plan and Directional Vision for WMP

This section of the WMP Guidelines⁶⁵ requires the utility to rank and discuss trends anticipated to exhibit the greatest impact on ignition probability and wildfire consequence within the utility’s service territory over the next 10 years. First, utilities must set forth objectives over the following timeframes: before the upcoming wildfire season, before the next annual update, within the next 3 years, and within the next 10 years. Second and more practically, utilities must report the current and planned qualifications of their workforce they expect in order to meet these objectives.

Goal, objectives, and program targets:

The goal of the WMP is shared across Energy Safety and all utilities: documented reductions in the number of ignitions caused by utility actions or equipment and minimization of the societal consequences (with specific consideration of the impact on Access and Functional Needs populations and marginalized communities) of both wildfires and the mitigations employed to reduce them, including PSPS.

⁶⁴ PG&E 2021 WMP Update, pp. 46-50.

⁶⁵ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 29-31 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



The WMP Guidelines⁶⁶ require utilities to provide their objectives which are unique to each utility and reflect its 1, 3, and 10-year projections of progress toward the WMP goal. The WMP Guidelines also require utilities to report their unique program targets, which are quantifiable measurements of activity identified in WMPs and subsequent updates used to show progress toward reaching the objectives, such as number of trees trimmed or miles of power lines hardened.

PG&E provides all required information on its overall objectives and WMP program targets in Tables 5.3-1 and 5.2-1. PG&E referenced its objectives and program targets that were described extensively in its first quarterly report.

Issues and remedies

While Energy Safety did not identify key areas for improvement in this competency, Energy Safety finds the following issue and directs the associated remedy. Energy Safety expects PG&E to take action to address this issue and report on progress made over the year in its 2022 WMP Update.

- ISSUE: PG&E does not have a sufficient methodology for establishing and committing to long-term plans in wildfire mitigation despite being able to in all other areas of planning and operations within their business.
 - REMEDY: PG&E must develop a robust methodology for planning out 10 years (or longer) within its Wildfire Mitigation Plan to reduce long-term risk and buy down the costs of mitigation efforts.

Workforce planning:

This subsection of the WMP Guidelines⁶⁷ requires utilities to report their worker qualifications and training practices regarding utility-related wildfire and PSPS mitigation for workers in mitigation-related roles including:

1. Vegetation inspections
2. Vegetation management projects
3. Asset inspections
4. Grid hardening
5. Risk event inspection

⁶⁶ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 29-30 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

⁶⁷ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 30-31 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



PG&E has met all the required elements of this subsection. For additional discussion on workforce issues specific to vegetation management, see section 5.5.

4.5 Metrics and Underlying Data

The WMP Guidelines⁶⁸ require utilities to report metrics and program targets as follows:

- *Progress metrics* that track how much utility wildfire mitigation activity has managed to change the conditions of a utility's wildfire risk exposure in terms of drivers of ignition probability.
- *Outcome metrics* that measure the performance of a utility and its service territory in terms of both leading and lagging indicators of wildfire risk, PSPS risk, and other direct and indirect consequences of wildfire and PSPS, including the potential unintended consequences of wildfire mitigation work.
- *Program targets* measure tracking of proposed wildfire mitigation activities used to show progress toward a utility's specific objectives.⁶⁹ Program targets track the utility's pace of completing activities as laid out in the WMPs but do not track the efficacy of those activities. The primary use of these program targets in [year] will be to gauge utility follow-through on existing WMPs.

This section also requires utilities to provide several geographic information system (GIS) files detailing spatial information about their service territory and performance, including recent weather patterns, location of recent ignitions, area and duration of PSPS events, location of lines and assets, geographic and population characteristics, and location of planned initiatives.

See the Data Governance section for a review of the utility's progress and shortcomings in its Quarterly Data Reports.

Figures

Below are additional charts, maps and tables used as part of Energy Safety's review of PG&E's WMP Update:

⁶⁸ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 32-41 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

⁶⁹ Objectives are unique to each utility and reflect the 1, 3, and 10-year projections of progress toward the WMP goal. See section 5.4 for review of the utility's objectives.




Figure 4.5.a: Number of ignitions per 10,000 RFW circuit mile days, IOUs.

PG&E generally has more ignitions per overhead circuit mile compared to SCE and SDG&E (Figure 4.5.a). However, when normalized by RFW days, ignitions were reduced in 2020 for PG&E, SCE, and SDG&E. Ignitions are generally dominated by contact from objects, with equipment failure also representing a considerable fraction.




Figure 4.5.b: Risk events per overhead circuit mile, including ignitions, IOUs.

PG&E has the most risk events per overhead circuit mile, including ignitions (Figure 4.5.b) compared to SCE and SDG&E. PG&E projects a rise in risk event frequency in 2021, but then a slight decline in 2022. Consistent with this trend, PG&E experiences both more Red Flag Warning overhead circuit mile days per year than SCE and SDG&E do (Figure 4.5.c) as well as a greater percentage of increase from 2019 to 2020.

Red Flag Warning (RFW) overhead (OH) circuit mile days per year – entire utility territory



Source: Table 6 of 2021 utility WMPs.

Figure 4.5.c: Red Flag Warning (RFW) overhead circuit mile days, large utilities.

Level 1, 2, and 3 asset inspection findings for transmission and distribution, per circuit mile inspected



Source: Inspection findings from Table 1 of utility 2021 WMPs
 Note: A Level 1 finding is an immediate safety and/or reliability risk with high probability for significant impact. A Level 2 finding is a variable (non-immediate high to low safety and/or reliability risk). A Level 3 finding is an acceptable safety and/or reliability risk.

Figure 4.5.d: Asset inspection findings per circuit mile inspected, IOUs.

SCE has considerably more asset inspection findings than either PG&E or SDG&E (Figure 4.5.d). PG&E findings increased in 2019 and 2020 due to an increase in Level 3 findings but remain well below SCE findings.

A summary of PG&E’s spatial data submission is included in the Data Governance section (Section 5.7).



5. MITIGATION INITIATIVES AND MATURITY EVALUATION

This section of the WMP Guidelines⁷⁰ is the heart of the plan and requires the utility to describe each mitigation initiative it will undertake to reduce the risk of catastrophic wildfire. The utility is also required to self-report its current and projected progress to mitigate wildfire risk effectively,⁷¹ a capability referred to in this document as “maturity” and measured by Energy Safety Utility Wildfire Mitigation Maturity Model (“Maturity Model”). Utility maturity is measured across the same categories used to report mitigation initiatives listed below, allowing WSD to evaluate a utility’s reported and projected maturity in wildfire mitigation in the context of its corresponding current and planned initiatives. The ten maturity and mitigation initiative categories are listed below, with further details in Appendix 10.3:


- 1) Risk assessment and mapping
- 2) Situational awareness and forecasting
- 3) Grid design and system hardening
- 4) Asset management and inspections
- 5) Vegetation management and inspections
- 6) Grid operations and operating protocols
- 7) Data governance
- 8) Resource allocation methodology
- 9) Emergency planning and preparedness
- 10) Stakeholder cooperation and community engagement

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:


⁷⁰ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 42-46 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

⁷¹ Utilities that submitted a WMP were required to complete a survey in which they answered specific questions which assessed their existing and future wildfire mitigation practices across 52 capabilities at the time of submission and at the end of the three-year plan horizon. The 52 capabilities are mapped to the same ten categories identified for mitigation initiatives. The results of the survey can be found in Attachment 11.1 The most recent survey for each utility can be found on Energy Safety website here: <https://energysafety.ca.gov/what-we-do/wildfire-mitigation-and-safety/wildfire-mitigation-plans/2021-wmp/>.



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.a: Self-reported maturity by category, IOUs.



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.b: Projected growth through WMP cycle in maturity, PG&E.

In the following sections, Energy Safety evaluates PG&E’s initiatives across the 10 categories in the context of its Maturity Model survey scores.

5.1 Risk Assessment and Mapping

Introduction

The risk assessment and mapping section of the WMP Guidelines⁷² requires the utility to discuss initiatives implemented to minimize the risk of its causing wildfires. Utilities must describe initiatives related to equipment maps and modeling of overall wildfire risk, ignition probability, wildfire consequence, risk-reduction impact, match-drop simulations,⁷³ and climate/weather-driven risks. This section also requires the utility to provide data on spending, miles of infrastructure treated, spend per treated line mile, ignition probability drivers targeted, projected risk reduction achieved from implementing the initiative, and other (i.e., non-ignition) risk drivers addressed by the initiative.

The parameters of risk assessment (discussed in this section) and resource allocation (discussed later in section 5.8) to reduce wildfire risk derive from the S-MAP and RAMP proceedings for the utility GRC (D.18-12-014).

Each large investor-owned utility is at a different stage in using the S-MAP/RAMP methodology approved in D.18-12-014. Going forward, each is supposed to employ uniform processes and scoring methods to assess current risk and estimate risk reduction attributable to its proposed mitigations.

The risk modeling conducted should ultimately inform the RSE analyses discussed in category 8, resource allocation methodology.

Overview

Energy Safety finds that PG&E has made progress in its risk assessment and mapping⁷⁴ and finds this portion of PG&E's 2021 WMP Update to be generally sufficient, subject to remedies. PG&E continues to show growth and improvement in developing its Wildfire Risk Models, which inform its risk assessment and mapping. PG&E is expected to provide updates on its progress on identified issues in its ongoing required submissions with Energy Safety.

⁷² WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 43-44 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

⁷³ Simulations of the potential wildfire consequences of ignitions that occur along electric lines and equipment effectively showing the potential consequences if an ignition or “match was dropped” at a specific point in a utility's territory.

⁷⁴ PG&E's Maturity Model score for Risk Assessment and Mapping did not increase from 2020 and remains at zero for 2021 due to limited improvements in automation. However, PG&E did show progress in some Maturity Model survey questions for Risk Assessment and Mapping. As described in Section 1.4, the scoring rubric for each the Maturity Model uses an “all or nothing” binary approach. Therefore, if an electrical corporation self-reports progress in survey questions, it does not always increase the Maturity Model score for that category.



Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E redesigned its 2021 Wildfire Distribution Risk Model that includes a vegetation probability of ignition, an equipment probability of ignition model, and a fire consequence model (further discussed below). The updated model informs which circuit segments PG&E considers highest risk and enables PG&E to prioritize circuit segments for mitigation based on risk.
- In 2020, PG&E implemented machine learning techniques to develop its maximum entropy (MaxEnt) probability models, which specifically evaluates ignition probability, as well as its wind event forecasting system and vegetation index models. In 2021, PG&E plans on building additional machine learning models to undergo vision analysis from aerial inspections to further identify risks in-field.
- In 2020, PG&E shifted its regression ignition likelihood models for both equipment and vegetation to probability of ignition models. These models were developed by predicting the probability of ignitions within 100 meter by 100 meter pixels, and were trained using CPUC reportable ignitions from 2015 to 2018 and tested using the 2019 ignitions.⁷⁵
- In 2020, PG&E changed vendors for its consequence risk model, which focuses more on the effects of ladder fuels than the previous model. In 2021, PG&E will incorporate the consequence model to include transmission asset failure probability, as well as integrating the impacts of mitigation measures implemented through the WMP process.
- Unlike SCE or SDG&E, PG&E establishes an RSE score for risk assessment.

Discussion of Revision Notice Critical Issue RN-PG&E-02

As described in Section 1.2, PG&E was issued a Revision Notice on May 4, 2021. PG&E responded to the Revision Notice on June 3, 2021. The table below lists the critical issues contained in the Revision Notice specific to this section of the Action Statement followed by discussion. PG&E resolved the critical issue by providing the information requested. However, Energy Safety requires updates to provide transparency for changes to the model as recommended by the third-party report PG&E contracted. Remedies outlined in the chart below must be addressed in a progress report due November 1, 2021.

⁷⁵ PG&E's Redlined 2021 WMP Update, p. 136-137.



| Critical issue | Description | Utility response | Energy Safety evaluation |
|----------------|---|---|---|
| RN-PG&E-02 | Inadequate Justification of Significant Changes to High Priority Circuit Segments | PG&E provided its internal validation report, its third-party review and validation, and other available supporting materials that reviewed and/or validated its 2021 Risk Model. PG&E provided an explanation and timeline for how and when it intends to address all recommendations provided by these reports, reviews, and validations. PG&E provided detailed descriptions of and justification for modeling assumptions, choice of inputs, and accuracy of outputs. | PG&E provided the required information. However, additional remedies are required. PG&E’s third-party evaluation findings provided recommendations for improving PG&E’s risk models, including further integration between PG&E’s risk model and PSPS model, a need for a stronger connection between SMEs and the model, and the need for a roadmap for further development of the models. To provide transparency, as well as ensure that PG&E is addressing the contractor’s findings, PG&E must provide updates on its progress for implementing the recommended changes. This issue is addressed in key area for improvement PG&E-21-06. |

Revision Notice Critical Issue RN-PG&E-02 required PG&E to provide further justification of its shift in CPZ prioritization, including external validation and reviews. While PG&E provided the required justification within its response, it is critical for PG&E to continue to provide updates on its modeling efforts in order to maintain transparency between now and the 2022 WMP Update regarding its prioritization of circuit segments. Any updates to PG&E’s risk models, particular regarding outputs and future work plans, should be discussed during the modeling working group established as part of PG&E-21-02 as well as PG&E-21-06 below.

In its response to the Revision Notice, PG&E provided a third-party review of PG&E’s 2021 Wildfire Distribution Risk Model. The third-party’s analysis included recommendations with areas in which PG&E could improve its Wildfire Risk Models. PG&E must continue to update its models and report its progress in implementing the third-party’s evaluation recommendations as part of the remedy for PG&E-21-06 below.

One particular area of improvement listed by the third-party evaluator was to analyze using outage data instead of ignition data in order to train its models. The third-party points out that:

“the smaller ignition dataset raises concern about the statistical power of the models trained on them. If there are too few ignitions to deliver a good model fit,

it will fail to accurately predict on out of sample data (new locations, future years, etc.).”⁷⁶

The third-party report, demonstrates that areas with high ignition rates do not necessarily correlate to areas of high outage rates.⁷⁷ However, due to the high volume of data points needed to reduce bias when implementing machine learning, SCE currently uses outage data in order to garner more accurate output from its model for ignition risk.⁷⁸ PG&E’s use of only ignition data to train its model weighs more heavily on the parameters in which an event would lead to an ignition as opposed to the cause of the event. Similar parameters should also be covered by the consequence side of the model, therefore leading to a higher emphasis on areas of higher ignition risk as opposed to the events that caused the ignition themselves. This is of greater importance given that PG&E’s second top ignition causes are from equipment failure,⁷⁹ as well as the impact that PG&E’s mitigations will have on equipment failure moving forward, which PG&E is working to include in its future model iterations. PG&E has stated that it is currently working on setting up a process in order to integrate accurate outage data that had the potential to lead to an ignition.⁸⁰ PG&E should work with other utilities, stakeholders, and experts via the modeling working group established by PG&E-21-02 to determine the most accurate approach for which input data sets to use in its models.

Another difference between PG&E’s consequence risk model in comparison to SDG&E and SCE is that PG&E uses the 90 percent (P90) consequence threshold, as opposed to the max consequence threshold (that is, P100) used by SDG&E and SCE. All three utilities use the same vendor for the consequence portion of their risk models, but each utility can choose which level of consequence to use in its unique model. PG&E should work with other utilities, stakeholders, and experts via the modeling working group established by PG&E-21-02 to determine which wind speed threshold is most accurate to use in its consequence model. PG&E should also further provide evidence of proper integration of wind speed within its models in response to PG&E-21-04 below.

⁷⁶ E3 Review of PG&E’s 2021 Wildfire Distribution Risk Model, p. 31.

⁷⁷ E3 Review of PG&E’s 2021 Wildfire Distribution Risk Model, p. 32.

⁷⁸ PG&E’s 2021 Wildfire Distribution Risk Model “used 222 ignition events for the Vegetation Probability of Ignition Model and 242 ignition events for the Equipment Probability of Ignition Model respectively,” from PG&E’s Response to WSD’s DR 10 Question 16. In comparison, SCE provided that “54,000 events are used to train the model” and “Roughly 23,000 events are used to test the model” from PG&E’s Response to WSD’s DR 4 Question 2.

⁷⁹ PG&E’s Redlined 2021 WMP Update at pdf p. 193.

⁸⁰ PG&E states that an improvement upon the imbalance of its ignition dataset could be to “[u]tilize an algorithm that predicts the probability of an ignition when an outage event occurs” which “allows the use of outage data, which is much less imbalanced than the ignitions dataset.” From PG&E’s 2021 Redlined 2021 WMP Update PGE-02 Attachment 01, PG&E’s 2021 Wildfire Distribution Risk Model Overview, p. 91.



Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|--|--|
| PG&E-21-01 | Unclear inclusion of future climate data into planning | PG&E’s 2021 WMP Update does not include PG&E’s climate resilience team’s evaluation of High Fire Risk Areas (HFRA) ⁸¹ map initiatives in order to validate that the maps are consistent with climate projections. | PG&E must explain how it incorporates components of its climate resilience team’s report into its own risk assessment. |
| PG&E-21-02 | Lack of consistency in approach to wildfire risk modeling across utilities | The utilities do not have a consistent approach to wildfire risk modeling. For example, in their wildfire risk models, utilities use different types of data, use their individual data sets in different ways, and use different third-party vendors. Energy Safety recognizes that the utilities have differing service territory characteristics, differing data availability, and are at different stages in developing their wildfire risk models. However, the utilities face similar enough circumstances that there should be some level | <p>The utilities⁸² must collaborate through a working group facilitated by Energy Safety⁸³ to develop a more consistent statewide approach to wildfire risk modeling. After Energy Safety completes its evaluation of all the utilities’ 2021 WMP Updates, it will provide additional detail on the specifics of this working group.</p> <p>A working group to address wildfire risk modeling will allow for:</p> <ol style="list-style-type: none"> 1. Collaboration among the utilities; 2. Stakeholder and academic expert input; and 3. Increased transparency. |

⁸¹ PG&E 2021 WMP Update at p. 85. PG&E identified areas of increased fire risk that are not currently included in the CPUC-designated HFTD and defined these as High Fire Risk Areas.

⁸² Here “utilities” refers to SDG&E and Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), PacifiCorp, Bear Valley Electric Service, Inc. (BVES), and Liberty Utilities; although this may not be the case every time “utilities” is used through the document.

⁸³ The WSD transitioned to the Office of Energy Infrastructure Safety (Energy Safety) on July 1, 2021.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|--|
| | | of consistency in statewide approaches to wildfire risk modeling. | |
| PG&E-21-03 | Inadequate speed of improvements made to risk modeling | PG&E self-reported a low risk assessment score in the Maturity Model with slower growth in comparison to the other two large investor-owned utilities (IOUs). While this seems to be largely due to lack of automation in many different areas, and while PG&E overhauled its modeling efforts between the 2020 and 2021 WMP submissions, PG&E fails to demonstrate growth at an adequate speed in regard to its risk assessment. | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it is applying automation as quickly as possible, explaining any constraints on progress. 2. Supply its workplan to enhance its modeling efforts. |
| PG&E-21-04 | PG&E does not adequately justify the wind speed inputs it uses in its Probability of Ignition models. | PG&E’s Outage Producing Winds (OPW) model finds a correlation between equipment failure and high wind speed. Despite the correlation, PG&E does not use peak wind speed as part of its input data set for its Equipment Probability of Ignition models. Instead, PG&E uses average wind speed. PG&E provides justification for its rationale in its Revision Notice Response, however inconsistencies remain between PG&E’s approach and that of its peer utilities that use peak or near-peak wind speeds | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it appropriately accounts for wind speed in its Probability of Ignition models’ input data sets. This shall be handled both within the Working Group set up in PG&E-21-02, as well as an individualized report. 2. Address discrepancies between its input data sets and those of peer utilities. |



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|---|
| | | as part of their Wildfire Risk Modeling input data sets. | |
| PG&E-21-05 | Lack of PSPS consequence model at a circuit-segment level | SCE and SDG&E both have functioning PSPS consequence models, while PG&E states that their PSPS consequence model is currently under development. ⁸⁴ PG&E is working collaboratively with other California utilities and will complete the task by the second half of 2021. However, PG&E does not describe any specific efforts or progress regarding the development of the PSPS risk model. The incorporation of PSPS consequence risk into the total risk reduction of a mitigation initiative is crucial to the decision-making framework. | <p>PG&E must provide:</p> <ol style="list-style-type: none"> 1. A detailed update on the functionality of its PSPS consequence model at a circuit-segment level, and 2. Quantitative targets for any remaining work or future developments. |
| PG&E-21-06 | Insufficient transparency for modifications to Wildfire Risk Models and circuit segment prioritization | Revision Notice Critical Issue RN-PG&E-02 required PG&E to provide further justification of its shift in CPZ prioritization, including external validation and reviews. While PG&E provided the required justification within its response, it is critical for PG&E to continue to provide updates on its modeling | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Provide an update on progress made on each of the third-party's recommendations. 2. Provide any and all updates to the explanation and timeline for how and when it intends to address the recommendations. 3. Provide an Excel spreadsheet detailing what changes have been made to its 2021 risk models since the submission of its 2021 WMP Update. |

⁸⁴ PG&E 2021 WMP Update Revision – Clean, p. 49



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|-----------|-------------|---|--|
| | | <p>efforts in order to maintain transparency between now and the 2022 WMP Update regarding its prioritization of circuit segments. Additionally, in its response to the Revision Notice, PG&E provided a third-party review of its 2021 Wildfire Distribution Risk Model. The third-party’s analysis included recommendations for PG&E to improve its Wildfire Risk Models.</p> | <p>4. Provide a description of any changes it has made to its circuit segment the prioritization as a result of changes to its risk model since the submission of its 2021 WMP Update.</p> |

Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: In its 2021 WMP Update PG&E identifies areas of increased fire risk that are not currently included in the CPUC-designated HFTD and defines these as High Fire Risk Areas (“HFRA”).⁸⁵ PG&E extends its prioritization of initiatives to these self-defined HFRA.
 - REMEDY: PG&E must separate HFRA from its non-HFTD costs, presented in the format of WMP Table 12.
 - REMEDY: If PG&E believes there are areas in its service territory that are not currently included in the HFTD but should be prioritized for mitigation efforts, PG&E shall provide a process outlining the formal steps necessary to have those areas considered for recognition in the CPUC-defined HFTD.⁸⁶
- ISSUE: In the Maturity Model, PG&E self-reported a low score in risk modeling automation, with slower growth than its peer utilities.⁸⁷ PG&E overhauled its

⁸⁵ PG&E 2021 WMP Update, p. 85

⁸⁶ Similarly to what occurred in the 2019 WMP review process, SCE was ordered to submit a “process for bringing its “High Fire Risk Areas” into conformity with the Commission’s High Fire-Threat District area maps, or discuss in more detail why it should not be required to do so.” (D.19-05-038, p. 53) As a result, in August 2019 SCE submitted a petition to modify D.17-12-024 to recognize SCE-identified HFRA as HFTD Tier 2 areas.

⁸⁷ Within the responses to the Maturity Survey, for capabilities 1 and 2, PG&E rated itself as not automated for its climate scenario modeling for both current and end of 2023 and ranked its ignition risk automation as currently not automated, expecting to move to partially automated (<50 percent) in 2023. In comparison, SCE rated itself as


Footnote continued on next page.

modeling efforts between the 2020 and 2021 WMP submissions. However, PG&E fails to demonstrate growth at a rate comparable to its peers in its risk modeling automation.

- REMEDY: PG&E must explain why it does not have the same level of automation for risk modeling as its peers, including an explanation of any constraints on progress; and
- REMEDY: PG&E must supply a workplan and schedule for enhancing its automation capabilities in its risk modeling.
- ISSUE: PG&E's new model does not include egress as an input (in contrast to its previous wildfire risk model, which did include egress as an input). PG&E instead relies on subject matter expertise to account for egress when determining how to prioritize system hardening projects.
 - REMEDY: PG&E must provide an update on its development of a methodology to accurately measure and account for egress or explain how it accounts for egress in determining which circuits segments to prioritize for mitigation.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:




Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.1.a: Risk assessment and mapping maturity score progress, IOUs.

partially automated for climate scenario modeling for both current and end of 2023 and expects to move from partially automated to mostly automated (>50 percent) for ignition risk. SDG&E rated itself as mostly automated for climate scenario modeling for both current and end of 2023 and expects to move from partially automated to mostly automated for ignition risk.

Actual and projected spend (\$K) per HFTD overhead circuit mile



Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.1.b: Risk assessment and mapping spend per HFTD overhead circuit mile, IOUs.

5.2 Situational Awareness and Forecasting

Introduction

A strong weather monitoring and situational awareness system is an essential fire prevention/mitigation risk reduction strategy because it effectively alerts a utility’s preparation and response to potentially dangerous fire weather conditions that can inform its decisions on PSPS implementation, grid design, and system hardening. It is also one of the most inexpensive strategies.

The situational awareness and forecasting section of the WMP Guidelines⁸⁸ requires the utility to discuss its use of cameras, weather stations, weather forecasting and modeling tools, grid monitoring sensors, fault indicators, and equipment monitoring. Situational awareness requires the utility to be aware of actual ignitions in real time and to understand the likelihood of utility ignitions based on grid and asset conditions, wind, fuel conditions, temperature, and other factors.

⁸⁸ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 44 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



The WMP Guidelines refer to key situational awareness measures, including:

1. Installation of advanced weather monitoring and weather stations that collect data on weather conditions so as to develop weather forecasts and predict where ignition and wildfire spread are likely;
2. Installation of high-definition cameras throughout a utility's service territory, with the ability to control the camera's direction and magnification remotely;
3. Use of continuous monitoring sensors that can provide near-real-time information on grid conditions;
4. Use of a fire risk or fire potential index that takes numerous data points in given weather conditions and predicts the likelihood of wildfire; and,
5. Use of personnel to physically monitor areas of electric lines and equipment in elevated fire risk conditions.

Overview

Energy Safety finds that PG&E has made progress in its situational awareness and forecasting and finds this portion of PG&E's 2021 WMP Update to be sufficient. PG&E continues to show growth and improvement by expanding its High Definition (HD) wildfire camera network, enhancing its satellite fire detection capabilities, installing continuous monitoring sensors, and updating its fire potential index (FPI).

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E has the largest deployment of HD cameras in comparison to peer utilities. PG&E installed 216 HD cameras in 2020 with plans to continue installing 135 HD cameras for 2021. This is in alignment with its long-term goal to have 600 high-definition cameras in 2022 with 90 percent visual coverage of all their HFTD areas.
- PG&E continues to be the only utility that has established an in-house fire protection team. It's Safety Infrastructure Protection Teams (SIPT) provide real-time information on weather and field conditions and monitor for potential wildfire hazards. In 2020, PG&E increased their SIPT staff from 28 crews to 40 crews and 40 engines. This is in alignment with what they forecasted in the 2020 plan. This increased staffing should provide additional personnel for monitoring for wildfire risks and support its PSPS events.
- PG&E is at the forefront in its Satellite Fire Detection capability compared to peer utilities. PG&E added a fourth polar-orbiting satellite, NOAA-20, to its fire detection data suite, which should enhance its fire detection capabilities. PG&E uses these data in combination with its HD cameras to visualize new or expanding fires that could impact their infrastructure or personnel.



- PG&E continues to improve its FPI, which informs its operational decisions to reduce fire risk and is a direct input into its PSPS framework. Improvements include recalibration to incorporate landscape changes from the 2020 fire season and enhancing its fuel model input, similar to peer utilities. Future improvements by September 1, 2021, will include an updated fire occurrence data set to improve the granularity of its FPI.
- PG&E developed (RSE) Risk Spend Efficiency Values for 12 of its 18 initiatives in Situational Awareness & Forecasting, much more than their peer utilities.

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|---|--|
| PG&E-21-07 | PG&E’s DFA and EFD technology pilot outcome is lacking justification for the scope of installment | PG&E’s pilot project was completed in 2020 for Distribution Fault Anticipation (D) and Early Fault Detection (EFD) technology with the determination to continue deployment. However, PG&E lacks details and performance metrics on the outcome and how PG&E made the decision to ramp up deployment to 600-800 circuits. | PG&E must: <ol style="list-style-type: none"> 1. Provide details and performance metrics on the outcome of the 2020 DFA and EFD technology pilot program 2. Explain how the determination was made to increase deployments of DFA/EFD technology across HFTD areas. |
| PG&E-21-08 | Weather station program target not met | PG&E’s 2021 WMP Update originally reported installation of 404 weather stations in 2020, surpassing its program target of 400. However, in PG&E’s revised 2021 WMP Update the weather station installations changed to 378 in 2020 falling short of its target without explanation. | PG&E must: <ol style="list-style-type: none"> 1. Provide details on why PG&E did not meet the targeted 400 weather station installs in 2020. 2. Explain why weather station installation totals in the original 2021 WMP Update differ from the revised 2021 WMP Update. |


Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issue and directs the associated remedy. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: PG&E does not have a proactive plan for installing fault indicators, which are typically placed by either troublemen⁸⁹ during restorations or by an engineering team after the fact to aid in future faults. These fault indicators typically aid in electric service reliability, as they can be leveraged to concentrate focus to a much smaller portion of the electric circuit when trying to pinpoint a system failure/fault. This can also lead to a faster response to a location if an ignition exists. The lack of fault indicators can lead to longer duration of outages and/or make faults, damaged assets, or ignitions more difficult to locate.
 - REMEDY: PG&E must (1) develop a proactive plan to evaluate the benefit of installing fault indicators post-events; or (2) demonstrate that fault detection is sufficiently covered, including reducing time to restoration of service, by other existing initiatives.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:




Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.2.a: Situational awareness and forecasting maturity score progress.

⁸⁹ “Troublemens” are the PG&E responders sent to investigate the cause for outages.

Actual and projected spend (\$K) per HFTD overhead circuit mile



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$1.15 | \$3.12 | \$1.31 |
| 2021 Planned Total | \$1.61 | \$4.35 | \$1.76 |
| 2022 Planned Total | \$2.05 | \$4.64 | \$2.76 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.2.b: Situational awareness and forecasting spend per HFTD overhead circuit mile, large utilities 2020-2022.

5.3 Grid Design and System Hardening

Introduction

The grid design and system hardening section of the WMPs Guidelines⁹⁰ examines how the utility is designing its system to reduce ignition risk and what it is doing to strengthen its distribution, transmission and substation infrastructure to prevent causing catastrophic wildfires. This section also requires discussion of routine and non-routine maintenance programs, including whether the utility replaces or upgrades infrastructure proactively rather than running facilities to failure. Programs in this category, which often cover the most expensive aspects of a WMP, include initiatives such as the installation of covered conductors to replace bare overhead wires, undergrounding of distribution or transmission lines, and pole replacement programs. The utility is required, at a minimum, to discuss grid design and system hardening in each of the following areas:

1. Capacitor maintenance and replacement,
2. Circuit breaker maintenance and installation to de-energize lines upon detecting a fault,
3. Covered conductor installation,
4. Covered conductor maintenance,

⁹⁰ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 44 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



5. Crossarm maintenance, repair, and replacement,
6. Distribution pole replacement and reinforcement, including with composite poles,
7. Expulsion fuse replacement,
8. Grid topology improvements to mitigate or reduce PSPS events,
9. Installation of system automation equipment,
10. Maintenance, repair, and replacement of connectors, including hotline clamps,
11. Mitigation of impact on customers and other residents affected during PSPS event,
12. Other corrective action,
13. Pole loading infrastructure hardening and replacement program based on pole loading assessment program,
14. Transformers maintenance and replacement,
15. Transmission tower maintenance and replacement,
16. Undergrounding of electric lines and/or equipment,
17. Updates to grid topology to minimize risk of ignition in HFTDs, and
18. Other/not listed items if an initiative cannot feasibly be classified within those listed above.

Overview

Energy Safety finds that PG&E has made progress in the areas of grid design and system hardening⁹¹ and finds this portion of PG&E's 2021 WMP Update to be generally sufficient, subject to remedies. PG&E continues to show growth and improvement in its initiative selection process. PG&E has made progress in prioritizing its highest risk circuit segments for mitigation, as well as in its evaluation process to determine the appropriate mitigation alternative for each of those circuit segments. PG&E is expected to provide updates on its progress on identified issues in its ongoing required submissions with Energy Safety.

For 2021, PG&E is targeting hardening 180 miles of overhead facilities. PG&E plans that eighty percent of the miles targeted for hardening will be in the highest risk categories, listed below. Additionally, in the 2021 WMP Update PG&E plans that 10 percent of the hardening will be performed through undergrounding or asset removal over the 3-year period from 2021-2023. However, PG&E announced on July 21, 2021, a new multi-year initiative to expand the undergrounding plan to 10,000 miles of electric distribution power lines in their HFTD.⁹² PG&E states that its highest wildfire risk miles include:

⁹¹ PG&E's Maturity Model score for Grid Design and System Hardening did not increase from 2020. However, in evaluating PG&E's 2021 WMP Update, Energy Safety found that PG&E did make progress in this area, as described in more detail in this section.

⁹²https://www.pge.com/en/about/newsroom/newsdetails/index.page?title=20210721_pge_announces_major_new_electric_infrastructure_safety_initiative_to_protect_communities_from_wildfire_threat_undergrounding_10000_miles_of_power_lines_in_highest_fire-threat_areas



1. The top 20 percent of the riskiest circuit segments based on the rankings provided by PG&E's 2021 Wildfire Distribution Risk Model (i.e., the risk buydown curve);
2. Fire rebuild miles;
3. PSPS mitigation miles; and
4. Public Safety Specialist identified miles.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E is currently developing a program to remove unneeded capacitors and other voltage regulating equipment.⁹³ These removals would reduce the risk of an ignition caused by capacitors, which is particularly important because of PG&E's high incidence of failure of capacitor banks. PG&E is also investigating adding SCADA-enabled controllers to all capacitors and removing or using switches on fixed bank capacitors.⁹⁴
- In 2020, PG&E's System Hardening Program established a 220-mile target to harden overhead facilities within the highest fire risk miles based on their 2019-2029 Wildfire Risk Model. PG&E completed approximately 342 total miles, which includes approximately 194 miles hardened in HFTD areas during fire rebuild efforts and another 21 miles undergrounded through the Butte rebuild effort.
- In 2020, PG&E developed a standard tree strike analysis using LiDAR data for facilities and tree locations.
- PG&E standardized the use of wood poles with an intumescent wrap to increase fire resiliency of hardened lines and supplement the supply limitations and design challenges associated with composite poles.
- PG&E refined its project timelines to better coordinate permitting, easements, vegetation clearing, and other dependencies in advance of the construction process for pole replacements.
- PG&E updated its rankings for its highest risk circuit protection zones (CPZs) based on the outputs of its new wildfire risk model. Because PG&E bases its grid hardening improvement prioritization on the CPZ rankings, the updated CPZ rankings resulted in a corresponding update to PG&E's grid hardening improvement prioritizations and timelines. PG&E believes that these updates represent a more accurate prioritization of CPZs for grid hardening. PG&E attributes the changes to its change in vendors for its consequence model, stating that the new vendor places a greater emphasis on "ladder fuels" which PG&E believes provides more accurate results than its previous consequence model.

⁹³ PG&E 2021 WMP Redlined Update, p.564.

⁹⁴ PG&E 2021 WMP Redlined Update, p.565.



- PG&E developed a new System Hardening Approval process by which it evaluates which circuit segments to target for mitigation and determines the optimal mitigation measure for each of the selected circuit segments. PG&E updated its system hardening plan to target: 1) the top 20 percent of its risk buydown curve (as determined by its 2021 Wildfire Risk Models), 2) fire rebuild, 3) PSPS mitigation, and 4) miles identified by a Public Safety Specialist (PSS).⁹⁵ Once PG&E identifies which CPZs to prioritize for mitigation, it then analyzes each CPZ to determine the optimal mitigation method. PG&E’s evaluation to determine the optimal mitigation method includes an analysis of costs, strike tree potential, ingress and egress, execution timelines, risk reduction, and other operational considerations.
- PG&E analyzes circuit segments across multiple initiatives, including vegetation management and system hardening. In 2021, PG&E plans to avoid overlapping initiatives, stating: “PG&E’s System Hardening and EVM program leads are working together to avoid overlap between the two programs over the next 3 years, where reasonable, based on where System Hardening work is planned.”⁹⁶ This further demonstrates that PG&E is working to tailor its initiative selections to the optimal solution for each CPZ, instead of choosing overarching initiatives that may overlap in benefits and therefore not provide the most efficient use of resources.

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|--|--|
| PG&E-21-09 | Limited evidence to support the effectiveness of covered conductor | The rationale to support the selection of covered conductor as a preferred initiative to mitigate wildfire risk lacks consistency among the utilities, leading some utilities to potentially | The utilities ⁹⁸ must coordinate to develop a consistent approach to evaluating the long-term risk reduction and cost-effectiveness of covered conductor deployment, including: |

⁹⁵ “PG&E’s System Hardening Program,” presented to WSD on March 21, 2021, p. 5. “Public Safety Specialists” are subject matter experts that “bring a localized knowledge of areas that are high risk” and “identified miles [to add] in addition to the risk prioritized miles,” p. 3.

⁹⁶ PG&E’s Response to WSD’s DR 10 Question 13.

⁹⁸ Here “utilities” refers to SDG&E and Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), PacifiCorp, Bear Valley Electric Service, Inc. (BVES), and Liberty Utilities; although this may not be the case every time “utilities” is used through the document.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|---|---|
| | | <p>expedite covered conductor deployment without first demonstrating a full understanding of its long-term risk reduction and cost-effectiveness. The utilities' current covered conductor pilot efforts are limited in scope⁹⁷ and therefore fail to provide a full basis for understanding how covered conductor will perform in the field. Additionally, utilities justify covered conductor installation by alluding to reduced PSPS risk but fail to provide adequate comparison to other initiatives' ability to reduce PSPS risk.</p> | <ol style="list-style-type: none"> 1. The effectiveness of covered conductor in the field in comparison to alternative initiatives. 2. How covered conductor installation compares to other initiatives in its potential to reduce PSPS risk. |
| PG&E-21-10 | Insufficient pace of expulsion fuse replacement plan | <p>The pace of PG&E's current program for expulsion fuse replacements is not proportional to those of SDG&E and SCE.⁹⁹ This is especially problematic given PG&E's larger service territory.</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it is replacing expulsion fuses with fuses that reduce wildfire risk at a speed that adequately addresses risk; 2. Explain any current limits or constraints on the scope of PG&E's expulsion fuse replacement program; 3. Increase the pace of its expulsion fuse replacement program, provided reasonable |

⁹⁷ Limited in terms of mileage installed, time elapsed since initial installation, or both.

⁹⁹ Cal Advocates' Comments state at p. 36: "PG&E has approximately 22,000 expulsion fuses in HFTDs and forecasts replacing about five percent of them in 2021" which is approximately 1,100 fuses. At this rate, it will take PG&E nearly two decades to remove all the expulsion fuses from the HFTD. By comparison, BVES replaced 2,200 in 2020, which is more expulsion fuses than PG&E in 2020, although PG&E's service territory is two thousand times larger than BVES. In 2021, SDG&E replaced "3,179 (with a focus in Tiers 3 and 2 of the HFTD), bringing the total replaced to 5,669 out of the 11,000 total populations of such fuses in the HFTD" (according to SDG&E's 2021 WMP Update, p. 197). SCE is replacing "13,000 locations by the end of 2022 (cumulative from the inception of the program in 2018)" (according to SCE's 2021 WMP Update, p. 216).



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|--|--|
| | | | constraints do not limit such expansion. |
| PG&E-21-11 | Insufficient detail regarding installation of expulsion fuses in HFTD areas | PG&E continues to install non-exempt expulsion fuses, which are considered to be fire hazards, in HFTD areas. PG&E installed approximately 71 non-exempt expulsion fuses in the HFTD 2019 and 44 fuses in 2020. PG&E states that it is acceptable to install non-exempt expulsion fuses in the HFTD under certain circumstances but does not detail whether the installed fuses were installed in those circumstances. | PG&E must: <ol style="list-style-type: none"> 1. Explain the circumstances under which it installed non-exempt expulsion fuses in HFTD areas. 2. Clarify if any of the new expulsion fuses it is installing in the HFTD in 2021 and beyond are non-exempt fuses. |
| PG&E-21-12 | Failure to adequately track copper conductor replacements and insufficient detail regarding targeting replacements to highest risk areas | While PG&E has identified that copper conductor poses a high risk to its system due to its high incidence of failure PG&E does not currently track its completed copper reconductoring projects. Additionally, PG&E’s copper reconductoring program extends outside of the HFTD, but PG&E does not provide sufficient evidence that its copper reconductoring plan targets its highest risk circuits. | PG&E must: <ol style="list-style-type: none"> 1. Develop a workplan to target and track copper reconductoring projects. 2. Demonstrate that it is targeting its copper reconductoring projects to its highest risk circuits, including justification for any projects outside of the HFTD. |
| PG&E-21-13 | Failure to demonstrate that system hardening plan targets highest risk | A small percentage of circuit-segments in PG&E’s distribution system pose a high percentage of PG&E’s wildfire risk. ¹⁰⁰ However, PG&E does not clearly | PG&E must fully demonstrate that its system hardening mitigation efforts target efficiently reducing wildfire risk and PSPS events, including a description of how PG&E |

¹⁰⁰ “2021 Wildfire Mitigation Plan Workshop Grid Design and System Hardening” presented February 23, 2021, p. 4.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|--|--|
| | circuit segments | demonstrate that its system hardening plan targets these segments. | determines the order in which circuit segments are scheduled for mitigation. |
| PG&E-21-14 | Inadequate transparency of system hardening plan | PG&E provides limited detail regarding its short-term system hardening plan and does not include its long-term system hardening plan. Additionally, PG&E’s July 21, 2021, press release ¹⁰¹ regarding its intention to underground 10,000 miles of power lines indicates that the system hardening plan and initiative selection process that PG&E presents in its 2021 WMP Update may change. PG&E has not provided any potential modifications to its 2021 WMP Update related to this press release. While Energy Safety is generally supportive of PG&E’s ambition to aggressively reduce its wildfire risk, PG&E must provide additional detail on its short-term and long-term plans for grid hardening, as well as an update on its progress. | PG&E must: 1. Provide its short-term ¹⁰² system hardening plans, including the following details for each planned project (via comprehensive list and GIS files): a. Location; b. Initiative type (covered conductor, undergrounding, line removal, etc.); c. Status of the project (scoping, design permitting, etc.); d. Relevant CPZs; e. Planned length; f. Risk-type identified for prioritization of the project (top 20 percent of risk buydown curve, fire rebuild, PSPS mitigation, public safety specialist identified, or non-risk related). a. 2. Provide its long-term system hardening plan regarding: Estimated rate |

¹⁰¹ “PG&E Announces Major New Electric Infrastructure Safety Initiative to Protect Communities From Wildfire Threat,” July 21, 2021: <https://investor.pgecorp.com/news-events/press-releases/press-release-details/2021/PGE-Announces-Major-New-Electric-Infrastructure-Safety-Initiative-to-Protect-Communities-From-Wildfire-Threat/default.aspx> (accessed July 28, 2021).

¹⁰² “Short-term” defined as a project that has entered the scoping process or planning phase, including the 1,120 miles identified for system hardening from 2021-2023, per PG&E’s Redlined 2021 WMP Update, pdf p. 653.



| Utility- # | Issue title | Issue description | Remedies required |
|---------------|-------------|-------------------|--|
| | | | <p>of system hardening per year;¹⁰³</p> <p>b. If/how PG&E plans to increase its resources to allow for an accelerated pace of system hardening.</p> <p>3. Explain how, if at all, PG&E’s recently announced undergrounding plan:</p> <p>a. Changes its decision-making framework for initiative selection for individual circuit segments;¹⁰⁴</p> <p>b. May cause delays, deferrals, and/or cancellation of research and/or deployment of advanced technology mitigations.</p> <p>4. Provide an update on its completed system hardening efforts through November 1, 2021.</p> <p>5. Additionally, if PG&E is moving forward with its stated intention to underground 10,000 miles of power lines, PG&E must provide detail in its 2022 WMP Update on the decision to underground and its plans for such undergrounding.</p> |
| | | | |

Additional Issues and Remedies

¹⁰³ If such differs from the 450 to 500 miles per year provided in PG&E’s Redlined 2021 WMP Update, pdf p. 653.

¹⁰⁴ As described in PG&E’s presentation to WSD on May 21, 2021 and summarized in a footnote above.

In addition to the key areas listed above, Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: Action PGE-14 (Class A)¹⁰⁵ from PG&E’s 2020 WMP states: PG&E shall 1) provide an explanation as to how it is prioritizing replacing aluminum conductors in areas that overlap both corrosion zones and the HFTD, 2) if PG&E is not prioritizing aluminum conductors located in overlapping corrosion zones and HFTDs, explain why, and 3) explain whether any higher priority is given to aluminum conductor within corrosion zones outside of HFTDs.¹⁰⁶ PG&E states that is not prioritizing conductors located in overlapping corrosion zones and HFTDs but does not explain why.¹⁰⁷ PG&E does not specifically explain whether any higher priority is given to aluminum conductor within corrosion zones outside of HFTDs.
 - REMEDY: PG&E must explain why it is not prioritizing conductors located in overlapping corrosion zones and HFTDs.
 - REMEDY: PG&E must specifically explain whether any higher priority is given to aluminum conductor within corrosion zones outside of HFTDs.
- ISSUE: PG&E does not provide details on its program to remove unneeded capacitors and other voltage regulating equipment. It also did not provide details for investigating adding SCADA-enabled controllers to all capacitors and removing or using switches on fixed bank capacitors. PG&E also does not include a timeline for implementation of its these programs and investigations.
 - REMEDY: PG&E must (1) provide an update on the status, scope, and timeline for its unneeded capacitor program analysis, (2) provide an estimated number of capacitor removals based on its analysis, if available, (3) provide an update on the status, scope, and timeline for adding SCADA-enabled controllers to capacitors, (4) provide an update on the status, scope, and timeline for removing or using switches on fixed bank capacitors, and (5) explain how adding SCADA-enabled controllers to capacitors and removing or using switches on fixed bank capacitors will reduce ignition risk.


Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:

¹⁰⁵ Action PGE-14 (Class A) can be found here (accessed July 30, 2021):
<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/docs/340895473.pdf> at p. 40.

¹⁰⁶ PG&E 2021 WMP Update, p. 477.

¹⁰⁷ PG&E 2021 WMP Update, p. 477.



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.3.a: Grid design and system hardening maturity score progress.

Actual and projected spend (\$K) per HFTD overhead circuit mile




| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$85.84 | \$69.29 | \$76.28 |
| 2021 Planned Total | \$85.37 | \$104.06 | \$92.16 |
| 2022 Planned Total | \$95.11 | \$119.32 | \$101.98 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.3.b: Grid design and system hardening spend per HFTD overhead circuit mile, large utilities 2020-2022.

Risk events per circuit mile



Source: Table 7.1 of utility 2021 WMPs

Figure 5.3.c: Risk events per circuit mile due to equipment/facility failure, large utilities 2020-2022.

5.4 Asset Management and Inspections

Introduction

The asset management and inspections section of the WMP Guidelines¹⁰⁸ requires the utility to discuss power line/infrastructure inspections for distribution and transmission assets within the HFTD, including infrared, light detection and ranging (LiDAR), substation, patrol, and detailed inspections, designed to minimize the risk of its facilities or equipment causing wildfires. The utility must describe its protocols relating to maintenance of any electric lines or equipment that could, directly or indirectly, relate to wildfire ignition. The utility must also describe how it ensures inspections are done properly through a program of quality control.

Overview

Energy Safety finds that PG&E has made progress in the areas of asset management and inspection and finds this portion of PG&E’s 2021 WMP Update to be generally sufficient, subject to remedies. PG&E is expected to provide updates on its progress on identified issues in its ongoing required submissions with Energy Safety.

¹⁰⁸ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, pp. 44-45 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E modified its enhanced inspection protocols after which time its corrective notification creation rate increased from 11 percent to 23 percent for distribution facilities.¹⁰⁹ Enhanced inspections include imaging of assets with checklists, as well as checklists that align with PG&E’s Failure Modes and Effects Analysis (FMEA). The 2021 checklist included 14 components and 55 questions. In 2021 and moving forward, PG&E plans to use its distribution risk model to determine which circuits to prioritize when scheduling inspections.
- PG&E’s corrective notifications generated from its transmission inspections increased from 10,137 in 2018 to 52,399 in 2020.
- PG&E states that in 2020 it completed approximately 3,000 distribution miles of LiDAR imagery, with data used for increasing GIS and pole loading accuracy.
- PG&E is piloting below-grade foundation inspections, corona inspections, conductor measurement, and drone-span inspections for its transmission assets. PG&E plans to include corona inspections as part of its infrared inspections in 2021. All other pilot programs are still under cost-benefit analysis.
- PG&E focuses enhanced inspections to specifically target components that present wildfire risk if left to “run to failure.” In general, this can be seen by PG&E’s projections for ignitions within HFTDs in 2021 and 2022, as seen in Figures 5.4.c and 5.4.d below. In particular, PG&E has seen a decrease in ignitions caused by conductor damage or failure as well as crossarm damage or failure. However, ignitions caused by transformer damage or failure as well as pole damage or failure remain relatively flat.

Discussion of Revision Notice Critical Issue RN-PG&E-04

As described in Section 1.2 a Revision Notice was issued to PG&E on May 4, 2021. PG&E responded to the Revision Notice on June 3, 2021. The table below lists the critical issues contained in the Revision Notice specific to this section of the Action Statement followed by discussion. RN-PG&E-04 was resolved in PG&E’s Revision Notice Response.

¹⁰⁹ “Creation rate” PG&E 2021 WMP Update, p. 635.



| Critical issue | Description | Utility response | Energy Safety evaluation |
|--|--|---|---|
| RN-PG&E-04 Equivocating Language in Asset Inspection QA/QC Process Descriptions | PG&E continues to use vague, noncommittal, and equivocating language to describe its processes for quality assurance and quality control (QA/QC) of distribution and transmission asset inspections. | PG&E revised its 2021 WMP Update to describe its QA/QC processes for its asset inspections using specific, measurable, quantifiable, and verifiable language and described its internal plans to address QA/QC issues related to asset inspections. | PG&E’s response was complete and this issue is resolved. See additional discussion below on key areas of improvement for QA/QC in PG&E-21-17. |

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|--|---|
| PG&E-21-15 | Insufficient detail regarding covered conductor maintenance | PG&E states “[c]overed conductor maintenance will be performed anywhere covered conductor is installed and found to have conditions requiring maintenance.” ¹¹⁰ PG&E does not provide more detail as to what conditions require maintenance. PG&E also does not explain or justify its spend projections for covered conductor maintenance. PG&E’s projected spend for covered conductor maintenance is higher in 2021 than in 2022, however the projected line miles to be treated remain the same. ¹¹¹ | PG&E must: 1. Provide its procedures for determining when covered conductor maintenance is required, including any thresholds and aspects analyzed during inspections. 2. Explain why PG&E’s cost projections decrease from 2021 to 2022 despite line mile projections remain the same. |

¹¹⁰ PG&E 2021 WMP Update, p. 479.

¹¹¹ PG&E Table 12, Line 40.



| Utility- # | Issue title | Issue description | Remedies required |
|---------------|--|--|---|
| PG&E-21-16 | Insufficient evidence of effective covered conductor maintenance program | PG&E does not have a separate covered conductor maintenance program. | <p>PG&E must provide all supporting material to demonstrate that its maintenance programs effectively maintain its covered conductor, including the following information:</p> <ol style="list-style-type: none"> 1. Pace and quantity of scheduled maintenance; and 2. Pace and quantity of inspections. <p>If PG&E finds that its existing maintenance programs do not provide effective maintenance for covered conductor, PG&E must:</p> <ol style="list-style-type: none"> 1. Enhance its current operations to provide such maintenance; 2. Detail the enhancements to its existing programs; and 3. Provide all supporting material for the enhancements to its existing program, including the information listed above. |
| PG&E-21-17 | Insufficient evidence of QA/QC for work performed by contractors | Several PG&E internal audits revealed contractors that failed to follow procedures or were unaware of the correct procedures that needed to be followed. PG&E’s response to cases where the vendor was unaware of or did not follow procedures often amounted to a reminder of how procedures should have been followed. In most cases, PG&E did not further investigate the quality of other work the same vendor | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it is tracking the quality of work of contractors performing asset management and inspection work. 2. Describe how it is addressing underperforming asset management and inspection contractors. 3. Describe how it is expanding quality control of work performed by asset management and inspection vendors, including additional quality controls for |



| Utility-# | Issue title | Issue description | Remedies required |
|-----------|-------------|--|--------------------------------------|
| | | had performed, nor require full retraining on the topic. | those with a history of flawed work. |

Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: In order to address PG&E’s higher incidence of equipment failure in comparison to other utilities, PG&E’s Ignition Investigation and Asset Failure Analysis team has started to benchmark with counterparts within the other utilities and plans to continue to do so in 2021.¹¹² PG&E outlines other updates to its programs to address equipment failure rates, such as enhancing its failure analysis program and increasing accuracy on ignition cause. While these changes appear beneficial, in order to adequately address deficiencies found in 2020, PG&E must continue to develop these programs and demonstrate its progress in its 2022 WMP Update.
 - REMEDY: PG&E must (1) provide any findings and associated corrective actions as a result of its failure analysis program development, (2) provide an update on any findings relating to equipment failure rates in comparison to other utilities, including explanations on modifications made to PG&E’s asset inspections and maintenance programs as a result of such findings, and (3) explain why projected ignition rates based on equipment failure or damage remains flat for some equipment types.

- ISSUE: PG&E experienced increased corrective notifications¹¹³ for both distribution and transmission facilities. It is unclear if the increases are due to PG&E’s enhanced inspection protocols enabling PG&E to identify critical infrastructure issues that it previously did not identify or if the increases are due to the ongoing deterioration of PG&E’s assets. PG&E must provide further details on the increase in corrective notifications for both distribution and transmission to demonstrate the adequacy of its enhanced inspections.
 - REMEDY: PG&E must (1) provide statistics (such as asset type, asset age, potential ignition risk, etc.) on the types of corrective notifications created as part of its distribution and transmission inspections, including 2020 and 2021 notifications, and track such statistics moving forward, (2) provide details on the types of corrective notifications that the enhanced inspections generate that

¹¹² PG&E’s Supplemental Filing Addressing Remedial Compliance Plan and First Quarterly Report Action Items, February 26, 2021, p. 35.

¹¹³ “Corrective notifications” are PG&E’s work orders when an issue is found in-field that requires replacement or repair.

previous inspection practices would have overlooked, (3) explain how PG&E has adjusted its inspection and maintenance practices as a result of the additional corrective notifications, (4) discuss how PG&E assesses trends in issues identified by corrective notifications, any trends it has recognized, and the associated actions it has taken in relation to these trends, and (4) discuss PG&E’s predictions for future corrective notification trends, including whether PG&E expects a decrease in corrective notifications in the future.

- ISSUE: PG&E does not currently use drones for detailed inspections of distribution assets despite its use of drones for transmission and substation inspections as well as distribution patrols. SCE and SDG&E both use drones to augment their distribution inspections and have reported some benefits, such as lower noise for customers.¹¹⁴
 - REMEDY: PG&E must either (1) pilot use of drones or other aerial inspections as part of its inspections of its distribution assets and include a cost-benefit analysis in its evaluation of the success of the pilot program, or (2) explain why its current detailed inspections of its distribution assets are adequate without the enhancement of aerial inspections, including a cost-benefit comparison of PG&E’s existing program of using aerial inspections to enhance distribution patrols to detailed inspections, including findings per mile.

- ISSUE: In its Maturity Model, PG&E’s self-assessment shows that it currently updates condition assessments in its equipment inventory database on an annual basis, and shows that PG&E does not anticipate progressing to more frequent updates by the start of 2023.¹¹⁵ However, regarding updates to asset information in its distribution risk model, PG&E states in its 2021 WMP Update: “[t]he frequency of updates in planning models to reflect the completion of risk mitigation work will occur on a quarterly basis beginning in 2021.”¹¹⁶ It is unclear if these statements are contradictory, or if PG&E plans to update its distribution risk model more frequently than its equipment inventory database. Regardless, PG&E appears to have the capacity to update its equipment inventory database more frequently than it currently shows in its Maturity Model.
 - REMEDY: PG&E must (a) explain the discrepancy of asset information updates between its Maturity Model assessment and the text within the WMP, and (b) develop a plan to increase the frequency in which condition assessments are updated in its equipment inventory database before the start of 2023 or explain why it is not possible for PG&E to do so.


Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:

¹¹⁴ SCE 2021 WMP Update, p. 242.

¹¹⁵ PG&E’s responses to the Utility Survey, p. 21.

¹¹⁶ PG&E 2021 WMP Update, p. 143.



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.4.a: Asset management & inspections maturity score progress.

Actual and projected spend (\$K) per HFTD overhead circuit mile



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$9.71 | \$26.17 | \$18.10 |
| 2021 Planned Total | \$8.64 | \$28.51 | \$15.17 |
| 2022 Planned Total | \$7.81 | \$19.92 | \$13.03 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.4.b: Asset management and inspections spend per HFTD overhead circuit mile, large utilities 2020-2022.




Figure 5.4.c: Distribution Equipment Failure Ignitions in HFTD Tier 2 or 3, measured and projected, from Table 7.2 of PG&E’s 2021 WMP Update. Any causes that had two or less ignitions throughout 2015-2022 were not included in the chart.




Figure 5.4.d: Transmission Equipment Failure Ignitions in HFTD Tier 2 or 3, measured and projected, from Table 7.2 of PG&E’s 2021 WMP Update. Any causes that had zero ignitions throughout 2015-2022 were not included in the chart.



5.5 Vegetation Management and Inspections

Introduction

This section of the WMP Guidelines¹¹⁷ requires utilities to discuss vegetation management inspections, including inspections that go beyond existing regulation, as well as infrared, light detection and ranging (LiDAR), and patrol inspections of vegetation around distribution and transmission lines/equipment, quality control of those inspections, and limitations on the availability of workers. The utility must also discuss collaborative efforts with local land managers, including efforts to maximize benefit from fuel treatment activities and fire break creation as well as the collaborative development of methods for identifying at-risk vegetation, determining trim clearances beyond minimum regulations, and identifying and mitigating impacts from tree trimming and removal (erosion, flooding, etc.).

Overview

PG&E's vegetation management (VM) program is unequivocally larger and more complex than those of other IOUs. While PG&E has made progress - updating its Vegetation Risk Model and developing a new GIS-based Vegetation Management System¹¹⁸ - it lags behind its peer utilities, SCE and SDG&E, in many aspects of its VM program. This latency is illustrated by PG&E's Maturity Model; PG&E does not foresee maturing five of six VM Maturity Model capabilities. PG&E's planned end WMP cycle VM maturity is 1, up from 0.7 in 2020, on a 0-4 scale with 0 being lowest. Comparatively, SCE and SDG&E have a planned end WMP cycle VM maturities of 3 and 3.3 respectively (see Attachment 1, Category E, page Attachements-23 for PG&E's 2021 VM Maturity Model Assessment).

In addition to the numerous VM issues Energy Safety has identified in PG&E's 2021 WMP Update, PG&E has other issues derived from the implementation of its VM program. As such, Energy Safety's Compliance Division, along with complaints from ratepayers and local governments, have informed several key areas for improvement in this section.

Below are summaries of other issues affecting PG&E's VM program:

PG&E's Oversight by U.S. Probation Court and the Federal Monitor

¹¹⁷ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 45 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

¹¹⁸ PG&E 2021 WMP Update Revision – Clean, p. 807.



Oversight of PG&E by U.S. Probation Court and the Federal Monitor stems from criminal proceedings for the San Bruno gas explosion on September 9, 2010.

In an October 16, 2020 letter to U.S. District Court Judge Alsup, who oversees PG&E’s criminal probation, the Federal Monitor alerted the court that “the Monitor team has not seen a meaningful improvement in the quality of [PG&E’s] work from late 2019 to 2020.”¹¹⁹

The letter outlines vegetation related issues the Federal Monitor has found: “the Monitor team is finding more missed trees...in 2020 than we did in the later part of 2019... although there were meaningful improvements within 2019, that improvement appears to have, at best, plateaued, and perhaps actual regression has occurred.”¹²⁰

Ultimately, the letter concludes that PG&E “failed to adhere to its risk models in its work execution and could have done better under its own chosen metrics and approaches. The Monitor team has identified these shortcomings to PG&E leadership and will monitor progress towards meeting past and current PG&E goals.”¹²¹

Enhanced Vegetation Management Audit by Energy Safety and Enhanced Oversight and Enforcement

On February 8, 2021, WSD published an audit of PG&E’s 2020 Enhanced Vegetation Management (EVM) program which resulted in seven findings:

1. PG&E failed to communicate its use of a new Risk Overlay Model and provided the WSD with conflicting information regarding when different risk prioritization models were used.
2. WSD received three different EVM prioritization models from PG&E (in September 2020, December 2020, and January 2021) and found that these three data submissions contain inconsistencies and conflicting information.
3. WSD identified concerns in the methodology used to arrive at the final risk score rankings provided in the December model.
4. PG&E appeared to not be sufficiently prioritizing or reducing the risk of wildfire ignition in its implementation of its EVM initiative.
5. PG&E’s January 13, 2021, data request response did not provide confidence that PG&E’s risk prioritization activities were being effectively operationalized.
6. WSD documented four EVM defects through inspections.
7. PG&E has not communicated adequately with WSD regarding defect resolution (PG&E corrected seven Energy Safety-identified defects that were documented as

¹¹⁹ Letter from Federal Monitor to U.S. District Court Judge Alsup, October 16, 2020, p. 1.

¹²⁰ Letter from Federal Monitor to U.S. District Court Judge Alsup, October 16, 2020, p. 1.

¹²¹ Letter from Federal Monitor to U.S. District Court Judge Alsup, October 16, 2020, p. 6.

disputed/unresolved without notifying WSD), data requests, or large-scale clearing projects.

As a result of these findings, the CPUC passed Resolution M-4852 on April 15, 2021. The Resolution confirmed that PG&E failed to make sufficient risk-driven investments in its vegetation management practices and placed PG&E into the first step of an enhanced oversight and enforcement process (EOE) developed in CPUC Decision 20-05-053. On May 6, 2021, PG&E submitted to the CPUC its Corrective Action Plan (CAP) in response to the findings listed above.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E’s Enhanced Vegetation Management (EVM) program is establishing new, increased clearances for high-risk circuits. Once established through the EVM program, the new clearances are maintained by routine trimming and inspections. The EVM program targets about 1800 circuit miles per year for treatment.
 - In its CAP submitted to the CPUC and Energy Safety as part of the EOE process noted above, PG&E has newly included in the 2021 EVM Scope of Work an additional 600 miles for EVM. These 600 miles “can be substituted for any miles in the highest risk 1,800 miles if we are unable to perform work on any of these miles.”¹²² PG&E cites permitting timelines and customer refusals as reasons its crews are sometimes “unable to perform work.”
- The updated 2021 Vegetation Risk Model allows PG&E to prioritize work with more granularity at the level of circuit protection zones (CPZs).¹²³ This model is used to prioritize work for PG&E’s EVM program.
- A targeted tree species study is being developed and executed to quantify failure risk by species and region. This study will enable PG&E to better assess the risk of individual trees in its large, biologically diverse service territory.
- PG&E forecasts a reduction in vegetation-caused ignitions due to mitigation programs that are informed by risk models over the three-year WMP term.¹²⁴
- PG&E conducted LiDAR inspections for 100 percent of its transmission circuits in the HFTD during mid-cycle which coincides with fire season.
- PG&E will expand the use of ground-based LiDAR for quality control (QC), monitoring the regulatory minimum four-foot radial clearance in HFTD Tier 2 and Tier 3.

¹²² PG&E Enhanced Oversight and Enforcement Process Corrective Action Plan Pursuant to Resolution M-4852, May 6, 2021, p. 14.

¹²³ CPZs are portions of a circuit that can be isolated from the rest of the system.
https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/vegetation-management.page (accessed July 12, 2021).

¹²⁴ PG&E 2021 WMP Update Revision – Clean, p. 95.



- PG&E is increasing the pool of qualified VM workers “by partnering with the IBEW and educational institutions... to establish a training program designed to provide the skills and knowledge necessary to perform tree crew work safely and competently.”¹²⁵
- PG&E is working toward consolidating the data collection tools for various VM activities into a new GIS-based vegetation management system it calls “One Vegetation Management.”¹²⁶

PG&E has room for improvement in the following areas:

- Ignitions due to contact with vegetation has remained static since 2017, with 13-14 ignitions per 10,000 overhead circuit miles. (Figure 2.6a)
- PG&E lags behind its peer utilities in the current and anticipated maturity of its VM capabilities (21-26) (Figure 5.3.5a) (see related key issue below).
- As shown in Figure 5.5.a, the percentage of spans inspected where at least some vegetation was found in non-complaint condition has increased significantly since 2015 and rapidly since 2018. Ideally, as PG&E’s VM program progresses, this percentage should decrease and plateau, indicating that PG&E vegetation crews are maintaining clearance effectively.

Discussion of Revision Notice Critical Issues RN-PG&E-05 and RN-PG&E-06

As described in Section 1.2, WSD issued a Revision Notice to PG&E on May 4, 2021. PG&E responded to the Revision Notice on June 3, 2021. The table below lists the critical issues contained in the Revision Notice specific to this section of the Action Statement followed by discussion.

| Critical issue | Description | Utility response | Energy Safety evaluation |
|----------------|--|--|--|
| RN-PG&E-05: | Unresolved Discrepancies in Vegetation Management Expenditure Data and Their Effect on the WMP | PG&E attributes the discrepancies for inconsistent spend data due to changing assumptions. | PG&E provided the required information, including a revised Table 12. However, Energy Safety remains concerned about the inconsistency of data and supports PG&E’s proposal to hire a "business liaison" for each major WMP initiative category.” See below for additional discussion. |
| RN-PG&E-06 | Contradictory Reduction in | PG&E explained how it is ensuring it is still | PG&E’s response is complete. However, the |

¹²⁵ PG&E 2021 WMP Update Revision – Clean, p. 724.

¹²⁶ PG&E 2021 WMP Update Revision – Clean, p. 807.




| Critical issue | Description | Utility response | Energy Safety evaluation |
|----------------|---|--|---|
| | Expenditure Allocation for Critical Vegetation Management Initiatives | meeting its risk reduction targets from vegetation contact despite modified percentage allocation and expenditure reduction and provided additional information regarding Section 7.3.5.13 and 7.3.5.14. | details PG&E provided regarding initiatives 7.3.5.13, Quality Assurance / Quality Control of vegetation inspections, and 7.3.5.14, Recruiting and training of vegetation management personnel, raise additional concerns for Energy Safety. See below for additional discussion on future remedies required in the 2022 WMP Update. |

Discussion of Revision Notice Critical Issue RN-PG&E-05

Revision Notice critical issue RN-PG&E-05 concerns discrepancies in PG&E’s vegetation management expenditure data. In its response PG&E cites changing assumptions for inconsistent spend data. In 2020, Energy Safety had asked PG&E to disaggregate¹²⁷ its spend throughout the WMP to align its programs with WSD-defined initiatives; this disaggregated spend was presented in PG&E’s First Quarterly Report. Since the first Quarterly report, PG&E has reported its 2020 WMP forecasted expenditure for the 2020-2022 WMP cycle for VM initiatives in the HFTD (VM HFTD Cycle) three times;¹²⁸ two of those submissions, including PG&E’s Revision Notice Response, were inconsistent with PG&E’s First Quarterly Report (see the bar graph below).

¹²⁷ Resolution WSD-002 condition Guidance-05 (Class B) and Resolution WSD-003 condition PG&E-1 (Class A).

¹²⁸ WSD_006-Q01, received February 22, 2021; WSD_010-Q19, received March 18, 2021; and PG&E’s Revision Notice Response, received June 3, 2021.



In its response to remedy 2 of RN_PG&E-05, PG&E states “WSD identified \$1,326,981,802 as the HFTD spend from the 2020 WMP. This amount is incorrect... The correct number representing the HFTD VM spend... is \$2,547,592,428.”¹²⁹ However, WSD corrected this \$1,326,981,802 figure on May 7, 2021, revising the figure to \$2,530,926,327. As Cal Advocates point out, even though PG&E corrects the value, it ignores the fact that value is still less than the values previously reported in September 2020 and February 2021.¹³⁰

Additionally, according to PG&E, WSD miscalculated the 2020 WMP VM territory cycle expenditure from WSD-006-Q01. However, PG&E does not address nor dispute the fact that "On March 9, 2021, PG&E responded to DR WSD_008-Q01 and confirmed that calculations Energy Safety made in ‘PGE - Table 12_v2’, analysis derived from PG&E’s response to WSD_006-Q01, are correct.”¹³¹

In PG&E’s Revision Notice Response reply comments, PG&E further explains the discrepancies in expenditure stating:

The small difference (less than 1 percent) between the 2020 WMP VM HFTD expenditure figure presented in the Revised 2021 WMP (\$2,547,592,428) and the figure presented in response to WSD_010-Q19 (\$2,530,926,327) exists because point forecasts for QA/QC, LiDAR, and fuel reduction initiatives were not removed from the total programmatic spend correctly before being broken down into HFTD vs. Non-HFTD when disaggregating the initiative-level details in order to respond to the request... This small difference is not material to approval of PG&E’s 2021 WMP Update.¹³²

¹²⁹ PG&E 2021 WMP Update Revision – Clean, p. 416.

¹³⁰ Comments of the Public Advocates Office on Pacific Gas and Electric’s (PG&E) June 3, 2021, Revision of its 2021 Wildfire Mitigation Plan Update, June 10, 2021, p. 18.

¹³¹ Wildfire Safety Division’s Revision Notice for Pacific Gas & Electric Company’s 2021 Wildfire Mitigation Plan Update, May 4, 2021, p. 16.

¹³² Reply Comments on Pacific Gas and Electric Company’s (U 39 E) Revision Notice Response, June 16, 2021, p. 17.



While \$16,666,101 may not be “material” in the grand scheme of wildfire mitigation, Energy Safety is less concerned with the values themselves but rather is alarmed by PG&E’s seeming inability to produce consistent expenditure figures. Errors like the one described above illustrate that PG&E is not performing simple quality control checks on its expenditure data submissions.

Energy Safety expects PG&E to have consistent financial expenditure data. In response to RN-PG&E-05 remedy 4, PG&E says it exploring having a dedicated “business liaison” for each major WMP initiative category to verify the financial, unit, and RSE assumptions.¹³³ For the sake of consistency across all WMP-related submissions, Energy Safety fully supports this idea and encourages PG&E to implement it immediately.

Discussion of Revision Notice Critical Issue RN-PG&E-06

Energy Safety identified significant reductions in PG&E’s budget allocations for initiatives considered critical to effective execution of its vegetation management programs.

For remedy 1, in which PG&E is required to explain how it is ensuring it is still meeting its risk reduction targets from vegetation contact despite modified percentage allocation and expenditure reduction, PG&E provided normalized expenditure figures using 2021 WMP Update assumptions to compare 2020 WMP and 2021 WMP Update expenditure.¹³⁴ While insightful, these figures again highlight that PG&E forecasts spending only \$39,372 on recruitment and training of VM personnel (initiative 7.3.5.14) during the 2020-2022 WMP cycle. PG&E does provide an estimate for the total costs associated with completion of the initial VM trainings by VM personnel (\$1,345,727.50 for 2020 and 2021)¹³⁵ but this estimate is not included as part of the WMP initiative expenditure. As such, it remains unclear what PG&E’s reported \$39,372 actually encompasses.

PG&E’s response to remedy 2 and 3 are complete. However, the details PG&E provided regarding initiatives 7.3.5.13, Quality Assurance / Quality Control of vegetation inspections, and 7.3.5.14, Recruiting and training of vegetation management personnel, raise additional concerns for Energy Safety. These concerns are included in the Additional Issues and Remedies of this section of the Action Statement.

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

¹³³ PG&E 2021 WMP Update Revision – Clean, p. 417.

¹³⁴ Table PG&E-Revision Notice-7.3.5-1: Comparison of 2020 and 2021 Expenditure Data for 7.3.5.6, 7.3.5.13, and 7.3.5.14 (using 2021 WMP financial assumptions), PG&E Revised 2021 WMP Update p. 689.

¹³⁵ PG&E 2021 WMP Update Revision – Clean, p. 729.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|---|---|
| PG&E-21-18 | Minimally planned maturity of VM program | <p>PG&E has increased the scale of its VM program but does not foresee maturing five of six VM Maturity Model capabilities. PG&E’s planned end WMP cycle VM maturity is 1, up from 0.7 in 2020. Comparatively, SCE and SDG&E have a planned end WMP cycle VM maturities of 3 and 3.3 respectively (see Figure 5.3.5a, below). Additionally, PG&E does not provide adequate discussions in the reoccurring subsection “5. Future improvements to initiative” nor in response to Quarterly Report Action PGE-25 (Class B), subpart 1. PG&E must create a long-term VM maturation strategy and establish clear goals and targets to prioritize work and monitor progress towards its risk-reduction goals.</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Reach a maturity of at least 1 for capabilities 24 “Vegetation grow-in mitigation” and 25 “Vegetation fall-in mitigation” by the end of 2023. 2. Clearly define goals and targets to reach each level of maturity for capabilities 21-26. 3. Include a timeline for completion of the goals and targets from (1). 4. Provide a long-term vision for each VM initiative in Subsection 5 “Future improvements to the initiative” (or similar) including any relevant timelines. |
| PG&E-21-19 | Delays in achieving mutually agreeable environmental mitigation | <p>PG&E cites delays in reaching mutually agreeable environmental and community impact mitigation efforts that “in certain situations,”¹³⁶ result in PG&E seeking court orders.¹³⁷ These delays, judicial or otherwise, can compromise working</p> | <p>PG&E must show progress on achieving environmental and community impact mitigation agreements with agencies, local governments, and tribal governments. This includes establishing and documenting regularly scheduled meetings between relevant parties to identify</p> |

¹³⁶ PG&E 2021 WMP Update Revision – Clean, p. 691.

¹³⁷ PG&E 2021 WMP Update Revision – Clean, p. 691.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|---|---|
| | | relationships between the community and state and local environmental agencies and cause further delays to WMP initiatives. | permit requirements and potential environmental and community impacts from vegetation management prior to commencement of work. Meeting cadence shall be appropriately in advance of permit applications and scheduled work. PG&E must consider the development of Operations and Maintenance Plans and Memorandums of Understandings with relevant federal, state, and local land managing agencies to facilitate agreed-upon review times of permits and/or vegetation management activities. PG&E must document the outcomes of these efforts and any lessons learned. |
| PG&E-21-20 | Non-inclusion of fire damage attributes in hazard tree assessments | In DR WSD_011, WSD asked PG&E whether fire impact characteristics (char, scorch, etc.) were included in PG&E’s Tree Assessment Tool (TAT). PG&E stated that the TAT “does not include post-fire specific factors such as char, etc. This tool was not developed for, or intended to be used in, post-wildfire response circumstances. When wildfires occur, PG&E performs a hazard tree assessment of the burned area to determine whether trees pose a | PG&E must: <ol style="list-style-type: none"> 1. Clarify what tool or standard PG&E and its contractors use in post-wildfire response circumstances for hazard tree assessments; 2. If such a tool or standard does not already include post-fire specific factors (e.g., crown, bole, and root scorch, char, duff consumption¹³⁸). PG&E must include these factors in such tool or standard. 3. If such a tool or standard does not exist, PG&E shall develop one to use in post-wildfire response circumstances. |

¹³⁸ Factors Affecting Survival of Fire Injured Trees: A Rating System For Determining Relative Probability of Survival of Conifers in the Blue and Wallowa Mountains, United States Forest Service, November 25, 2002.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|--|--|
| | | <p>threat to electric assets and if they should be abated.” Contradictorily, PG&E specifically defines the TAT in its WMP as a “Tool that evaluates an individual tree’s likelihood of failing and supplies instruction of whether to abate or not abate the tree.” It is unclear whether PG&E has another tool, other than its TAT, it uses to perform hazard tree assessments in post-wildfire response circumstances or whether it uses no tool or standard assessment for hazard tree assessments in post-wildfire response circumstances.</p> | <p>4. Provide the training to its staff and contractors in post-fire tree assessments. 5. Use such a tool during PG&E’s Phase 2 “Non-Imminent Hazard Trees” post-wildfire response.¹³⁹ PG&E should use such a tool during Phase 1 “Imminent Threat Inspection” as feasible.</p> |
| PG&E-21-21 | Unknown environmental impact and efficacy of PG&E’s Preventative Fire Retardant Program (PFRP) | PG&E plans to undertake a review of fire-retardant chemicals ahead of the 2021 wildfire season to pilot under its Utility Defensible Space (UDS) program “pre-treat[ing] ROWs and around equipment in select locations to limit a spark from causing an | <p>PG&E must provide:</p> <ol style="list-style-type: none"> 1. Its review¹⁴² of fire-retardant that includes the following: product toxicological and environmental analysis; efficacy analysis; environmental planning and permitting assessment; and the scope of use. 2. A report on the objectives and execution of its PFRP in 2021 and its PFRP plan for 2022. |

¹³⁹ Phase 2 “Non-Imminent Hazard Trees” is described in “WSD-001 Glass Fire,” response received March 1, 2021: Under PG&E’s emergency operations protocols, there are two phases of vegetation management inspections. The duration of each phase will vary due to timeline dependencies such as CAL FIRE clearance/accessibility, availability of pre-inspectors and the volume of damage or fire footprint. Phase 1 - Imminent Threat Inspection: Inspect and eliminate any tree that is actively failing and identify trees that will need to be removed by construction crews to support reconstruction work to restore power. Phase 2 - Non-Imminent Hazard Trees: Listing non-immediate hazard trees for work; this can be done in parallel with Phase 1 if inspectors are available.

¹⁴² PG&E 2021 WMP Update Revision – Clean, p. 705.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|---|---|
| | | <p>ignition.”¹⁴⁰ In PG&E’s 2021 WMP Update, it had not determined a long-term plan for this initiative, considering it a pilot, and had no set targets (e.g., number of circuit miles or acres to be treated with retardant). However, on August 30, 2021, PG&E informed Energy Safety it has been “applying preventative fire retardant on poles and underneath powerlines in high risk areas to reduce the potential of a catastrophic wildfire” to “81 pilot [circuit] miles”¹⁴¹ as part of its Preventative Fire Retardant Program (PFRP). Fire retardant is typically used as an emergency measure applied in front of imminent fire and the efficacy and environmental impact of PG&E’s PFRP are unknown.</p> | <ol style="list-style-type: none"> 3. Quarterly reports regarding the deployment of fire-retardant to the Compliance Division of OEIS per CPUC approved Compliance Operational Protocols.¹⁴³ These reports must include where and when the retardant was used, how much retardant was used, and the specific fire-retardant that was used. 4. An RSE value for its PFRP. |
| PG&E-21-22 | Incomplete identification of vegetation species and record keeping | In Table PG&E-7.3.5-6 on p. 666, PG&E reports that “Oak” and “Pine” are species that have caused >1 percent of several regions’ outages. However, these | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Use scientific names in its reporting (as opposed to common names). This change will be reflected in the upcoming updates to Energy Safety GIS Reporting Standard. |

¹⁴⁰ PG&E 2021 WMP Update Revision – Clean, p. 706.

¹⁴¹ Presentation to the Office of Energy Infrastructure Safety and the CPUC’s Safety Enforcement Division from PG&E titled “Public Safety Measures: Addressing Extreme Drought”, August 6, 2021.

¹⁴³ Wildfire Safety Division – Compliance Operational Protocols, February 16, 2021: <https://energysafety.ca.gov/wp-content/uploads/docs/misc/wsd/2021.02.16-compliance-operational-protocols.pdf>.



| Utility-# | Issue title | Issue description | Remedies required |
|-----------|-------------|--|---|
| | | <p>are not tree species, but tree genera. PG&E needs to ensure proper identification of trees to the species level. This specificity will ensure that the “regional species risk values”¹⁴⁴ input to its TAT are updated and accurate. While PG&E does not currently prescribe tree-work based on specific species,¹⁴⁵ it may choose to do so in the future; in this case, accurate recordkeeping of the species designation is essential.</p> | <ol style="list-style-type: none"> 2. Add genus and species designation input capabilities into its systems which track vegetation (e.g., vegetation inventory system and vegetation-caused outage reports). 3. Identify the genus and species of a tree that has caused an outage¹⁴⁶ or ignition¹⁴⁷ in the Quarterly Data Reports (QDRs) (in these cases, an unknown “sp.” designation is not acceptable). 4. If the tree’s species designation is unknown (i.e., if the inspector knows the tree as “Quercus” but is unsure whether the tree is, for example, Quercus kelloggii, Quercus lobata, or Quercus agrifolia), it must be recorded as such. Instead of simply “Quercus,” use “Quercus sp.” If referencing multiple species within a genus use “spp.” (e.g., Quercus spp.).¹⁴⁸ 5. Teach tree species identification skills in its VM personnel training programs, both in initial and continuing education. 6. Encourage all VM personnel identify trees to species in all VM activities and reporting, where possible. |

¹⁴⁴ PG&E 2021 WMP Update, p. 667.

¹⁴⁵ PG&E 2021 WMP Update, p. 667.

¹⁴⁶ WSD GIS Data Reporting Standard Version 2, Transmission Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.5 & Distribution Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.7.

¹⁴⁷ WSD GIS Data Reporting Standard Version 2, Ignition (Feature Class), Section 3.4.3.

¹⁴⁸ Jenks, Matthew A. (undated, from 2012 archived copy), “Plant Nomenclature,” Department of Horticulture and Landscape Architecture, Purdue University, accessed May 18, 2021.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|---|--|
| PG&E-21-23 | Inadequate joint plan to study the effectiveness of enhanced clearances | RCP Action-PGE-35 ¹⁴⁹ (Class A) required PG&E, SCE, and SDG&E to “submit a joint, unified plan” to begin a study of the effectiveness of extended vegetation clearances. PG&E submitted its plan to study the effectiveness of extended vegetation clearance as part of its February 26, 2021, “Supplemental Filing Addressing Remedial Compliance Plan and First Quarterly Report Action Items.” PG&E, SCE, and SDG&E presented the “joint, unified” plan to Energy Safety on February 18, 2021. While it was apparent the three large utilities had discussed a unified approach, each utility presented differing analyses that would be performed to measure the effectiveness of enhanced clearances. This presentation’s content was not included in the February 26, 2021, “Supplemental Filing Addressing Remedial Compliance Plan and First | <p>PG&E, SCE, and SDG&E will participate in a multi-year vegetation clearance study. Energy Safety will confirm the details of this study in due course. The objectives of this study are to:</p> <ol style="list-style-type: none"> 1. Establish uniform data collection standards. 2. Create a cross-utility database of tree-caused risk events (i.e., outages and ignitions caused by vegetation contact). 3. Incorporate biotic and abiotic factors¹⁵⁰ into the determination of outage and ignition risk caused by vegetation contact. 4. Assess the effectiveness of enhanced clearances. <p>In preparation for this study and the eventual analysis, PG&E must collect the relevant data; the required data are currently defined by Energy Safety Geographic Information System (GIS Data Reporting Standard for California Electrical Corporations - V2). Table 2 below outlines the feature classes which Energy Safety believes will be most relevant to the study. Energy Safety will also be updating the GIS Reporting Standards in 2021, which may include additional</p> |

¹⁴⁹ Wildfire Safety Division Evaluation of Pacific Gas and Electric Company’s Remedial Compliance Plan can be found here (accessed August 2, 2021):

<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/pge-rcp-action-statement-20201230.pdf>

¹⁵⁰ Biotic factors include all living things (e.g., an animal or plant) that influence or affect an ecosystem and the organisms in it; abiotic factors include all nonliving conditions or things (e.g., climate or habitat) that influence or affect an ecosystem and the organisms in it.



| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|--|---|
| | | <p>Quarterly Report Action Items.”</p> <p>Energy Safety acknowledges the complexity of this issue; any study performed assessing the effectiveness of enhanced clearances will take years of data collection and rigorous analysis.</p> | <p>data attributes for vegetation-related risk events.</p> |
| PG&E-21-24 | Need for quantified vegetation management (VM) compliance targets | <p>In Table 12, PG&E only defines quantitative targets for six of 20 VM initiatives. Energy Safety is statutorily required to audit PG&E when a “substantial portion” of PG&E’s VM work is complete;¹⁵¹ without quantifiable targets in the WMP and subsequent reporting on those targets in the Quarterly Data Report (QDR) and Quarterly Initiative Update (QIU), Energy Safety cannot fully realize its statutory obligations.</p> | <p>PG&E must define quantitative targets for all VM initiatives. If quantitative targets are not applicable to an initiative, PG&E must fully justify this, define goals within that initiative, and include a timeline in which it expects to achieve those goals.</p> |

Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E’s 2022 WMP Update.

¹⁵¹ Pub. Util. Code § 8386.3(c)(5)(A).



- ISSUE: PG&E describes creating defensible space around substations "beyond PRC 4291 defensible space recommended zones."¹⁵² PG&E does not provide justification for increased clearances at substations.
 - REMEDY: Define the extent of the expanded substation clearance and the activities that occur beyond PRC 4291 Defensible Space recommended zones (e.g., removal of flash fuels, limbing trees, felling hazard trees, etc.)
 - REMEDY: Justify the decision to increase clearances at substations beyond PRC 4291 defensible space recommended zones.
- ISSUE: PG&E indicates there were an unspecified number of "carry-over" trees trimmed in 2020.¹⁵³ Work was scheduled and began on these trees in 2019 but the work was not 100 percent completed and verified until 2020.
 - REMEDY: Detail PG&E's efforts to reduce the number of "carry-over" trees so repeat visits due to barriers (e.g., permitting, access) are limited and trees are trimmed in a more timely and efficient manner.
 - REMEDY: Provide a table that indicates the number of "carry-over" trees by region and Priority Level Finding.
- ISSUE: PG&E's audit target for 2021 quality verification (QV) is the same as 2020; this is despite PG&E having exceeded its target by 500 audits in 2020. Additionally, PG&E states that "For 2021, PG&E anticipates more than tripling our work verification workforce by adding more than 200 quality inspectors to increase our ability to verify that vegetation management was completed to meet or exceed state and federal standards." With a tripled workforce, PG&E should be able increase the target number of audits.
 - REMEDY: PG&E must consider increasing its QV audit goal for 2021 and beyond.
- ISSUE: PG&E does not detail how it "proactively communicates and partners with impacted customers, landowners, government agencies and community organizations regarding the planned work."¹⁵⁴ Rather it lists "various forms of communication."¹⁵⁵ In subsection 4 "Progress on initiative and plans for next year," PG&E does not detail how it will work with the community, rather it details its internal environmental review process, and cites seeking court orders and working with agencies and legislature to address constraints to their activities.
 - REMEDY: Provide a flow chart or decision tree¹⁵⁶ on communication forms for customers and partner agencies for routine VM, EVM, and emergency work.
 - REMEDY: Explain the capabilities of ProjectWise,¹⁵⁷ and whether it will be used to communicate with customers, governments, and agencies.
- ISSUE: In Section 7.3.5.5, PG&E describes a new pilot program, Utility Defensible Space (UDS), for fuel reduction work along powerline right of ways. However, PG&E does not

¹⁵² PG&E 2021 WMP Update, p. 679.

¹⁵³ PG&E 2021 WMP Update Revision – Clean, p. 694.

¹⁵⁴ PG&E 2021 WMP Update Revision – Clean, p. 690.

¹⁵⁵ PG&E 2021 WMP Update Revision – Clean, p. 690.

¹⁵⁶ For an example of a decision tree visit <https://hbr.org/1964/07/decision-trees-for-decision-making>

¹⁵⁷ PG&E 2021 WMP Update Revision – Clean, p. 691.



describe their process for removal, disposal, and cleanup of vegetative material (slash, cut limbs, trees, etc.). This discussion is required by the 2021 WMP Guidelines and was obtained only through a data request.¹⁵⁸

- REMEDY: In Section 7.3.5.5, PG&E must discuss its plan and execution of fuel management activities that reduce the availability of fuel in proximity to potential sources of ignition, including both reduction or adjustment of live fuel (in terms of species or otherwise) and of dead fuel, including “slash” from VM activities that produce vegetation material such as branch trimmings and felled trees.
- ISSUE: In response to Revision Notice critical issue RN-PG&E-06, PG&E explained that audits (i.e., its QA, QV, and WV programs) “track retention of initial VM training retention,”¹⁵⁹ “reinforce expectations of quality, wildfire risk mitigation, and safety,”¹⁶⁰ and “identify deficiencies.”¹⁶¹ In the same response, PG&E admits that it “does not have a continuing education, or ‘refresher’ curriculum for VM.” Energy Safety contends that PG&E has been reactively training its VM crews using deficiencies found during audits rather than requiring proactive continuing education; this reactive vs proactive approach is illustrated by the disparity between PG&E’s reported 2020-2022 WMP cycle spend on 7.3.5.13, Quality Assurance / Quality Control of vegetation inspections, and 7.3.5.14, Recruiting and training of vegetation management personnel, which are \$32,506,607 and \$39,372, respectively. Continuing education and audits are not mutually exclusive and should work in tandem to avoid and remedy VM error. PG&E does state that it is “currently in the process of creating a refresher course that will be updated yearly” which will be “ready for use in 2022.”¹⁶²
 - REMEDY: PG&E must report on the progress of developing and implementing its new refresher curriculum in Section 7.3.5.14 (or equivalent). This includes detailing the “issues across various scopes of work identified in the previous year”¹⁶³ and the “changes to [its] VM programs or changes to safety or work standards”¹⁶⁴ which PG&E intends to include as part of the refresher course.
- ISSUE: In Revision Notice critical issue RN-PG&E-06, PG&E is required to provide VM training pass/fail rates.¹⁶⁵ In its response, PG&E states that its Structured Learning Path (SLP) software allows individuals to re-take the knowledge checks as many times as needed in order to pass, and as a result, PG&E does not track pass/fail rates.¹⁶⁶ As Cal Advocates points out, “since PG&E allows individuals to re-take the knowledge checks as

¹⁵⁸ WildfireMitigationPlans_DR_WSD_011-Q05

¹⁵⁹ PG&E 2021 WMP Update Revision – Clean, p. 731

¹⁶⁰ PG&E 2021 WMP Update Revision – Clean, p. 733

¹⁶¹ PG&E 2021 WMP Update Revision – Clean, p. 733

¹⁶² PG&E 2021 WMP Update Revision – Clean, p. 722

¹⁶³ PG&E 2021 WMP Update Revision – Clean, p. 728

¹⁶⁴ PG&E 2021 WMP Update Revision – Clean, p. 728

¹⁶⁵ Wildfire Safety Division’s Revision Notice for Pacific Gas & Electric Company’s 2021 Wildfire Mitigation Plan Update, May 4, 2021, p. 22.

¹⁶⁶ PG&E 2021 WMP Update Revision – Clean, p. 730.



many times as needed, it is possible for an individual to pass through rote memorization after multiple failed attempts, without necessarily comprehending the material. Additionally, if PG&E does not track the number of attempts individuals take to pass, it is impossible to track statistical anomalies that may indicate a problem.”¹⁶⁷ PG&E had planned for VM personnel to take a proctored exam at the conclusion of the SLP which would limit participants to only three attempts to pass.; however, this exam was not implemented due to the COVID-19 pandemic.¹⁶⁸

- REMEDY: PG&E must begin tracking passing metrics including, but not limited to, the number of attempts taken to pass the SLP knowledge checks in order to track statistical anomalies that may indicate a problem.
- REMEDY: PG&E should consider implementing its proctored exam with limited pass attempts at the conclusion of the SLP as soon as possible.
- ISSUE: In response to revision notice critical issue RN-PG&E-06, PG&E states it “currently tracks the ISA certification of VM team members as part of the onboarding process” and that it has been providing the ISA’s Tree Risk Assessment Qualification (TRAQ)¹⁶⁹ training to current ISA Certified Arborists.¹⁷⁰ PG&E’s response indicates that PG&E does not track ISA certification after onboarding for renewals or initial certification of existing employees. Additionally, there is no indication that PG&E invests in, encourages, monitors, or tracks employee or contractor’s progress towards initial certification after onboarding. ISA training and certification is one pathway towards creating a more qualified workforce; PG&E is missing an opportunity to improve the skills of its workers and prove to Energy Safety, agencies, governments, and public that it is invested in improving the skills and qualifications of its workers.
 - REMEDY: PG&E must describe how it is promoting and ensuring the continued professional growth of its VM personnel.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:

¹⁶⁷ Comments of the Public Advocates Office on Pacific Gas and Electric’s (PG&E) June 3, 2021 Revision of its 2021 Wildfire Mitigation Plan Update, June 10, 2021, p. 22.

¹⁶⁸ PG&E 2021 WMP Update Revision – Clean, p. 730.


¹⁶⁹ <https://www.isa-arbor.com/Credentials/ISA-Tree-Risk-Assessment-Qualification>

¹⁷⁰ PG&E 2021 WMP Update Revision – Clean, pp. 731-732.



| | | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
|---|---|-----------|-----------|-----------|-----------|-----------|-----------|
| Vegetation clearance findings from inspection - total | Number of spans inspected where at least some vegetation was found in non-compliant condition - total | 2,402 | 3,010 | 3,372 | 5,072 | 37,914 | 52,248 |
| | Number of spans inspected for vegetation compliance - total | 1,443,176 | 1,562,166 | 1,458,738 | 1,496,906 | 1,525,349 | 1,649,978 |
| | Percentage of spans inspected where at least some vegetation was found in non-complaint condition | 0.17% | 0.19% | 0.23% | 0.34% | 2.49% | 3.17% |
| Vegetation clearance findings from inspection - in HFTD | Number of spans inspected where at least some vegetation was found in non-compliant condition in HFTD | 204 | 442 | 912 | 1,919 | 14,469 | 24,998 |
| | Number of spans inspected for vegetation compliance in HFTD | 170,577 | 337,899 | 323,228 | 428,070 | 457,740 | 546,184 |
| | Percentage of spans inspected where at least some vegetation was found in non-complaint condition in HFTD | 0.12% | 0.13% | 0.28% | 0.45% | 3.16% | 4.58% |

Figure 5.5.a: Vegetation clearance finding from inspections (from WMP Table 1)



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.5.b: Vegetation management and inspections maturity score progress.

Actual and projected spend (\$K) per HFTD overhead circuit mile




| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$46.99 | \$27.01 | \$17.59 |
| 2021 Planned Total | \$48.81 | \$26.38 | \$15.90 |
| 2022 Planned Total | \$46.96 | \$27.12 | \$15.90 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.5.c: Vegetation management and inspections spend per HFTD overhead circuit mile, large utilities 2020-2022.

Risk events per circuit mile



Source: Table 7.1 of utility 2021 WMPs

Figure 5.3.d: Risk events per circuit mile due to vegetation contact, large utilities 2016-2021.



5.6 Grid Operations and Operating Protocols, Including PSPS

Introduction

The grid operations and operating protocols section of the WMP Guidelines¹⁷¹ requires discussion of ways the utility operates its system to reduce wildfire risk. For example, disabling the reclosing function of automatic reclosers¹⁷² during periods of high fire danger (e.g., during Red Flag Warning conditions) can reduce utility ignition potential by minimizing the duration and amount of energy released when there is a fault. This section also requires discussion of work procedures in elevated fire risk conditions and protocols to reduce the frequency and scope of de-energization including PSPS events (e.g., through sectionalization, etc.). This section also requires the utility to report whether it has stationed and/or on-call ignition prevention and suppression resources and services.

Overview

Energy Safety finds that PG&E has made progress in the areas of grid operations and operating protocols and finds this portion of PG&E's 2021 WMP Update to be generally sufficient, subject to remedies. PG&E is expected to provide updates on its progress on identified issues in its ongoing required submissions with Energy Safety. PPS is also discussed in Section 6.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- In 2020, PG&E disabled all of its automatic reclosers within Tier 2 and 3 HFTDs prior to fire season. In 2021, PG&E plans to continue following its Utility Procedure TD-1464P-01 (Fire Index Patrol and Non-Reclose Procedure) which outlines recloser settings during fire season. PG&E states that 99 percent of distribution reclosing devices and 95 percent of transmission line devices are SCADA-enabled, but the remaining are disabled manually.
- PG&E continued to grow its Safety and Infrastructure Protection Team (SIPT) Program. SIPTs consist of two-person crews certified in safety and infrastructure protection and trained in fire suppression and prevention who accompany PG&E personnel during high-risk work activities in elevated fire risk conditions.¹⁷³ As of PG&E's 2021 WMP Update,

¹⁷¹ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 45 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

¹⁷² A recloser is a switching device that is designed to detect and interrupt momentary fault conditions. The device can reclose automatically and reopen if a fault condition is still detected. However, if a recloser closes a circuit that poses the risk of ignition, wildfire may be the result. For that reason, reclosers are disabled in certain high fire risk conditions. During overcurrent situations, circuit breakers trip a switch that shuts off power to the electrical line.

¹⁷³ PG&E 2021 WMP Update, p. 686.



PG&E’s SIPT Program consisted of 40 SIPTs available to respond Monday through Friday, with eight SIPTs on-call on weekends and holidays during the summer preparedness period.

- In 2020, PG&E developed “SafetyNet observation cards” that allowed PG&E personnel to submit comments about the safety of activities being performed. PG&E received 9,500 observation cards, with 99.1 percent demonstrating safe activities in which employees adhered to Standard TD-1464S (Preventing and Mitigating Fires While Performing PG&E Work).¹⁷⁴ In 2021, PG&E states that it is using lessons-learned and findings to expand a quality control program for following Standard TD-1464S.
- PG&E installed over 600 sectionalization devices and 54 transmission switches in order to narrow the de-energization scope of PSPS events. These installations are intended to narrow the boundaries of PSPS events to be as close as possible to the boundaries of PG&E’s critical fire weather areas.¹⁷⁵

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|---|--|
| PG&E-21-25 | Lack of specificity regarding how increased grid hardening will change system operations, change PSPS thresholds, and reduce PPS events | PG&E does not commit to changes in its PPS thresholds for increased grid hardening. PG&E does not specify how increased grid hardening will change system operations. | For each mitigation alternative, including pilot program initiatives, PG&E must provide quantitative analysis on: 1. Changes in system operations. 2. Changes in PPS thresholds. 3. Estimated changes in the frequency, duration, and number of customers impacted by PPS events. |

¹⁷⁴ PG&E 2021 WMP Update, p. 689.

¹⁷⁵ PG&E 2021 WMP Redlined Update, p. 810.

Additional Issues and Remedies


In addition to the key areas listed above, Energy Safety finds the following issue and directs the associated remedy. All remedies must be addressed in PG&E’s 2022 WMP Update.

ISSUE: PG&E states that it may potentially increase its fixed-wing fleet in the next two years, therefore decreasing the need to contract aircraft operators for inspection work. However, PG&E does not provide details on its evaluation of this program.

REMEDY: PG&E must (1) explain how it is evaluating the need to increase its fixed-wing fleet, including providing a cost-benefit analysis comparing increasing its fixed-wing fleet to contracting aircraft operators for inspection work, (2) provide details on the intended increase for PG&E’s fixed-wing fleet, including how PG&E has determined or will determine the additional number of fixed-wing crafts to purchase, and (3) discuss how it anticipates an increase in its fixed-wing fleet would impact helicopter inspections.

Figures


Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.6.a: Grid operations and protocols maturity score progress.

Actual and projected spend (\$K) per HFTD overhead circuit mile



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$5.93 | \$2.20 | \$3.80 |
| 2021 Planned Total | \$6.22 | \$3.98 | \$4.60 |
| 2022 Planned Total | \$5.84 | \$3.54 | \$3.49 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests

Figure 5.6.b: Grid operations and protocols spend per HFTD overhead circuit mile, large utilities 2020-2022.

5.7 Data Governance

Introduction

The data governance section of the WMP Guidelines¹⁷⁶ requires information on the utility's initiatives to create a centralized wildfire-related data repository, conduct collaborative research on utility ignition and wildfire, document and share wildfire-related data and algorithms, and track and analyze near-miss data. In addition, this section discusses the quality and completeness of Quarterly Data Reports (QDR), consisting of spatial and non-spatial data submitted as required by condition Guidance-10 in resolution WSD-002. Initial submissions of data were received in September 2020, and QA/QC reports were issued for the spatial data component of those submissions in December 2020. Since those initial QA/QC reports, WSD received two more QDRs in December 2020 and in February or March 2021 (submitted with the utility's 2021 WMP Update). The spatial data are subject to the WSD GIS Data Reporting Standard (GIS Standard), the first version of which was published by the WSD on August 21,

¹⁷⁶ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 45 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

2020, and which was updated on February 4, 2021.¹⁷⁷ The analysis of spatial data in this section focuses on specific areas where the data PG&E submitted with its 2021 WMP Update do not meet the GIS Standard.

Overview

Over the last year, PG&E made progress in developing its data governance program and took important steps to create a central data repository. PG&E provided some information on its collaborative research, but that information was not sufficiently detailed. PG&E provided some information on documentation and disclosure of wildfire-related data and algorithms, but this information was not sufficiently detailed. PG&E did not substantially improve the quality of its quarterly spatial data compared to previous submissions, but these data were generally fairly complete.

Progress over the past year

Energy Safety finds that PG&E has made the following progress:

- Implemented centralized enterprise data platform
- Established an enterprise data management organization
- Built prototype asset failure analysis tool for conductor and distribution transformer failure
- Built prototype Grid Data Analytics Tool to identify and resolve the source of outages
- Ongoing probabilistic wildfire risk assessment modeling (collaboration with UCLA)
- Ongoing research in monitoring distribution feeder using optical sensors to detect faults
- New partnership with Cal Poly wildland urban interface institute - “advising on the direction of research”
- Created a team to collect risk event data

PG&E has room for improvement in the following areas:

- Spatial data in the Quarterly Data Report (QDR) submission: PG&E has not made significant progress compared to the previous quarterly data submission. The data submitted for Q4 2020 have several fundamental issues which negatively affect the useability of the data and do not meet the standard. Many of the issues indicate a lack of internal quality control review of data which may have been converted from other formats or systems. Some of the more significant problems were:
 - Locations which are obviously in error: some of the data submitted in several feature classes, including vegetation management inspections, had no location or were located well outside the continental US.

¹⁷⁷ The most recent version of the standard, version 2, is available here:
<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/wsd-gis-data-reporting-standard-v2.pdf>
(accessed July 15, 2021).

- Missing age data: PG&E did not provide age data for the majority of its transmission line assets or any connection devices. Notably, PG&E did not provide estimated age ranges for any assets, which are requested when more specific age data are not available.
- Missing primary keys: primary key/unique ID fields are fundamental, and data submitted without a unique primary key are not useable. The listed feature classes or tables had some records with missing primary keys or values in primary key fields that are not unique to each record:
 - Vegetation Management Project Log
 - PSPS Event Damage Point
 - PSPS Event Conductor Damage Detail
 - Risk Event Asset Log


Issues and Remedies

While Energy Safety did not identify key areas for improvement in this competency, Energy Safety finds the following issue and directs the associated remedy. Energy Safety expects PG&E to take action to address this issues and report on progress made over the year in its 2022 WMP Update.

- ISSUE: PG&E’s spatial QDR data submissions have shortcomings that must be remedied. PG&E lacks internal quality control on its data submissions. Data are sometimes incomplete or unexplained.
 - REMEDY: PG&E must submit correct locations, complete age data, and primary keys.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:




Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.7.a: Data governance maturity score progress.

As noted in Figure 5.7.a, PG&E shows significant progression in their data governance maturity score, however, it remains behind both SCE and SDG&E in this area.

Actual and projected spend (\$K) per HFTD overhead circuit mile



Source: Table 12 of utility 2021 WMPs and subsequent data requests

Figure 5.7.b: Data governance spend per HFTD overhead circuit mile, large utilities 2020-2022.

As Figure 5.7.b shows, PG&E is spending more per HFTD overhead circuit mile on data governance than either SCE or SDG&E.

5.8 Resource Allocation Methodology

Introduction

The resource allocation methodology section of the WMP Guidelines¹⁷⁸ requires the utility to describe its methodology for prioritizing programs by cost-efficiency. This section requires utilities to discuss risk reduction scenario analysis and provide an RSE analysis for each aspect of the plan.

¹⁷⁸ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 45 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.



Overview

In its initial WMP Update submission, PG&E aggregated several system hardening initiatives into a larger program. In a Revision Notice, PG&E was required to disaggregate its system hardening program and report the miles treated, spend, and RSE estimates for individual initiatives. PG&E sufficiently addressed the critical issue.

Since the 2020 WMP, PG&E has made progress in its resource allocation methodology capabilities. Specifically, PG&E reported over 10 times more RSE estimates for mitigation initiatives compared to last year. Even with the recent developments, however, it is still unclear how RSE estimates are weighted against other decision-making factors for the initiative-selection process. PG&E must bring clarity to its initiative-selection process by providing a thorough overview of the initiative selection procedure from beginning to implementation. Energy Safety and the WSAB recommend the utilities provide a visual diagram to bring clarity to the utilities' decision-making process.¹⁷⁹ Energy Safety finds that PG&E has made progress in its resource allocation methodology capabilities and finds this portion of PG&E's 2021 WMP Update to be sufficient, subject to remedies.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E provided 10 times more RSE estimates for mitigation initiatives compared to the 2020 WMP.
- PG&E updated its fire spread technology to show the locations where specific infrastructure failures can lead to ignitions that have the highest consequences. This update allows PG&E to make better risk-informed decisions for infrastructure inspections.
- PG&E incorporated the updated risk model in its System Inspection Program to prioritize inspection workplans.
- PG&E estimated the fire season ignition probabilities using a machine learning model with a Maximum Entropy (MaxEnt) classifier. The models are trained on ignition (or outage) locations and gridded spatial (raster) environmental and asset attribute data. This analysis incorporated larger and more accurate data sets (for example tree type and ground cover).

PG&E has room for improvement in the following area:

- PG&E does not report progress in portfolio-wide initiative allocation methodology (capability 41) and portfolio-wide innovation in new wildfire initiatives (capability 42). PG&E reports stagnant growth in these capabilities due to a lack of RSE verification

¹⁷⁹ WSAB's "Recommendations on the 2021 Wildfire Mitigation Plan Updates for Large Investor-Owned Utilities," Recommendation 3 of Section 2, p. 5.

methodology for existing and new initiatives. Specifically, for capabilities 41c and 42b, PG&E states that the utility does not verify RSE estimates and does not have a program in place for evaluating the RSE estimates of new initiatives. PG&E must improve in this category by developing a robust RSE verification methodology. More discussion relating to this topic is found in PG&E-21-28.

- PG&E’s RSE estimate for covered conductor installation is vastly different from the other large electrical utilities, as shown in Table 3 below.

Table 3: Covered conductor values from the large electrical utilities.

| Utility | 2020-2022 Circuit Miles ¹⁸⁰ | 2020-2022 Cost Per Mile ¹⁸¹ | Risk Reduction Efficiency ¹⁸² | RSE ¹⁸³ |
|---------|---|---|---|--------------------|
| PG&E | 918 | \$1,498,188 | 62% | 4.08 |
| SDG&E | 81.9 | \$1,883,977 | 70% | 76.73 |
| SCE | 3,965 | \$550,725 | 64% | 4,192 |

The reason for the discrepancy between RSE estimates is not clear at this time, with differences potentially stemming from the comparatively much lower cost per mile given by SCE while maintaining a comparatively similar risk reduction efficiency, as seen in Table 3. More evaluation is needed to determine why PG&E’s RSE value differs from the other two large electrical utilities. RSE values for covered conductor should be more standardized in future WMP updates. More discussion relating to this topic is found in PG&E-21-28.

Discussion of Revision Notice Critical Issue RN-PG&E-03

As described in Section 1.2, a Revision Notice was issued to PG&E on May 4, 2021. PG&E responded to the Revision Notice on June 3, 2021. The table below lists the critical issue contained in the Revision Notice specific to this section of the Action Statement followed by discussion. The issue was resolved.

¹⁸⁰ Comments of The Utility Reform Network on 2021 Wildfire Mitigation Plan Updates, p. 35.

¹⁸¹ Ibid.

¹⁸² Values from PG&E’s response to WSD-PGE-010 Q011, provided on March 18, 2021; SDG&E 2021 WMP, p. 192; and SCE’s response to TURN-SCE-006 Q004, provided on March 17, 2021.

¹⁸³ Values from Table 12 of the WMP Update submissions under the “Estimated RSE for HFTD Tier 3” column for “Covered Conductor Installation”; PG&E’s RSE value comes from the utility’s Errata (dated March 17, 2021, accessed May 19, 2021: https://www.pge.com/pge_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/2021-Wildfire-Safety-Plan-Errata.pdf).



| Critical issue | Description | Utility response | Energy Safety evaluation |
|----------------|---|--|---|
| RN-PG&E-03 | Unacceptable Aggregation of System Hardening Risk-Spend Efficiencies (RSEs) | PG&E provided the detailed costs, miles treated, RSE estimates, and other relevant information and data for each of the following mitigations: covered conductor installation, undergrounding, and remote grid. PG&E submitted this information as a revised Table 12. | PG&E addressed the critical issue by providing the costs, miles treated, and RSE estimates for covered conductor installation, undergrounding, and remote grid. |

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

| Utility-# | Issue title | Issue description | Remedies required |
|------------|---|--|--|
| PG&E-21-26 | Inadequate discussion on impact of RSEs in initiative selection | PG&E does not clearly explain how RSE estimates impact the initiative selection process. RSE estimates provide a pathway to assess the relative benefit provided by the mitigation initiatives and must play an integral role in the selection process. Energy Safety understands the dynamic nature of initiative selection due to work management efficiencies, operational realities, resource constraints, and other factors. However, a clear description of how RSE estimates impact the selection process must be provided to | PG&E must provide an overview of its decision-making framework to include a clear explanation of how RSE estimates impact decision making for initiative selection. The overview must show the rankings of the relative decision-making factors (e.g., planning and execution lead times, resource constraints, etc.) and pinpoint where quantifiable risk reductions and RSE estimates are considered in the initiative selection process. Energy Safety recommends a cascading, dynamic “if-then” style flowchart to effectively demonstrate this prioritization process and satisfy this requirement. |



| | | | |
|------------|---|---|--|
| | | ensure consistency across initiatives. | |
| PG&E-21-27 | Lack of methodology to verify RSE estimates | For capability 41c of the 2021 Maturity Survey, PG&E showed no planned progress by selecting “Utility does not verify RSE estimates” for the years 2020 - 2023. In order to rely on RSEs to select mitigation initiatives, PG&E must have high confidence that the calculated RSEs are accurate. Moreover, for capability 40a of the 2021 Maturity Survey PG&E selected “Utility has accurate relative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate.” Without a verification process, the utility cannot guarantee reliability of RSE estimations. PG&E must develop a methodology to assess the accuracy of its RSE estimates. Comparatively SCE and SDG&E can, at a base level, verify their calculated RSEs with historical and experimental pilot data. | PG&E must provide a detailed RSE verification plan with attainable benchmarks and timeline. |
| PG&E-21-28 | RSE values vary across utilities | Energy Safety raises a concern that there are stark variances in RSE estimates, sometimes on several orders of magnitude, for the same initiatives calculated by different utilities. For example, PG&E’s RSE for covered conductor installation was | The utilities ¹⁸⁷ must collaborate through a working group facilitated by Energy Safety ¹⁸⁸ to develop a more standardized approach to the inputs and assumptions used for RSE calculations. After Energy Safety completes its evaluation of the 2021 WMP Updates, it will |

¹⁸⁷ Here “utilities” refers to PG&E, San Diego Gas & Electric (SDG&E), Southern California Edison Company (SCE).

¹⁸⁸ The WSD transitioned to the Office of Energy Infrastructure Safety (Energy Safety) on July 1, 2021.



| | | | |
|--|--|---|--|
| | | <p>4.08,¹⁸⁴ SDG&E’s RSE was 76.73,¹⁸⁵ and SCE’s RSE was 4,192.¹⁸⁶ These drastic differences reveal that there are significant discrepancies between the utilities’ inputs and assumptions, which further support the need for exploration and alignment of these calculations.</p> | <p>provide additional detail on the specifics of this working group.</p> <p>This working group will focus on addressing the inconsistencies between the utilities’ inputs and assumptions, used for their RSE calculations, which will allow for:</p> <ol style="list-style-type: none"> 1. Collaboration among utilities; 2. Stakeholder and academic expert input; and 3. Increased transparency. |
|--|--|---|--|

Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: In its 2021 WMP Update, PG&E continues to use noncommittal and equivocating language to describe future improvements to resource allocation methodology. Per Guidance-8, part iii of Section 5.4.4 of Resolution WSD-002, “Continued use of equivocating language may result in denial of future WMPs.”¹⁸⁹ Regarding PG&E’s future improvements to PG&E’s risk spend efficiency analysis, PG&E states, “RSE calculations are *continually being refined by better data* for effectiveness and scope calculations, coupled with *better input* from the SME as the use of data for RSE calculations is *better understood* with time.”¹⁹⁰ The phrases “continually being refined”, “better data”, “better input”, and “better understood” are not measurable, quantifiable, or verifiable by Energy Safety. The usage of these phrases indicts a lack of commitment for PG&E to improve its resource allocation methodology.
 - REMEDY: PG&E must eliminate the usage of equivocating language in order to provide measurable, quantifiable, and verifiable benchmarks.

¹⁸⁴ Value from PG&E’s Errata (dated March 17, 2021, accessed May 19, 2021:

https://www.pge.com/pge_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/2021-Wildfire-Safety-Plan-Errata.pdf

¹⁸⁵ Value from Table 12 of SDGE’s 2021 WMP Update submissions under the “Estimated RSE for HFTD Tier 3” column for “Covered Conductor Installation.”

¹⁸⁶ Value from Table 12 of SCE’s 2021 WMP Update submissions under the “Estimated RSE for HFTD Tier 3” column for “Covered Conductor Installation.”

¹⁸⁹ “Condition (Guidance-8, Class C): In its 2021 WMP update, each electrical corporation shall: [...] iii) Dispense with empty rhetoric and not use terms that are ambiguous, misleading, or otherwise have the result of diluting commitments. Continued use of equivocating language may result in denial of future WMPs” (p. 24).

¹⁹⁰ PG&E’s 2021 WMP Update Revised – Clean, p. 813-814

- ISSUE: For capability 41a of the 2021 Maturity Survey, PG&E selected “Utility does not base capital allocation on RSE” for 2021 and starting 2023, the “Utility will consider estimates of RSE for capital allocation”. Compared to its peers, SCE and SDGE are at least considering estimates of RSE when allocating capital resources.
 - REMEDY: PG&E must: 1) explain why it does not currently consider RSE estimates for capital resource allocation, and 2) provide a detailed pathway to begin the consideration of RSE estimates for capital resource allocation in its 2022 WMP Update.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:

Top 5 Initiative Activities by Planned Spend – PG&E (\$M)

| | Initiative Activity | Category | 2020 Plan From 2020 WMP | 2020 Actual From 2021 WMP | 2021 Plan | 2022 Plan | Total WMP Cycle Planned Spend | Initiative Spend as % of Total Planned Spend |
|--|---|--------------------------------|-------------------------|---------------------------|----------------|----------------|-------------------------------|--|
| 1 | 7.3.5.2 Detailed inspections of vegetation around distribution electric lines and equipment | Vegetation Management | \$188 | \$1,098 | \$1,065 | \$1,023 | \$3,186 | 21% |
| 2 | 7.3.3.17.1 Updates to grid topology to minimize risk of ignition in HFTDs, System Hardening, Distribution | Grid Design & System Hardening | \$246 | \$460 | \$338 | \$872 | \$1,671 | 11% |
| 3 | 7.3.3.12.3 Other corrective action, Maintenance, Transmission | Grid Design & System Hardening | \$237 | \$552 | \$544 | \$390 | \$1,486 | 10% |
| 4 | 7.3.3.12.4 Other corrective action, Maintenance, Distribution | Grid Design & System Hardening | \$305 | \$348 | \$322 | \$297 | \$968 | 7% |
| 5 | 7.3.3.6 Distribution pole replacement and reinforcement, including with composite poles | Grid Design & System Hardening | \$253 | \$244 | \$304 | \$360 | \$908 | 6% |
| Total spend for top 5 initiatives | | | \$1,229 | \$2,702 | \$2,574 | \$2,943 | \$8,219 | 55% |


Source: Table 12 of 2021 utility WMPs, PGE Revision Notice data and subsequent data requests

Top 5 initiatives make up over 50% of total WMP cycle planned spend

Figure 5.8.a: Resource allocation detail for top five initiative activities by planned spend, PG&E.



Actual and planned spend by initiative category (\$M)



Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E Revision Notice Data

Figure 5.8.b: Overview of spend by initiative category, PG&E.

Total WMP Cycle Planned Spend (\$M and %)

Top 3 spend categories the same across all utilities


| | PG&E Plan Total | SCE Plan Total | SDG&E Plan Total |
|---|-------------------|------------------------------|------------------|
| Grid Design & System Hardening | \$8,225 M (56%) | \$4,097 M (61%) | \$1,219 M (65%) |
| Veg Mgmt. & Inspections | \$4,409 M (30%) | \$1,127 M (17%) | \$223 M (12%) |
| Asset Mgmt. & Inspections | \$808 M (5%) | \$1,044 M (15%) | \$209 M (11%) |
| Grid Operations & Protocols | \$556 M (4%) | \$136 M (2%) | \$54 M (3%) |
| Data Governance | \$414 M (3%) | \$35 M (0.5%) | \$47 M (2%) |
| Situational Awareness & Forecasting | \$149 M (1%) | \$170 M (3%) | \$26 M (1%) |
| Emergency Planning & Preparedness | \$76 M (0.5%) | \$35 M (1%) | \$47 M (3%) |
| Stakeholder Cooperation & Community Engagement | \$155 M (1%) | \$51 M (1%) | \$39 M (2%) |
| Resource Allocation & Methodology | \$21 M (0.1%) | \$59 M (1%) | \$18 M (1%) |
| Risk Assessment & Mapping | \$20 M (0.1%) | \$ 3 (0.04%) | \$5 M (0.2%) |
| Total Planned Spend for WMP cycle | \$14,832 M | \$6,768 M¹ | \$1,886 M |

Source: Tables 3-1, 3-2 and 12 of 2021 utility WMPs, subsequent data requests, SCE and PGE Revision Notices
 1. SCE's total planned spend for WMP cycle includes the addition of initiative 7.1.D – Alternative Technologies, which does not belong to a WMP category

Figure 5.8.c: Breakdown of planned spend by category, large utilities.



Total WMP Cycle Planned Spend (\$M), territory-wide




Grid Design & System Hardening is the highest-spend category for all 3 IOUs

| | PG&E (\$M) | SCE (\$M) | SDG&E (\$M) |
|--------------------------------|------------|-----------|-------------|
| Grid Design & System Hardening | \$8,225 | \$4,097 | \$1,219 |
| Veg. Mgmt. & Inspections | \$4,409 | \$1,127 | \$223 |
| Asset Mgmt. & Inspections | \$808 | \$1,044 | \$209 |
| Grid Operations & Protocols | \$556 | \$136 | \$54 |
| Other | \$835 | \$363 | \$182 |

Source: Table 12 of utility 2021 WMPs, SCE and PGE Revision Notices, and subsequent data requests.

Figure 5.8.d: Overview of planned spend, territory-wide, large utilities.

Total WMP Cycle Planned Spend (\$M), HFTD-only spend




Grid Design & System Hardening is the highest-spend category for all 3 IOUs in HFTDs

| | PG&E (\$M) | SCE (\$M) | SDG&E (\$M) |
|--------------------------------|------------|-----------|-------------|
| Grid Design & System Hardening | \$5,920 | \$2,457 | \$1,050 |
| Veg. Mgmt. & Inspections | \$2,569 | \$1,063 | \$223 |
| Asset Mgmt. & Inspections | \$457 | \$899 | \$210 |
| Grid Operations & Protocols | \$555 | \$136 | \$0 |
| Other | \$798 | \$289 | \$4 |

SDG&E did not report HFTD / non-HFTD split for Grid. Ops

Source: Table 12 of utility 2021 WMPs, PG&E and SCE Revision Notices, and subsequent data requests


Figure 5.8.e: Overview of total planned spend, HFTD-only, large utilities.



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.8.f: Resource allocation methodology maturity score progress.

Actual and projected spend (\$K) per HFTD overhead circuit mile



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$0.21 | \$3.23 | \$1.19 |
| 2021 Planned Total | \$0.23 | \$0.54 | \$1.64 |
| 2022 Planned Total | \$0.23 | \$0.43 | \$1.25 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.8.g: Resource allocation methodology spend per HFTD overhead circuit mile, large utilities 2020-2022.

5.9 Emergency Planning and Preparedness

Introduction

This section of the WMP Guidelines¹⁹¹ requires a general description of the utility's overall emergency preparedness and response plan, including discussion of how the plan is consistent with legal requirements for customer support before, during, and after a wildfire, including support for low-income customers, billing adjustments, deposit waivers, extended payment plans, suspension of disconnection and nonpayment fees, and repairs. Utilities are also required to describe emergency communications before, during, and after a wildfire in languages deemed prevalent in a utility's territory (D.19-05-036, supplemented by D.20-03-004),¹⁹² and other languages required by the Commission.

This section of the WMP Guidelines also requires discussion of the utility's plans for coordination with first responders and other public safety organizations, plans to prepare for and restore service, including workforce mobilization and repositioning of equipment and employees, and a showing that the utility has an adequately sized and trained workforce to promptly restore service after a major event.

Overview

PG&E's Emergency Planning and Preparedness has improved from 2020, including its implementation of training workforce for service restoration, community outreach and emergency preparedness protocols. PG&E continues to improve the adequacy of its workforce by providing its apprentices and linemen with the training and tools necessary to support outage restoration, patrols, inspection, and maintenance to reduce system impacts, ensure public safety, and reduce the risk of wildfire.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- In 2020, PG&E reports it met its hiring goal for 2020 by hiring 40 linemen and 100 apprentices.¹⁹³ PG&E indicates it has departments focused on identifying, hiring, retaining, and training a qualified field workforce to ensure restoration of power to customers in a safe, efficient, and timely manner. In February 2020, PG&E, Cal OES, the

¹⁹¹ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 46 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

¹⁹² A language is prevalent if it is spoken by 1,000 or more persons in the utility's territory or if it is spoken by 5 percent or more of the population within a "public safety answering point" in the utility territory. See California Government Code Section 53112 for more information.

¹⁹³ PG&E 2021 WMP Update, p. 769.

CPUC, and the other utilities entered an agreement to help ensure consistent training requirements for all EOC staff.¹⁹⁴

- PG&E reports that it engages with stakeholders with a focus on emergency planning and preparedness; has updated its outreach approach based on individual communities' past PSPS and wildfire impacts with a focus on providing support to heavily impacted communities with information and resources; and details its community outreach, public awareness, and engagement plan.
- PG&E established a plan in 2019 to ensure the restoration of basic services, community functionality, and support access to resources that facilitate recovery. PG&E indicates it has used the plan in six emergencies through 2020.
- In 2021, PG&E updated its emergency response plan standards and published its 2020 Company Emergency Response Plan (CERP) to align with standardized emergency management practices of public partners and facilitate stronger coordination during emergency response. It also expanded roles and responsibilities of its Emergency Operations Center.
- In 2020, PG&E reports it focused on the creation or update of standards for service restoration with training for 1) performing work within vegetated lands that could result in fire ignition, 2) disabling, reclosing, and testing electric circuits and patrol/restoration actions during fire season, 3) establishing guidelines for PSPS events, and 4) PSPS scoping, de-energizing, and restoration.¹⁹⁵
- In 2020, PG&E reports it acquired 65 helicopters, as well as two fixed-wing aircraft, equipped with cameras, capable of night flying. These aircraft were used during PSPS events to expedite patrols and restoration activities and supported emergent wildfire events and other activities as they occurred.¹⁹⁶

Issues and Remedies

Energy Safety finds the following issues and directs associated remedies. All remedies must be addressed in PG&E's 2022 WMP Update.

- ISSUE: PG&E states that after a wildfire event the utility reviews and evaluates communications to customers and the public. This feedback is then used to improve customer and public communications and outreach efforts for the following year. However, PG&E fails to explain the type of information collected about wildfire outreach efforts, how it is collected, and how it is used to inform future outreach efforts (or prioritize improvements).
 - REMEDY: PG&E needs to develop a transparent methodology to track customer feedback, identify priorities and incorporate those into future plans.
- ISSUE: PG&E indicates it uses the After Action Review (AAR) process to identify key lessons learned from each Emergency Operations Center (EOC) and develop protocols learned from wildfire response. While PG&E explains how it formalizes the AAR process,

¹⁹⁴ PG&E 2021 WMP Update, p. 746.

¹⁹⁵ PG&E 2021 WMP Update, p. 811.


¹⁹⁶ PG&E 2021 WMP Update, p. 813.

it is difficult to determine the how effective the process has been in improving protocols.

- REMEDY: PG&E must describe what lessons it learned through its AAR process and how the corrective action improvements were implemented following this process.
- ISSUE: PG&E shows a decrease in its Emergency Planning and Preparedness spend, despite significant increases in self-reported maturity.
 - REMEDY: PG&E must describe how it plans to accomplish its projected maturity in Emergency Planning and Preparedness initiatives when spend has decreased.

Figures


Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.9.a: Emergency planning and preparedness maturity score progress.

Actual and projected spend (\$K) per 1,000 customers



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$4.05 | \$1.16 | \$10.97 |
| 2021 Planned Total | \$4.68 | \$2.79 | \$13.47 |
| 2022 Planned Total | \$4.86 | \$2.83 | \$11.64 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.9.b: Emergency planning and preparedness spend per HFTD overhead circuit mile, large utilities 2020-2022.

5.10 Stakeholder Cooperation and Community Engagement

Introduction

The final initiative category in the WMP Guidelines¹⁹⁷ requires the utility to report on the extent to which it will engage the communities it serves and cooperate and share best practices with community members, agencies outside California, fire suppression agencies, forest service entities and others engaged in vegetation management or fuel reduction.

Overview

Energy Safety finds that PG&E has made progress in Stakeholder Cooperation and Community Engagement and finds this portion of PG&E’s 2021 WMP Update to be sufficient. PG&E has a strategic approach toward stakeholder cooperation and community engagement and details its

¹⁹⁷ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 46 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

outreach and engagement plan support fueled by ongoing evaluation on the effectiveness of its efforts.

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- In 2020, PG&E reports it launched a new PSPS Portal for public safety partners and established a PSPS Advisory Board, which includes representatives from local and tribal governments.
- In 2020, PG&E states it engaged with over 250 community-based organizations (CBO) and has secured contracts with 66 CBOs to provide additional resources to customers during PSPS events.¹⁹⁸
- PG&E reports progress on engagement and outreach efforts, including hosting 200 meetings, establishing five regional working groups, three PSPS workshops, co-hosting 35 wildfire sessions with OES, and having 84 million average monthly advertising impressions in advance of PSPS events or likelihood of wildfire.¹⁹⁹
- PG&E describes growth in cooperation and sharing best practices with entities both inside and outside of California as it became a founding member of the Utility Executive Steering Group for the International Wildfire Risk Mitigation Consortium (IWRMC). An example benefit was the Rapid Earth Fault Current Limiter technology that PG&E installed in 2020 and is actively testing to assess wildfire risk mitigation.
- In 2020, PG&E reports its Public Safety Specialist (PSS) team supported 600 external engagement activities including: hosting PSPS listening sessions, Wildfire Safety Working Sessions, regional working group meetings, gas/electric safety workshops, professional group meetings, wildfire safety trainings, and gas safety outreach with external public safety partners.²⁰⁰
- In 2020 PG&E reports it combined its PSS team with Gas Operations and Electric Operations, hired additional members and expanded the team. PG&E claims its collaboration with external safety partners improved its overall operational efficiencies and communications.
- As part of an existing agreement with the United States Forest Service (USFS), PG&E reports it developed the Fuels Reduction Partnership Program that received \$5M in funding to address fuel reduction within all 11 USFS forests in PG&E's service territory. In 2020, the USFS was able to acquire the necessary machinery to efficiently and safely complete fuels reduction project work. This machinery will also support additional fuels reduction work over multiple years on acreages beyond the 2020 work areas.
- PG&E reports it established agreements to reduce wildfire risk by allowing PG&E to expedite critical, routine operations and maintenance activity on land managed by other

¹⁹⁸ PG&E 2021 WMP Update, p. 823

¹⁹⁹ PG&E 2021 WMP Update, p. 824

²⁰⁰ PG&E 2021 WMP Update, p. 835.



federal and state landowners, including with California State Parks, the Bureau of Land Management, and the National Park Service.

- In 2020, PG&E reports the Community Wildfire Safety Program (CWSP) Project Management Office (PMO) Team increased to seven PG&E staff plus contractor support to cover program management, work tracking, regulatory deliverables (including the development of the WMP itself), wildfire workstream coordination, communications planning, and issue resolution.


PG&E has room for improvement in the following area:

- While PG&E describes how it reaches out to stakeholders, it fails to provide information about how it collects stakeholder feedback (not just feedback about outreach efforts) and how it incorporates this information into both its community engagement efforts and its wildfire mitigation planning.
- As described above, PG&E indicates longstanding relationships with the USFS²⁰¹ and other agencies to coordinate fuel reduction, system maintenance on non-PG&E rights of way, and secure government funding to support coordinated mitigation initiatives. However, its responses to questions under capability 52 of the Utility Maturity Survey ("Collaboration on wildfire mitigation planning with stakeholders") show little growth between year 1 and year 3 in this area. PG&E also reports reorganization and expansion of its Public Safety Specialists (PSS) team, which supports and prioritizes external engagement activities, in 2020. Energy Safety expects to see growth reflected in PG&E's Maturity Survey responses to match progress described by PG&E in its 2021 WMP Update. For instance, how PG&E is adjusting its plans to cooperate with other stakeholders state-wide, with focus on areas that would have the biggest impact in reducing wildfire risk.

Figures

Below are additional charts, maps and tables used as part of Energy Safety's review of PG&E's WMP Update:


²⁰¹ PG&E 2021 WMP Update, p. 840-841. PG&E indicates it "is the first IOU in California to partner with a federal agency on a program of this type. The Company is always looking at ways to improve and make the Fuels Reduction Partnership Program more effective. [...] Future coordination of the program will also identify and focus on areas of improvement such as funding adjustments, use of new technologies, and new process developments for fuels management."



Source: 2021 Maturity Model survey data for PG&E, SCE and SDG&E

Figure 5.10.a: Stakeholder cooperation and community engagement maturity score progress.

Actual and projected spend (\$K) per 1,000 customers



| | PG&E (\$K) | SCE (\$K) | SDG&E (\$K) |
|---------------------------|------------|-----------|-------------|
| 2020 Actual Total | \$8.59 | \$0.77 | \$10.11 |
| 2021 Planned Total | \$9.46 | \$4.55 | \$10.10 |
| 2022 Planned Total | \$9.50 | \$4.57 | \$9.46 |

Source: Table 12 of utility 2021 WMPs and subsequent data requests; PG&E and SCE Revision Notice Data

Figure 5.10.b: Stakeholder cooperation and community engagement spend per 1,000 customers, large utilities 2020-2022.

6 PUBLIC SAFETY POWER SHUTOFF (PSPS), INCLUDING DIRECTIONAL VISION FOR PSPS

Introduction

In recent years, Public Safety Power Shutoffs (PSPS) have been increasingly used by utilities to mitigate wildfire risk. PSPS events introduce substantial risk to the public and impose a



significant burden on public services that must activate during a PSPS event. Energy Safety supports the use of PSPS only as a last resort and expects the utilities to clearly present plans for reducing the scale, scope, and frequency of PSPS events.

In 2021, WSD separated the reporting of PSPS from the reporting of mitigations and progress metrics to reflect the definition of PSPS as a last resort rather than a mitigation option (pursuant to CPUC Guidance Resolution WSD-002 and PSPS CPUC decisions D.19-05-036 and D.20-03-004).²⁰² This section of the WMP Guidelines²⁰³ requires utilities to report their current and projected progress in PSPS mitigation, including lessons learned from the prior year, de-energization and re-energization protocols, PSPS outcome metrics, plans to reduce future PSPS impacts, and community engagement.

Overview

Energy Safety finds that PG&E has made progress in addressing PSPS, including directional vision for PSPS and finds this portion of PG&E's 2021 WMP Update to be sufficient, subject to remedies.

In its initial WMP submission, PG&E omitted targets for reduction in scale, scope, and frequency of PSPS, citing uncertainty surrounding proposed conditions in its federal probation case.²⁰⁴ In a Revision Notice, PG&E was required to update its WMP to remedy the omission of quantitative targets. PG&E sufficiently addressed the remedy in its Revision Notice Response and the critical issue is de-escalated.

In the WMP, PG&E outlines its plans to make PSPS events "smaller, shorter, and smarter"²⁰⁵ and recognizes PSPS as a measure of last resort to reduce the risk of catastrophic fires. Over the long-term, PG&E expects a significant reduction in PSPS customer impact as new technologies are deployed and hardening projects are completed.

²⁰² When calculating RSE for PSPS, electrical corporations generally assume 100 percent wildfire risk mitigation and very low implementation costs because societal costs and impact are not included. When calculated this way, PSPS will always rise to the top as a wildfire mitigation tool, but it will always fail to account for its true costs to customers. Therefore, electrical corporations shall not rely on RSE calculations as a tool to justify the use of PSPS.

²⁰³ WSD-011 Attachment 2.2, 2021 Wildfire Mitigation Plan Guidelines Template, p. 46-49 (accessed July 18, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2021/attachment-2.2-to-wsd-011-2021-wmp-guidelines-template.pdf>.

²⁰⁴ PG&E 2021 Wildfire Mitigation Plan Report, February 5, 2021, p. 847.

²⁰⁵ PG&E 2021 Wildfire Mitigation Plan – Revised, June 3, 2021, p. 932,

Progress Over the Past Year

Energy Safety finds that PG&E has made the following progress:

- PG&E reduced the size of PSPS events from 2019, despite more severe weather events in 2020. PG&E attributes the reductions in improvements to meteorology tools and increased segmentation.
- PG&E has scaled and improved post-PSPS restoration operations.
- PG&E updated its PSPS Portal tool for 2020, providing maps, situation reports, critical facility lists, and Medical Baseline customer lists to local agencies, state agencies, and first responders.
- In 2020, PG&E established the Telecommunications Resiliency Collaborative to coordinate during emergency events and promote overall resiliency with telecommunication providers.
- PG&E has shown continued refinement of the models and factors that are considered during decision-making. PG&E does not have a singular algorithm that yields an objective result on whether to initiate a PSPS event and the ultimate decision is a “judgement by the meteorology team”.²⁰⁶

PG&E has room for improvement in the following areas:

- PG&E’s methodology for projecting PSPS customer hours requires further refinement. PSPS projections generate great stakeholder and public interest,²⁰⁷ yet PG&E’s projections are difficult to compare to recorded data from past PSPS events.
- As highlighted in PG&E-21-25, in section 5.6 above, PG&E lacks specificity regarding how grid hardening efforts will change PSPS thresholds and reduce PSPS events.

Discussion of Revision Notice Critical Issue RN-PG&E-01

As described in Section 1.2, a Revision Notice was issued to PG&E on May 4, 2021. PG&E responded to the Revision Notice on June 3, 2021. The table below lists the critical issues contained in the Revision Notice specific to this section of the Action Statement followed by discussion. While PG&E provided sufficient information to resolve the critical issue, additional information and remedies are required in the future. Please see the section on “key areas for improvement” below for more information.

²⁰⁶ PG&E 2021 Wildfire Mitigation Plan Report, February 5, 2021, p. 881.

²⁰⁷ Comments on PG&E’s 2021 WMP Update from: Cal Advocates, ATC, Kevin Collins, GPI, MGRA, RCRC, SCC, Valley Women’s Club for the San Lorenzo Valley, Professor Sandoval, and TURN.



| Critical issue | Description | Utility response | Energy Safety evaluation |
|--|---|--|--|
| RN-PG&E-01 Omission of Quantitative Targets for Reduction in PSPS Scale, Scope, and Frequency | PG&E omitted inclusion of quantitative targets for reducing the scale, scope, and frequency of PSPS events; it does not fully explain how its programmatic commitments over the next WMP cycle will reduce PSPS events; and it projects an increase in customer planned outage hours for 2021 and 2022 despite the implementation of mitigation measures over this time period. | PG&E responded to each required remedy, including: 1) description of changes to its PSPS protocols, 2) quantitative targets for reducing scale, scope, and frequency of PSPS, 3) description of PSPS target methodology, 4) expected quantitative reduction of PSPS scale, scope, and/or frequency from programmatic commitments, 5) detail of how major programs are factored into PSPS projections, and 6) explanation of why its projected customer outage hours for 2021 and 2022 are an increase over recorded customer outage hours in 2020. | PG&E’s response sufficiently addresses each required remedy; however, PG&E states that its PSPS approach will likely change in August 2021 and the new approach may be “substantially” ²⁰⁸ different than PG&E’s current approach. ²⁰⁹ Energy Safety recognizes the need to continually refine and improve PSPS protocols, but significant changes to PSPS protocols could result in significant changes to PSPS commitments. As soon as practicable, PG&E must provide an update, including showing how its new PSPS protocols affect targets. See key area for improvement PG&E-21-29 below. |

Key Areas for Improvement and Remedies

Energy Safety finds that PG&E must focus on the following areas as significant to reducing utility-related wildfire risk. Remedies to the following issues must be addressed in a progress report due November 1, 2021.

²⁰⁸ PG&E Revision Notice response, section 2 “2021 PSPS Protocols,” page 983.

²⁰⁹ In its Revision Notice response, PG&E labels its current PSPS protocols, in effect from May 2021 through August 2021, as “2020 PSPS Protocols Plus Tree Overstrike Potential and Priority Tags.”



| Utility-# | Issue title | Issue description | Remedies required |
|------------|--|---|---|
| PG&E-21-29 | PSPS targets and projections set to expire | PG&E states that its PSPS approach will likely change in August 2021. When PG&E updates its approach, the PSPS targets and projections presented in its WMP Update and Revision Notice response will become obsolete. | <p>As soon as practicable, PG&E must submit a Change Order Report:²¹⁰ ²¹¹</p> <ol style="list-style-type: none"> 1. Describing in full and complete detail its updated PSPS protocols. 2. Showing how its updated PSPS protocols affect PSPS projections (Table 11). 3. Showing how its updated PSPS protocols affect all quantitative and qualitative targets for reducing the scale, scope, and frequency of PSPS. 4. Meeting all requirements for a Change Order Report set out in section 7 of this Action Statement. |

Additional Issues and Remedies

In addition to the key areas listed above, Energy Safety finds the following issue and directs the associated remedy. All remedies must be addressed in PG&E’s 2022 WMP Update.

- ISSUE: PG&E’s projections for customer outage hours uses an 11-year average of simulated historical PSPS events. In the lookback simulation, the PSPS duration each customer experienced is calculated as the weather duration plus restoration time, which results in the lookback simulation using maximum event hours for customers, regardless of the hours actually experienced by customers. This methodology does not provide an accurate projection of PSPS customer hours and creates an estimate that is difficult to compare to past events.
 - REMEDY: PG&E must refine its PSPS projection methodology. Projections must be comparable to recorded data from past events. To the extent practicable, projections should factor the actual duration experienced from past PSPS events.

²¹⁰ This reporting requirements do not replace or amend any reporting or other obligations that may be imposed on PG&E by the CPUC, including CPUC Resolution M-4856 associated with PG&E’s new considerations of tree overstrike factors into its PSPS protocols.

²¹¹ Change Order Reports are described in Section 7 of this Action Statement.

Figures

Below are additional charts, maps and tables used as part of Energy Safety’s review of PG&E’s WMP Update:




Figure 6.a: Customer hours of PSPS per Red Flag Warning (RFW) circuit mile day




Figure 6.b: PSPS duration in customer hours (total), PG&E Scenario 1: Forecasted data as average of historical data




Figure 6.c: PSPS duration in customer hours (total), PG&E Scenario 2: Forecasted data with 2021 planned WMP mitigations in place




Figure 6.d: PSPS duration in customer hours (total), PG&E Scenario 3: Forecasted data with 2021 mitigations and 2020 PSPS protocols plus tree overstrike potential and priority tags criteria added





Figure 6.e: PSPS duration in customer hours (total), PG&E all scenarios


Critical infrastructure impacted by PSPS, total



Source: Table 11 of 2021 utility WMPs, SCE and PGE Revision Notice Data
Notes:
Critical infrastructure impacted by PSPS is the number of critical infrastructure (in accordance with D.19-05-042) locations impacted per hour multiplied by hours offline per year.
SCE provided low/high values for their 2021 projections, thus the average of those values was taken and is shown here. The low values were 1 (Q3) and 1,658 (Q4). The high values were 4 (Q3) and 5,320 (Q4).
SCE stated that there was a typo in their originally-submitted 2021 WMP data, for 2019 and 2020. This typo has been corrected here.

Figure 6.f: PSPS impacts on critical infrastructure, PG&E Scenario 1: Forecasted data as average of historical data

Critical infrastructure impacted by PSPS, total




Source: Table 11 of 2021 utility WMPs, SCE and PGE Revision Notice Data

Notes:

Critical infrastructure impacted by PSPS is the number of critical infrastructure (in accordance with D.19-05-042) locations impacted per hour multiplied by hours offline per year. SCE provided low/high values for their 2021 projections, thus the average of those values was taken and is shown here. The low values were 1 (Q3) and 1,658 (Q4). The high values were 4 (Q3) and 5,320 (Q4). SCE stated that there was a typo in their originally-submitted 2021 WMP data, for 2019 and 2020. This typo has been corrected here.

Figure 6.g: PSPS impacts on critical infrastructure, PG&E Scenario 2: Forecasted data with 2021 planned WMP mitigations in place

Critical infrastructure impacted by PSPS, total



Source: Table 11 of 2021 utility WMPs, SCE and PGE Revision Notice Data


Notes:

Critical infrastructure impacted by PSPS is the number of critical infrastructure (in accordance with D.19-05-042) locations impacted per hour multiplied by hours offline per year. SCE provided low/high values for their 2021 projections, thus the average of those values was taken and is shown here. The low values were 1 (Q3) and 1,658 (Q4). The high values were 4 (Q3) and 5,320 (Q4). SCE stated that there was a typo in their originally-submitted 2021 WMP data, for 2019 and 2020. This typo has been corrected here.

Figure 6.h: PSPS impacts on critical infrastructure, PG&E Scenario 3: Forecasted data with 2021 mitigations and 2020 PSPS protocols plus tree overstrike potential and priority tags criteria added



Critical infrastructure impacted by PSPS, total



PG&E Scenarios

Scenario 1: Forecasted data as average of historical data

Scenario 2: Forecasted data with 2021 planned WMP mitigations in place

Scenario 3: Forecasted data with 2021 mitigations and 2020 PSPS protocols plus tree overstrike potential and priority tags criteria added

Source: Table 11 of 2021 utility WMPs, PGE Revision Notice Data
 Notes: Critical infrastructure impacted by PSPS is the number of critical infrastructure (in accordance with D.19-05-042) locations impacted per hour multiplied by hours off line per year.

Figure 6.i: PSPS impacts on critical infrastructure, PG&E all scenarios

7 NEXT STEPS

PG&E must address the issues identified in Energy Safety’s review of PG&E’s 2021 WMP Update over the course of the next year. PG&E must place particular focus on the key areas for improvement described above. PG&E must report progress on these key areas in the Progress Reports, as described in Section 1.3 of this Action Statement.

Change Orders

If PG&E seeks to significantly modify (i.e., reduce, increase, or end) WMP mitigation measures in response to data and results on electrical corporation ignition risk reduction impacts, PG&E must submit a Change Order Report. At a high level, the objective of the change order process is to ensure the electrical corporation continues to follow the most effective and efficient approach to mitigating its wildfire risk. This could change as new information becomes available and as the electrical corporation gains experience and measures the outcomes of its initiatives.

The change order process set forth herein provides a mechanism for the electrical corporation to make adjustments based on this information and experience. The goal of this process is to ensure that utilities make significant changes to their WMPs only if the utilities demonstrate these changes to be improvements per WMP approval criteria (i.e., completeness, technical feasibility, effectiveness, and resource use efficiency). Another goal of the change order process is to maximize Energy Safety’s visibility and ability to respond to any significant changes to the approved plan as efficiently and in as streamlined a way as possible.



A “significant” change to a utility’s WMP that would trigger the change order process is defined below:

- A change falls into the following initiative categories, i) risk assessment and mapping, ii) vegetation management and inspections, iv) grid design and system hardening, or v) asset management and inspections.

or

- A change to the utility’s PSPS strategy, protocols and/or decision-making criteria.

and

- Meets one or more of the following criteria:
 - A change that would result in an increase, decrease, or reallocation of more than \$5 million constituting a greater than 10 percent change in spend allocation.
 - A change that reduces or increases the estimated risk reduction value of an initiative more than 25 percent.
 - A change that results in a radical shift of either the strategic direction or purpose of an initiative (e.g., introducing use of a novel risk model that reverses the risk profile of the utility’s circuits).

If an electrical corporation is unsure whether a change is significant, the corporation is encouraged to submit an advance inquiry on the matter. The change order process is not intended to provide electrical corporations with a pass to unilaterally change their WMP initiatives and program targets; rather, its purpose is to provide a mechanism for refining certain elements of WMP initiatives when there is demonstrable quantitative and qualitative justification for doing so.

Utilities shall submit any Change Order Reports by 5:00 p.m. on November 1, 2021. Energy Safety will review change orders and may issue either an approval or a denial if proposed changes are deemed to be materially out of alignment with Energy Safety’s goals.

At a minimum, each proposed change order shall provide the following information:

- i. The proposed change
 - a. The initiative being altered with reference to where in the WMP the initiative is discussed
 - b. The planned budget of that initiative, including:
 - i. Planned spend in the 2020 WMP and the 2021 WMP Update of the initiative being altered
 - ii. Of the planned spend identified in i. above, how much has already been spent
 - iii. Planned spend for the remainder of the WMP plan period
 - iv. If spend is being redeployed, how much is being redeployed and to/from which budget
 - c. The type of change being proposed, reported as one of the following:
 - i. Increase in scale



- ii. Decrease in scale
 - iii. Change in prioritization
 - iv. Change in deployment timing
 - v. Change in work being done
 - vi. Other change (described)
 - d. A detailed description of the proposed change
 - ii. Justification for the proposed change
 - a. In what way, if any, does the change address or improve:
 - i. Completeness
 - ii. Technical feasibility of the initiative
 - iii. Effectiveness of the initiative
 - iv. Resource use efficiency over portfolio of WMP initiatives
 - iii. Change in expected outcomes from the proposed change
 - a. What outcomes, including quantitative ignition probability and PSPS risk reduction, was the changed initiative expected to achieve in the 2021 WMP Update?
 - b. What outcomes, including quantitative ignition probability and PSPS risk reduction, will the initiative deliver with the proposed adjustment?

Submission of Change Order Reports shall be through Energy Safety’s e-filing system. Change orders must be submitted to the 2021 WMPs Docket (docket #2021-WMPs). Utilities shall concurrently serve all reports on the Department of Forestry and Fire Protection at CALFIREUtilityFireMitigationUnit@fire.ca.gov and the CPUC listserve for R.18-10-007.

Stakeholders may comment on Change Order Reports within fifteen days of submission following the submission instructions above but may not otherwise seek change orders through this process. Energy Safety may modify the process for submitting or reviewing change orders at its discretion with written notice.

8 CONSULTATION WITH CAL FIRE HAS OCCURRED

Pub. Util. Code Section 8386.3(a) requires Energy Safety to consult with CAL FIRE in reviewing electrical corporations’ 2021 WMP Updates. Energy Safety and CAL FIRE have a memorandum of understanding in place to facilitate this consultation (Pub. Util. Code Section 8386.5). Energy Safety has met these requirements, but this Action Statement does not purport to speak for CAL FIRE.

9 COMMENTS ON DRAFT ACTION STATEMENT

On August 30, 2021, PG&E, Mussey Grade Road Alliance (MGRA), Green Power Institute (GPI), and the Public Advocates Office at the California Public Utilities Commission (Cal Advocates), timely submitted comments on the draft PG&E Resolution and Action Statement.

9.1. PG&E Comment Summary and Response

While PG&E’s comments indicate support and a willingness to participate and provide information on a number of required remedies, the utility expressed the following concerns and clarifications on Energy Safety’s draft evaluation findings.

Regarding Risk Assessment and Mapping, PG&E suggests edits for clarification regarding the issue description for PG&E-21-03. PG&E states that “[the] Action Statement also does not explain the growth in risk assessment scores for the other utilities and the type of growth by these utilities that demonstrates ‘adequate speed’”²¹² and therefore proposes removing such text from the issue description. Energy Safety disagrees with the removal of this text and associated edit, as PG&E still needs to demonstrate that it is on par with other utilities in this category. While Energy Safety recognizes that each utility faces unique circumstances and barriers, PG&E is behind SCE and SDG&E in Risk Assessment and Mapping maturity, and projects that it will remain behind SCE and SDG&E in 2022. As demonstrated in Figure 5.1.a above, PG&E’s maturity score for Risk Assessment and Mapping is currently a 0 with a predicted progression to a maturity score of 1.2 at the end of the 2022 WMP cycle. SCE and SDG&E have current maturity scores of 1.4 and 1.8 respectively, and project scores of 2.2 and 2.4 respectively by the end of the 2022 WMP cycle. PG&E should demonstrate proper progress in maturing its risk assessment and mapping at a comparable pace to its peers.

Regarding Situational Awareness, PG&E provides edits to the remedy related to PG&E-21-07. These edits intend to clarify that PG&E utilized DFA/efd technology deployments in HFTD areas, not across PG&E’s entire service territory. Energy Safety recognizes PG&E’s desire to accurately reflect the details and performance metrics of DFA/efd technology in HFTD versus the entire service territory, and therefore agrees with the recommendations from PGE on PG&E-21-07. Changes have been made to PG&E-21-07 to reflect this.

Regarding PG&E-21-18, PG&E requests that Energy Safety “provide to PG&E and the other electrical corporations additional information as to how [Energy Safety] calculates maturity scores so that the electrical corporations can make more informed decisions as to actions to take and goals to set to mature their VM programs.”²¹³ Energy Safety will consider this request. In the meantime, it is worth noting that of the 16 questions that comprise capabilities 24 and 25 (that are related to PG&E-21-18), PG&E expects to mature its capability in the area addressed by only one of these questions (E.V.a²¹⁴) out of a possible 11 (five questions are fully matured). This allows PG&E several opportunities to mature capabilities 24 and 25.

Regarding PG&E-21-19, PG&E requests that the issue description more accurately represent how only in “certain limited circumstances, PG&E is required to seek a judicial remedy” for VM

²¹² Pacific Gas and Electric Company’s Comments on Draft Resolution WSD-021 and Draft Action Statement, p. 2.

²¹³ Pacific Gas and Electric Company’s Comments on Draft Resolution WSD-021 and Draft Action Statement p. 3.

²¹⁴ Wildfire Mitigation Maturity Utility Survey, p. 28.



conflicts. Energy Safety recognizes PG&E’s desire for the evaluation to accurately characterize the content of its 2021 WMP Update. As such, Energy Safety has made this amendment to PG&E-21-19.

Regarding PG&E 21-21, PG&E requests that the issue description remove text that presumes PG&E has a “long-term”²¹⁵ plan for its Preventative Fire Retardant Program. Energy Safety recognizes PG&E’s desire for the evaluation to accurately characterize the content of its 2021 WMP Update. As such, Energy Safety has modified PG&E-21-21 to remove such an assumption.

Regarding PG&E 21-22, PG&E requests that Energy Safety modify item 1 to allow PG&E to use “unique identifier[s]”²¹⁶ in lieu of documenting trees using scientific nomenclature. Energy Safety understands that PG&E currently uses these unique identifiers. If PG&E’s vegetation management systems currently have the capability to identify both the genus and species of vegetation, using unique identifiers or otherwise, PG&E has already fulfilled item 2 of PG&E-21-22. However, in accordance with item 1, PG&E must use scientific names in its reporting to Energy Safety; remedy 1 does not apply to how PG&E (or any utility) records genus and species internally. If PG&E chooses to continue to use its unique identifiers in its operations, it must convert the unique identifiers into scientific nomenclature for its Quarterly Data Reports in accordance with the Energy Safety GIS Data Standard.

Regarding PG&E-21-24, PG&E requests that Energy Safety modify the issue description given the ambiguity of how Energy Safety defined quantitative VM targets found in Table 12, pointing out that it provided for “line miles treated” for 13 of the initiatives, not six. PG&E does provide “line miles treated” for 13 vegetation management initiatives. However, PG&E often chose to report all line miles within its territory as “treated”; in these instances, it is unclear as to whether this indicates an annual target. Energy Safety will work with PG&E and other utilities to better define quantitative VM targets (in some cases, using other units besides “line miles treated”) and strive to provide additional guidance in the forthcoming 2022 WMP Guidelines.

9.2. MGRA Comment Summary and Response

MGRA’s comments generally support Energy Safety’s identified Key Areas for Improvement and associated Remedies, as well as many of the Additional Issues and Remedies.

Regarding System Hardening, MGRA provides suggested edits to better reflect potential impacts from PG&E’s press release to underground 10,000 miles moving forward. In general, Energy Safety agrees with MGRA and intends to monitor the impact PG&E’s undergrounding plan has on its WMPs moving forward. However, it should be noted that approval of this WMP Update does not include approval of PG&E’s new undergrounding plan. PG&E’s new undergrounding plan is still in development and was not included in PG&E’s submittal for its

²¹⁵ Draft Evaluation of PG&E’s 2021 WMP Update, p. 80.

²¹⁶ Pacific Gas and Electric Company’s Comments on Draft Resolution WSD-021 and Draft Action Statement p. 5.



2021 WMP Update. Energy Safety adopted MGRA’s suggested addition to PG&E-21-14 requiring that PG&E report on changes to “advanced technology mitigations research and deployment” resulting from PG&E’s new undergrounding plan.²¹⁷ Energy Safety also added a requirement to PG&E-21-14 that, if PG&E is moving forward with its stated intention to underground 10,000 miles of power lines, PG&E must provide detail in its 2022 WMP Update on the decision to underground and its plans for such undergrounding.

Regarding Resource Allocation Methodology, MGRA provided clarifying edits regarding PG&E’s machine learning model. Energy Safety agrees that MGRA’s suggested edits increase the accuracy of this section and therefore made these changes.

MGRA made several other recommendations; Energy Safety appreciates these other recommendations but has not incorporated them into this Final Action Statement.

9.3. GPI Comment Summary and Response

GPI’s comments generally support Energy Safety’s identified Key Areas for Improvement and associated Remedies, as well as many of the Additional Issues and Remedies.

GPI suggests that PG&E’s responses and associated adjustments regarding PG&E-21-01 and PG&E-21-04 be discussed as part of the risk model working group. GPI suggests other related recommendations, such as implementing an on-going third-party evaluation of the wildfire risk models, requiring additional information on ingress and egress route considerations from all IOUs, and including an issue and associated remedy regarding integration of “post PSPS inspection findings into PSPS risk modeling methodologies and threshold adjustments.”²¹⁸ These topics apply across all the electrical corporations and not just to PG&E. Therefore, Energy Safety did not amend PG&E’s Action Statement with GPI’s suggested edits. Energy Safety will add GPI’s recommendations to the list of topics to potentially address in the cross-utility working group established by PG&E-21-02.

GPI also recommends establishing a second joint utility working group to develop and align PSPS risk modeling methods. Energy Safety agrees with the intent of GPI’s suggestion to accelerate PG&E’s development of granular PSPS consequence modeling. SCE and SDG&E have PSPS consequence modeling integrated within their wildfire risk models, thus development of PSPS risk modeling methods is a natural fit with the planned wildfire risk modeling work group. Benefit of lessons learned from implementation of PSPS consequence modeling and how to achieve capability can productively be leveraged through this group. For these reasons a second joint utility working group is not currently desirable to assist with PG&E’s lack of PSPS consequence model at a circuit-segment level to address remedy PG&E-21-05.

²¹⁷ Mussey Grade Road Alliance Comments on Proposed Resolution WSD-021, p. 6.

²¹⁸ Comments of the Green Power Institute on Draft Resolution WSD-021. p. 7.



Regarding Grid Design and System Hardening, GPI recommends Energy Safety remove a bullet point regarding PG&E's progress on avoiding overlapping initiatives. GPI expresses concern that this bullet point "makes the assumption that PG&E is capable of assessing the incremental RSE and other quantitative and qualitative benefits (or lack thereof) of overlapping wildfire mitigation initiatives."²¹⁹ Energy Safety does not make this assumption, and believes that the bullet point appropriately highlights PG&E's progress in ensuring that it is not unnecessarily doubling up on initiatives and is instead coordinating EVM work based on where System Hardening work is planned. GPI recommends removing the progress statement in the bullet point "until PG&E and the utilities are able to evaluate and quantify the risk mitigation value of overlapping initiatives (e.g. VM and grid hardening deployed together)."²²⁰ Energy Safety agrees that PG&E and the other utilities should continue to evaluate and quantify the risk mitigation value of deploying overlapping initiatives when useful. However, Energy Safety believes that PG&E has progressed in its efforts to eliminate overlapping initiatives when and where those overlaps are not useful or intentional. Therefore, Energy Safety did not remove this bullet point regarding PG&E's progress.

Regarding PG&E 21-22, GPI recommends Energy Safety add language to the issue description to align it with the evaluation of SCE and SDG&E's 2021 WMP Updates. Energy Safety agrees and has modified the issue description for PG&E-21-22 accordingly.

GPI made several other recommendations regarding VM. Energy Safety appreciates these other recommendations but has not incorporated them into this Final Action Statement.

9.4. Cal Advocates Comment Summary and Response

Cal Advocates' comments generally support Energy Safety's identified Key Areas for Improvement and associated Remedies, as well as many of the Additional Issues and Remedies.

Regarding System Hardening, Cal Advocates suggests revising the remedy for PG&E-21-09 to include further clarification of Energy Safety's intended oversight of the utilities in developing a consistent approach to evaluating the long-term risk reduction and cost-effectiveness of covered conductor deployment. Energy Safety will review the utilities' progress on this matter based on the November 1 progress reports and evaluate the need for oversight at this time.

Cal Advocates made some broader recommendations, including those relating to the change order process. Energy Safety appreciates these comments and will take them into consideration at the appropriate time. Regarding the change order process, Energy Safety will be publishing its final position shortly.

²¹⁹ Comments of the Green Power Institute on Draft Resolution WSD-021. p. 5.

²²⁰ Comments of the Green Power Institute on Draft Resolution WSD-021. p. 5.



10 CONCLUSION

PG&E's 2021 WMP Update is approved. However, PG&E must continue to improve its efforts to reduce wildfire risk and meet or exceed the efforts of peer utilities. PG&E must scale up the scope and pace of its wildfire mitigation efforts to match the scale of the risks it faces.

Catastrophic wildfires remain a serious threat to the health and safety of Californians. Electrical corporations, including PG&E must continue to make progress toward reducing utility-related wildfire risk. Through the approval of PG&E's 2021 WMP Update submission, Energy Safety expects PG&E to effectively implement its wildfire mitigation activities to reduce the risk of utility-related ignitions and the potential catastrophic consequences if an ignition occurs as well as to reduce the scale, scope, and frequency of PSPS events. PG&E must meet the commitments in its 2021 WMP Update and fully comply with the conditions listed in this Action Statement to ensure it is achieving a meaningful reduction of utility-related wildfire and PSPS risk within its service territory. Energy Safety expects that in the November 1, 2021, Progress Report PG&E will address all of the key areas of concern outlined in this Action Statement and undertake every effort necessary to accelerate a reduction in its wildfire risk.

Lucy Morgans

Acting Program Manager, Safety Policy Division
Office of Energy Infrastructure Safety



11 APPENDIX

11.1 Complete Table of 2021 Key Areas for Improvement and Remedies

| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|--|--|
| PG&E-21-01 | Unclear inclusion of future climate data into planning | PG&E’s 2021 WMP Update does not include PG&E’s climate resilience team’s evaluation of High Fire Risk Areas (HFRA) ²²¹ map initiatives in order to validate that the maps are consistent with climate projections. | PG&E must explain how it incorporates components of its climate resilience team’s report into its own risk assessment. |
| PG&E-21-02 | Lack of consistency in approach to wildfire risk modeling across utilities | The utilities do not have a consistent approach to wildfire risk modeling. For example, in their wildfire risk models, utilities use different types of data, use their individual data sets in different ways, and use different third-party vendors. Energy Safety recognizes that the utilities have differing service territory characteristics, differing data availability, and are at different stages in developing their wildfire risk models. However, the utilities face similar enough circumstances that there should be some level of consistency in statewide | <p>The utilities²²² must collaborate through a working group facilitated by Energy Safety²²³ to develop a more consistent statewide approach to wildfire risk modeling. After Energy Safety completes its evaluation of all the utilities’ 2021 WMP Updates, it will provide additional detail on the specifics of this working group.</p> <p>A working group to address wildfire risk modeling will allow for:</p> <ol style="list-style-type: none"> 1. Collaboration among the utilities; 2. Stakeholder and academic expert input; and 3. Increased transparency. |

²²¹ PG&E 2021 WMP Update at p. 85. PG&E identified areas of increased fire risk that are not currently included in the CPUC-designated HFTD and defined these as High Fire Risk Areas.

²²² Here “utilities” refers to SDG&E and Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), PacifiCorp, Bear Valley Electric Service, Inc. (BVES), and Liberty Utilities; although this may not be the case every time “utilities” is used through the document.

²²³ The WSD transitioned to the Office of Energy Infrastructure Safety (Energy Safety) on July 1, 2021.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|---|--|
| | | approaches to wildfire risk modeling. | |
| PG&E-21-03 | Inadequate speed of improvements made to risk modeling | PG&E self-reported a low risk assessment score in the Maturity Model with slower growth in comparison to the other two large investor-owned utilities (IOUs). While this seems to be largely due to lack of automation in many different areas, and while PG&E overhauled its modeling efforts between the 2020 and 2021 WMP submissions, PG&E fails to demonstrate growth at an adequate speed in regard to its risk assessment. | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it is applying automation as quickly as possible, explaining any constraints on progress. 2. Supply its workplan to enhance its modeling efforts. |
| PG&E-21-04 | PG&E does not adequately justify the wind speed inputs it uses in its Probability of Ignition models. | PG&E’s Outage Producing Winds (OPW) model finds a correlation between equipment failure and high wind speed. Despite the correlation, PG&E does not use peak wind speed as part of its input data set for its Equipment Probability of Ignition models. Instead, PG&E uses average wind speed. PG&E provides justification for its rationale in its Revision Notice Response, however inconsistencies remain between PG&E’s approach and that of its peer utilities that use peak or near-peak wind speeds as part of | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it appropriately accounts for wind speed in its Probability of Ignition models’ input data sets. This shall be handled both within the Working Group set up in PG&E-21-02, as well as an individualized report. 2. Address discrepancies between its input data sets and those of peer utilities. |



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|--|--|
| | | their Wildfire Risk Modeling input data sets. | |
| PG&E-21-05 | Lack of PSPS consequence model at a circuit-segment level | SCE and SDG&E both have functioning PSPS consequence models, while PG&E states that their PSPS consequence model is currently under development. ²²⁴ PG&E is working collaboratively with other California utilities and will complete the task by the second half of 2021. However, PG&E does not describe any specific efforts or progress regarding the development of the PSPS risk model. The incorporation of PSPS consequence risk into the total risk reduction of a mitigation initiative is crucial to the decision-making framework. | <p>PG&E must provide:</p> <ol style="list-style-type: none"> 1. A detailed update on the functionality of its PSPS consequence model at a circuit-segment level, and 2. Quantitative targets for any remaining work or future developments. |
| PG&E-21-06 | Insufficient transparency for modifications to Wildfire Risk Models and circuit segment prioritization | Revision Notice Critical Issue RN-PG&E-02 required PG&E to provide further justification of its shift in CPZ prioritization, including external validation and reviews. While PG&E provided the required justification within its response, it is critical for PG&E to continue to provide updates on its modeling | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Provide an update on progress made on each of the third-party’s recommendations. 2. Provide any and all updates to the explanation and timeline for how and when it intends to address the recommendations. 3. Provide an Excel spreadsheet detailing what changes have been made to its 2021 risk models since |

²²⁴ PG&E 2021 WMP Update Revision – Clean, p. 49.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|---|---|
| | | <p>efforts in order to maintain transparency between now and the 2022 WMP Update regarding its prioritization of circuit segments. Additionally, in its response to the Revision Notice, PG&E provided a third-party review of its 2021 Wildfire Distribution Risk Model. The third-party’s analysis included recommendations for PG&E to improve its Wildfire Risk Models.</p> | <p>the submission of its 2021 WMP Update. 4. Provide a description of any changes it has made to its circuit segment the prioritization as a result of changes to its risk model since the submission of its 2021 WMP Update.</p> |
| PG&E-21-07 | PG&E’s DFA and EFD technology pilot outcome is lacking justification for the scope of installment | <p>PG&E’s pilot project was completed in 2020 for Distribution Fault Anticipation (D) and Early Fault Detection (EFD) technology with the determination to continue deployment. However, PG&E lacks details and performance metrics on the outcome and how PG&E made the decision to ramp up deployment to 600-800 circuits.</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Provide details and performance metrics on the outcome of the 2020 DFA and EFD technology pilot program 2. Explain how the determination was made to increase deployments of DFA/EFD technology across its HFTD areas. |
| PG&E-21-08 | Weather station program target not met | <p>PG&E’s 2021 WMP Update originally reported installation of 404 weather stations in 2020, surpassing its program target of 400. However, in PG&E’s revised 2021 WMP Update the weather station installations changed to 378 in 2020</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Provide details on why PG&E did not meet the targeted 400 weather station installs in 2020. 2. Explain why weather station installation totals in the original 2021 WMP Update differ from the revised 2021 WMP Update. |



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|--|
| | | falling short of its target without explanation. | |
| PG&E-21-09 | Limited evidence to support the effectiveness of covered conductor | The rationale to support the selection of covered conductor as a preferred initiative to mitigate wildfire risk lacks consistency among the utilities, leading some utilities to potentially expedite covered conductor deployment without first demonstrating a full understanding of its long-term risk reduction and cost-effectiveness. The utilities’ current covered conductor pilot efforts are limited in scope ²²⁵ and therefore fail to provide a full basis for understanding how covered conductor will perform in the field. Additionally, utilities justify covered conductor installation by alluding to reduced PSPS risk but fail to provide adequate comparison to other initiatives’ ability to reduce PSPS risk. | The utilities ²²⁶ must coordinate to develop a consistent approach to evaluating the long-term risk reduction and cost-effectiveness of covered conductor deployment, including: 1. The effectiveness of covered conductor in the field in comparison to alternative initiatives. 2. How covered conductor installation compares to other initiatives in its potential to reduce PSPS risk. |
| PG&E-21-10 | Insufficient pace of expulsion fuse | The pace of PG&E’s current program for expulsion fuse | PG&E must: |

²²⁵ Limited in terms of mileage installed, time elapsed since initial installation, or both.

²²⁶ Here “utilities” refers to SDG&E and Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), PacifiCorp, Bear Valley Electric Service, Inc. (BVES), and Liberty Utilities; although this may not be the case every time “utilities” is used through the document.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|--|
| | replacement plan | replacements is not proportional to those of SDG&E and SCE. ²²⁷ This is especially problematic given PG&E’s larger service territory. | <ol style="list-style-type: none"> 1. Demonstrate that it is replacing expulsion fuses with fuses that reduce wildfire risk at a speed that adequately addresses risk; 2. Explain any current limits or constraints on the scope of PG&E’s expulsion fuse replacement program; 3. Increase the pace of its expulsion fuse replacement program, provided reasonable constraints do not limit such expansion. |
| PG&E-21-11 | Insufficient detail regarding installation of expulsion fuses in HFTD areas | PG&E continues to install non-exempt expulsion fuses, which are considered to be fire hazards, in HFTD areas. PG&E installed approximately 71 non-exempt expulsion fuses in the HFTD 2019 and 44 fuses in 2020. PG&E states that it is acceptable to install non-exempt expulsion fuses in the HFTD under certain circumstances but does not detail whether the installed fuses were installed in those circumstances. | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Explain the circumstances under which it installed non-exempt expulsion fuses in HFTD areas. 2. Clarify if any of the new expulsion fuses it is installing in the HFTD in 2021 and beyond are non-exempt fuses. |

²²⁷ Cal Advocates’ Comments state at p. 36: “PG&E has approximately 22,000 expulsion fuses in HFTDs and forecasts replacing about five percent of them in 2021” which is approximately 1,100 fuses. At this rate, it will take PG&E nearly two decades to remove all the expulsion fuses from the HFTD. By comparison, BVES replaced 2,200 in 2020, which is more expulsion fuses than PG&E in 2020, although PG&E’s service territory is two thousand times larger than BVES. In 2021, SDG&E replaced “3,179 (with a focus in Tiers 3 and 2 of the HFTD), bringing the total replaced to 5,669 out of the 11,000 total populations of such fuses in the HFTD” (according to SDG&E’s 2021 WMP Update, p. 197). SCE is replacing “13,000 locations by the end of 2022 (cumulative from the inception of the program in 2018)” (according to SCE’s 2021 WMP Update, p. 216).



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|---|
| PG&E-21-12 | Failure to adequately track copper conductor replacements and insufficient detail regarding targeting replacements to highest risk areas | While PG&E has identified that copper conductor poses a high risk to its system due to its high incidence of failure PG&E does not currently track its completed copper reconductoring projects. Additionally, PG&E's copper reconductoring program extends outside of the HFTD, but PG&E does not provide sufficient evidence that its copper reconductoring plan targets its highest risk circuits. | PG&E must: 1. Develop a workplan to target and track copper reconductoring projects. 2. Demonstrate that it is targeting its copper reconductoring projects to its highest risk circuits, including justification for any projects outside of the HFTD. |
| PG&E-21-13 | Failure to demonstrate that system hardening plan targets highest risk circuit segments | A small percentage of circuit-segments in PG&E's distribution system pose a high percentage of PG&E's wildfire risk. ²²⁸ However, PG&E does not clearly demonstrate that its system hardening plan targets these segments. | PG&E must fully demonstrate that its system hardening mitigation efforts target efficiently reducing wildfire risk and PSPS events, including a description of how PG&E determines the order in which circuit segments are scheduled for mitigation. |
| PG&E-21-14 | Inadequate transparency of system hardening plan | PG&E provides limited detail regarding its short-term system hardening plan and does not include its long-term system hardening plan. Additionally, PG&E's July | PG&E must: 1. Provide its short-term ²³⁰ system hardening plans, including the following details for each planned project (via comprehensive list and GIS files): a. Location; b. Initiative type (covered conductor, |

²²⁸ "2021 Wildfire Mitigation Plan Workshop Grid Design and System Hardening" presented February 23, 2021, p. 4.

²³⁰ "Short-term" defined as a project that has entered the scoping process or planning phase, including the 1,120 miles identified for system hardening from 2021-2023, per PG&E's Redlined 2021 WMP Update, pdf p. 653.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|-----------|-------------|--|--|
| | | <p>21, 2021, press release²²⁹ regarding its intention to underground 10,000 miles of power lines indicates that the system hardening plan and initiative selection process that PG&E presents in its 2021 WMP Update may change. PG&E has not provided any potential modifications to its 2021 WMP Update related to this press release. While Energy Safety is generally supportive of PG&E’s ambition to aggressively reduce its wildfire risk, PG&E must provide additional detail on its short-term and long-term plans for grid hardening, as well as an update on its progress.</p> | <p>undergrounding, line removal, etc.);</p> <ul style="list-style-type: none"> c. Status of the project (scoping, design permitting, etc.); d. Relevant CPZs; e. Planned length; f. Risk-type identified for prioritization of the project (top 20 percent of risk buydown curve, fire rebuild, PSPS mitigation, public safety specialist identified, or non-risk related). <p>2. Provide its long-term system hardening plan regarding:</p> <ul style="list-style-type: none"> a. Estimated rate of system hardening per year;²³¹ b. If/how PG&E plans to increase its resources to allow for an accelerated pace of system hardening. <p>3. Explain how, if at all, PG&E’s recently announced undergrounding plan:</p> <ul style="list-style-type: none"> a. Changes its decision-making framework for initiative selection for individual circuit segments;²³² |

²²⁹ “PG&E Announces Major New Electric Infrastructure Safety Initiative to Protect Communities From Wildfire Threat,” July 21, 2021: <https://investor.pgecorp.com/news-events/press-releases/press-release-details/2021/PGE-Announces-Major-New-Electric-Infrastructure-Safety-Initiative-to-Protect-Communities-From-Wildfire-Threat/default.aspx> (accessed July 28, 2021).

²³¹ If such differs from the 450 to 500 miles per year provided in PG&E’s Redlined 2021 WMP Update, pdf p. 653.

²³² As described in PG&E’s presentation to WSD on May 21, 2021 and summarized in a footnote above.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|--|
| | | | <p>b. May cause delays, deferrals, and/or cancellation of research and/or deployment of advanced technology mitigations.</p> <p>4. Provide an update on its completed system hardening efforts through November 1, 2021.</p> <p>5. Additionally, if PG&E is moving forward with its stated intention to underground 10,000 miles of power lines, PG&E must provide detail in its 2022 WMP Update on the decision to underground and plans for such undergrounding.</p> |
| PG&E-21-15 | Insufficient detail regarding covered conductor maintenance | <p>PG&E states “[c]overed conductor maintenance will be performed anywhere covered conductor is installed and found to have conditions requiring maintenance.”²³³ PG&E does not provide more detail as to what conditions require maintenance. PG&E also does not explain or justify its spend projections for covered conductor maintenance. PG&E’s projected spend for covered conductor maintenance is higher in 2021 than in 2022, however the projected line</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Provide its procedures for determining when covered conductor maintenance is required, including any thresholds and aspects analyzed during inspections. 2. Explain why PG&E’s cost projections decrease from 2021 to 2022 despite line mile projections remain the same. |

²³³ PG&E 2021 WMP Update, p. 479.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|--|---|
| | | miles to be treated remain the same. ²³⁴ | |
| PG&E-21-16 | Insufficient evidence of effective covered conductor maintenance program | PG&E does not have a separate covered conductor maintenance program. | <p>PG&E must provide all supporting material to demonstrate that its maintenance programs effectively maintain its covered conductor, including the following information:</p> <ol style="list-style-type: none"> 1. Pace and quantity of scheduled maintenance; and 2. Pace and quantity of inspections. <p>If PG&E finds that its existing maintenance programs do not provide effective maintenance for covered conductor, PG&E must:</p> <ol style="list-style-type: none"> 1. Enhance its current operations to provide such maintenance; 2. Detail the enhancements to its existing programs; and 3. Provide all supporting material for the enhancements to its existing program, including the information listed above. |
| PG&E-21-17 | Insufficient evidence of QA/QC for work performed by contractors | Several PG&E internal audits revealed contractors that failed to follow procedures or were unaware of the correct procedures that needed to be followed. PG&E’s response to cases where the vendor was unaware of or did not follow procedures often | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Demonstrate that it is tracking the quality of work of contractors performing asset management and inspection work. 2. Describe how it is addressing underperforming asset management and inspection contractors. |

²³⁴ PG&E Table 12, Line 40.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|---|
| | | <p>amounted to a reminder of how procedures should have been followed. In most cases, PG&E did not further investigate the quality of other work the same vendor had performed, nor require full retraining on the topic.</p> | <p>3. Describe how it is expanding quality control of work performed by asset management and inspection vendors, including additional quality controls for those with a history of flawed work.</p> |
| PG&E-21-18 | Minimally planned maturity of VM program | <p>PG&E has increased the scale of its VM program but does not foresee maturing five of six VM Maturity Model capabilities. PG&E’s planned end WMP cycle VM maturity is 1, up from 0.7 in 2020. Comparatively, SCE and SDG&E have a planned end WMP cycle VM maturities of 3 and 3.3 respectively (see Figure 5.3.5a, below). Additionally, PG&E does not provide adequate discussions in the reoccurring subsection “5. Future improvements to initiative” nor in response to Quarterly Report Action PGE-25 (Class B), subpart 1. PG&E must create a long-term VM maturation strategy and establish clear goals and targets to prioritize work and monitor progress towards its risk-reduction goals.</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Reach a maturity of at least 1 for capabilities 24 “Vegetation grow-in mitigation” and 25 “Vegetation fall-in mitigation” by the end of 2023. 2. Clearly define goals and targets to reach each level of maturity for capabilities 21-26. 3. Include a timeline for completion of the goals and targets from (1). 4. Provide a long-term vision for each VM initiative in Subsection 5 “Future improvements to the initiative” (or similar) including any relevant timelines. |



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|--|
| PG&E-21-19 | Delays in achieving mutually agreeable environmental mitigation | PG&E cites delays in reaching mutually agreeable environmental and community impact mitigation efforts that “in certain situations,” ²³⁵ result in PG&E seeking court orders. ²³⁶ These delays, judicial or otherwise, can compromise working relationships between the community and state and local environmental agencies and cause further delays to WMP initiatives. | PG&E must show progress on achieving environmental and community impact mitigation agreements with agencies, local governments, and tribal governments. This includes establishing and documenting regularly scheduled meetings between relevant parties to identify permit requirements and potential environmental and community impacts from vegetation management prior to commencement of work. Meeting cadence shall be appropriately in advance of permit applications and scheduled work. PG&E must consider the development of Operations and Maintenance Plans and Memorandums of Understandings with relevant federal, state, and local land managing agencies to facilitate agreed-upon review times of permits and/or vegetation management activities. PG&E must document the outcomes of these efforts and any lessons learned. |
| PG&E-21-20 | Non-inclusion of fire damage attributes in hazard tree assessments | In DR WSD_011, WSD asked PG&E whether fire impact characteristics (char, scorch, etc.) were included in PG&E’s Tree Assessment Tool (TAT). PG&E stated that the TAT “does not include post-fire | PG&E must: 1. Clarify what tool or standard PG&E and its contractors use in post-wildfire response circumstances for hazard tree assessments; |

²³⁵ PG&E 2021 WMP Update Revision – Clean, p. 691.

²³⁶ PG&E 2021 WMP Update Revision – Clean, p. 691.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|-----------|-------------|--|--|
| | | <p>specific factors such as char, etc. This tool was not developed for, or intended to be used in, post-wildfire response circumstances. When wildfires occur, PG&E performs a hazard tree assessment of the burned area to determine whether trees pose a threat to electric assets and if they should be abated.” Contradictorily, PG&E specifically defines the TAT in its WMP as a “Tool that evaluates an individual tree’s likelihood of failing and supplies instruction of whether to abate or not abate the tree.” It is unclear whether PG&E has another tool, other than its TAT, it uses to perform hazard tree assessments in post-wildfire response circumstances or whether it uses no tool or standard assessment for hazard tree assessments in post-wildfire response circumstances.</p> | <p>2. If such a tool or standard does not already include post-fire specific factors (e.g., crown, bole, and root scorch, char, duff consumption²³⁷). PG&E must include these factors in such tool or standard.</p> <p>3. If such a tool or standard does not exist, PG&E shall develop one to use in post-wildfire response circumstances.</p> <p>4. Provide the training to its staff and contractors in post-fire tree assessments.</p> <p>5. Use such a tool during PG&E’s Phase 2 “Non-Imminent Hazard Trees” post-wildfire response.²³⁸ PG&E should use such a tool during Phase 1 “Imminent Threat Inspection” as feasible.</p> |

²³⁷ *Factors Affecting Survival of Fire Injured Trees: A Rating System For Determining Relative Probability of Survival of Conifers in the Blue and Wallowa Mountains*, United States Forest Service, November 25, 2002.

²³⁸ Phase 2 “Non-Imminent Hazard Trees” is described in “WSD-001 Glass Fire,” response received March 1, 2021: Under PG&E’s emergency operations protocols, there are two phases of vegetation management inspections. The duration of each phase will vary due to timeline dependencies such as CAL FIRE clearance/accessibility, availability of pre-inspectors and the volume of damage or fire footprint. Phase 1 - Imminent Threat Inspection: Inspect and eliminate any tree that is actively failing and identify trees that will need to be removed by construction crews to support reconstruction work to restore power. Phase 2 - Non-Imminent Hazard Trees: Listing non-immediate hazard trees for work; this can be done in parallel with Phase 1 if inspectors are available.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|--|--|
| PG&E-21-21 | Unknown environmental impact and efficacy of PG&E’s Preventative Fire Retardant Program (PFRP) | PG&E plans to undertake a review of fire-retardant chemicals ahead of the 2021 wildfire season to pilot under its Utility Defensible Space (UDS) program “pre-treat[ing] ROWs and around equipment in select locations to limit a spark from causing an ignition.” ²³⁹ In PG&E’s 2021 WMP Update, it had not determined a long-term plan for this initiative, considering it a pilot, and had no set targets (e.g., number of circuit miles or acres to be treated with retardant). However, on August 30, 2021, PG&E informed Energy Safety it has been “applying preventative fire retardant on poles and underneath powerlines in high risk areas to reduce the potential of a catastrophic wildfire” to “81 pilot [circuit] miles” ²⁴⁰ as part of its Preventative Fire Retardant Program (PFRP). Fire retardant is typically used as an emergency | <p>PG&E must provide:</p> <ol style="list-style-type: none"> 1. Its review²⁴¹ of fire-retardant that includes the following: product toxicological and environmental analysis; efficacy analysis; environmental planning and permitting assessment; and the scope of use. 2. A report on the objectives and execution of its PFRP in 2021 and its PFRP plan for 2022. 3. Quarterly reports regarding the deployment of fire-retardant to the Compliance Division of OEIS per CPUC approved Compliance Operational Protocols.²⁴² These reports must include where and when the retardant was used, how much retardant was used, and the specific fire-retardant that was used. 4. An RSE valueits PFRP. |

²³⁹ PG&E 2021 WMP Update Revision – Clean, p. 706.

²⁴⁰ Presentation to the Office of Energy Infrastructure Safety and the CPUC’s Safety Enforcement Division from PG&E titled “Public Safety Measures: Addressing Extreme Drought”, August 6, 2021.

²⁴¹ PG&E 2021 WMP Update Revision – Clean, p. 705.

²⁴² Wildfire Safety Division – Compliance Operational Protocols, February 16, 2021: <https://energysafety.ca.gov/wp-content/uploads/docs/misc/wsd/2021.02.16-compliance-operational-protocols.pdf>.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|---|--|
| | | <p>measure applied in front of imminent fire and the efficacy and environmental impact of PG&E’s PFRP are unknown.</p> | |
| PG&E-21-22 | <p>Incomplete identification of vegetation species and record keeping</p> | <p>In Table PG&E-7.3.5-6 on p. 666, PG&E reports that “Oak” and “Pine” are species that have caused >1 percent of several regions’ outages. However, these are not tree species, but tree genera. PG&E needs to ensure proper identification of trees to the species level. This specificity will ensure that the “regional species risk values”²⁴³ input to its TAT are updated and accurate. While PG&E does not currently prescribe tree-work based on specific species,²⁴⁴ it may choose to do so in the future; in this case, accurate recordkeeping of the species designation is essential.</p> | <p>PG&E must:</p> <ol style="list-style-type: none"> 1. Use scientific names in its reporting (as opposed to common names). This change will be reflected in the upcoming updates to Energy Safety GIS Reporting Standard. 2. Add genus and species designation input capabilities into its systems which track vegetation (e.g., vegetation inventory system and vegetation-caused outage reports). 3. Identify the genus and species of a tree that has caused an outage²⁴⁵ or ignition²⁴⁶ in the Quarterly Data Reports (QDRs) (in these cases, an unknown “sp.” designation is not acceptable). 4. If the tree’s species designation is unknown (i.e., if the inspector knows the tree as “Quercus” but is unsure whether the tree is, for example, Quercus kelloggii, Quercus lobata, or Quercus agrifolia), it must be recorded as such. Instead of simply “Quercus,” use “Quercus sp.” If referencing |

²⁴³ PG&E 2021 WMP Update, p. 667.

²⁴⁴ PG&E 2021 WMP Update, p. 667.

²⁴⁵ WSD GIS Data Reporting Standard Version 2, Transmission Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.5 & Distribution Vegetation Caused Unplanned Outage (Feature Class), Section 3.4.7.

²⁴⁶ WSD GIS Data Reporting Standard Version 2, Ignition (Feature Class), Section 3.4.3.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|---|
| | | | <p>multiple species within a genus use “spp.” (e.g., Quercus spp.).²⁴⁷</p> <p>5. Teach tree species identification skills in its VM personnel training programs, both in initial and continuing education.</p> <p>6. Encourage all VM personnel identify trees to species in all VM activities and reporting, where possible.</p> |
| PG&E-21-23 | Inadequate joint plan to study the effectiveness of enhanced clearances | RCP Action-PGE-35 ²⁴⁸ (Class A) required PG&E, SCE, and SDG&E to “submit a joint, unified plan” to begin a study of the effectiveness of extended vegetation clearances. PG&E submitted its plan to study the effectiveness of extended vegetation clearance as part of its February 26, 2021, “Supplemental Filing Addressing Remedial Compliance Plan and First Quarterly Report Action Items.” PG&E, SCE, and SDG&E presented the “joint, unified” plan to Energy Safety on February 18, 2021. While it was apparent the three large | <p>PG&E, SCE, and SDG&E will participate in a multi-year vegetation clearance study. Energy Safety will confirm the details of this study in due course. The objectives of this study are to:</p> <ol style="list-style-type: none"> 1. Establish uniform data collection standards. 2. Create a cross-utility database of tree-caused risk events (i.e., outages and ignitions caused by vegetation contact). 3. Incorporate biotic and abiotic factors²⁴⁹ into the determination of outage and ignition risk caused by vegetation contact. 4. Assess the effectiveness of enhanced clearances. <p>In preparation for this study and the eventual analysis, PG&E must</p> |

²⁴⁷ Jenks, Matthew A. (undated, from 2012 archived copy), “Plant Nomenclature,” Department of Horticulture and Landscape Architecture, Purdue University, accessed May 18, 2021.

²⁴⁸ Wildfire Safety Division Evaluation of Pacific Gas and Electric Company’s Remedial Compliance Plan can be found here (accessed August 2, 2021):

<https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/pge-rcp-action-statement-20201230.pdf>

²⁴⁹ Biotic factors include all living things (e.g., an animal or plant) that influence or affect an ecosystem and the organisms in it; abiotic factors include all nonliving conditions or things (e.g., climate or habitat) that influence or affect an ecosystem and the organisms in it.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|---|
| | | <p>utilities had discussed a unified approach, each utility presented differing analyses that would be performed to measure the effectiveness of enhanced clearances. This presentation’s content was not included in the February 26, 2021, “Supplemental Filing Addressing Remedial Compliance Plan and First Quarterly Report Action Items.”</p> <p>Energy Safety acknowledges the complexity of this issue; any study performed assessing the effectiveness of enhanced clearances will take years of data collection and rigorous analysis.</p> | <p>collect the relevant data; the required data are currently defined by Energy Safety Geographic Information System (GIS Data Reporting Standard for California Electrical Corporations - V2). Table 2 in Section 5.5 of this Action Statement outlines the feature classes which Energy Safety believes will be most relevant to the study. Energy Safety will also be updating the GIS Reporting Standards in 2021, which may include additional data attributes for vegetation-related risk events.</p> |
| PG&E-21-24 | Need for quantified vegetation management (VM) compliance targets | <p>In Table 12, PG&E only defines quantitative targets for six of 20 VM initiatives. Energy Safety is statutorily required to audit PG&E when a “substantial portion” of PG&E’s VM work is complete,²⁵⁰ without quantifiable targets in the WMP and subsequent reporting on those targets in the Quarterly Data Report (QDR) and</p> | <p>PG&E must define quantitative targets for all VM initiatives. If quantitative targets are not applicable to an initiative, PG&E must fully justify this, define goals within that initiative, and include a timeline in which it expects to achieve those goals.</p> |

²⁵⁰ Pub. Util. Code § 8386.3(c)(5)(A).



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|---|
| | | <p>Quarterly Initiative Update (QIU), Energy Safety cannot fully realize its statutory obligations.</p> | |
| PG&E-21-25 | <p>Lack of specificity regarding how increased grid hardening will change system operations, change PSPS thresholds, and reduce PSPS events</p> | <p>PG&E does not commit to changes in its PSPS thresholds for increased grid hardening. PG&E does not specify how increased grid hardening will change system operations.</p> | <p>For each mitigation alternative, including pilot program initiatives, PG&E must provide quantitative analysis on:</p> <ol style="list-style-type: none"> 1. Changes in system operations. 2. Changes in PSPS thresholds. 3. Estimated changes in the frequency, duration, and number of customers impacted by PSPS events. |
| PG&E-21-26 | <p>Inadequate discussion on impact of RSEs in initiative selection</p> | <p>PG&E does not clearly explain how RSE estimates impact the initiative selection process. RSE estimates provide a pathway to assess the relative benefit provided by the mitigation initiatives and must play an integral role in the selection process. Energy Safety understands the dynamic nature of initiative selection due to work management efficiencies, operational realities, resource constraints, and other factors. However, a clear description of how RSE estimates impact the selection process must be provided to ensure consistency across initiatives.</p> | <p>PG&E must provide an overview of its decision-making framework to include a clear explanation of how RSE estimates impact decision making for initiative selection. The overview must show the rankings of the relative decision-making factors (e.g., planning and execution lead times, resource constraints, etc.) and pinpoint where quantifiable risk reductions and RSE estimates are considered in the initiative selection process. Energy Safety recommends a cascading, dynamic “if-then” style flowchart to effectively demonstrate this prioritization process and satisfy this requirement.</p> |



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|---|--|--|
| PG&E-21-27 | Lack of methodology to verify RSE estimates | <p>For capability 41c of the 2021 Maturity Survey, PG&E showed no planned progress by selecting “Utility does not verify RSE estimates” for the years 2020 - 2023. In order to rely on RSEs to select mitigation initiatives, PG&E must have high confidence that the calculated RSEs are accurate. Moreover, for capability 40a of the 2021 Maturity Survey PG&E selected “Utility has accurate relative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate.” Without a verification process, the utility cannot guarantee reliability of RSE estimations. PG&E must develop a methodology to assess the accuracy of its RSE estimates. Comparatively SCE and SDG&E can, at a base level, verify their calculated RSEs with historical and experimental pilot data.</p> | PG&E must provide a detailed RSE verification plan with attainable benchmarks and timeline. |
| PG&E-21-28 | RSE values vary across utilities | Energy Safety raises a concern that there are stark variances in RSE estimates, sometimes on several orders of | The utilities ²⁵⁴ must collaborate through a working group facilitated by Energy Safety ²⁵⁵ to develop a more standardized approach to the |

²⁵⁴ Here “utilities” refers to PG&E, San Diego Gas & Electric (SDG&E), Southern California Edison Company (SCE).

²⁵⁵ The WSD transitioned to the Office of Energy Infrastructure Safety (Energy Safety) on July 1, 2021.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|------------|--|---|--|
| | | <p>magnitude, for the same initiatives calculated by different utilities. For example, PG&E’s RSE for covered conductor installation was 4.08,²⁵¹ SDG&E’s RSE was 76.73,²⁵² and SCE’s RSE was 4,192.²⁵³ These drastic differences reveal that there are significant discrepancies between the utilities’ inputs and assumptions, which further support the need for exploration and alignment of these calculations.</p> | <p>inputs and assumptions used for RSE calculations. After Energy Safety completes its evaluation of the 2021 WMP Updates, it will provide additional detail on the specifics of this working group.</p> <p>This working group will focus on addressing the inconsistencies between the utilities’ inputs and assumptions, used for their RSE calculations, which will allow for:</p> <ol style="list-style-type: none"> 1. Collaboration among utilities; 2. Stakeholder and academic expert input; and 3. Increased transparency. |
| PG&E-21-29 | PSPS targets and projections set to expire | <p>PG&E states that its PSPS approach will likely change in August 2021. When PG&E updates its approach, the PSPS targets and projections presented in its WMP Update and Revision Notice response will become obsolete.</p> | <p>As soon as practicable, PG&E must submit a Change Order Report:²⁵⁶</p> <ol style="list-style-type: none"> 1. Describing in full and complete detail its updated PSPS protocols. 2. Showing how its updated PSPS protocols affect PSPS projections (Table 11). 3. Showing how its updated PSPS protocols affect all quantitative and qualitative targets for reducing the scale, scope, and frequency of PSPS. |

²⁵¹ Value from PG&E’s Errata (dated March 17, 2021, accessed May 19, 2021:

https://www.pge.com/pge_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/2021-Wildfire-Safety-Plan-Errata.pdf

²⁵² Value from Table 12 of SDGE’s 2021 WMP Update submissions under the “Estimated RSE for HFTD Tier 3” column for “Covered Conductor Installation.”

²⁵³ Value from Table 12 of SCE’s 2021 WMP Update submissions under the “Estimated RSE for HFTD Tier 3” column for “Covered Conductor Installation.”

²⁵⁶ This reporting requirements do not replace or amend any reporting or other obligations that may be imposed on PG&E by the CPUC, including CPUC Resolution M-4856 associated with PG&E’s new considerations of tree overstrike factors into its PSPS protocols.



| Utility-# | Issue title | Issue description | Remedies required and alternative timeline if applicable |
|-----------|-------------|-------------------|---|
| | | | Meeting all requirements for a Change Order Report set out in section 7 of this Action Statement. |

11.2 Status of 2020 WMP Deficiencies

The 2020 WMP Resolutions for each utility contained a set of “Deficiencies” and associated “Conditions” to remedy those issues. Each issue was categorized into one of the following classes, with Class A being the most serious:

- Class A – aspects of the WMP are lacking or flawed;
- Class B – insufficient detail or justification provided in the WMP;
- Class C – gaps in baseline or historical data, as required in the 2020 WMP Guidelines.

Class A deficiencies were of the highest concern and required a utility to develop and submit to Energy Safety a Remedial Compliance Plan (RCP) to resolve the identified issue within 45 days of Commission ratification of the Resolution. Class B deficiencies were of medium concern and required reporting by the utility to provide missing data or a progress update in its Quarterly Report. Such reporting was either on a one-time basis or ongoing as set forth in each condition. Class C deficiencies required the utility to submit additional detail and information or otherwise come into compliance in its following annual WMP Update. Detailed descriptions of the RCP and quarterly reports are contained in Resolution WSD-002, the Guidance Resolution on Wildfire Mitigation Plans.²⁵⁷

Deficiencies have either been resolved or are folded into 2021 issues, as detailed in the table below.

| Deficiency | Description | WSD-003 Determination | Status |
|---------------------|--|-----------------------|---|
| Guidance 1, Class B | Lack of risk spend efficiency (RSE) information | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| Guidance 2, Class B | Lack of alternatives analysis for chosen initiatives | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| Guidance 3, Class A | Lack of risk modeling to inform decision-making | Insufficient | Conditions met, resolved |

²⁵⁷ Guidance Resolution WSD-002 can be found here (accessed July 23, 2021): <https://energysafety.ca.gov/wp-content/uploads/docs/wmp-2020/docs/340859823.pdf>



| Deficiency | Description | WSD-003 Determination | Status |
|-------------------------|---|----------------------------------|---|
| Guidance 4, Class B | Lack of discussion on PSPS impacts | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| Guidance 5, Class B | Aggregation of initiatives into programs | Sufficient | Conditions met, resolved |
| Guidance 6, Class B | Failure to disaggregate WMP initiatives from standard operations | Sufficient | Conditions met, resolved |
| Guidance 7, Class B | Lack of detail on effectiveness of “enhanced” inspection programs | Insufficient | Conditions met, resolved |
| Guidance 8, Class C | Prevalence of Equivocating Language – failure of commitment | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| Guidance 9, Class B | Insufficient discussion of pilot programs | Insufficient | Conditions met, resolved |
| Guidance 10, Class B | Data issues - general | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| Guidance 11, Class B | Lack of detail on plans to address personnel shortages | Insufficient | Conditions met, resolved |
| Guidance 12, Class B | Lack of detail on long-term planning | Insufficient | Conditions not met, wrapped into a new issue for 2021 (bulleted, not boxed) |
| PG&E-1, Class A | PG&E groups initiatives into programs and does not provide granular initiative detail | Insufficient | Conditions met, resolved |
| PG&E-2, Class B | Equipment failure | Insufficient | Conditions not met, wrapped into a new issue for 2021 (bulleted, not boxed) |
| PG&E-3, Class A | High incidence of conductor failure | Insufficient | Conditions not met, wrapped into a new issue for 2021 |



| Deficiency | Description | WSD-003 Determination | Status |
|---------------------|---|----------------------------------|--|
| PG&E-4, Class C | Capacitor bank failure | Insufficient | Conditions not met, wrapped into a new issue for 2021 (bulleted, not boxed) |
| PG&E-5, Class B | PG&E provides little discussion of how it uses the results of relative risk scoring method | Insufficient | Conditions met, resolved |
| PG&E-6, Class B | Discrepancy between ignition reduction projections | Sufficient | Conditions met, resolved |
| PG&E-7, Class B | It is not clear if PG&E’s line risk scoring sufficiently incorporates all risks that cause ignition and PSPS | Insufficient | Conditions met, resolved |
| PG&E-8, Class A | Annual risk ranking is quickly out of date | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| PG&E-9, Class B | How PG&E weighs egress as a risk factor | Insufficient | Conditions not met, progress being monitored |
| PG&E-10, Class B | PG&E lacks sufficient weather station coverage | Insufficient | Conditions met, resolved |
| PG&E-11, Class B | Including additional relevant reports | Sufficient | Conditions met, resolved |
| PG&E-12, Class B | PG&E’s fuse replacement program planned to take 7 years | Insufficient | Conditions not met, wrapped into a new issue for 2021 |
| PG&E-13, Class B | PG&E does not explain how the factors limiting microgrid deployment will impact its microgrid plans | Insufficient | Conditions met, resolved |
| PG&E-14, Class B | Level 3 findings | Insufficient | Conditions met, resolved |



| Deficiency | Description | WSD-003 Determination | Status |
|-------------------|--|------------------------------|--|
| PG&E-15, Class A | It is unclear how PG&E classifies findings at the appropriate level | Insufficient | Conditions met, resolved |
| PG&E-16, Class C | PG&E’s record keeping is deficient | Insufficient | Conditions not met, progress being monitored |
| PG&E-17, Class B | Effectiveness of inspections using infrared technology | Insufficient | Conditions met, resolved |
| PG&E-18, Class B | PG&E does not describe in detail how its hazard tree analysis focuses on at-risk trees. | Insufficient | Conditions met, resolved |
| PG&E-19, Class B | Low pass rate on EVM QA | Insufficient | Conditions met, resolved |
| PG&E-20, Class B | PG&E is redistributing resources to focus more on transmission clearances | Insufficient | Conditions met, resolved |
| PG&E-21, Class B | PG&E fails to describe why additional programs for transmission clearances are necessary | Insufficient | Conditions met, resolved |
| PG&E-22, Class B | Some of PG&E’s vegetation management inspectors may lack proper certification | Insufficient | Conditions met, resolved |
| PG&E-23, Class B | Vegetation waste and fuel management processes unclear | Insufficient | Conditions met, resolved |
| PG&E-24, Class B | Improving prioritization | Insufficient | Condition not met, wrapped into a new issue for 2021 |
| PG&E-25, Class A | Lack of details in PG&E’s WMP on how to address personnel shortages | Insufficient | Conditions met, resolved |



| Deficiency | Description | WSD-003 Determination | Status |
|---------------------|---|-----------------------|--|
| PG&E-26, Class A | Effectiveness of increased vegetation clearances | Insufficient | Condition not met, wrapped into a new issue for 2021 |
| PG&E-27, Class A | Public safety partner coordination | Insufficient | Conditions met, resolved |
| PG&E-28, Class B | Lack of justification and detail for PG&E's self-assessed stakeholder engagement capabilities | Sufficient | Conditions met, resolved |
| PG&E-29, Class B | Cooperation and sharing of best practices | Sufficient | Conditions met, resolved |



12 ATTACHMENTS

Attachment 1: PG&E's 2021 Maturity Survey

PG&E: Description of Data Sources

Data related to the Maturity Model is based on the latest submitted versions of 2021 Utility Wildfire Mitigation Maturity Survey (“Survey”) as of May 5, 2021. Data for the Maturity Model is pulled from Survey responses unless stated otherwise.

All source data (the WMP and the Survey responses) are available at:

<https://energysafety.ca.gov/what-we-do/wildfire-mitigation-and-safety/wildfire-mitigation-plans/2021-wmp/>.

All the analysis and corresponding tables presented in this appendix rely upon data that is self-reported by the utilities. By using and presenting this self-reported data in this appendix, Energy Safety is not independently validating that all data elements submitted by utilities are accurate. Energy Safety will continue to evaluate utility data, conduct data requests, and conduct additional compliance activities to ensure that data provided is accurate.

PG&E: Introduction to Maturity Model Scoring²⁵⁸

In order to determine “maturity” in any one capability, Energy Safety assigned levels to each aspect of the electrical corporations’ wildfire mitigation efforts. Each capability was assigned a level, from 0 – 4 range, with 0 being the lowest and 4 the highest. Energy Safety calculated a maturity level, in accordance with the required elements to achieve each level, as outlined in the Maturity Model rubric.

The levels were calculated using an “all or nothing” binary approach. That is, levels are reported as whole numbers only.²⁵⁹ Thus, in order to reach a specific maturity level, an electrical corporation would have to meet 100 percent of the threshold requirements for that level, as detailed in the maturity model rubric. In general, the Maturity Model rubric outlines numerous elements that are required to be met to achieve a given level, and the sophistication of requirements to reach a level typically increases with each successively higher maturity level.

For example, to obtain a level of 1 in capability 24 of the 52 total capabilities, titled “Vegetation grow-in mitigation,” the electrical corporation (or utility) must demonstrate

²⁵⁸ From WSD-002 p. 10-11

²⁵⁹ Note: The category averages shown in 11.1.3 (below) average the capability scores and may include decimals.



the following: “[u]tility maintains vegetation around lines and equipment according to minimum statutory and regulatory clearances. Utility: i) removes vegetation waste along right of ways and ii) within 1 week of cutting vegetation across entire grid.”

Thus, in order to receive a maturity level of 1 for capability 24, an electrical corporation would not only have to maintain minimum regulatory clearances around its overhead lines but also remove the vegetation waste along its right of ways within one week of conducting vegetation clearance work. If an electrical corporation meets only one of these requirements, then it would be assigned the next lowest level. In this example, a level of 0 would be assigned and the electrical corporation would not receive “partial credit” toward a level of 1.



PG&E: Maturity detail by capability

Legend: *Maturity Model Scores*



Category A. Risk Assessment and Mapping

| | | | |
|--|--|--|---|
| | Avg cycle start maturity: 0 | Avg current maturity: 0 | Avg projected cycle end maturity: 1.2 |
| Capability 1. Climate scenario modeling | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 1a: How sophisticated is utility's ability to estimate the risk of weather scenarios? | i. No clear ability to understand incremental risk under various weather scenarios | i. No clear ability to understand incremental risk under various weather scenarios | ii. Wildfire risk can be reliably determined based on weather and its impacts |
| 1b: How are scenarios assessed? | i. No formal assessment process | i. No formal assessment process | ii. Independent expert assessment |
| 1c: How granular is utility's ability to model scenarios? | ii. Regional | ii. Regional | iii. Circuit-based |
| 1d: How automated is the tool? | i. Not automated | i. Not automated | i. Not automated |
| 1e: What additional information is used to estimate model weather scenarios and their risk? | i. None | ii. Weather, how weather effects failure modes and propagation | iv. Weather measured at the circuit level, how weather effects failure modes and propagation, existing hardware |



| | | | |
|---|--|--|---|
| 1f: To what extent is future change in climate taken into account for future risk estimation? | i. Future climate change not accounted for in estimating future weather and resulting risk | i. Future climate change not accounted for in estimating future weather and resulting risk | ii. Future risk estimates take into account generally higher risk across entire service territory due to changing climate |
|---|--|--|---|

Capability 2. Ignition risk estimation

| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 1 (projected) |
|--|-------------------|-------------------------------|--|
|--|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|--|--|--|---|
| 2a: How is ignition risk calculated? | ii. Tools and processes can reliably categorize the risk of ignition across the grid into at least two categories based on characteristics and condition of lines, equipment, surrounding vegetation, and localized weather patterns | ii. Tools and processes can reliably categorize the risk of ignition across the grid into at least two categories based on characteristics and condition of lines, equipment, surrounding vegetation, and localized weather patterns | iii. Tools and processes can quantitatively and accurately assess the risk of ignition across the grid based on characteristics and condition of lines, equipment, surrounding vegetation, and localized weather patterns |
| 2b: How automated is the ignition risk calculation tool? | i. Not automated | i. Not automated | ii. Partially (<50%) |
| 2c: How granular is the tool? | iii. Circuit-based | iii. Circuit-based | iii. Circuit-based |
| 2d: How is risk assessment confirmed? Select all that apply. | i. By experts ii. By historical data | i. By experts ii. By historical data | i. By experts ii. By historical data iii. Through real-time learning |
| 2e: What confidence interval, in percent, does the utility use in its wildfire risk assessments? | >60%, or no quantified confidence interval | >60%, or no quantified confidence interval | >60%, or no quantified confidence interval |



| |
|--|
| |
|--|

Capability 3. Estimation of wildfire consequences for communities

| | | | |
|---|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 1 (projected) |
|---|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|--|--|--|--|
| 3a: How is estimated consequence of ignition relayed? | ii. Ignition events categorized as low or high risk to communities | iv. Consequence of ignition events quantitatively, accurately, and precisely estimated | iv. Consequence of ignition events quantitatively, accurately, and precisely estimated |
| 3b: What metrics are used to estimate the consequence of ignition risk? | i. As a function of at least one of the following: structures burned, potential fatalities, or area burned | i. As a function of at least one of the following: structures burned, potential fatalities, or area burned | ii. As a function of at least potential fatalities, and one or both of structures burned, or area burned |
| 3c: Is the ignition risk impact analysis available for all seasons? | ii. Yes | ii. Yes | ii. Yes |
| 3d: How automated is the ignition risk estimation process? | i. Not automated | i. Not automated | ii. Partially (<50%) |
| 3e: How granular is the ignition risk estimation process? | iii. Circuit-based | iii. Circuit-based | iii. Circuit-based |
| 3f: How are the outputs of the ignition risk impact assessment tool evaluated? | i. Outputs not evaluated | ii. Outputs independently assessed by experts | iii. Outputs independently assessed by experts and confirmed by historical data |
| 3g: What other inputs are used to estimate impact? | i. Level and conditions of vegetation and weather | i. Level and conditions of vegetation and weather | i. Level and conditions of vegetation and weather |



| Capability 4. Estimation of wildfire and PSPS risk-reduction impact | | | |
|--|--|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 4a: How is risk reduction impact estimated? | i. No clear estimation of risk reduction potential across most initiatives | i. No clear estimation of risk reduction potential across most initiatives | iii. Approach reliably estimates risk reduction potential of initiatives, on an ordinal scale (e.g. 1-5) |
| 4b: How automated is your ignition risk reduction impact assessment tool? | i. Not automated | i. Not automated | ii. Partially (<50%) |
| 4c: How granular is the ignition risk reduction impact assessment tool? | i. Less granular than regional, or no tool at all | iii. Circuit-based | iii. Circuit-based |
| 4d: How are ignition risk reduction impact assessment tool estimates assessed? | i. No or limited formal evidence or support for estimates | ii. With evidence and logical reasoning | iii. Independent expert assessment |
| 4e: What additional information is used to estimate risk reduction impact? | ii. Existing hardware type and condition | iv. Existing hardware type and condition, including operating history; level and condition of vegetation; weather | v. Existing hardware type and condition, including operating history; level and condition of vegetation; weather; and combination of initiatives already deployed |



Capability 5. Risk maps and simulation algorithms

| | | | |
|---|-------------------|-------------------------------|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 1 (projected) |
|---|-------------------|-------------------------------|---|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|---|--|---|---|
| 5a: What is the protocol to update risk mapping algorithms? | i. No defined process for updating risk mapping algorithms | ii. Risk mapping algorithms updated based on detected deviations of risk model to ignitions and propagation | ii. Risk mapping algorithms updated based on detected deviations of risk model to ignitions and propagation |
| 5b: How automated is the mechanism to determine whether to update algorithms based on deviations? | ii. Partially (<50%) | ii. Partially (<50%) | ii. Partially (<50%) |
| 5c: How are deviations from risk model to ignitions and propagation detected? | i. Not currently calculated | i. Not currently calculated | ii. Manually |
| 5d: How are decisions to update algorithms evaluated? | i. Not currently evaluated | ii. Independently evaluated by experts | iii. Independently evaluated by experts and historical data |
| 5e: What other data is used to make decisions on whether to update algorithms? | i. Historic ignition and propagation data | i. Historic ignition and propagation data | iii. Current and historic ignition and propagation data; near-miss data |
| | | | |



Category B. Situational Awareness and Forecasting

| | | | |
|---|---|--|--|
| | Avg cycle start maturity: 1.4 | Avg current maturity: 1.6 | Avg projected cycle end maturity: 1.8 |
| Capability 6. Weather variables collected | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 6a: What weather data is currently collected? | ii. Wind being measured accurately enough along the grid to estimate ignition probability | iii. Range of accurate weather variables (e.g. humidity, precipitation, surface and atmospheric wind conditions) that impact probability of ignition and propagation from utility assets | iii. Range of accurate weather variables (e.g. humidity, precipitation, surface and atmospheric wind conditions) that impact probability of ignition and propagation from utility assets |
| 6b: How are measurements validated? | ii. Manual field calibration measurements | ii. Manual field calibration measurements | ii. Manual field calibration measurements |
| 6c: Are elements that cannot be reliably measured in real time being predicted (e.g., fuel moisture content)? | ii. Yes | ii. Yes | ii. Yes |
| 6d: How many sources are being used to provide data on weather metrics being collected? | iii. More than one | iii. More than one | iii. More than one |
| | | | |



| Capability 7. Weather data resolution | | | |
|---|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 7a: How granular is the weather data that is collected? | iii. Weather data has sufficient granularity to reliably measure weather conditions in HFTD areas, and along the entire grid and in all areas needed to predict weather on the grid | iii. Weather data has sufficient granularity to reliably measure weather conditions in HFTD areas, and along the entire grid and in all areas needed to predict weather on the grid | iv. Weather data has sufficient granularity to reliably measure weather conditions in HFTD areas, and along the entire grid and in all areas needed to predict weather on the grid. Also includes wind estimations at various atmospheric altitudes relevant to ignition risk |
| 7b: How frequently is data gathered | iv. At least six times per hour | iv. At least six times per hour | iv. At least six times per hour |
| 7c: How granular is the tool? | ii. Regional | ii. Regional | iii. Circuit-based |
| 7d: How automated is the process to measure weather conditions? | iv. Fully | iv. Fully | iv. Fully |
| | | | |



| Capability 8. Weather forecasting ability | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 8a: How sophisticated is the utility's weather forecasting capability? | iii. Utility has the ability to use a combination of accurate weather stations and external weather data to make accurate forecasts | iii. Utility has the ability to use a combination of accurate weather stations and external weather data to make accurate forecasts | iii. Utility has the ability to use a combination of accurate weather stations and external weather data to make accurate forecasts |
| 8b: How far in advance can accurate forecasts be prepared? | i. Less than two weeks in advance | i. Less than two weeks in advance | i. Less than two weeks in advance |
| 8c: At what level of granularity can forecasts be prepared? | iii. Circuit-based | iii. Circuit-based | iii. Circuit-based |
| 8d: How are results error-checked? | iii. Criteria for option (ii) met, and forecasted results are subsequently error checked against measured weather data | iii. Criteria for option (ii) met, and forecasted results are subsequently error checked against measured weather data | iii. Criteria for option (ii) met, and forecasted results are subsequently error checked against measured weather data |
| 8e: How automated is the forecast process? | iii. Mostly (>=50%) | iii. Mostly (>=50%) | iii. Mostly (>=50%) |
| | | | |



| Capability 9. External sources used in weather forecasting | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 9a: What source does the utility use for weather data? | iii. Utility uses a combination of accurate weather stations and external weather data | iii. Utility uses a combination of accurate weather stations and external weather data | iii. Utility uses a combination of accurate weather stations and external weather data |
| 9b: How is weather station data checked for errors? | ii. Mostly manual processes for error checking weather stations with external data sources | ii. Mostly manual processes for error checking weather stations with external data sources | ii. Mostly manual processes for error checking weather stations with external data sources |
| 9c: For what is weather data used? | iii. Weather data is used to create a single visual and configurable live map that can be used to help make decisions | iii. Weather data is used to create a single visual and configurable live map that can be used to help make decisions | iii. Weather data is used to create a single visual and configurable live map that can be used to help make decisions |
| | | | |



| Capability 10. Wildfire detection processes and capabilities | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 10 : Are there well-defined procedures for detecting ignitions along the grid? | ii. Yes | ii. Yes | ii. Yes |
| 10b: What equipment is used to detect ignitions? | iv. Well-defined equipment for detecting ignitions along grid, including remote detection equipment including cameras, and satellite monitoring | iv. Well-defined equipment for detecting ignitions along grid, including remote detection equipment including cameras, and satellite monitoring | iv. Well-defined equipment for detecting ignitions along grid, including remote detection equipment including cameras, and satellite monitoring |
| 10 : How is information on detected ignitions reported? | iii. Procedure exists for notifying suppression forces and key stakeholders | iii. Procedure exists for notifying suppression forces and key stakeholders | iii. Procedure exists for notifying suppression forces and key stakeholders |
| 10d: What role does ignition detection software play in wildfire detection? | ii. Ignition detection software in cameras used to augment ignition detection procedures | ii. Ignition detection software in cameras used to augment ignition detection procedures | ii. Ignition detection software in cameras used to augment ignition detection procedures |
| | | | |
| | | | |



Category C. Grid design and system hardening

| | | | |
|---|---|---|--|
| | Avg cycle start maturity: 0.8 | Avg current maturity: 0.8 | Avg projected cycle end maturity: 2 |
| Capability 11. Approach to prioritizing initiatives across territory | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 11a: How are wildfire risk reduction initiatives prioritized? | ii. Plan prioritizes risk reduction initiatives to within only HFTD areas | ii. Plan prioritizes risk reduction initiatives to within only HFTD areas | iii. Plan prioritizes wildfire risk reduction initiatives based on local geography and conditions within only HFTD areas |



| Capability 12. Grid design for minimizing ignition risk | | | |
|--|---|---|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 12a: Does grid design meet minimum G095 requirements and loading standards in HFTD areas? | ii. Yes | ii. Yes | iii. Grid topology exceeds design requirements, designed based on accurate understanding of drivers of utility ignition risk |
| 12b: Does the utility provide micro grids or islanding where traditional grid infrastructure is impracticable and wildfire risk is high? | ii. Yes | ii. Yes | ii. Yes |
| 12c: Does routing of new portions of the grid take wildfire risk into account? | i. Yes | i. Yes | i. Yes |
| 12d: Are efforts made to incorporate the latest asset management strategies and new technologies into grid topology? | ii. Yes, some effort made in HFTD areas | ii. Yes, some effort made in HFTD areas | iii. Yes, across the entire service area |
| | | | |



| Capability 13. Grid design for resiliency and minimizing PSPS | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 0 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 13a: What level of redundancy does the utility's transmission architecture have? | i. Many single points of failure | i. Many single points of failure | i. Many single points of failure |
| 13b: What level of redundancy does the utility's distribution architecture have? | i. Many single points of failure | i. Many single points of failure | i. Many single points of failure |
| 13c: What level of sectionalization does the utility's distribution architecture have? | ii. Switches in HFTD areas to individually isolate circuits | ii. Switches in HFTD areas to individually isolate circuits | ii. Switches in HFTD areas to individually isolate circuits |
| 13d: How does the utility consider egress points in its grid topology? | ii. Egress points used as an input for grid topology design | i. Does not consider | ii. Egress points used as an input for grid topology design |
| | | | |



| Capability 14. Risk-based grid hardening and cost efficiency | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 14a: Does the utility have an understanding of the risk spend efficiency of hardening initiatives? | ii. Utility has an accurate understanding of the relative cost and effectiveness of different initiatives | ii. Utility has an accurate understanding of the relative cost and effectiveness of different initiatives | ii. Utility has an accurate understanding of the relative cost and effectiveness of different initiatives |
| 14b: At what level can estimates be prepared? | iii. Circuit-based | iii. Circuit-based | iii. Circuit-based |
| 14c: How frequently are estimates updated? | ii. Less frequently than annually | ii. Less frequently than annually | iii. Annually or more frequently |
| 14d: What grid hardening initiatives does the utility include within its evaluation? | ii. Some | ii. Some | iii. Most |
| 14e: Can the utility evaluate risk reduction synergies from combination of various initiatives? | i. No | i. No | ii. Yes |
| | | | |



| Capability 15. Grid design and asset innovation | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 15 : How are new hardening solution initiatives evaluated? | ii. New initiatives evaluated based on installation into grid and measuring direct reduction in ignition events | ii. New initiatives evaluated based on installation into grid and measuring direct reduction in ignition events | iii. New initiatives evaluated based on installation into grid and measuring direct reduction in ignition events, and measuring reduction impact on near-miss metrics |
| 15b: Are results of pilot and commercial deployments, including project performance, project cost, geography, climate, vegetation etc. shared in sufficient detail to inform decision making at other utilities? | i. No | i. No | ii. Yes, with a limited set of partners |
| 15 : Is performance of new initiatives independently audited? | i. No | i. No | i. No |



Category D. Asset management and inspections

| | | | |
|---|--|--|---|
| | Avg cycle start maturity: 0.6 | Avg current maturity: 0.8 | Avg projected cycle end maturity: 1.2 |
| Capability 16. Asset inventory and condition assessments | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 0 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 16a: What information is captured in the equipment inventory database? | ii. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle | ii. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle | iii. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections and repairs |
| 16 : How frequently is the condition assessment updated? | ii. Annually | ii. Annually | ii. Annually |
| 16c: Does all equipment in HFTD areas have the ability to detect and respond to malfunctions? | ii. A system and approach are in place to reliably detect incipient malfunctions likely to cause ignition | ii. A system and approach are in place to reliably detect incipient malfunctions likely to cause ignition | ii. A system and approach are in place to reliably detect incipient malfunctions likely to cause ignition |
| 16 : How granular is the inventory? | iii. At the asset level | iii. At the asset level | iii. At the asset level |
| | | | |



| Capability 17. Asset inspection cycle | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 17a: How frequent are your patrol inspections? | ii. Consistent with minimum regulatory requirements | ii. Consistent with minimum regulatory requirements | iii. Above minimum regulatory requirements, with more frequent inspections for highest risk equipment |
| 17b: How are patrol inspections scheduled? | i. Based on annual or periodic schedules | i. Based on annual or periodic schedules | ii. Based on up-to-date static maps of equipment types and environment |
| 17c: What are the inputs to scheduling patrol inspections? | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment |
| 17d: How frequent are detailed inspections? | iii. Above minimum regulatory requirements, with more frequent inspections for highest risk equipment | iii. Above minimum regulatory requirements, with more frequent inspections for highest risk equipment | iii. Above minimum regulatory requirements, with more frequent inspections for highest risk equipment |
| 17e: How are detailed inspections scheduled? | i. Based on annual or periodic schedules | i. Based on annual or periodic schedules | ii. Based on up-to-date static maps of equipment types and environment |
| 17f: What are the inputs to scheduling detailed inspections? | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment |
| 17g: How frequent are your other inspections? | ii. Consistent with minimum regulatory requirements | ii. Consistent with minimum regulatory requirements | ii. Consistent with minimum regulatory requirements |
| 17h: How are other inspections scheduled? | i. Based on annual or periodic schedules | i. Based on annual or periodic schedules | ii. Based on up-to-date static maps of equipment types and environment |
| 17i: What are the inputs to scheduling other inspections? | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment | i. At least annually updated or verified static maps of equipment and environment |



| Capability 18. Asset inspection effectiveness | | | |
|---|--|--|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 18a: What items are captured within inspection procedures and checklists? | ii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations | ii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations | iii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations, and includes lines and equipment typically responsible for ignitions and near misses |
| 18b: How are procedures and checklists determined? | i. Based on statute and regulatory guidelines only | i. Based on statute and regulatory guidelines only | i. Based on statute and regulatory guidelines only |
| 18c: At what level of granularity are the depth of checklists, training, and procedures customized? | i. Across the service territory | i. Across the service territory | i. Across the service territory |



| Capability 19. Asset maintenance and repair | | | |
|--|--|--|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 19a: What level are electrical lines and equipment maintained at? | i. Electric lines and equipment not consistently maintained at required condition over multiple circuits | i. Electric lines and equipment not consistently maintained at required condition over multiple circuits | ii. Electrical lines and equipment maintained as required by regulation |
| 19b: How are service intervals set? | i. Based on wildfire risk in relevant area | i. Based on wildfire risk in relevant area | ii. Based on wildfire risk in relevant circuit |
| 19c: What do maintenance and repair procedures take into account? | i. Wildfire risk | i. Wildfire risk | ii. Wildfire risk, performance history, and past operating conditions |
| | | | |



| Capability 20. QA/QC for asset management | | | |
|--|---|---|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 20a: How is contractor activity audited? | ii. Through an established and functioning audit process to manage and confirm work completed by subcontractors | ii. Through an established and functioning audit process to manage and confirm work completed by subcontractors | iii. Through an established and demonstrably functioning audit process to manage and confirm work completed by subcontractors, where contractor activity is subject to semi-automated audits using technologies capable of sampling the contractor's work (e.g., LiDAR scans, photographic evidence) |
| 20b: Do contractors follow the same processes and standards as utility's own employees? | ii. Yes | ii. Yes | ii. Yes |
| 20c: How frequently is QA/QC information used to identify deficiencies in quality of work performance and inspections performance? | iii. On an ad hoc basis | iv. Regularly | iv. Regularly |
| 20d: How are work and inspections that do not meet utility-prescribed standards remediated? | ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections | ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections | iii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections, and recommend training based on weaknesses |
| 20e: Are workforce management software tools used to manage and confirm work completed by subcontractors? | ii. Yes | ii. Yes | ii. Yes |



Category E. Vegetation management and inspections

| | | | |
|--|--|--|--|
| | Avg cycle start maturity: 0.7 | Avg current maturity: 0.7 | Avg projected cycle end maturity: 1 |
| Capability 21. Vegetation inventory and condition assessments | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 21a: What information is captured in the inventory? | ii. Centralized inventory of vegetation clearances based on most recent inspection | ii. Centralized inventory of vegetation clearances based on most recent inspection | iii. Centralized inventory of vegetation clearances, including predominant vegetation species and individual high risk-trees across grid |
| 21b: How frequently is inventory updated? | ii. Annually | ii. Annually | iii. Within 1 month of collection |
| 21c: Are inspections independently verified by third party experts? | ii. Yes | ii. Yes | ii. Yes |
| 21d: How granular is the inventory? | iv. Asset-based | iv. Asset-based | iv. Asset-based |
| | | | |



| Capability 22. Vegetation inspection cycle | | | |
|--|--|--|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 22a: How frequent are all types of vegetation inspections? | ii. Consistent with minimum regulatory requirements | ii. Consistent with minimum regulatory requirements | iii. Above minimum regulatory requirements, with more frequent inspections for highest risk areas |
| 22b: How are vegetation inspections scheduled? | i. Based on annual or periodic schedules | i. Based on annual or periodic schedules | i. Based on annual or periodic schedules |
| 22c: What are the inputs to scheduling vegetation inspections? | i. At least annually-updated static maps of vegetation and environment | i. At least annually-updated static maps of vegetation and environment | i. At least annually-updated static maps of vegetation and environment |
| | | | |



| Capability 23. Vegetation inspection effectiveness | | | |
|---|--|--|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 23a: What items are captured within inspection procedures and checklists? | ii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations | ii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations | iii. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations, and includes vegetation types typically responsible for ignitions and near misses |
| 23b: How are procedures and checklists determined? | i. Based on statute and regulatory guidelines only | i. Based on statute and regulatory guidelines only | i. Based on statute and regulatory guidelines only |
| 23c: At what level of granularity are the depth of checklists, training, and procedures customized? | i. Across the service territory | i. Across the service territory | i. Across the service territory |



| Capability 24. Vegetation grow-in mitigation | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 0 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 24a: How does utility clearance around lines and equipment perform relative to expected standards? | ii. Utility meet minimum statutory and regulatory clearances around all lines and equipment | ii. Utility meet minimum statutory and regulatory clearances around all lines and equipment | ii. Utility meet minimum statutory and regulatory clearances around all lines and equipment |
| 24b: Does utility meet or exceed minimum statutory or regulatory clearances during all seasons? | ii. Yes | ii. Yes | ii. Yes |
| 24c: What modeling is used to guide clearances around lines and equipment? | iii. None of the above | iii. None of the above | iii. None of the above |
| 24d: What biological modeling is used to guide clearance around lines and equipment | iii. None of the above | iii. None of the above | iii. None of the above |
| 24e: Are community organizations engaged in setting local clearances and protocols? | i. No | i. No | i. No |
| 24f: Does the utility remove vegetation waste along its right of way across the entire grid? | i. No | i. No | i. No |
| 24g: How long after cutting vegetation does the utility remove vegetation waste along right of way? | ii. Longer than 1 week | ii. Longer than 1 week | ii. Longer than 1 week |
| 24h: Does the utility work with local landowners to provide a cost-effective use for cutting vegetation? | i. No | i. No | i. No |



| | | | |
|---|---------|---------|---------|
| 24i: Does the utility work with partners to identify new cost-effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste? | ii. Yes | ii. Yes | ii. Yes |
|---|---------|---------|---------|

Capability 25. Vegetation fall-in mitigation

| | | | |
|---|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | |
|---|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|---|---|---|--|
| 25a: Does the utility have a process for treating vegetation outside of right of ways? | iii. Utility systematically removes vegetation outside of right of way | iii. Utility systematically removes vegetation outside of right of way | iv. Utility systematically removes vegetation outside of right of way, informing relevant communities of removal |
| 25b: How is potential vegetation that may pose a threat identified? | ii. Based on the height of trees with potential to make contact with electric lines and equipment | ii. Based on the height of trees with potential to make contact with electric lines and equipment | ii. Based on the height of trees with potential to make contact with electric lines and equipment |
| 25c: Is vegetation removed with cooperation from the community? | ii. Yes | ii. Yes | ii. Yes |
| 25d: Does the utility remove vegetation waste outside its right of way across the entire grid? | i. No | i. No | i. No |
| 25e: How long after cutting vegetation does the utility remove vegetation waste outside its right of way? | ii. Longer than 1 week | ii. Longer than 1 week | ii. Longer than 1 week |



| | | | |
|---|---------|---------|---------|
| 25f: Does the utility work with local landowners to provide a cost-effective use for cutting vegetation? | i. No | i. No | i. No |
| 25g: Does the utility work with partners to identify new cost-effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste? | ii. Yes | ii. Yes | ii. Yes |
| | | | |

| Capability 26. QA/QC for vegetation management | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 26a: How is contractor and employee activity audited? | ii. Through an established and functioning audit process to manage and confirm work completed by subcontractors | ii. Through an established and functioning audit process to manage and confirm work completed by subcontractors | ii. Through an established and functioning audit process to manage and confirm work completed by subcontractors |
| 26b: Do contractors follow the same processes and standards as utility's own employees? | ii. Yes | ii. Yes | ii. Yes |
| 26c: How frequently is QA/QC information used to identify deficiencies in quality of work performance and inspections performance? | iv. Regularly | iv. Regularly | iv. Regularly |
| 26d: How is work and inspections that do not meet | ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections | ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections | ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections |



| | | | |
|---|-------|-------|---------|
| utility-prescribed standards remediated? | | | |
| 26e: Are workforce management software tools used to manage and confirm work completed by subcontractors? | i. No | i. No | ii. Yes |
| | | | |



Category F. Grid operations and protocols

| | | | |
|--|---|---|---|
| | Avg cycle start maturity: 1.3 | Avg current maturity: 2.2 | Avg projected cycle end maturity: 2.3 |
| Capability 27. Protective equipment and device settings | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 3 | By end of year 1 (current): 3 | Planned state by end of cycle: 3 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 27a: How are grid elements adjusted during high threat weather conditions? | iv. Utility increases sensitivity of risk reduction elements during high threat weather conditions based on risk mapping and monitors near misses | iv. Utility increases sensitivity of risk reduction elements during high threat weather conditions based on risk mapping and monitors near misses | iv. Utility increases sensitivity of risk reduction elements during high threat weather conditions based on risk mapping and monitors near misses |
| 27b: Is there an automated process for adjusting sensitivity of grid elements and evaluating effectiveness? | ii. Partially automated process | ii. Partially automated process | ii. Partially automated process |
| 27c: Is there a predetermined protocol driven by fire conditions for adjusting sensitivity of grid elements? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



| Capability 28. Incorporating ignition risk factors in grid control | | | |
|--|---|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 28a: Does the utility have a clearly explained process for determining whether to operate the grid beyond current or voltage designs? | ii. Yes | ii. Yes | ii. Yes |
| 28b: Does the utility have systems in place to automatically track operation history including current, loads, and voltage throughout the grid at the circuit level? | i. No | ii. Yes | ii. Yes |
| 28c: Does the utility use predictive modeling to estimate the expected life and make equipment maintenance, rebuild, or replacement decisions based on grid operating history, and is that model reviewed? | ii. Modeling is used, but not evaluated by external experts | i. Modeling is not used | i. Modeling is not used |
| 28d: When does the utility operate the grid above rated voltage and current load? | ii. Only in conditions that are unlikely to cause wildfire | i. During any conditions | i. During any conditions |
| | | | |



| Capability 29. PSPS op. model and consequence mitigation | | | |
|---|--|--|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 3 | Planned state by end of cycle: 3 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 29a: How effective is PSPS event forecasting? | iv. PSPS event generally forecasted accurately with fewer than 25% of predictions being false positives | iv. PSPS event generally forecasted accurately with fewer than 25% of predictions being false positives | iv. PSPS event generally forecasted accurately with fewer than 25% of predictions being false positives |
| 29b: What share of customers are communicated to regarding forecasted PSPS events? | ii. PSPS event are communicated to >95% of affected customers and >99% of medical baseline customers in advance of PSPS action | iv. PSPS event are communicated to >99% of affected customers and >99.9% of medical baseline customers in advance of PSPS action | iv. PSPS event are communicated to >99% of affected customers and >99.9% of medical baseline customers in advance of PSPS action |
| 29c: During PSPS events, what percent of customers complain? | iii. Less than 0.5% | iii. Less than 0.5% | iii. Less than 0.5% |
| 29d: During PSPS events, does the utility's website go down? | ii. Yes | i. No | i. No |
| 29e: During PSPS events, what is the average downtime per customer? | v. Less than 0.1 hours | v. Less than 0.1 hours | v. Less than 0.1 hours |
| 29f: Are specific resources provided to all affected customers to alleviate the impact of the power shutoff (e.g., providing backup generators, supplies, batteries, etc.)? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



| Capability 30. Protocols for PSPS initiation | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 30a: Does the utility have explicit thresholds for activating a PSPS? | ii. Utility has explicit policies and explanation for the thresholds above which PSPS is activated as a measure of last resort | ii. Utility has explicit policies and explanation for the thresholds above which PSPS is activated as a measure of last resort | ii. Utility has explicit policies and explanation for the thresholds above which PSPS is activated as a measure of last resort |
| 30b: Which of the following does the utility take into account when making PSPS decisions? Select all that apply | ii. A partially automated system which recommends circuits for which PSPS should be activated and is validated by SMEs | ii. A partially automated system which recommends circuits for which PSPS should be activated and is validated by SMEs | ii. A partially automated system which recommends circuits for which PSPS should be activated and is validated by SMEs |
| 30c: Under which circumstances does the utility de-energize circuits? Select all that apply. | i. Upon detection of damaged conditions of electric equipment ii. When circuit presents a safety risk to suppression or other personnel iii. When equipment has come into contact with foreign objects posing ignition risk iv. Additional reasons not listed | i. Upon detection of damaged conditions of electric equipment ii. When circuit presents a safety risk to suppression or other personnel iii. When equipment has come into contact with foreign objects posing ignition risk iv. Additional reasons not listed | i. Upon detection of damaged conditions of electric equipment ii. When circuit presents a safety risk to suppression or other personnel iii. When equipment has come into contact with foreign objects posing ignition risk iv. Additional reasons not listed |
| 30d: Given the condition of the grid, with what probability does the utility expect any large scale PSPS events affecting more than 10,000 people to occur in the coming year? | ii. Greater than 5% - Grid condition paired with risk indicates that PSPS may be necessary in 2020 in some areas | ii. Greater than 5% - Grid condition paired with risk indicates that PSPS may be necessary in 2020 in some areas | ii. Greater than 5% - Grid condition paired with risk indicates that PSPS may be necessary in 2020 in some areas |
| | | | |



| Capability 31. Protocols for PSPS re-energization | | | |
|---|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 31a: Is there a process for inspecting de-energized sections of the grid prior to re-energization? | ii. Existing process for accurately inspecting de-energized sections of the grid prior to re-energization | ii. Existing process for accurately inspecting de-energized sections of the grid prior to re-energization | ii. Existing process for accurately inspecting de-energized sections of the grid prior to re-energization |
| 31b: How automated is the process for inspecting de-energized sections of the grid prior to re-energization? | i. Manual process, not automated at all | i. Manual process, not automated at all | ii. Partially automated (<50%) |
| 31c: What is the average amount of time that it takes you to re-energize your grid from a PSPS once weather has subsided to below your de-energization threshold? | ii. Within 24 hours | iv. Within 12 hours | iv. Within 12 hours |
| 31d: What level of understanding of probability of ignitions after PSPS events does the utility have across the grid? | ii. Some probability estimates exist | iii. Utility has accurate quantitative understanding of ignition risk following re-energization, by asset, validated by historical data and near misses | iii. Utility has accurate quantitative understanding of ignition risk following re-energization, by asset, validated by historical data and near misses |

Capability 32. Ignition prevention and suppression



| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 3 | Planned state by end of cycle: 3 (projected) |
|---|--|--|--|
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 32a: Does the utility have defined policies around the role of workers in suppressing ignitions? | iii. Utilities have explicit policies about the role of crews, including contractors and subcontractors, at the site of ignition | iii. Utilities have explicit policies about the role of crews, including contractors and subcontractors, at the site of ignition | iii. Utilities have explicit policies about the role of crews, including contractors and subcontractors, at the site of ignition |
| 32b: What training and tools are provided to workers in the field? | iii. All criteria in option (ii) met; In addition, suppression tools and training to suppress small ignitions caused by workers or in immediate vicinity of workers are provided | 0 | 0 |
| 32c: In the events where workers have encountered an ignition, have any Cal/OSHA reported injuries or fatalities occurred in in the last year? | i. No | i. No | i. No |
| 32d: Does the utility provide training to other workers at other utilities and outside the utility industry on best practices to minimize, report and suppress ignitions? | i. No | i. No | i. No |

Category G. Data governance



| | | |
|-------------------------------|---------------------------|---------------------------------------|
| Avg cycle start maturity: 0.3 | Avg current maturity: 0.8 | Avg projected cycle end maturity: 2.8 |
|-------------------------------|---------------------------|---------------------------------------|

Capability 33. Data collection and curation

| | | | |
|---|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
|---|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|--|----------------|----------------------------|---|
| 33a: Does the utility have a centralized database of situational, operational, and risk data? | i. No | i. No | ii. Yes |
| 33b: Is the utility able to use advanced analytics on its centralized database of situational, operational, and risk data to make operational and investment decisions? | i. No | i. No | iii. Yes, for both short term and long-term decision making |
| 33c: Does the utility collect data from all sensed portions of electric lines, equipment, weather stations, etc.? | ii. Yes | ii. Yes | ii. Yes |
| 33d: Is the utility's database of situational, operational, and risk data able to ingest and share data using real-time API protocols with a wide variety of stakeholders? | i. No | i. No | i. No |
| 33e: Does the utility identify highest priority additional data sources to improve decision making? | ii. Yes | ii. Yes | iii. Yes, with plans to incorporate these into centralized database of situational, operational and risk data |



| | | | |
|---|-------|-------|---------|
| 33f: Does the utility share best practices for database management and use with other utilities in California and beyond? | i. No | i. No | ii. Yes |
| | | | |

| Capability 34. Data transparency and analytics | | | |
|---|--|--|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 34a: Is there a single document cataloging all fire-related data and algorithms, analyses, and data processes? | i. No | i. No | ii. Yes |
| 34b: Is there an explanation of the sources, cleaning processes, and assumptions made in the single document catalog? | i. No | i. No | ii. Yes |
| 34c: Are all analyses, algorithms, and data processing explained and documented? | ii. Analyses, algorithms, and data processing are documented | ii. Analyses, algorithms, and data processing are documented | iii. Analyses, algorithms, and data processing are documented and explained |
| 34d: Is there a system for sharing data in real time across multiple levels of permissions? | iii. System is capable of sharing across at least three levels of permissions, including a.) utility-regulator permissions, b.) first responder permissions, and c.) public data sharing | iii. System is capable of sharing across at least three levels of permissions, including a.) utility-regulator permissions, b.) first responder permissions, and c.) public data sharing | iii. System is capable of sharing across at least three levels of permissions, including a.) utility-regulator permissions, b.) first responder permissions, and c.) public data sharing |



| | | | |
|--|--|--|--|
| 34e: Are the most relevant wildfire related data algorithms disclosed? | iii. Yes, disclosed publicly in WMP upon request | iii. Yes, disclosed publicly in WMP upon request | iii. Yes, disclosed publicly in WMP upon request |
|--|--|--|--|

Capability 35. Near-miss tracking

| | | | |
|---|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 2 | Planned state by end of cycle: 3 (projected) |
|---|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|---|----------------|----------------------------|-------------------------------|
| 35a: Does the utility track near miss data for all near misses with wildfire ignition potential? | i. No | ii. Yes | ii. Yes |
| 35b: Based on near miss data captured, is the utility able to simulate wildfire potential given an ignition based on event characteristics, fuel loads, and moisture? | i. No | ii. Yes | ii. Yes |
| 35c: Does the utility capture data related to the specific mode of failure when capturing near-miss data? | i. No | ii. Yes | ii. Yes |
| 35d: Is the utility able to predict the probability of a near miss in causing an ignition based on a set of event characteristics? | i. No | i. No | ii. Yes |
| 35e: Does the utility use data from near misses to change grid operation protocols in real time? | i. No | i. No | i. No |

Capability 36. Data sharing with research community



| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 4 (projected) |
|---|---|--|--|
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 36a: Does the utility make disclosures and share data? | ii. Utility makes required disclosures, but does not share data beyond what is required | ii. Utility makes required disclosures, but does not share data beyond what is required | iii. Utility makes required disclosures and shares data beyond what is required |
| 36b: Does the utility in engage in research? | iii. Utility funds and participates in both independent and collaborative research | iv. Utility funds and participates in both independent and collaborative research, and ensures that research, where possible, is abstracted and applied to other utilities | iv. Utility funds and participates in both independent and collaborative research, and ensures that research, where possible, is abstracted and applied to other utilities |
| 36c: What subjects does utility research address? | ii. Utility ignited wildfires and risk reduction initiatives | ii. Utility ignited wildfires and risk reduction initiatives | ii. Utility ignited wildfires and risk reduction initiatives |
| 36d: Does the utility promote best practices based on latest independent scientific and operational research? | i. No | ii. Yes | ii. Yes |



Category H. Resource allocation methodology

| | | | |
|--|---|---|--|
| | Avg cycle start maturity: 0.2 | Avg current maturity: 0.8 | Avg projected cycle end maturity: 1.5 |
| Capability 37. Scenario analysis across different risk levels | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 37a: For what risk scenarios is the utility able to provide projected cost and total risk reduction potential? | i. Utility does not project proposed initiatives or costs across different levels of risk scenarios | i. Utility does not project proposed initiatives or costs across different levels of risk scenarios | iii. Utility provides an accurate high-risk reduction and low risk reduction scenario, in addition to their proposed scenario, and the projected cost and total risk reduction potential |
| 37b: For what level of granularity is the utility able to provide projections for each scenario? | i. Territory-level or greater | i. Territory-level or greater | iii. Circuit level |
| 37c: Does the utility include a long term (e.g., 6-10 year) risk estimate taking into account macro factors (climate change, etc.) as well as planned risk reduction initiatives in its scenarios? | ii. Yes | ii. Yes | ii. Yes |
| 37d: Does the utility provide an estimate of impact on reliability factors in its scenarios? | i. No | i. No | ii. Yes |



| Capability 38. Presentation of relative risk spend efficiency for portfolio of initiatives | | | |
|---|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 38a: Does the utility present accurate qualitative rankings for its initiatives by risk spend efficiency? | ii. Yes | ii. Yes | ii. Yes |
| 38b: What initiatives are captured in the ranking of risk spend efficiency? | i. Common commercial initiatives | i. Common commercial initiatives | iii. All commercial initiatives and emerging initiatives |
| 38c: Does the utility include figures for present value cost and project risk reduction impact of each initiative, clearly documenting all assumptions (e.g. useful life, discount rate, etc.)? | i. No | i. No | ii. Yes |
| 38d: Does the utility provide an explanation of their investment in each particular initiative? | ii. Yes, including the expected overall reduction in risk | ii. Yes, including the expected overall reduction in risk | iii. Yes, including the expected overall reduction in risk and estimates of impact on reliability factors |
| 38e: At what level of granularity is the utility able to provide risk efficiency figures? | i. Territory-level or greater | iii. Circuit level | iii. Circuit level |
| | | | |



| Capability 39. Process for determining risk spend efficiency of vegetation management initiatives | | | |
|---|--|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 39a: How accurate of a risk spend efficiency calculation can the utility provide? | i. Utility has no clear understanding of the relative risk spend efficiency of various clearances and types of vegetation management initiatives | ii. Utility has an accurate relative understanding of the cost and effectiveness to produce a reliable risk spend efficiency estimate | iii. Utility has accurate quantitative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate |
| 39b: At what level can estimates be prepared? | i. Less granular than regional, or not at all | iii. Circuit-based | iii. Circuit-based |
| 39c: How frequently are estimates updated? | iii. Annually or more frequently | iii. Annually or more frequently | iii. Annually or more frequently |
| 39d: What vegetation management initiatives does the utility include within its evaluation? | iii. Most | iii. Most | iv. All |
| 39e: Can the utility evaluate risk reduction synergies from combination of various initiatives? | i. No | i. No | ii. Yes |
| | | | |



| Capability 40. Process for determining risk spend efficiency of system hardening initiatives | | | |
|---|--|--|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 40a: How accurate of a risk spend efficiency calculation can the utility provide? | ii. Utility has accurate relative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate | ii. Utility has accurate relative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate | iii. Utility has accurate quantitative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate |
| 40b: At what level can estimates be prepared? | i. Less granular than regional, or not at all | iii. Circuit-based | iii. Circuit-based |
| 40c: How frequently are estimates updated? | iii. Annually or more frequently | iii. Annually or more frequently | iii. Annually or more frequently |
| 40d: What grid hardening initiatives are included in the utility risk spend efficiency analysis? | ii. Some commercially available grid hardening initiatives | ii. Some commercially available grid hardening initiatives | iv. All commercially available grid hardening initiatives |
| 40e: Can the utility evaluate risk reduction effects from the combination of various initiatives? | i. No | i. No | ii. Yes |



| Capability 41. Portfolio-wide initiative allocation methodology | | | |
|---|--|--|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 41a: To what extent does the utility allocate capital to initiatives based on risk-spend efficiency (RSE)? | i. Utility does not base capital allocation on RSE | i. Utility does not base capital allocation on RSE | ii. Utility considers estimates of RSE when allocating capital |
| 41b: What information does the utility take into account when generating RSE estimates? | i. Average estimate of RSE by initiative category | i. Average estimate of RSE by initiative category | ii. Specific information by initiative, including state of equipment and location where initiative will be implemented |
| 41c: How does the utility verify RSE estimates? | i. Utility does not verify RSE estimates | i. Utility does not verify RSE estimates | i. Utility does not verify RSE estimates |
| 41d: Does the utility take into consideration impact on safety, reliability, and other priorities when making spending decisions? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



| Capability 42. Portfolio-wide innovation in new wildfire initiatives | | | |
|--|--|--|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 1 | By end of year 1 (current): 1 | Planned state by end of cycle: 1 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 42a: How does the utility develop and evaluate the efficacy of new wildfire initiatives? | ii. Utility uses pilots and measures direct reduction in ignition events | ii. Utility uses pilots and measures direct reduction in ignition events | iii. Utility uses pilots and measures direct reduction in ignition events and near-misses. |
| 42b: How does the utility develop and evaluate the risk spend efficiency of new wildfire initiatives? | i. No program in place | i. No program in place | i. No program in place |
| 42c: At what level of granularity does the utility measure the efficacy of new wildfire initiatives? | ii. Entire territory | ii. Entire territory | iii. Circuit |
| 42d: Are the reviews of innovative initiatives audited by independent parties? | i. No | i. No | i. No |
| 42e: Does the utility share the findings of its evaluation of innovative initiatives with other utilities, academia, and the general public? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



Category I. Emergency planning and preparedness

| | | | |
|---|---|---|---|
| | Avg cycle start maturity: 0.4 | Avg current maturity: 2 | Avg projected cycle end maturity: 3.6 |
| Capability 43. Wildfire plan integrated with overall disaster/ emergency plan | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 43a: Is the wildfire plan integrated with overall disaster and emergency plans? | iii. Wildfire plan is an integrated component of overall plan | iii. Wildfire plan is an integrated component of overall plan | iii. Wildfire plan is an integrated component of overall plan |
| 43b: Does the utility run drills to audit the viability and execution of its wildfire plans? | i. No | i. No | ii. Yes |
| 43c: Is the impact of confounding events or multiple simultaneous disasters considered in the planning process? | i. No | ii. Yes | ii. Yes |
| 43d: Is the plan integrated with disaster and emergency preparedness plans of other relevant stakeholders (e.g., CAL FIRE, Fire Safe Councils, etc.)? | i. No | ii. Yes | ii. Yes |
| 43e: Does the utility take a leading role in planning, coordinating, and integrating plans across stakeholders? | i. No | i. No | ii. Yes |



| Capability 44. Plan to restore service after wildfire related outage | | | |
|--|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 44a: Are there detailed and actionable procedures in place to restore service after a wildfire related outage? | ii. Yes | ii. Yes | ii. Yes |
| 44b: Are employee and subcontractor crews trained in, and aware of, plans? | ii. Yes | ii. Yes | ii. Yes |
| 44c: To what level are procedures to restore service after a wildfire-related outage customized? | i. Territory-wide | | 0 0 |
| 44d: Is the customized procedure to restore service based on topography, vegetation, and community needs? | ii. Yes | ii. Yes | ii. Yes |
| 44e: Is there an inventory of high risk spend efficiency resources available for repairs? | i. No | i. No | ii. Yes |
| 44f: Is the wildfire plan integrated with overall disaster and emergency plans? | iii. Wildfire plan is an integrated component of overall plan | iii. Wildfire plan is an integrated component of overall plan | iii. Wildfire plan is an integrated component of overall plan |



| Capability 45. Emergency community engagement during and after wildfire | | | |
|---|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 2 | Planned state by end of cycle: 2 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 45a: Does the utility provide clear and substantially complete communication of available information relevant to affected customers? | ii. Yes | iii. Yes, along with referrals to other agencies | iii. Yes, along with referrals to other agencies |
| 45b: What percent of affected customers receive complete details of available information? | ii. >95% of customers | iii. >98% of customers | iv. >99% of customers |
| 45c: What percent of affected medical baseline customers receive complete details of available information? | i. <=99% | iii. >99.5% of medical baseline customers | iii. >99.5% of medical baseline customers |
| 45d: How does the utility assist where helpful with communication of information related to power outages to customers? | iii. None of the above | ii. Through availability of relevant evacuation information and links on website and toll-free telephone number, and assisting disaster response professionals as requested | ii. Through availability of relevant evacuation information and links on website and toll-free telephone number, and assisting disaster response professionals as requested |
| 45e: How does the utility with engage other emergency management agencies during emergency situations? | ii. Utility engages with other agencies in an ad hoc manner | ii. Utility engages with other agencies in an ad hoc manner | iii. Utility has detailed and actionable established protocols for engaging with emergency management organizations |
| 45f: Does the utility communicate and coordinate resources to communities during emergencies (e.g., shelters, supplies, transportation etc.)? | ii. Yes | ii. Yes | ii. Yes |



| Capability 46. Protocols in place to learn from wildfire events | | | |
|--|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 4 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 46a: Is there a protocol in place to record the outcome of emergency events and to clearly and actionably document learnings and potential process improvements? | ii. Yes | ii. Yes | ii. Yes |
| 46b: Is there a defined process and staff responsible for incorporating learnings into emergency plan? | i. No | ii. Yes | ii. Yes |
| 46c: Once updated based on learnings and improvements, is the updated plan tested using "dry runs" to confirm its effectiveness? | i. No | ii. Yes | ii. Yes |
| 46d: Is there a defined process to solicit input from a variety of other stakeholders and incorporate learnings from other stakeholders into the emergency plan? | i. No | ii. Yes | ii. Yes |
| | | | |



| Capability 47. Processes for continuous improvement after wildfire and PSPS | | | |
|--|-----------------------------|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 2 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 47a: Does the utility conduct an evaluation or debrief process after a wildfire? | ii. Yes | ii. Yes | ii. Yes |
| 47b: Does the utility conduct a customer survey and utilize partners to disseminate requests for stakeholder engagement? | i. No | iii. Both | iii. Both |
| 47c: In what other activities does the utility engage? | iii. Debriefs with partners | iv. Public listening sessions, debriefs with partners, and others | iv. Public listening sessions, debriefs with partners, and others |
| 47d: Does the utility share with partners findings about what can be improved? | i. No | ii. Yes | ii. Yes |
| 47e: Are feedback and recommendations on potential improvements made public? | i. No | ii. Yes | ii. Yes |
| 47f: Does the utility conduct proactive outreach to local agencies and organizations to solicit additional feedback on what can be improved? | i. No | ii. Yes | ii. Yes |
| 47g: Does the utility have a clear plan for post-event listening and incorporating lessons learned from all stakeholders? | i. No | ii. Yes | ii. Yes |



| | | |
|--|-------|---------|
| 47h: Does the utility track the implementation of recommendations and report upon their impact? | i. No | ii. Yes |
| 47i: Does the utility have a process to conduct reviews after wildfires in other the territory of other utilities and states to identify and address areas of improvement? | i. No | ii. Yes |

Category J. Stakeholder cooperation and community engagement

| | | | |
|--|--------------------------------------|---------------------------------------|--|
| | Avg cycle start maturity: 1.4 | Avg current maturity: 2.4 | Avg projected cycle end maturity: 2.8 |
| Capability 48. Cooperation and best practice sharing with other utilities | | | |
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 3 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 48a: Does the utility actively work to identify best practices from other utilities through a clearly defined operational process? | i. No | iii. Yes, from other global utilities | iii. Yes, from other global utilities |
| 48b: Does the utility successfully adopt and implement best practices identified from other utilities? | ii. Yes | ii. Yes | ii. Yes |
| 48c: Does the utility seek to share best practices and lessons learned in a consistent format? | ii. Yes | ii. Yes | ii. Yes |



| | | | |
|--|---------|---------|---------|
| 48d: Does the utility share best practices and lessons via a consistent and predictable set of venues/media? | ii. Yes | ii. Yes | ii. Yes |
| 48e: Does the utility participate in annual benchmarking exercises with other utilities to find areas for improvement? | ii. Yes | ii. Yes | ii. Yes |
| 48f: Has the utility implemented a defined process for testing lessons learned from other utilities to ensure local applicability? | i. No | i. No | ii. Yes |
| | | | |

Capability 49. Engagement with communities on utility wildfire mitigation initiatives

| | | | |
|--|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 3 | By end of year 1 (current): 3 | Planned state by end of cycle: 3 (projected) |
|--|-------------------|-------------------------------|--|

Responses to survey questions
Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|--|----------------|----------------------------|-------------------------------|
| 49a: Does the utility have a clear and actionable plan to develop or maintain a collaborative relationship with local communities? | ii. Yes | ii. Yes | ii. Yes |
| 49b: Are there communities in HFTD areas where meaningful resistance is expected in response to efforts to mitigate fire risk (e.g. vegetation clearance)? | ii. Yes | ii. Yes | ii. Yes |



| | | | |
|--|-------------------|-------------------|-------------------|
| 49c: What percent of landowners are non-compliant with utility initiatives (e.g., vegetation management)? | v. Less than 0.5% | v. Less than 0.5% | v. Less than 0.5% |
| 49d: What percent of landowners complain about utility initiatives (e.g., vegetation management)? | iv. Less than 1 % | iv. Less than 1 % | iv. Less than 1 % |
| 49e: Does the utility have a demonstratively cooperative relationship with communities containing >90% of the population in HFTD areas (e.g. by being recognized by other agencies as having a cooperative relationship with those communities in HFTD areas)? | i. No | i. No | ii. Yes |
| 49f: Does utility have records of landowners throughout communities containing >90% of the population in HFTD areas reaching out to notify of risks, dangers or issues in the past year? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



| Capability 50. Engagement with LEP and AFN populations | | | |
|--|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 4 | Planned state by end of cycle: 4 (projected) |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 50a: Can the utility provide a plan to partner with organizations representing Limited English Proficiency (LEP) and Access & Functional Needs (AFN) communities? | ii. Yes | ii. Yes | ii. Yes |
| 50b: Can the utility outline how these partnerships create pathways for implementing suggested activities to address the needs of these communities? | ii. Yes | ii. Yes | ii. Yes |
| 50c: Can the utility point to clear examples of how those relationships have driven the utility's ability to interact with and prepare LEP & AFN communities for wildfire mitigation activities? | i. No | ii. Yes | ii. Yes |
| 50d: Does the utility have a specific annually-updated action plan further reduce wildfire and PSPS risk to LEP & AFN communities? | i. No | ii. Yes | ii. Yes |



Capability 51. Collaboration with emergency response agencies

| | | | |
|--|-------------------|-------------------------------|--|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 2 | By end of year 1 (current): 2 | Planned state by end of cycle: 3 (projected) |
|--|-------------------|-------------------------------|--|

Responses to survey questions

Survey questions and the utility's responses are shown below

| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
|---|---|--|--|
| 51a: What is the cooperative model between the utility and suppression agencies? | ii. Utility cooperates with suppression agencies by notifying them of ignitions | iii. Utility cooperates with suppression agencies by working cooperatively with them to detect ignitions, in addition to notifying them of ignitions as needed | iii. Utility cooperates with suppression agencies by working cooperatively with them to detect ignitions, in addition to notifying them of ignitions as needed |
| 51b: In what areas is the utility cooperating with suppression agencies | iii. Throughout utility service areas | iii. Throughout utility service areas | iii. Throughout utility service areas |
| 51c: Does the utility accurately predict and communicate the forecasted fire propagation path using available analytics resources and weather data? | i. No | i. No | ii. Yes |
| 51d: Does the utility communicate fire paths to the community as requested? | i. No | i. No | i. No |
| 51e: Does the utility work to assist suppression crews logistically, where possible? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



| Capability 52. Collaboration on wildfire mitigation planning with stakeholders | | | |
|---|---|---|---|
| Capability maturity level based on Maturity Rubric (0 - 4) | Start of cycle: 0 | By end of year 1 (current): 0 | |
| Responses to survey questions | | | |
| Survey questions and the utility's responses are shown below | | | |
| Question | Start of cycle | By end of year 1 (current) | Planned state by end of cycle |
| 52a: Where does the utility conduct substantial fuel management? | i. Utility does not conduct fuel management | i. Utility does not conduct fuel management | i. Utility does not conduct fuel management |
| 52b: Does the utility engage with other stakeholders as part of its fuel management efforts? | i. Utility does not coordinate with broader fuel management efforts by other stakeholders | i. Utility does not coordinate with broader fuel management efforts by other stakeholders | iii. Utility shares fuel management plans with other stakeholders and works with other stakeholders conducting fuel management concurrently |
| 52c: Does the utility cultivate a native vegetative ecosystem across territory that is consistent with lower fire risk? | i. No | i. No | i. No |
| 52d: Does the utility fund local groups (e.g., fire safe councils) to support fuel management? | ii. Yes | ii. Yes | ii. Yes |
| | | | |



○ **PG&E: Numerical maturity summary**

Please reference the Guidance Resolution for the Maturity Rubric and for necessary context to interpret the levels shown below. **All levels are based solely on the Maturity Rubric and on PG&E’s responses to the Utility Wildfire Mitigation Maturity Survey (“Survey”).**

Start: Score reported in February 2020; **Current:** Score reported in February 2021; **End:** Score reported in February 2021 projected for February 2023





| Category | Capability 1 | Capability 2 | Capability 3 | Capability 4 | Capability 5 | Capability 6 |
|--|---|---|--|---|---|---|
| A. Risk Assessment and Mapping | 1. Climate scenario modeling | 2. Ignition risk estimation | 3. Estimation of wildfire consequences for communities | 4. Estimation of wildfire and PSPS risk-reduction impact | 5. Risk maps and simulation algorithms | |
| | Start: 0 Current: 0 End: 1 | Start: 0 Current: 0 End: 1 | Start: 0 Current: 0 End: 1 | Start: 0 Current: 0 End: 2 | Start: 0 Current: 0 End: 1 | |
| B. Situational Awareness and Forecasting | 6. Weather variables collected | 7. Weather data resolution | 8. Weather forecasting ability | 9. External sources used in weather forecasting | 10. Wildfire detection processes and capabilities | |
| | Start: 1 Current: 2 End: 2 | Start: 1 Current: 1 End: 2 | Start: 1 Current: 1 End: 1 | Start: 2 Current: 2 End: 2 | Start: 2 Current: 2 End: 2 | |
| C. Grid design and system hardening | 11. Approach to prioritizing initiatives across territory | 12. Grid design for minimizing ignition risk | 13. Grid design for resiliency and minimizing PSPS | 14. Risk-based grid hardening and cost efficiency | 15. Grid design and asset innovation | |
| | Start: 1 Current: 1 End: 2 | Start: 1 Current: 1 End: 4 | Start: 0 Current: 0 End: 0 | Start: 1 Current: 1 End: 2 | Start: 1 Current: 1 End: 2 | |
| D. Asset management and inspections | 16. Asset inventory and condition assessments | 17. Asset inspection cycle | 18. Asset inspection effectiveness | 19. Asset maintenance and repair | 20. QA/QC for asset management | |
| | Start: 0 Current: 0 End: 0 | Start: 1 Current: 1 End: 2 | Start: 1 Current: 1 End: 1 | Start: 0 Current: 0 End: 1 | Start: 1 Current: 2 End: 2 | |
| E. Vegetation management and inspections | 21. Vegetation inventory and condition assessments | 22. Vegetation inspection cycle | 23. Vegetation inspection effectiveness | 24. Vegetation grow-in mitigation | 25. Vegetation fall-in mitigation | 26. QA/QC for vegetation management |
| | Start: 0 Current: 0 End: 2 | Start: 1 Current: 1 End: 1 | Start: 1 Current: 1 End: 1 | Start: 0 Current: 0 End: 0 | Start: 0 Current: 0 End: 0 | Start: 2 Current: 2 End: 2 |
| F. Grid operations and protocols | 27. Protective equipment and device settings | 28. Incorporating ignition risk factors in grid control | 29. PSPS op. model and consequence mitigation | 30. Protocols for PSPS initiation | 31. Protocols for PSPS re-energization | 32. Ignition prevention and suppression |
| | Start: 3 Current: 3 End: 3 | Start: 0 Current: 1 End: 1 | Start: 0 Current: 3 End: 3 | Start: 2 Current: 2 End: 2 | Start: 1 Current: 1 End: 2 | Start: 2 Current: 3 End: 3 |
| G. Data governance | 33. Data collection and curation | 34. Data transparency and analytics | 35. Near-miss tracking | 36. Data sharing with research community | | |
| | Start: 0 Current: 0 End: 2 | Start: 0 Current: 0 End: 2 | Start: 0 Current: 2 End: 3 | Start: 1 Current: 1 End: 4 | | |
| H. Resource allocation methodology | 37. Scenario analysis across different risk levels | 38. Presentation of relative risk spend efficiency for portfolio of initiatives | 39. Process for determining risk spend efficiency of vegetation management initiatives | 40. Process for determining risk spend efficiency of system hardening initiatives | 41. Portfolio-wide initiative allocation methodology | 42. Portfolio-wide innovation in new wildfire initiatives |
| | Start: 0 Current: 0 End: 2 | Start: 0 Current: 0 End: 2 | Start: 0 Current: 2 End: 2 | Start: 0 Current: 2 End: 2 | Start: 0 Current: 0 End: 0 | Start: 1 Current: 1 End: 1 |
| I. Emergency planning and preparedness | 43. Wildfire plan integrated with overall disaster/emergency plan | 44. Plan to restore service after wildfire related outage | 45. Emergency community engagement during and after wildfire | 46. Protocols in place to learn from wildfire events | 47. Processes for continuous improvement after wildfire and PSPS | |
| | Start: 0 Current: 0 End: 4 | Start: 2 Current: 2 End: 4 | Start: 0 Current: 2 End: 2 | Start: 0 Current: 4 End: 4 | Start: 0 Current: 2 End: 4 | |
| J. Stakeholder cooperation and community engagement | 48. Cooperation and best practice sharing with other utilities | 49. Engagement with communities on utility wildfire mitigation initiatives | 50. Engagement with LEP and AFN populations | 51. Collaboration with emergency response agencies | 52. Collaboration on wildfire mitigation planning with stakeholders | |
| | Start: 0 Current: 3 End: 4 | Start: 3 Current: 3 End: 3 | Start: 2 Current: 4 End: 4 | Start: 2 Current: 2 End: 3 | Start: 0 Current: 0 End: 0 | |



• Attachment 2: Definition of Initiatives by Category

| Category | Initiative activity | Definition |
|---|---|--|
| A. Risk mapping and simulation | A summarized risk map that shows the overall ignition probability and estimated wildfire consequence along the electric lines and equipment | Development and use of tools and processes to develop and update risk map and simulations and to estimate risk reduction potential of initiatives for a given portion of the grid (or more granularly, e.g., circuit, span, or asset). May include verification efforts, independent assessment by experts, and updates. |
| | Climate-driven risk map and modeling based on various relevant weather scenarios | Development and use of tools and processes to estimate incremental risk of foreseeable climate scenarios, such as drought, across a given portion of the grid (or more granularly, e.g., circuit, span, or asset). May include verification efforts, independent assessment by experts, and updates. |
| | Ignition probability mapping showing the probability of ignition along the electric lines and equipment | Development and use of tools and processes to assess the risk of ignition across regions of the grid (or more granularly, e.g., circuits, spans, or assets). |
| | Initiative mapping and estimation of wildfire and PSPS risk-reduction impact | Development of a tool to estimate the risk reduction efficacy (for both wildfire and PSPS risk) and risk-spend efficiency of various initiatives. |
| | Match drop simulations showing the potential wildfire consequence of ignitions that occur along the electric lines and equipment | Development and use of tools and processes to assess the impact of potential ignition and risk to communities (e.g., in terms of potential fatalities, structures burned, monetary damages, area burned, impact on air quality and greenhouse gas, or GHG, reduction goals, etc.). |
| | B. Situational awareness and forecasting | Advanced weather monitoring and weather stations |
| Continuous monitoring sensors | | Installation, maintenance, and monitoring of sensors and sensorized equipment used to monitor the condition of electric lines and equipment. |
| Fault indicators for detecting faults on electric lines and equipment | | Installation and maintenance of fault indicators. |
| Forecast of a fire risk index, fire potential index, or similar | | Index that uses a combination of weather parameters (such as wind speed, humidity, and temperature), vegetation and/or fuel conditions, and other factors to judge current fire risk and to create a forecast indicative of fire risk. A sufficiently |



| | | |
|--|---|--|
| | | granular index shall inform operational decision-making. |
| | Personnel monitoring areas of electric lines and equipment in elevated fire risk conditions | Personnel position within utility service territory to monitor system conditions and weather on site. Field observations shall inform operational decisions. |
| | Weather forecasting and estimating impacts on electric lines and equipment | Development methodology for forecast of weather conditions relevant to utility operations, forecasting weather conditions and conducting analysis to incorporate into utility decision-making, learning and updates to reduce false positives and false negatives of forecast PSPS conditions. |
| C. Grid design and system hardening | Capacitor maintenance and replacement program | Remediation, adjustments, or installations of new equipment to improve or replace existing capacitor equipment. |
| | Circuit breaker maintenance and installation to de-energize lines upon detecting a fault | Remediation, adjustments, or installations of new equipment to improve or replace existing fast switching circuit breaker equipment to improve the ability to protect electrical circuits from damage caused by overload of electricity or short circuit. |
| | Covered conductor installation | Installation of covered or insulated conductors to replace standard bare or unprotected conductors (defined in accordance with GO 95 as supply conductors, including but not limited to lead wires, not enclosed in a grounded metal pole or not covered by: a “suitable protective covering” (in accordance with Rule 22.8), grounded metal conduit, or grounded metal sheath or shield). In accordance with GO 95, conductor is defined as a material suitable for: (1) carrying electric current, usually in the form of a wire, cable or bus bar, or (2) transmitting light in the case of fiber optics; insulated conductors as those which are surrounded by an insulating material (in accordance with Rule 21.6), the dielectric strength of which is sufficient to withstand the maximum difference of potential at normal operating voltages of the circuit without breakdown or puncture; and suitable protective covering as a covering of wood or other non-conductive material having the electrical insulating efficiency (12kV/in. dry) and impact strength (20ft.-lbs) of 1.5 inches of redwood or other material meeting the requirements of Rule 22.8-A, 22.8-B, 22.8-C or 22.8-D. |
| | Covered conductor maintenance | Remediation and adjustments to installed covered or insulated conductors. In accordance with GO 95, conductor is defined as a material suitable for: (1) |



| | | |
|--|---|---|
| | | carrying electric current, usually in the form of a wire, cable or bus bar, or (2) transmitting light in the case of fiber optics; insulated conductors as those which are surrounded by an insulating material (in accordance with Rule 21.6), the dielectric strength of which is sufficient to withstand the maximum difference of potential at normal operating voltages of the circuit without breakdown or puncture; and suitable protective covering as a covering of wood or other non-conductive material having the electrical insulating efficiency (12kV/in. dry) and impact strength (20ft.-lbs) of 1.5 inches of redwood or other material meeting the requirements of Rule 22.8-A, 22.8-B, 22.8-C or 22.8-D. |
| | Crossarm maintenance, repair, and replacement | Remediation, adjustments, or installations of new equipment to improve or replace existing crossarms, defined as horizontal support attached to poles or structures generally at right angles to the conductor supported in accordance with GO 95. |
| | Distribution pole replacement and reinforcement, including with composite poles | Remediation, adjustments, or installations of new equipment to improve or replace existing distribution poles (i.e., those supporting lines under 65kV), including with equipment such as composite poles manufactured with materials reduce ignition probability by increasing pole lifespan and resilience against failure from object contact and other events. |
| | Expulsion fuse replacement | Installations of new and CAL FIRE-approved power fuses to replace existing expulsion fuse equipment. |
| | Grid topology improvements to mitigate or reduce PSPS events | Plan to support and actions taken to mitigate or reduce PSPS events in terms of geographic scope and number of customers affected, such as installation and operation of electrical equipment to sectionalize or island portions of the grid, microgrids, or local generation. |
| | Installation of system automation equipment | Installation of electric equipment that increases the ability of the utility to automate system operation and monitoring, including equipment that can be adjusted remotely such as automatic reclosers (switching devices designed to detect and interrupt momentary faults that can reclose automatically and detect if a fault remains, remaining open if so). |
| | Maintenance, repair, and replacement of connectors, including hotline clamps | Remediation, adjustments, or installations of new equipment to improve or replace existing connector equipment, such as hotline clamps. |



| | | |
|--|--|--|
| | Mitigation of impact on customers and other residents affected during PSPS event | Actions taken to improve access to electricity for customers and other residents during PSPS events, such as installation and operation of local generation equipment (at the community, household, or other level). |
| | Other corrective action | Other maintenance, repair, or replacement of utility equipment and structures so that they function properly and safely, including remediation activities (such as insulator washing) of other electric equipment deficiencies that may increase ignition probability due to potential equipment failure or other drivers. |
| | Pole loading infrastructure hardening and replacement program based on pole loading assessment program | Actions taken to remediate, adjust, or install replacement equipment for poles that the utility has identified as failing to meet safety factor requirements in accordance with GO 95 or additional utility standards in the utility's pole loading assessment program. |
| | Transformers maintenance and replacement | Remediation, adjustments, or installations of new equipment to improve or replace existing transformer equipment. |
| | Transmission tower maintenance and replacement | Remediation, adjustments, or installations of new equipment to improve or replace existing transmission towers (e.g., structures such as lattice steel towers or tubular steel poles that support lines at or above 65kV). |
| | Undergrounding of electric lines and/or equipment | Actions taken to convert overhead electric lines and/or equipment to underground electric lines and/or equipment (i.e., located underground and in accordance with GO 128). |
| | Updates to grid topology to minimize risk of ignition in HFTDs | Changes in the plan, installation, construction, removal, and/or undergrounding to minimize the risk of ignition due to the design, location, or configuration of utility electric equipment in HFTDs. |
| D. Asset management and inspections | Detailed inspections of distribution electric lines and equipment | In accordance with GO 165, careful visual inspections of overhead electric distribution lines and equipment where individual pieces of equipment and structures are carefully examined, visually and through use of routine diagnostic test, as appropriate, and (if practical and if useful information can be so gathered) opened, and the condition of each rated and recorded. |
| | Detailed inspections of transmission electric lines and equipment | Careful visual inspections of overhead electric transmission lines and equipment where individual pieces of equipment and structures are carefully examined, visually and through use of routine diagnostic test, as appropriate, and (if practical and |



| | | |
|--|---|---|
| | | if useful information can be so gathered) opened, and the condition of each rated and recorded. |
| | Improvement of inspections | Identifying and addressing deficiencies in inspections protocols and implementation by improving training and the evaluation of inspectors. |
| | Infrared inspections of distribution electric lines and equipment | Inspections of overhead electric distribution lines, equipment, and right-of-way using infrared (heat-sensing) technology and cameras that can identify “hot spots,” or conditions that indicate deterioration or potential equipment failures, of electrical equipment. |
| | Infrared inspections of transmission electric lines and equipment | Inspections of overhead electric transmission lines, equipment, and right-of-way using infrared (heat-sensing) technology and cameras that can identify “hot spots,” or conditions that indicate deterioration or potential equipment failures, of electrical equipment. |
| | Intrusive pole inspections | In accordance with GO 165, intrusive inspections involve movement of soil, taking samples for analysis, and/or using more sophisticated diagnostic tools beyond visual inspections or instrument reading. |
| | LiDAR inspections of distribution electric lines and equipment | Inspections of overhead electric distribution lines, equipment, and right-of-way using LiDAR (light detection and ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances). |
| | LiDAR inspections of transmission electric lines and equipment | Inspections of overhead electric transmission lines, equipment, and right-of-way using LiDAR (light detection and ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances). |
| | Other discretionary inspection of distribution electric lines and equipment, beyond inspections mandated by rules and regulations | Inspections of overhead electric distribution lines, equipment, and right-of-way that exceed or otherwise go beyond those mandated by rules and regulations, including GO 165, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept. |
| | Other discretionary inspection of transmission electric lines and equipment, beyond inspections mandated by rules and regulations | Inspections of overhead electric transmission lines, equipment, and right-of-way that exceed or otherwise go beyond those mandated by rules and regulations, including GO 165, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems |



| | | |
|--|---|--|
| | | identified, or other aspects of inspection or records kept. |
| | Patrol inspections of distribution electric lines and equipment | In accordance with GO 165, simple visual inspections of overhead electric distribution lines and equipment that is designed to identify obvious structural problems and hazards. Patrol inspections may be carried out in the course of other company business. |
| | Patrol inspections of transmission electric lines and equipment | Simple visual inspections of overhead electric transmission lines and equipment that is designed to identify obvious structural problems and hazards. Patrol inspections may be carried out in the course of other company business. |
| | Pole loading assessment program to determine safety factor | Calculations to determine whether a pole meets pole loading safety factor requirements of GO 95, including planning and information collection needed to support said calculations. Calculations shall consider many factors including the size, location, and type of pole; types of attachments; length of conductors attached; and number and design of supporting guys, per D.15-11-021. |
| | Quality assurance / quality control of inspections | Establishment and function of audit process to manage and confirm work completed by employees or subcontractors, including packaging QA/QC information for input to decision-making and related integrated workforce management processes. |
| | Substation inspections | In accordance with GO 175, inspection of substations performed by qualified persons and according to the frequency established by the utility, including record-keeping. |
| E. Vegetation management and inspection | Additional efforts to manage community and environmental impacts | Plan and execution of strategy to mitigate negative impacts from utility vegetation management to local communities and the environment, such as coordination with communities to plan and execute vegetation management work or promotion of fire-resistant planting practices |
| | Detailed inspections of vegetation around distribution electric lines and equipment | Careful visual inspections of vegetation around the right-of-way, where individual trees are carefully examined, visually, and the condition of each rated and recorded. |
| | Detailed inspections of vegetation around transmission electric lines and equipment | Careful visual inspections of vegetation around the right-of-way, where individual trees are carefully examined, visually, and the condition of each rated and recorded. |
| | Emergency response vegetation management | Plan and execution of vegetation management activities, such as trimming or removal, executed |



| | | |
|--|--|---|
| | due to Red Flag Warning or other urgent conditions | based upon and in advance of forecast weather conditions that indicate high fire threat in terms of ignition probability and wildfire consequence. |
| | Fuel management and reduction of “slash” from vegetation management activities | Plan and execution of fuel management activities that reduce the availability of fuel in proximity to potential sources of ignition, including both reduction or adjustment of live fuel (in terms of species or otherwise) and of dead fuel, including “slash” from vegetation management activities that produce vegetation material such as branch trimmings and felled trees. |
| | Improvement of inspections | Identifying and addressing deficiencies in inspections protocols and implementation by improving training and the evaluation of inspectors. |
| | LiDAR inspections of vegetation around distribution electric lines and equipment | Inspections of right-of-way using LiDAR (light detection and ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances). |
| | LiDAR inspections of vegetation around transmission electric lines and equipment | Inspections of right-of-way using LiDAR (light detection and ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances). |
| | Other discretionary inspections of vegetation around distribution electric lines and equipment | Inspections of rights-of-way and adjacent vegetation that may be hazardous, which exceeds or otherwise go beyond those mandated by rules and regulations, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept. |
| | Other discretionary inspections of vegetation around transmission electric lines and equipment | Inspections of rights-of-way and adjacent vegetation that may be hazardous, which exceeds or otherwise go beyond those mandated by rules and regulations, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept. |
| | Patrol inspections of vegetation around distribution electric lines and equipment | Visual inspections of vegetation along rights-of-way that is designed to identify obvious hazards. Patrol inspections may be carried out in the course of other company business. |
| | Patrol inspections of vegetation around transmission electric lines and equipment | Visual inspections of vegetation along rights-of-way that is designed to identify obvious hazards. Patrol inspections may be carried out in the course of other company business. |
| | Quality assurance / quality control of vegetation inspections | Establishment and function of audit process to manage and confirm work completed by employees or subcontractors, including packaging |



| | | |
|---|--|---|
| | | QA/QC information for input to decision-making and related integrated workforce management processes. |
| | Recruiting and training of vegetation management personnel | Programs to ensure that the utility is able to identify and hire qualified vegetation management personnel and to ensure that both full-time employees and contractors tasked with vegetation management responsibilities are adequately trained to perform vegetation management work, according to the utility's wildfire mitigation plan, in addition to rules and regulations for safety. |
| | Remediation of at-risk species | Actions taken to reduce the ignition probability and wildfire consequence attributable to at-risk vegetation species, such as trimming, removal, and replacement. |
| | Removal and remediation of trees with strike potential to electric lines and equipment | Actions taken to remove or otherwise remediate trees that could potentially strike electrical equipment, if adverse events such as failure at the ground-level of the tree or branch breakout within the canopy of the tree, occur. |
| | Substation inspection | Inspection of vegetation surrounding substations, performed by qualified persons and according to the frequency established by the utility, including record-keeping. |
| | Substation vegetation management | Based on location and risk to substation equipment only, actions taken to reduce the ignition probability and wildfire consequence attributable to contact from vegetation to substation equipment. |
| | Vegetation inventory system | Inputs, operation, and support for centralized inventory of vegetation clearances updated based upon inspection results, including (1) inventory of species, (2) forecasting of growth, (3) forecasting of when growth threatens minimum right-of-way clearances ("grow-in" risk) or creates fall-in/fly-in risk. |
| | Vegetation management to achieve clearances around electric lines and equipment | Actions taken to ensure that vegetation does not encroach upon the minimum clearances set forth in Table 1 of GO 95, measured between line conductors and vegetation, such as trimming adjacent or overhanging tree limbs. |
| F. Grid operations and protocols | Automatic recloser operations | Designing and executing protocols to deactivate automatic reclosers based on local conditions for ignition probability and wildfire consequence. |
| | Crew-accompanying ignition prevention and | Those firefighting staff and equipment (such as fire suppression engines and trailers, firefighting hose, valves, and water) that are deployed with |



| | | |
|---|--|--|
| | suppression resources and services | construction crews and other electric workers to provide site-specific fire prevention and ignition mitigation during on-site work |
| | Personnel work procedures and training in conditions of elevated fire risk | Work activity guidelines that designate what type of work can be performed during operating conditions of different levels of wildfire risk. Training for personnel on these guidelines and the procedures they prescribe, from normal operating procedures to increased mitigation measures to constraints on work performed. |
| | Protocols for PSPS re-energization | Designing and executing procedures that accelerate the restoration of electric service in areas that were de-energized, while maintaining safety and reliability standards. |
| | PSPS events and mitigation of PSPS impacts | Designing, executing, and improving upon protocols to conduct PSPS events, including development of advanced methodologies to determine when to use PSPS, and to mitigate the impact of PSPS events on affected customers and local residents. |
| | Stationed and on-call ignition prevention and suppression resources and services | Firefighting staff and equipment (such as fire suppression engines and trailers, firefighting hose, valves, firefighting foam, chemical extinguishing agent, and water) stationed at utility facilities and/or standing by to respond to calls for fire suppression assistance. |
| G. Data governance | Centralized repository for data | Designing, maintaining, hosting, and upgrading a platform that supports storage, processing, and utilization of all utility proprietary data and data compiled by the utility from other sources. |
| | Collaborative research on utility ignition and/or wildfire | Developing and executing research work on utility ignition and/or wildfire topics in collaboration with other non-utility partners, such as academic institutions and research groups, to include data-sharing and funding as applicable. |
| | Documentation and disclosure of wildfire-related data and algorithms | Design and execution of processes to document and disclose wildfire-related data and algorithms to accord with rules and regulations, including use of scenarios for forecasting and stress testing. |
| | Tracking and analysis of near miss data | Tools and procedures to monitor, record, and conduct analysis of data on near miss events. |
| H. Resource allocation methodology | Allocation methodology development and application | Development of prioritization methodology for human and financial resources, including application of said methodology to utility decision-making. |
| | Risk reduction scenario development and analysis | Development of modeling capabilities for different risk reduction scenarios based on wildfire |



| | | |
|--|--|--|
| | | mitigation initiative implementation; analysis and application to utility decision-making. |
| | Risk spend efficiency analysis | Tools, procedures, and expertise to support analysis of wildfire mitigation initiative risk-spend efficiency, in terms of MAVF and/ or MARS methodologies. |
| I. Emergency planning and preparedness | Adequate and trained workforce for service restoration | Actions taken to identify, hire, retain, and train qualified workforce to conduct service restoration in response to emergencies, including short-term contracting strategy and implementation. |
| | Community outreach, public awareness, and communications efforts | Actions to identify and contact key community stakeholders; increase public awareness of emergency planning and preparedness information; and design, translate, distribute, and evaluate effectiveness of communications taken before, during, and after a wildfire, including Access and Functional Needs populations and Limited English Proficiency populations in particular. |
| | Customer support in emergencies | Resources dedicated to customer support during emergencies, such as website pages and other digital resources, dedicated phone lines, etc. |
| | Disaster and emergency preparedness plan | Development of plan to deploy resources according to prioritization methodology for disaster and emergency preparedness of utility and within utility service territory (such as considerations for critical facilities and infrastructure), including strategy for collaboration with Public Safety Partners and communities. |
| | Preparedness and planning for service restoration | Development of plans to prepare the utility to restore service after emergencies, such as developing employee and staff trainings, and to conduct inspections and remediation necessary to re-energize lines and restore service to customers. |
| | Protocols in place to learn from wildfire events | Tools and procedures to monitor effectiveness of strategy and actions taken to prepare for emergencies and of strategy and actions taken during and after emergencies, including based on an accounting of the outcomes of wildfire events. |
| J. Stakeholder cooperation and community engagement | Community engagement | Strategy and actions taken to identify and contact key community stakeholders; increase public awareness and support of utility wildfire mitigation activity; and design, translate, distribute, and evaluate effectiveness of related communications. Includes specific strategies and actions taken to address concerns and serve needs of Access and |



| | | |
|--|---|--|
| | | Functional Needs populations and Limited English Proficiency populations in particular. |
| | Cooperation and best practice sharing with agencies outside CA | Strategy and actions taken to engage with agencies outside of California to exchange best practices both for utility wildfire mitigation and for stakeholder cooperation to mitigate and respond to wildfires. |
| | Cooperation with suppression agencies | Coordination with CAL FIRE, federal fire authorities, county fire authorities, and local fire authorities to support planning and operations, including support of aerial and ground firefighting in real-time, including information-sharing, dispatch of resources, and dedicated staff. |
| | Forest service and fuel reduction cooperation and joint roadmap | Strategy and actions taken to engage with local, state, and federal entities responsible for or participating in forest management and fuel reduction activities; and design utility cooperation strategy and joint stakeholder roadmap (plan for coordinating stakeholder efforts for forest management and fuel reduction activities). |



- Attachment 3: Glossary of Terms

| Term | Definition |
|---------------|---|
| AB | Assembly Bill |
| AFN | Access and Functional Needs |
| ALJ | Administrative Law Judge |
| BVES | Bear Valley Electric Service |
| CAISO | California Independent System Operator |
| Cal Advocates | Public Advocate's Office |
| CAL FIRE | California Department of Forestry and Fire Protection |
| CEJA | California Environmental Justice Alliance |
| CNRA | California Natural Resources Agency |
| D. | Decision |
| DFA | Distribution Fault Attribution |
| DR | Data Request |
| EBMUD | East Bay Municipal Utility District |
| EFD | Early Fault Detection |
| EPIC | Electric Program Investment Charge |
| EPUC | Energy Producers and Users Coalition |
| EVM | Enhanced Vegetation Management |
| FERC | Federal Energy Regulatory Commission |
| FGDC | Federal Geographic Data Committee |
| FIRIS | Fire Integrated Real Time Intelligence System |
| FMEA | Failure Modes and Effects Analysis |
| FPI | Fire Potential Index |
| GIS | Geographic Information Systems |
| GO | General Order |



| Term | Definition |
|----------------------|---|
| GPI | Green Power Institute |
| GRC | General Rate Case |
| HFRA | High Fire Risk Area |
| HFTD | High Fire Threat District |
| Horizon West | Horizon West Transmission |
| HWT | Horizon West Transmission |
| I. | Investigation |
| ICS | Incident Command System |
| ICS | Incident Command Structure |
| IOU | Investor-Owned Utility |
| ISA | International Society of Arboriculture |
| ITO | Independent Transmission Operator |
| IVM | Integrated Vegetation Management Plan |
| IVR | Interactive Voice Response |
| JIS | Joint Information System |
| kV | Kilovolt |
| Liberty | Liberty Utilities / CalPeco Electric |
| LiDAR | Light Detection and Ranging |
| LTE | Long-Term Evolution |
| Maturity Model | Utility Wildfire Mitigation Maturity Model |
| MAVF | Multi-Attribute Value Function |
| MGRA | Mussey Grade Road Alliance |
| MMAA | Mountain Mutual Aid Association |
| NERC | North American Electric Reliability Corporation |
| NFDRS | National Fire Danger Rating System |
| OCFA | Orange County Fire Authority |
| OEIS (Energy Safety) | Office of Energy Infrastructure Safety |
| OP | Ordering Paragraph |
| OPW | Outage Producing Winds |



| Term | Definition |
|------------------|--|
| PG&E | Pacific Gas and Electric Company |
| PLP | Pole Loading Assessment Program |
| PMO (PacifiCorp) | Project Management Office |
| PMO (SCE) | Public Safety Program Management Office |
| PMU | Phasor Measurement Unit |
| POC | Protect Our Communities Foundation |
| PRC | Public Resources Code |
| PSPS | Public Safety Power Shutoff |
| QA | Quality Assurance |
| QC | Quality Control |
| R. | Rulemaking |
| RAMP | Risk Assessment and Management Phase |
| RAR | Remote Automatic Reclosers |
| RBDM | Risk-Based Decision Making |
| RCP | Remedial Compliance Plan |
| RCRC | Rural County Representatives of California |
| REFCL | Rapid Earth Fault Current Limiter |
| RFW | Red Flag Warning |
| RSE | Risk-Spend Efficiency |
| SB | Senate Bill |
| SCADA | Supervisory Control and Data Acquisition |
| SCE | Southern California Edison Company |
| SDG&E | San Diego Gas & Electric Company |
| S-MAP | Safety Model Assessment Proceeding |
| SMJU | Small and Multijurisdictional Utility |



| Term | Definition |
|-------------|------------------------------------|
| SUI | Wildland-Urban Interface |
| SWATI | Santa Ana Wildfire Threat Index |
| TAT | Tree Assessment Tool |
| TBC | Trans Bay Cable |
| TURN | The Utility Reform Network |
| USFS | United States Forest Service |
| WMP | Wildfire Mitigation Plan |
| WRRM | Wildfire Risk Reduction Model |
| WSAB | Wildfire Safety Advisory Board |
| WSD | Wildfire Safety Division |
| WSIP | Wildfire Safety Inspection Program |