



September 2, 2025

Jaime Hoffman
President – Trans Bay Cable
P.O. Box 666
Pittsburg, CA 94565

SUBJECT: Notice on Errata for the Trans Bay Cable 2026-2028 Base Wildfire Mitigation Plan

Mr. Hoffman:

Trans Bay Cable's (TBC) submitted its 2026-2028 Base Wildfire Mitigation Plan (2026-2028 Base WMP) to the Office of Energy Infrastructure Safety's (Energy Safety) 2026-2028 Base WMPs docket (#2026-2028-Base-WMPs) on July 25, 2025.^{1, 2} Energy Safety identified the substantive and non-substantive errors listed in Table 1 of this Notice on Errata for TBC to correct.

TBC must revise its 2026-2028 Base WMP R0 to correct the errors identified in Table 1, herein. TBC must submit its revised 2026-2028 Base WMP to Energy Safety's 2026-2028 Base WMPs docket by September 16, 2025.

If TBC, during its review, identifies additional non-substantive errors (spelling, grammar, etc.), it may make corrections to its 2026-2028 Base WMP beyond those listed in Table 1. If TBC makes additional corrections, it must provide a list of each correction in its cover letter that will accompany its response to this Notice on Errata.


The schedule for this TBC Notice on Errata is as follows:

Revised TBC 2026-2028 Base WMP R1	September 16, 2025
Energy Safety Draft Decision Issued No Later Than	November 26, 2025

¹ TBC, 2026-2028 Base WMP

² Office of Energy Infrastructure Safety, [2026 - 2028 Electrical Corporation Wildfire Mitigation Plans docket](https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2026-2028-Base-WMPs), Accessed April 10, 2025, (URL:<https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2026-2028-Base-WMPs>).

Sincerely,

A handwritten signature in black ink, appearing to read "Nicole Dunlap". The signature is fluid and cursive, with a prominent initial "N" and a long, sweeping underline.

Nicole Dunlap
Program Manager | Electrical Safety Policy Division
Office of Energy Infrastructure Safety

Encl: Table 1: Errors in the TBC 2026-2028 Base WMP.

Table 1. Errors in the TBC 2026-2028 Base WMP R0

Section	WMP Page Number	Correction or Clarification
Section 10	140-142	<p>The WMP Guidelines require that each Base WMP cover a three-year period designated by Energy Safety.³ TBC must revise its Base WMP to include only activities scheduled for the 2026-2028 Base WMP cycle or must explain why out-of-cycle activities are relevant to the 2026-2028 Base WMP cycle. For example:</p> <p>a. In <i>Table 10-1, Situational Awareness Targets by Year</i>, TBC reported activities scheduled for completion in 2025 within its 2026-2028 Base WMP, such as Utilization of Technosylva's Wildfire Analyst Platform (SA-02) and Completion of Upgrades to Optos/Firecaster (SA-02).⁴</p>
Section 8, 10	102, 147	<p>Version 5 of TBC's Maintenance Practices, approved by CAISO in 2024, switches TBC's asset inspection from weekly and monthly inspections to just monthly inspections, effective January 1, 2025.⁵</p> <p>However, TBC's 2026-2028 Base WMP is inconsistent with the approved practices and still states "weekly" in some sections instead of "monthly." TBC must revise its inspection interval to align with Version 5 of TBC's Maintenance Practice.⁶ For example:</p>

³ WMP Guidelines, Chapter I, Section 3.1, page 2.

⁴ TBC, 2026-2028 Base WMP, Section 10.1, pages 140-142.

⁵ TBC, 2026-2028 Base WMP, Section 8.3.1.3, page 81.

⁶ TBC, 2026-2028 Base WMP, Section 8.3.1.3, page 81.

Section	WMP Page Number	Correction or Clarification
		<ul style="list-style-type: none">a. In Section 8.7.3, Personnel Work Procedures and Training Conditions of Elevated Fire Risk, TBC states, “TBC Operations personnel are trained on all relevant TBC procedures, including regular weekly inspections...”⁷b. In Section 10.3, Grid Monitoring Systems, TBC states, “TBC also performs weekly asset inspections...”⁸
Section 8	67	<p>TBC repeated sub-section titles in its 2026-2028 Base WMP, and TBC must correct its section titles to conform to the WMP Guidelines. For example:</p> <ul style="list-style-type: none">a. Both Sections 8.1.1 and 8.1.2 are titled “Qualitative Targets,”⁹ whereas Section 8.1.2 must be “Quantitative Targets” per the WMP Guidelines.¹⁰

⁷ TBC, 2026-2028 Base WMP, Section 8.7.3, page 102.

⁸ TBC, 2026-2028 Base WMP, Section 10.3, page 147.

⁹ TBC, 2026-2028 Base WMP, Section 10.3, pages 66-67.

¹⁰ WMP Guidelines, pages 80-81.

Appendix A: References Table

Citation	Reference
TBC, 2026-2028 Base WMP	Trans Bay Cable, TBC 2026-2028 Base WMP R0 , Published July 28, 2025, URL:(https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=59060&shareable=true)
WMP Guidelines	Office of Energy Infrastructure Safety, Wildfire Mitigation Plan Guidelines , Published February 24, 2025, URL:(https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=58026&shareable=true).
Policy Division Process Guidelines	Office of Energy Infrastructure Safety, Policy Division Process Guidelines , Published February 24, 2025, URL:(https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=58025&shareable=true).
#2026-2028-Base-WMPs	Office of Energy Infrastructure Safety, 2026 - 2028 Electrical Corporation Wildfire Mitigation Plans docket , Accessed April 10, 2025, (URL: https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2026-2028-Base-WMPs).