

December 5, 2025

*VIA ELECTRONIC FILING*

Docket # 2025 NON

Sheryl Bilbrey  
Program Manager  
Environmental Science Division  
Office of Energy Infrastructure Safety  
715 P Street, 20th Floor  
Sacramento, CA 95814  
[Sheryl.Bilbrey@energysafety.ca.gov](mailto:Sheryl.Bilbrey@energysafety.ca.gov)

**RE: PacifiCorp's Response to Notice of Non-Performance – PC\_AKM\_20250911\_1105**

Dear Sheryl Bilbrey:

PacifiCorp provides the following response to the finding identified in the “Notice of Non-Performance *NON\_ESD\_PC\_AKM\_20250911\_1105*” (NON) issued by the Office of Energy Infrastructure Safety (Energy Safety) on November 6, 2025. On September 11, 2025, Energy Safety conducted an inspection of PacifiCorp’s WMP initiatives in the vicinity of the city of Sims, California.

Energy Safety found the following deficiency:

**Deficiency 1.** Energy Safety observed that in implementing 2025 WMP initiative 8.2.3.1.1 Wood and Slash Management, PacifiCorp failed to adhere to its protocol of managing wood and slash near Pole ID 06236005-026002, Vegetation Management ID DN\_Insp\_2025\_5G99 at coordinates 41.003248, -122.407049. Energy Safety considers this non-performance to be in the Minor risk category.

**PacifiCorp Response:**


In response to the NON, the company conducted a field inspection, and the site was cleaned in accordance with PacifiCorp’s standard operating procedures on November 21, 2025. All debris was removed in compliance with these procedures, as shown in the below photos.



**Picture 1: Near Pole ID 06236005-026002, at Coordinates 41.003248, -122.407049. Picture taken November 21, 2025.**



**Picture 2: Near Pole ID 06236005-026002, at Coordinates 41.003248, -122.407049. Picture taken November 21, 2025.**



**Picture 3: Near Pole ID 06236005-026002, at Coordinates 41.003248, -122.407049. Picture taken November 21, 2025.**

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NON\_ESD\_PC\_AKM\_20250911\_1105.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at [pooja.kishore@pacificorp.com](mailto:pooja.kishore@pacificorp.com) and [californiadockets@pacificorp.com](mailto:californiadockets@pacificorp.com).

Sincerely,

*Carrie Laird*

Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: [environmentalscience@energysafety.ca.gov](mailto:environmentalscience@energysafety.ca.gov)

[Akiko.Masuda@energysafety.ca.gov](mailto:Akiko.Masuda@energysafety.ca.gov)

[Elizabeth.McAlpine@energysafety.ca.gov](mailto:Elizabeth.McAlpine@energysafety.ca.gov)