

January 21, 2026

VIA ELECTRONIC FILING

Docket # 2024 NON

Patrick Doherty
Program Manager
Performance Assessment Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Patrick.Doherty@energysafety.ca.gov

RE: PacifiCorp's Response to Notice of Non-Performance – PC_IAG_20250522_1252

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the Notice of Non-Performance (NON), *NON_CAD_PC_IAG_20250522_1252* issued by the Office of Energy Infrastructure Safety (Energy Safety) on December 22, 2025. On May 22, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Yreka, California.

Energy Safety found the following deficiency:

Deficiency 1. Energy Safety observed that in implementing 2024 WMP initiative 8.1.2.12 - Expulsion Fuse Replacements, PC failed to complete the installation of CAL FIRE-approved non expulsion fuses on Pole ID 624507.272701, Grid Hardening ID 7074439 at coordinates 41.7241174853914, -122.645554862033. Energy Safety considers this non-performance to be in the Minor risk category. PC must complete a corrective action for this deficiency by 12 months from date of this notice.

PacifiCorp Response:

In response to the notice of non-performance, the company conducted a field inspection and corrective action has been completed for the Notice of Non-Performance associated with Pole ID 06245007.272701. Currently the two open fuses are not being used as there is no need for three-phase loads at this location. If there is a need for three phases in the future, the conductors will be tested and energized to support that future load.



Picture 1: Near Pole ID 624507.272701, at Coordinates 41.7241174853914, -122.645554862033. Picture taken January 13, 2026.



Picture 2: Near Pole ID 624507.272701, at Coordinates 41.7241174853914, -122.645554862033. Picture taken January 13, 2026.



Picture 3: Near Pole ID 624507.272701, at Coordinates 41.7241174853914, -122.645554862033. Picture taken January 13, 2026.



Picture 4: Near Pole ID 624507.272701, at Coordinates 41.7241174853914, -122.645554862033. Picture taken January 13, 2026.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NON_CAD_PC_IAG_20250522_1252.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,

Carrie Laird

Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: assetperformance@energysafety.ca.gov

Shannon.Greene@energysafety.ca.gov

Yana.Loginova@energysafety.ca.gov

Babak.Kaviani@energysafety.ca.gov

Samuel.Isaiah@energysafety.ca.gov

Ivan.Garcia@energysafety.ca.gov

Patrick.Doherty@energysafety.ca.gov