



February 3, 2026

Daniel Kushner
Senior Director, Electric Risk & Compliance
Pacific Gas and Electric Company
300 Lakeside Drive
Oakland, CA 94612

NOTICE OF DATA INACCURACY

Mr. Kushner:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by Pacific Gas and Electric Company (PG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy prior to the submission of PG&E's 2025 Annual Implementation Report may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PG&E to miss a WMP target or prevents Energy Safety from ensuring that PG&E performed the targets and statements made in PG&E's 2025 WMP.

On November 4, 2025, Energy Safety conducted an inspection of Pacific Gas and Electric Company's WMP initiatives in the vicinity of the city of Placerville, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 121157324, Grid Hardening ID 5020410E-2BAC-41B3-8668-E49899519422 at coordinates 38.7239480000341, -120.788760000523, the inspector observed that PG&E failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PG&E reached the target set in WMP initiative Grid Design and System Hardening when it has not. If PG&E does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to down conductor detection devices, PG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Report on PG&E's WMP Performance.

Within 30 days from the issuance date of this NODI, PG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,¹ and the associated file name(s) must begin with the NODI identification number.

Sincerely,

Patrick Doherty

Patrick Doherty
Program Manager | Performance Assessment Division
Office of Energy Infrastructure Safety
Patrick.Doherty@energysafety.ca.gov

Cc:

Wade Greenacre, PG&E
WAG9@pge.com
Mandy Knockaert, PG&E
ARKN@pge.com
Electric Data Requests
ElectricDataRequests@pge.com

Alexander Scott, Energy Safety
Alexander.scott@energysafety.ca.gov
Yana Loginova, Energy Safety
Yana.Loginova@energysafety.ca.gov
Babak Kaviani, Energy Safety
Babak.Kaviani@energysafety.ca.gov
Samuel Isaiah, Energy Safety
Samuel.Isaiah@energysafety.ca.gov
Shannon Greene, Energy Safety
Shannon.Greene@energysafety.ca.gov
assetperformance@energysafety.ca.gov

¹ <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



State of California – A Natural Resources Agency

OFFICE OF ENERGY INFRASTRUCTURE SAFETY

715 P Street, 20th Floor | Sacramento, CA 95814

916.902.6000 | www.energysafety.ca.gov

Gavin Newsom, Governor

Caroline Thomas Jacobs, Director

INSPECTION REPORT

Electrical Corporation:	Pacific Gas and Electric Company
Report Number:	PAD_PGE_AXS_20251104_1051
Date of inspection:	November 4, 2025
City and/or County of Inspection:	Placerville, El Dorado County
Inspector:	Alexander Scott
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 2 (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.10.1 – Down Conductor Detection Devices
Inspection Purpose:	Assess the accuracy of Pacific Gas and Electric Company's QDR data, completeness of its work, and performance of WMP requirements.

WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	121157324	{5020410E-2BAC-41B3-8668-E49899519422}	38.7239480000341, -120.788760000523	Tier 2	8.1.2.10.1 – Down Conductor Detection Devices	Inaccurate data provided on DCD device installation.

Observations

On Pole ID121157324, Grid Hardening ID {5020410E-2BAC-41B3-8668-E49899519422} at 3233-3251 Washington St, Placerville, CA, 95667, USA, 38.7239480000341, -120.788760000523, the inspector observed a Down Conductor Detection Device (DCD) was not present at the coordinates provided. The nearest DCD installed was 94.5 yards away on a different pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there is inaccurate data because of these facts:

1. PG&E reported in the 2025 Q2 QDR that work on WMP initiative 8.1.2.10.1 – Down Conductor Detection Devices was completed at this location.
2. The inspector did not observe a DCD at this location.

This observation warrants a notice of data inaccuracy. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

Exhibits

Exhibit A: Photo Log

Structure ID: 121157324

Data Inaccuracy 1

	
GImg1: Overall Structure	GImg2: Structure ID