



February 3, 2026

Crystal Bertolini  
Team Lead, Wildfire Mitigation Program Compliance  
San Diego Gas & Electric Company  
8316 Century Park Court, CP32F  
San Diego, CA 92123

### **NOTICE OF DATA INACCURACY**

Ms. Bertolini:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by San Diego Gas & Electric Company (SDG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues SDG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy prior to the submission of SDG&E's 2025 Annual Implementation Report may lead to a Notice of Non-Performance (NON) if the inaccuracy causes SDG&E to miss a WMP target or prevents Energy Safety from ensuring that SDG&E performed the targets and statements made in SDG&E's 2025 WMP.

On October 8, 2025, Energy Safety conducted an inspection of San Diego Gas & Electric Company's WMP initiatives in the vicinity of the city of Valley Center, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID P612194, Grid Hardening ID P612194\_0350-L-CC\_83638 at coordinates 33.3146668789374, -117.102580, the inspector observed that SDG&E failed to provide accurate data.

The data inaccuracy identified in this notice could make it appear as though SDG&E reached the target set in its WMP initiative related to covered conductor installation when it has not. If SDG&E does not address this data inaccuracy and includes the inaccurate data in SDG&E's reporting regarding its WMP initiative related to covered conductor installation, SDG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on SDG&E's WMP Performance.

Within 30 days from the issuance date of this NODI, SDG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,<sup>1</sup> and the associated file name(s) must begin with the NODI identification number.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.doherty@energysafety.ca.gov](mailto:Patrick.doherty@energysafety.ca.gov)

Cc:

[WildfireMitigationCompliance@sdge.com](mailto:WildfireMitigationCompliance@sdge.com)

Jonathan Woldemariam, SDG&E

[JWoldemariam@sdge.com](mailto:JWoldemariam@sdge.com)

Kari Kloberdanz, SDG&E

[KKloberdanz@sdge.com](mailto:KKloberdanz@sdge.com)

Shewit Woldegiorgis, SDG&E

[SWoldegiorgis@sdge.com](mailto:SWoldegiorgis@sdge.com)

Laura Fulton, SDG&E

[LFulton@sdge.com](mailto:LFulton@sdge.com)

Kimberly Siebenthal, SDG&E

[KSiebenthal@sdge.com](mailto:KSiebenthal@sdge.com)

Mary Innamorato, SDG&E

[MInnamorato@sdge.com](mailto:MInnamorato@sdge.com)

Yana Loginova, Energy Safety

[Yana.Loginova@energysafety.ca.gov](mailto:Yana.Loginova@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

[Assetperformance@energysafety.ca.gov](mailto:Assetperformance@energysafety.ca.gov)

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



**State of California – A Natural Resources Agency**  
**OFFICE OF ENERGY INFRASTRUCTURE SAFETY**  
715 P Street, 20th Floor | Sacramento, CA 95814  
916.902.6000 | [www.energysafety.ca.gov](http://www.energysafety.ca.gov)

**Gavin Newsom, Governor**  
**Caroline Thomas Jacobs, Director**

## INSPECTION REPORT

Electrical Corporation:	San Diego Gas and Electric Company
Report Number:	PAD_SDGE_SIS_20251008_1332
Date of Inspection:	October 8, 2025
City and/or County of Inspection:	Valley Center, San Diego County
Inspector:	Samuel Isaiah
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 2 (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.1 – Covered Conductor Installation (WMP.455)
Inspection Purpose:	Assess the accuracy of San Diego Gas and Electric Company's QDR data, completeness of its work, and performance of WMP requirements.

## WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	P612194	P612194_0350-L-CC_83638	33.3146668789374, -117.102580	Tier 2	<a href="#">8.1.2.1</a> Covered conductor installation	Inaccurate data provided on covered conductor installation

# Observations

## Data Inaccuracy 1

### **Findings:**

On Pole ID P612194, Grid Hardening ID P612194\_0350-L-CC\_83638 at 10562-10798 Camino del Venado, Valley Center, CA, 92082, 33.3146668789374, -117.102580, the inspector observed that no covered conductor was installed at this location. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as IA1Img1, IA1Img2, IA1Img3 and IA1Img4.

Energy Safety concludes that there is inaccurate data because of these facts:

1. SDG&E's 2025 Q2 QDR identified that WMP Covered Conductor (8.1.2.1) work was complete at the inspection location.
2. Covered conductor was not installed.

This observation indicates that the data regarding covered conductor installation was not accurate. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

# Exhibits

## Exhibit A: Photo Log


Structure ID: P612194

Data Inaccuracy 1



**GImg1:** Overall Structure

**GImg2:** Structure ID



**IA1Img1:** No Covered Conductor observed

**IA1Img2:** No Covered Conductor observed



**IA1Img3:** No Covered Conductor observed



**IA1Img4:** No Covered Conductor observed