

February 23, 2026

VIA ELECTRONIC FILING

Docket # 2025 NON

Patrick Doherty
Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Patrick.Doherty@energysafety.ca.gov

RE: PacifiCorp's Response to Notice of Non-Performance – PAD_PC_IAG_20251007_0944

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the “Notice of Non-Performance, “*NON_PAD_PC_IAG_20251007_0944*” (NON) issued by the Office of Energy Infrastructure Safety (Energy Safety) on January 23, 2026. On October 7, 2025, Energy Safety conducted an inspection of PacifiCorp’s WMP initiatives in the vicinity of the city of Montague, California.

Energy Safety found the following deficiency:


Deficiency 1. Energy Safety observed that in implementing 2025 WMP initiative 8.1.2.12 - Expulsion Fuse Replacements, PC failed to complete the installation of CAL FIRE-approved non expulsion fuses on a pole with work associated with Grid Hardening ID 7112939 at coordinates 41.71146536840899, -122.59407909092792. Energy Safety considers this non-performance to be in the Minor risk category.

PacifiCorp Response:

In response to the Notice of Non-performance, PacifiCorp conducted a field inspection and confirmed that solid blades are installed at this location. Although these installations were reported as complete in 2024, CAL FIRE has not yet updated its standard to recognize solid blades as non-expulsion alternatives for line fuses. Consequently, PacifiCorp has discontinued counting similar installations as completed units; however, the existing installations will remain in place. PacifiCorp conducted a field inspection on January 29, 2026, and confirmed that solid blades are installed at this location. This location remains non-exempt.

5G149.06245007.0369960

Solid blade fuses.



Picture 1: Near Grid Hardening ID 7112939 at coordinates 41.71146536840899, -122.59407909092792. Picture taken January 29, 2026.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NON_PAD_PC_IAG_20251007_0944.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,

Carrie Laird

Carrie Laird
Vice President, Wildfire Mitigation and Emergency Operations

cc: assetperformance@energysafety.ca.gov
Shannon.Greene@energysafety.ca.gov
Yana.Loginova@energysafety.ca.gov
Babak.Kaviani@energysafety.ca.gov
Samuel.Isaiah@energysafety.ca.gov
Ivan.Garcia@energysafety.ca.gov
Patrick.Doherty@energysafety.ca.gov