



February 26, 2026

Joshua Jones  
Vice President of Transmission & Distribution Operations  
PacifiCorp  
1700 NE Multnomah, Suite 2000  
Portland, OR 97232

## **NOTICE OF DATA INACCURACY**

Mr. Jones:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by PacifiCorp (PC) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PC a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PC to miss a WMP target or prevents Energy Safety from ensuring that PC performed the targets and statements made in PC's 2025 WMP.

On October 8, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 06241005.026700, Grid Hardening ID 8077661s at coordinates 41.4315635714616, -122.388970, the inspector observed that PC failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PC reached the target set in its WMP initiative related to covered conductor installation when it has not. If PC does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to covered conductor installation, PC may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on PC's WMP Performance.

Within 30 days from the issuance date of this NODI, PC should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,<sup>1</sup> and the associated file name(s) must begin with the NODI identification number.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

Cc:

[californiadockets@pacificorp.com](mailto:californiadockets@pacificorp.com)

Megan Buckner, PacifiCorp

[Megan.Buckner@pacificorp.com](mailto:Megan.Buckner@pacificorp.com)

Pooja Kishore, PacifiCorp

[Pooja.Kishore@pacificorp.com](mailto:Pooja.Kishore@pacificorp.com)

Tim Clark, PacifiCorp

[Tim.Clark@pacificorp.com](mailto:Tim.Clark@pacificorp.com)

Jonathan Moulton, PacifiCorp

[Jonathan.Moulton@pacificorp.com](mailto:Jonathan.Moulton@pacificorp.com)

Bruce Dao, PacifiCorp

[Bruce.Dao@pacificorp.com](mailto:Bruce.Dao@pacificorp.com)

Melissa Swenson, PacifiCorp

[Melissa.Swenson@pacificorp.com](mailto:Melissa.Swenson@pacificorp.com)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

Babak Kaviani, Energy Safety

[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

[assetperformance@energysafety.ca.gov](mailto:assetperformance@energysafety.ca.gov)

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



# INSPECTION REPORT

Electrical Corporation:	PacifiCorp
Report Number:	PAD_PC_BKA_20251008_1455
Date of Inspection:	October 8, 2025
City and/or County of Inspection:	Weed, Siskiyou County
Inspector:	Babak Kaviani
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter 2 (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.1 – Covered conductor installation
Inspection Purpose:	Assess the accuracy of PacifiCorp’s QDR data, completeness of its work, and performance of WMP requirements.

## WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	06241005.026700	8077661s	41.4315635714616, -122.388970	Tier 2	8.1.2.1 – Covered conductor installation	Inaccurate data provided on covered conductor installation.

# Observations

On Pole ID 06241005.026700, Grid Hardening ID 8077661s at Mile 0.7 US Hwy 97 N, Weed, CA, 96094, USA, 41.4315635714616, -122.388970, the inspector observed that no covered conductor was installed south of the subject pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there are inaccurate data because of these facts:

1. PC reported in the 2025 Q2 QDR that work on WMP initiative 8.1.2.1 – Covered conductor installation was completed at this location.
2. The inspector did not observe covered conductor installed south of the subject pole.

This observation warrants a notice of data inaccuracy. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

# Exhibits

Exhibit A: Photo Log

Structure ID: 06241005026700

Data Inaccuracy 1



**G1mg1:** Overall structure, south-facing view with no covered conductor installed south of Pole 06241005026700



**G1mg2:** Structure ID



**IA1Img1:** North-facing view showing no overhead conductor installed south of Pole 06241005026700



**IA1Img2:** East-facing view showing riser and no covered conductor installed south of Pole 06241005026700