



February 26, 2026

Joshua Jones
Vice President of Transmission & Distribution Operations
PacifiCorp
1700 NE Multnomah, Suite 2000
Portland, OR 97232

NOTICE OF DATA INACCURACY

Mr. Jones:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by PacifiCorp (PC) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PC a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PC to miss a WMP target or prevents Energy Safety from ensuring that PC performed the targets and statements made in PC's 2025 WMP.

On October 8, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 06241005.026600, Grid Hardening ID 8077661v at coordinates 41.430785127256, -122.388902, the inspector observed that PC failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PC reached the target set in its WMP initiative related to covered conductor installation when it has not. If PC does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to covered conductor installation, PC may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on PC's WMP Performance.

Within 30 days from the issuance date of this NODI, PC should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,¹ and the associated file name(s) must begin with the NODI identification number.

Sincerely,

Patrick Doherty

Patrick Doherty
Program Manager | Performance Assessment Division
Office of Energy Infrastructure Safety
Patrick.Doherty@energysafety.ca.gov

Cc:

californiadockets@pacificorp.com

Megan Buckner, PacifiCorp

Megan.Buckner@pacificorp.com

Pooja Kishore, PacifiCorp

Pooja.Kishore@pacificorp.com

Tim Clark, PacifiCorp

Tim.Clark@pacificorp.com

Jonathan Moulton, PacifiCorp

Jonathan.Moulton@pacificorp.com

Bruce Dao, PacifiCorp

Bruce.Dao@pacificorp.com

Melissa Swenson, PacifiCorp

Melissa.Swenson@pacificorp.com

Shannon Greene, Energy Safety

Shannon.Greene@energysafety.ca.gov

Babak Kaviani, Energy Safety

Babak.Kaviani@energysafety.ca.gov

Samuel Isaiah, Energy Safety

Samuel.Isaiah@energysafety.ca.gov

assetperformance@energysafety.ca.gov

¹ <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



INSPECTION REPORT

| | |
|---|--|
| Electrical Corporation: | PacifiCorp |
| Report Number: | PAD_PC_BKA_20251008_1424 |
| Date of Inspection: | October 8, 2025 |
| City and/or County of Inspection: | Weed, Siskiyou County |
| Inspector: | Babak Kaviani |
| WMP Year Inspected: | 2025 |
| Quarterly Data Report (QDR) Referenced: | Quarter 2 (Q2) |
| Inspection Selection: | Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report. |
| Relevant WMP Initiative(s): | 8.1.2.1 – Covered conductor installation |
| Inspection Purpose: | Assess the accuracy of PacifiCorp’s QDR data, completeness of its work, and performance of WMP requirements. |

WMP Inspection Data Inaccuracies

| Data Inaccuracy # | Structure ID | Grid Hardening ID | Lat/Long | HFTD | Initiative Number | Data Inaccuracy Description |
|-------------------|-----------------|-------------------|---------------------------------|--------|--|---|
| Data Inaccuracy 1 | 06241005.026600 | 8077661v | 41.430785127256, -122.388902 | Tier 2 | 8.1.2.1 – Covered conductor installation | Inaccurate data provided on covered conductor installation. |

Observations

On Pole ID 06241005026600, Grid Hardening ID 8077661v at Mile 0.6 US Hwy 97 S, Weed, CA, 96094, USA, 41.430785127256, -122.388902, the inspector observed that no covered conductor was installed west of the subject pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there are inaccurate data because of these facts:

1. PC reported in the 2025 Q2 QDR that work on WMP initiative 8.1.2.1 – Covered conductor installation was completed at this location.
2. The inspector did not observe covered conductor installed west of the subject pole.

This observation warrants a notice of data inaccuracy. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

Exhibits

Exhibit A: Photo Log

Structure ID: 06241005.026600

Data Inaccuracy 1



G1mg1: Overall Structure



G1mg2: Structure ID



Gimg3: West-facing view showing no covered conductor installed west of Pole 06241005026600