



March 5, 2026

Daniel Kushner
Senior Director, Electric Risk & Compliance
Pacific Gas and Electric Company
300 Lakeside Drive
Oakland, CA 94612

NOTICE OF DATA INACCURACY

Mr. Kushner:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by Pacific Gas and Electric Company (PG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy PG&E may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PG&E to miss a WMP target or prevents Energy Safety from ensuring that PG&E performed the targets and statements made in PG&E 2025 WMP.

On November 5, 2025, Energy Safety conducted an inspection of Pacific Gas and Electric Company's WMP initiatives in the vicinity of the city of Greenwood, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 121774370, Grid Hardening ID 35293664 at coordinates 38.8946392264835, -120.910976913624, the inspector observed that PG&E failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PG&E reached the target set in its WMP initiative related to Grid Design and System Hardening when it has not. If PG&E does not address this data inaccuracy and includes the inaccurate data in its reporting regarding the WMP initiative related to Grid Design and System Hardening, PG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on PG&E's WMP Performance.

Within 30 days from the issuance date of this NODI, PG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,¹ and the associated file name(s) must begin with the NODI identification number.

Sincerely,

Patrick Doherty

Patrick Doherty
Program Manager | Performance Assessment Division
Office of Energy Infrastructure Safety
Patrick.Doherty@energysafety.ca.gov

Cc:

Wade Greenacre, PG&E

WAG9@pge.com

Mandy Knockaert, PG&E

ARKN@pge.com

Electric Data Requests

ElectricDataRequests@pge.com

Romeo Marroquin Ajcac, Energy Safety

Romeo.MarroquinAjcac@energysafety.ca.gov

Babak Kaviani, Energy Safety

Babak.Kaviani@energysafety.ca.gov

Samuel Isaiah, Energy Safety

Samuel.Isaiah@energysafety.ca.gov

Shannon Greene, Energy Safety

Shannon.Greene@energysafety.ca.gov

assetperformance@energysafety.ca.gov

¹ <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



INSPECTION REPORT

Electrical Corporation:	Pacific Gas and Electric Company
Report Number:	PAD_PGE_BKA_20251105_1110
Date of Inspection:	November 5, 2025
City and/or County of Inspection:	Greenwood, El Dorado County
Inspector:	Babak Kaviani
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.2.1 Covered Conductor Installation – Distribution
Inspection Purpose:	Assess the accuracy of Pacific Gas and Electric Company’s QDR data, completeness of its work, and performance of WMP requirements.

WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	121774370	35293664	38.8946392264835, -120.910976913624	Tier 2	8.1.2.1 – Covered Conductor Installation – Distribution	Inaccurate data provided on covered conductor installation.

Observations

On Pole ID 121774370, Grid Hardening ID 35293664 at 2641 Greenwood Rd, Greenwood, CA, 95635, USA, 38.8946392264835, -120.910976913624, the inspector observed no covered conductor installation between Pole ID 121774370 (southeast side) and Pole ID 121471467 (northwest side). The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there are inaccurate data because of these facts:

1. PG&E reported in the 2025 Q2 QDR that work on WMP initiative 8.1.2.1 – Covered Conductor Installation – Distribution was completed at this location.
2. The inspector did not observe covered conductor installed between Pole ID 121774370 (southeast side) and Pole ID 121471467 (northwest side).
3. The inspector observed bare conductor between Pole ID 121774370 (southeast side) and Pole ID 121471467 (northwest side).

This observation warrants a notice of data inaccuracy. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

Exhibits

Exhibit A: Photo Log

Structure ID: 121774370 & 121471467

Data Inaccuracy 1

	
<p>G1mg1: Overall structure, southeast-facing view with no covered conductor installed southeast of Pole 121774370</p>	<p>G1mg2: Structure ID</p>



G1mg3: Overall Structure, Northwest-facing view with no covered conductor installed northwest of Pole 121471467



G1mg4: Second structure ID



IA1mg1: Southeast view of pole 121774370



IA1mg2: Close up view of pole 121774370 showing bare conductor on southeast side (Recloser side)



IA1Img3: Close up view of pole 121471467 showing bare conductor on either side