

March 5, 2026

VIA ELECTRONIC FILING

Docket # 2025 NODI

Patrick Doherty
Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Patrick.Doherty@energysafety.ca.gov

RE: PacifiCorp's Response to Notice of Data Inaccuracy - PAD_PC_IAG_20251009_1243

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the "Notice of Data Inaccuracy, "NODI_PAD_PC_IAG_20251009_1243" (NODI) issued by the Office of Energy Infrastructure Safety (Energy Safety) on February 03, 2026. On October 9, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California.

Energy Safety found the following Data Inaccuracy:

Data Inaccuracy 1. On Pole ID 6242005.0365761, Grid Hardening ID 10088765 at coordinates 41.446700386554426, -122.37029398059661, the inspector observed that PC failed to adhere to data accuracy.

PacifiCorp Response:

Following the notice of data inaccuracy, the company conducted a field inspection on February 5, 2026. No corrective actions were required. PacifiCorp had initially planned to install a fuse on this pole; however, based on a recommendation from the local engineer, the fuse was instead installed on the adjacent pole (ID 06242005.0366601).

5G83, Weed 06242005.0365761

No fuses installed.



Picture 1: Near Pole ID 6242005.0365761, Grid Hardening ID 10088765 at coordinates 41.446700386554426, -122.37029398059661. Picture taken February 05, 2026.

06242005.0366601

100A Fuse installed.



Picture 2: Near Pole ID 6242005.0365761, Grid Hardening ID 10088765 at coordinates 41.446700386554426, -122.37029398059661. Picture taken February 05, 2026.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NODI_PAD_PC_IAG_20251009_1243.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,

Carrie Laird

Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: assetperformance@energysafety.ca.gov

Shannon.Greene@energysafety.ca.gov

Yana.Loginova@energysafety.ca.gov

Babak.Kaviani@energysafety.ca.gov

Samuel.Isaiah@energysafety.ca.gov

Ivan.Garcia@energysafety.ca.gov

Patrick.Doherty@energysafety.ca.gov