

March 9, 2026

Patrick Doherty, Compliance Program Manager
Performance Assessment Division
Office of Energy Infrastructure Safety
California Natural Resources Agency
715 P Street 20th Floor
Sacramento, CA 95814

BY ENERGY SAFETY E-FILING

SUBJECT: Southern California Edison Company's Response to Notice of Data Inaccuracy (NODI_PAD_SCE_KSF_20260113_1125)

Dear Mr. Doherty:

Southern California Edison Company (SCE) appreciates the opportunity to provide this response to the finding identified in the Notice of Data Inaccuracy

NODI_PAD_SCE_KSF_20260113_1125 which SCE received on **February 9, 2026 (Notice)**, based on the Office of Energy Infrastructure Safety's (Energy Safety) field inspections conducted in SCE's service area on **January 13, 2026**. SCE appreciates Energy Safety's efforts to identify, communicate and work together to resolve potential wildfire risks. The enclosed response describes corrective actions taken or planned by SCE to remedy the finding identified in the Notice and to prevent recurrence.

If you have any questions, or require additional information, please contact Liz Leano at 626-302-3662 or Elizabeth.Leano@sce.com.

Sincerely,

//s//

Brandon Tolentino
Vice President of Wildfire and Business Resiliency
Southern California Edison

SCE Response

Finding:

Notice	#	Structures
NODI_PAD_SCE_KSF_20260113_1125	1	4630772E

Summary of Findings:

Energy Safety's Notice states that on January 13, 2026, Energy Safety conducted an inspection of Southern California Edison Company's WMP initiatives in the vicinity of the city of Oak View, California. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 4630772E, Grid Hardening ID TD2091619-4630772E at coordinates 34.4133144995652, -119.285974247888, the inspector observed that covered conductor was not installed at the stated location.

Response:

Structure 4630772E required only guy anchor remediation to support adjacent pole lines with covered conductor and does not require covered conductor itself. This pole was included in the WMP Quarterly Data Report (QDR) because of SCE's current reporting process, which includes all structures pertaining to the work order design for covered conductor installations. Although included in the QDR, this pole is not reported as part of SCE's covered conductor mileage and target.