



March 11, 2026

Daniel Kushner  
Senior Director, Electric Risk & Compliance  
Pacific Gas and Electric Company  
300 Lakeside Drive  
Oakland, CA 94612

## **NOTICE OF DATA INACCURACY**

Mr. Kushner:

Pursuant to Government Code section 15472, et seq, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by Pacific Gas and Electric Company (PG&E) in accordance with its 2025 Wildfire Mitigation Plan (WMP) and determined the existence of a data inaccuracy. Energy Safety therefore issues PG&E a Notice of Data Inaccuracy (NODI). Failure to remedy this data inaccuracy may lead to a Notice of Non-Performance (NON) if the inaccuracy causes PG&E to miss a WMP target or prevents Energy Safety from ensuring that PG&E performed the targets and statements made in PG&E's 2025 WMP.

On November 19, 2025, Energy Safety conducted an inspection of Pacific Gas and Electric Company's WMP initiatives in the vicinity of the city of Cambria, California. The inspection report is enclosed herewith. Energy Safety found the following data inaccuracies:

Data Inaccuracy 1. On Pole ID 121798717, Grid Hardening ID 123347214 at coordinates 35.5445319974426, -121.084874539239, the inspector observed that PG&E failed to adhere to data accuracy.

The data inaccuracy identified in this notice could make it appear as though PG&E reached the target set in its WMP initiative related to Work Orders (Asset Management) when it has not. If PG&E does not address this data inaccuracy and includes the inaccurate data in its reporting regarding its WMP initiative related to Work Orders (Asset Management), PG&E may be found to fail to achieve the target for that WMP initiative. This failure may be raised in a future NON or in Energy Safety's 2025 Annual Performance Report on PG&E's WMP Performance.

Within 30 days from the issuance date of this NODI, PG&E should provide a response advising Energy Safety of corrective actions taken or planned to remedy the identified data inaccuracy or inaccuracies.

This response shall be filed in the Energy Safety e-Filing system under the 2025 NODI Docket,<sup>1</sup> and the associated file name(s) must begin with the NODI identification number.

Sincerely,

*Patrick Doherty*

Patrick Doherty  
Program Manager | Performance Assessment Division  
Office of Energy Infrastructure Safety  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

Cc:

Wade Greenacre, PG&E

[WAG9@pge.com](mailto:WAG9@pge.com)

Mandy Knockaert, PG&E

[ARKN@pge.com](mailto:ARKN@pge.com)

Electric Data Requests

[ElectricDataRequests@pge.com](mailto:ElectricDataRequests@pge.com)

Romeo Marroquin Ajcac, Energy Safety

[Romeo.MarroquinAjcac@energysafety.ca.gov](mailto:Romeo.MarroquinAjcac@energysafety.ca.gov)

Yana Loginova, Energy Safety

[Yana.Loginova@energysafety.ca.gov](mailto:Yana.Loginova@energysafety.ca.gov)

Babak Kaviani, Energy Safety

[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

Shannon Greene, Energy Safety

[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)

[assetperformance@energysafety.ca.gov](mailto:assetperformance@energysafety.ca.gov)

---

<sup>1</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2025%20NODI>



State of California – A Natural Resources Agency  
**OFFICE OF ENERGY INFRASTRUCTURE SAFETY**  
715 P Street, 20th Floor | Sacramento, CA 95814  
916.902.6000 | [www.energysafety.ca.gov](http://www.energysafety.ca.gov)

Gavin Newsom, Governor  
Caroline Thomas Jacobs, Director

# INSPECTION REPORT

Electrical Corporation:	Pacific Gas and Electric Company
Report Number:	PAD_PGE_BKA_20251119_1214
Date of Inspection:	November 19, 2025
City and/or County of Inspection:	Cambria, San Luis Obispo County
Inspector:	Babak Kaviani
WMP Year Inspected:	2025
Quarterly Data Report (QDR) Referenced:	Quarter (Q2)
Inspection Selection:	Energy Safety viewed the contents of the Q2 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.7.2 – Open Work Orders – Distribution Tags
Inspection Purpose:	Assess the accuracy of Pacific Gas and Electric Company’s QDR data, completeness of its work, and performance of WMP requirements.

## WMP Inspection Data Inaccuracies

Data Inaccuracy #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Data Inaccuracy Description
Data Inaccuracy 1	121798717	123347214	35.5445319974426, -121.084874539239	Tier 2	8.1.7.2 – Open Work Orders – Distribution Tags	Inaccurate data provided on Open Work Orders – Distribution Tags

# Observations

On Pole ID 121798717, Grid Hardening ID 123347214 at 1622 Astor Ave, Cambria, CA, 93428, USA, 35.5445319974426, -121.084874539239, the inspector observed that another tag for the same initiative, with the same FieldNotes (POLE\_DECA\_REPL - 1622 ASTOR AVE Cambria), was submitted under Grid Hardening ID 124941506. The field notes claim two poles were replaced, and the inspector only observed one pole. The inspector's observation is documented in Data Inaccuracy 1 photographs, which are attached to this report as Exhibit A.

Energy Safety concludes that there are inaccurate data because of these facts:

1. PG&E reported in the 2025 Q2 QDR that work on WMP initiative 8.1.7.2 – Open Work Orders – Distribution Tags was completed at this location.
2. The inspector observed that another tag for the same initiative, with the same FieldNotes (POLE\_DECA\_REPL - 1622 ASTOR AVE Cambria), was submitted under Grid Hardening ID 124941506. The “Date End” for this Grid Hardening initiative was submitted as 5/20/25, 5:00 PM. This Tag was cancelled with the reason: “Pole has been replaced & Other FDA's Addressed.”
3. Pole ID 121798717 was replaced under the tag with Grid Hardening ID 123347214, with the “Date End” recorded as 4/3/25, 5:00 PM.

This observation warrants a notice of data inaccuracy. Failure to rectify this data inaccuracy prior to the submission of any performance assessments, such as annual reports, may result in a notice of non-performance.

# Exhibits

Exhibit A: Photo Log

Structure ID: 121798717

Data Inaccuracy 1

 A photograph showing a tall wooden utility pole with multiple cross-arms and power lines. The pole is situated in a residential area with trees and a wooden fence in the background under a clear blue sky.	 A close-up photograph of the wooden utility pole. A yellow identification tag is attached to the pole, displaying the number 121798717. A white PVC pipe is visible on the left side of the pole.
<p><b>G1mg1:</b> Overall structure</p>	<p><b>G1mg2:</b> Structure ID</p>