

April 6, 2026

***VIA ELECTRONIC FILING***

Docket # 2025 NODI

Patrick Doherty  
Program Manager  
Compliance Assurance Division  
Office of Energy Infrastructure Safety  
715 P Street, 20th Floor  
Sacramento, CA 95814  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

**RE: PacifiCorp's Response to Notice of Data Inaccuracy – PAD\_PC\_BKA\_20251008\_1508**

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the “Notice of Data Inaccuracy, “NODI\_PAD\_PC\_BKA\_20251008\_1508” (NODI) issued by the Office of Energy Infrastructure Safety (Energy Safety) on March 5, 2026. On October 8, 2025, Energy Safety conducted an inspection of PacifiCorp’s WMP initiatives in the vicinity of the city of Weed, California.

Energy Safety found the following Data Inaccuracy:

**Data Inaccuracy 1.** Energy Safety observed that on Pole ID 14/46, Grid Hardening ID 8077661d at coordinates 41.4319310131561, - 122.389053, the inspector observed that PC failed to adhere to data accuracy.

**PacifiCorp Response:**

In response to the Notice of Data Inaccuracy, the company conducted a field inspection on March 6, 2026. PacifiCorp confirmed that there is no covered conductor on Pole ID 14/46. The conductor in this area has been undergrounded and reflected as part of Grid Hardening IDs 8077661s and 8077661v. Figure 1 below is a screen shot of Grid Hardening IDs 8077661d, 8077661s, and 8077661v as submitted in the Quarterly Data Report (QDR):

- 8077661d is shown in red representing overhead conductor on circuit 5G83. The northern span of tree wire is installed in the field; the southern span (circled) is incorrect and will be corrected.
- 8077661s is shown in blue representing underground conductor on 5G83.
- 8077661v is shown in yellow representing underground conductor on 5G45.



**Figure 1 of Grid Hardening IDs 8077661d, 8077661s, and 8077661v**

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NODI\_PAD\_PC\_BKA\_20251008\_1508.

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at [pooja.kishore@pacificorp.com](mailto:pooja.kishore@pacificorp.com) and [californiadockets@pacificorp.com](mailto:californiadockets@pacificorp.com).

Sincerely,

*Carrie Laird*

Carrie Laird  
Vice President, Wildfire Mitigation and Emergency Operations

cc: [assetperformance@energysafety.ca.gov](mailto:assetperformance@energysafety.ca.gov)  
[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)  
[Yana.Loginova@energysafety.ca.gov](mailto:Yana.Loginova@energysafety.ca.gov)  
[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)  
[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)  
[Ivan.Garcia@energysafety.ca.gov](mailto:Ivan.Garcia@energysafety.ca.gov)  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)