

April 10, 2026

***VIA ELECTRONIC FILING***

Docket # 2025 NODI

Patrick Doherty  
Program Manager  
Compliance Assurance Division  
Office of Energy Infrastructure Safety  
715 P Street, 20th Floor  
Sacramento, CA 95814  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)

**RE: PacifiCorp's Response to Notice of Data Inaccuracy-PAD\_PC\_BKA\_20251008\_1530.2**

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the "Notice of Data Inaccuracy, "NODI\_PAD\_PC\_BKA\_20251008\_1530.2" (NODI) issued by the Office of Energy Infrastructure Safety (Energy Safety) on March 11, 2026. On October 8, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California.

Energy Safety found the following Data Inaccuracy:

**Data Inaccuracy 1.** Energy Safety observed that in On Grid Hardening ID 8077661 at coordinates 41.4293338392048, -122.389104, the inspector observed that PC failed to adhere to data accuracy.

**PacifiCorp Response:**

In response to the Notice of Data Inaccuracy, PacifiCorp conducted a field inspection on March 12, 2026. The inspection confirmed that a Cal Fire-approved non-expulsion fuse is installed on Grid Hardening ID 8077661 at the specified GPS location. The violation cited is identical to that documented in NODI\_PAD\_PC\_BKA\_20251008\_1536.2. Please refer to PacifiCorp's April 10, 2026 Response to Energy Safety's Notice of Data Inaccuracy – PAD\_PC\_BKA\_20251008\_1530.1 for further context regarding this NODI.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NODI\_PAD\_PC\_BKA\_20251008\_1530.2.


Office of Energy Infrastructure Safety

April 10, 2026

Page 2

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at [pooja.kishore@pacificorp.com](mailto:pooja.kishore@pacificorp.com) and [californiadockets@pacificorp.com](mailto:californiadockets@pacificorp.com).

Sincerely,



Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: [assetperformance@energysafety.ca.gov](mailto:assetperformance@energysafety.ca.gov)  
[Shannon.Greene@energysafety.ca.gov](mailto:Shannon.Greene@energysafety.ca.gov)  
[Babak.Kaviani@energysafety.ca.gov](mailto:Babak.Kaviani@energysafety.ca.gov)  
[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)  
[Ivan.Garcia@energysafety.ca.gov](mailto:Ivan.Garcia@energysafety.ca.gov)  
[Patrick.Doherty@energysafety.ca.gov](mailto:Patrick.Doherty@energysafety.ca.gov)