

April 10, 2026

VIA ELECTRONIC FILING

Docket # 2025 NODI

Patrick Doherty
Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814
Patrick.Doherty@energysafety.ca.gov

RE: PacifiCorp's Response to Notice of Data Inaccuracy-PAD_PC_BKA_20251008_1536.2

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding identified in the "Notice of Data Inaccuracy, "NODI_PAD_PC_BKA_20251008_1536.2" (NODI) issued by the Office of Energy Infrastructure Safety (Energy Safety) on March 11, 2026. On October 8, 2025, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California.

Energy Safety found the following Data Inaccuracy:

Data Inaccuracy 1. Energy Safety observed that in On Grid Hardening ID 8077661 at coordinates 41.4293338392048, -122.389120, the inspector observed that PC failed to adhere to data accuracy.

PacifiCorp Response:

In response to the Notice of Data Inaccuracy, a field inspection was conducted on March 12, 2026. The inspection confirmed that a Cal-Fire-approved Non-Expulsion Fuse is installed under Work Order Grid Hardening ID 8077661 at the identified GPS location. The Notice of Data Inaccuracy cited is identical to that in NODI_PAD_PC_BKA_20251008_1530.2 and pertains to the same GPS coordinates and fuse. Please refer to PacifiCorp's April 10, 2026, Response to Energy Safety's Notice of Data Inaccuracy – PAD_PC_BKA_20251008_1530.1 for further context regarding this NODI.



Picture 1: Near Grid Hardening ID 8077661 at coordinates 41.4293338392048, -122.389120, Picture taken March 12, 2026.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NODI_PAD_PC_BKA_20251008_1536.2.

Office of Energy Infrastructure Safety

April 10, 2026

Page 3

Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at pooja.kishore@pacificorp.com and californiadockets@pacificorp.com.

Sincerely,



Carrie Laird

Vice President, Wildfire Mitigation and Emergency Operations

cc: assetperformance@energysafety.ca.gov
Shannon.Greene@energysafety.ca.gov
Babak.Kaviani@energysafety.ca.gov
Samuel.Isaiah@energysafety.ca.gov
Ivan.Garcia@energysafety.ca.gov
Patrick.Doherty@energysafety.ca.gov