

# **PG&E'S WILDFIRE DISTRIBUTION RISK MODEL (WDRM)**


**OFFICE OF ENERGY INFRASTRUCTURE SAFETY WORKSHOP  
OCTOBER 5, 2021**

- Our Understanding
- Evolution of Risk Assessment and Modeling
- Models and Their Applications
- 2021 WDRM (version 2)
- Third Party Validation
- 2022 WDRM (version 3)
- Future Model Schedule
- PSPS Circuit Consequence Model
- Collaboration Between California IOUs
- Appendix

### We were asked to address the following topics:

- An **overview of your current ignition, consequence, and PSPS risk models**, including any **subsequent models** and how each model is utilized
- Details of the **components of each model**, such as the **inputs and data used, modeling assumptions and algorithms, and outputs including confidences and uncertainties**
- **Changes being implemented and / or considered to your risk models for the 2022 WMP Update**, along with an explanation

# Evolution of Risk Assessment and Modeling



# Models and their Applications



## PG&E has developed a suite of risk models for various use cases, including:

Enterprise Risk Model using the bow tie methodology to assess risks at an enterprise level and mitigation program effectiveness at program level for GRC, RAMP and Investment Planning purposes evaluating Drivers, Exposure, Outcomes, Consequences, Tranches




Wildfire Risk Models for specific voltage classes (i.e. Distribution and Transmission) comprising Probability of Ignition Models, and Wildfire Consequence Model used to assess risk at a more granular level (e.g. circuit segment) for the purposes of mitigation work planning and prioritization

PSPS Operational Model comprised of the Ignition Probability Weather (IPW) and Fire Potential Index (FPI) models used to inform PSPS de-energizations during elevated fire weather conditions

PSPS Circuit Consequence Model to assess customer impacts from a PSPS de-energization event

The Wildfire Distribution Risk Model is one of many efforts that inform PG&E's Wildfire Mitigation Plan



# **2021 WILDFIRE DISTRIBUTION RISK MODEL (VERSION 2)**


# Modeling Objectives and Framework



## Risk and Data Analytics Team Objectives:

- (1) *Provide situational awareness of risk*
- (2) *Enable risk-informed decisions making, and*
- (3) *Enable PG&E to develop line-of-sight on risk reductions from wildfire risk mitigation initiatives*

**2021 established the baseline and foundation for future development of the WDRM to progress PG&E risk modeling and capability maturity**




# 2021 Wildfire Risk Modeling Approach

PG&E's wildfire risk modeling framework is aligned with our wildfire risk bowtie defined in the 2020 RAMP, and is used to assess Probability of Ignition or Likelihood of Risk Event (LoRE) and the Consequence of Risk Event (CoRE)

## LoRE



Vegetation Ignition Model



Equipment Ignition Model



## CoRE



Wildfire Consequence Model

$$\text{Risk} = \text{Ignition Probability} \times \text{Wildfire Consequence}$$

## Mitigation Programs



System Hardening Prioritization



Enhanced Vegetation Management Prioritization




Inspection Ordering & Cadence



Repair Prioritization




# Maximum Entropy (MaxEnt) Approach




**Locations and characteristics of areas where ignitions occur are collected and compiled**

+



**Similarities between the conditions at ignition points are identified, and evaluated for commonality**

=




**Places where there are similar conditions across the examined area are given a probability of the event occurring based on similarity to other ignition locations and a level of uncertainty**

# Vegetation Probability of Ignition – Covariates



Rank	Model Feature	Feature description	Units	Permutation Importance (%)
1	tree-height-max	Satellite derived tree height estimates – highest tree per-raster pixel	m	26.1
2	100-hour-fuels-avg	standard fire modeling metric of fuel dryness for fuels about 1-3" in diameter, mean over season	%	24.1
3	vapor-pressure-deficit-avg	vapor pressure deficit, mean over season	kPa	21.6
4	gusty-summer-day-pct	The percentage of days with sustained hourly wind speeds over 20 mph	%	6
5	HFTD	High Fire Threat District (2 or 3)		4.2
6	precipitation-avg	Seasonal daily average precipitation	mm	3.1
7	Impervious	NLCD imperviousness product - represent urban impervious surfaces as a percentage of developed surface	%	2.8
8	specific-humidity-avg	Seasonal average specific humidity	kg/kg	2.4
9	burn-index-avg	National Fire Danger Rating System (USNFDRS) Burning Index (BI)		2.3
10	wind-max	Annual 99th percentile hourly wind speed at 10m	m/s	1.9
11	temperature-avg	Average of daily maximum temperature in Kelvin	K	1.6
12	windy-summer-day-pct	The percentage of days with sustained hourly wind speeds over 15 mph	%	1
13	local-topography	The topographic position index (TPI) extracted from the USGS national elevation dataset		0.8
14	tree-height-avg	Satellite derived tree height estimates – average per-raster pixel	m	0.8
15	1000-hour-fuels-avg	standard fire modeling metric of fuel dryness for fuels about 3-8" in diameter, mean over season		0.6
16	energy-release-avg	USNFDRS Energy Release Component (ERC)		0.4



Predicted annual HFTD ignitions (average): **100**  
 Observed total HFTD ignitions (2015-2018): **401**


### Model Performance

- ROC-AUC - 0.737 (in-sample)
- ROC-AUC - 0.716 (out-of-sample)

# Equipment Probability of Ignition – Covariates



Rank	Model Feature	Feature Description	Units	Permutation Importance
1	Unburnable	non-burnable area	%	30.8
2	precipitation_ave	daily precipitation, mean	mm	29.8
3	conductor_material_acsr	conductor material: ACSR	%	9.7
4	estimated_age	estimated conductor age	years	8.9
5	tree_height_max	max tree height	m	4.3
6	splice_record_exists	Reliability Program splice	%	4.3
7	vapor_pressure_deficit_ave	vapor pressure deficit, mean	kPa	4.0
8	conductor_size_2	conductor size: 2	%	3.4
9	conductor_size_4	conductor size: 4	%	1.6
10	100_hour_fuels_ave	100-hour fuel moisture, mean	%	1.1
11	max_temperature_ave	max temperature, mean	K	1.0
12	wind_ave	wind speed, mean	m/s	0.9
13	local_topography	TPI	%	0.2
14	conductor_size_6	conductor size: 6	%	0.1
15	conductor_material_al	conductor material: Al	%	~0
16	conductor_material_cu	conductor material: Cu	%	~0
17	coastal	coastal	%	~0
18	specific_humidity_ave	specific humidity, mean	%	~0




Predicted annual HFTD ignitions (average): **60**  
 Observed total HFTD ignitions (2015-2018): 242

### Model Performance

- ROC-AUC - 0.76 (in-sample)
- ROC-AUC - 0.74 (out-of-sample)

# Probability and Consequence Visualization



$$\text{Risk} = \text{Ignition Probability} \times \text{Wildfire Consequence}$$

Please visit the 2021 Wildfire Mitigation Plan Section 4.5.1 for more detailed information

## Risk Model



*2021 Wildfire Distribution Risk Model*



## Additional Considerations



*Updated 2020 LiDAR data on strike potential trees across the 25,000 miles of HFTDs*



*Public Safety Specialist expertise regarding fire history by area and the details on specific locations in terms of terrain and egress routes*



*System hardening projects and fire rebuilds underway and completed*




*Frequency and number of customers impacted by PSPS events in 2019 and 2020*



## Workplans & Metrics



*Enhanced Vegetation Management*




*System Hardening*



*PG&E Public Safety Metrics*



# Additional Steps to Develop 2021 EVM Scope of Work




# System Hardening Example

## Keswick 1101 Circuit Protection Zone (CPZ)


- This circuit segment is in the top 50 miles in the risk profile curve
- 6.6 miles in total length
- The 100m X 100m squares (blue, yellow and red) on the picture each have a risk score
- Total CPZ risk score is 48.84 MAVF units (sum of all the 100m grid squares along the circuit)
- Average risk score of all the grid points results in the CPZ mean risk score of 1.25 units
- Circuit segment was evaluated for OH and UG solutions



# Model Visualization and Application



**Circuit Segment View**



**Risk Pixel View**



### E3 have demonstrated expertise in:


- Energy and risk modeling methods and data analytics
- Machine learning
- California's energy landscape and the critical need and value of risk models

### E3 performed an independent review of the 2021 WDRM focused on two main objectives:

1. Is the model and documentation “fit for purpose”?
2. Does the model produce reasonable results

### E3 found that the 2021 Distribution Risk Model:

- Is **appropriately designed for its stated goals** including PG&E's goal to develop a model that provides estimates of risk from ignitions caused by its own equipment.
- Provides a **better predictor of where ignitions could occur and what damages could be expected from those ignitions than its older 2018-2019 model**. The improvements are primarily due to the use of more accurate consequence data and a more suitable modeling (MaxEnt) approach.
- PG&E's approach **represents a meaningful step above the industry standard approach used for planning and assessing where to target more traditional grid hardening measures**.



### **E3 highlighted areas for improvement which were captured as commitments in the 2021 WMP:**


- Strengthen the critical link that is often required between experts and models to effectively mitigate risk
- Strengthen and clarify the relationship between the Wildfire Distribution Risk Model and the PSPS model
- Improve documentation how the family of PG&E's fire risk mitigation models/data work together to address key questions
- Better balance model parsimony in using fewer parameters by including parameters that provide a direct line of sight to the impact of risk mitigation measures
- Explore more modeling algorithms in order to determine the best approach

# **2022 WILDFIRE DISTRIBUTION RISK MODEL (VERSION 3)**


Based on E3 feedback and risk model vision and schedule described in the 2021 WMP the v3 WDRM adds 8 new groups of features

### 2022 WMP

- 1 Model extends beyond HFTD to entire distribution system
- 2 Added models for support structures and transformers
- 3 Develop and evaluate wider range of model algorithms
- 4 Updated training data sets with 2020 outages, ignitions and PSPS damages
- 5 Improve coordination between PSPS and WDRM
- 6 Automation of composite model framework
- 7 Developed sub-models to composite or add probabilities and risks
- 8 Risk reduction for mitigation options at a granular level



1



## Model Geographic Expansion


**Model extended to entire Overhead PG&E Distribution System including Primary and Secondary (added all black circuits)**

**Wildfire Consequence model extended to all 'burnable' areas including HFRA and Tier 1**

# Expansion of Wildfire Consequence beyond HFTD Tiers 2 & 3



1



## Model Geographic Expansion


As climate change is not static, Technosylva fire simulations were modeled beyond HFTD to consider all 'burnable' areas within PG&E's Service Territory

In 'non-burnable' locations the probability of outage and ignition is available, but the wildfire consequence is not calculated

Modeling more detailed sub-models to represent risk drivers requires modeling outages and then outages to ignitions for Likelihood of Risk Event (LoRE)

2

## Likelihood of Risk Event (LoRE)



**$Risk = Outage Probability \times Ignition Probability Given Outage \times Wildfire Consequence$**

# WDRM v3 Models and Algorithms

3

	<b>Vegetation Outage Model</b>	<i>MaxEnt</i>
	<b>Conductor Outage Model</b>	
	<b>Support Structure Outage Model</b>	<i>Random Forest Classifier</i>
	<b>Transformer Outage Model</b>	

	<b>Probability of an Ignition Given an Outage</b>	<i>Logistic Regression</i>

Probability models employ a range of model algorithms best suited to the problem

<b>Wildfire Consequence Model</b>		<i>Technosyva</i>
-----------------------------------	--	-------------------



4

## Added/Improved Covariates

### Tree


- LiDAR
- Species

### Asset

- Asset Age
- Height
- Pole Test & Treat
- Pole Material
- Pole Treatment
- Soil
- Maintenance tags
- Electric Loading

### Meteorology

- Average Wind
- Precipitation Max.
- Gusty Wind Pct.
- Windy Summer Pct.
- Vapor Pressure
- Humidity



## Train/Test Sets

Outages

PSPS Damages

Added curated data sets have resulted in additional models and improvements in predictive performance

# P(Ignition) Models Overview – OPW/IPW vs. WDRM



5

Improved alignment between the PSPS and WDRM as both models calculate  $p(\text{outage}) * p(\text{ignition} | \text{outage})$  for a given cause, and sum over causes

**OPW  
Probability Outage by  
Cause**  
  
Outputs: 2x2km, Hourly

**Outage Cause**  
  
P(Vegetation)  
P(Equipment-Structural)  
P(Animal-3<sup>rd</sup> Party)  
P(Equipment-Electrical)  
P(Unknown Cause)

**Ignition Rate Depends Only  
On Cause**  
  
Vegetation: 8.7%  
Equipment-Structural: 5.3%  
Animal – 3<sup>rd</sup> Party: 5.2%  
Equipment-Electrical: 1.5%  
Unknown: 3.6%

**IPW  
Probability of Ignition  
by Cause**  
  
Outputs: 2x2km, Hourly

**WDRM  
Probability Outage by  
Cause**  
  
Outputs: 100m x 100m,  
Fire Season & Rest of  
Year

**Outage Cause**  
  
P(Tree trunk into conductor)  
P(Tree trunk into pole)  
P(Tree branch into conductor)  
P(Tree branch into pole)  
P(Animal)  
P(Other)

**Ignition Rate**  
  
Depends on cause, land use  
category, typical fuel moisture,  
impervious surface.

**WDRM  
Probability of Ignition  
by Cause**  
  
Outputs: 100m x 100m,  
Fire Season & Rest of Year





*OPW: Very high temporal resolution, moderate spatial resolution. This is what you want for PSPS decisions.*


*WDRM outage model: Very low temporal resolution, high spatial resolution. This is what you want for system hardening, EVM, and other mitigation work planning decisions.*

*Both models use similar (but not identical) breakdown by cause.*

*Candidate for future unification.*




6 Across the Risk Model Framework Methodology, automation improvements have been developed resulting in a more reproducible and transparent process, with emphasis on data visualization.




7

The total risk or probability at a specific location is provided by the sum of the LoRE sub-models



Full Territory Risk Pixels



- Transformers
- Support Structures
- Conductors
- Vegetation Causes


This allows for the ability to identify the risk driver influencing a risk score at a location

Single Pixel Breakdown of Total Wildfire Risk

7

A large set of models predicting individual outage causes can be modularly combined to give a risk score relevant to the strategic use case

### Total Overhead Distribution System Wildfire Risk



### Relevant Models For Hardening





### Relevant Models For Veg Management




# Composite Risk Model Values at a Location – Vegetation Example

7

## Relevant Models For Veg Management



*Locations with high branch failure risk*



*Locations with high trunk failure risk*

Sub-model details can allow for more targeted mitigations to locations more prone to branch or trunk failures

# Composite Risk Model Values at a Location – System Hardening Example



7

## Relevant Models For Hardening



Branch Failures  
Trunk Failures  
Transformer Electrical


Support Structure  
Primary Conductor



System Hardening type can be targeted to the sub-models by risk characteristic

8

**With granular sub-models, SME informed effectiveness factors can be applied resulting in a pixel level effectiveness estimate for mitigation identification**




*SH effectiveness identifying locations with the highest potential for risk reduction due to SH mitigation*



# Evaluating Risk Reduction due to Effectiveness of Mitigations Options

8


Wildfire Risk may be the same at two locations but, due to the risk of the individual sub-models the **most effective mitigation may differ**



The following examples highlight how the sub-model details in the composite model architecture enable improved identification of the most effective risk mitigations


# Estimate Risk by Location and Prioritize

8



## Team identifies locations when looking at only one type of risk:

- Location B has a **higher risk of transformer caused wildfire**
- A **new transformer is 80% effective** in reducing the probability of failure
- **Location B is the higher priority location for a transformer replacement project** even though the wildfire consequence at Location A is higher



	Probability of ignition	Consequence of the ignition	Risk Score
Location A	0.0010%	6000	0.06
Stacked Bar of Risk (A)	All assets – any vegetation causes		0.00
	<b>Transformers - electrical/mechanical causes</b>	<b>(consequence at A is constant, 6000)</b>	<b>0.02</b>
	Support Structures - mechanical causes		0.02
	Conductors etc. - electrical/mechanical causes		0.02
Location B	0.0885%	2000	1.77
Location C	0.0500%	6000	3

	Probability of ignition	Consequence of the ignition	Risk Score
Location A	0.0010%	6000	0.06
Location B	0.0885%	2000	1.77
Stacked Bar of Risk (B)	All assets – any vegetation causes		1.20
	<b>Transformers - electrical/mechanical causes</b>	<b>(consequence at B is constant, 2000)</b>	<b>0.45</b>
	Support Structures - mechanical causes		0.02
	Conductors etc. - electrical/mechanical causes		0.05
Location C	0.0500%	6000	3

# Estimate Risk by Location and Prioritize



8




## Location A


**Risk lower, largest reduction in risk from system hardening**

One area (A) may have **lower chance of ignition of 0.0015%**, with very little of that due to vegetation because of the **lack of trees in the area**

However, there are a **large number of buildings or structures in the area**, leading to **higher wildfire consequence (6000)**

 **Mitigation<sub>system hard.</sub>** → Hardening system (if 50% effective) could reduce the risk score to 0.03 – **BUT system hardening at Location B is more effective**

	Probability of ignition	Consequence of the ignition	Risk Score
Location A	0.0010%	6000	0.06
All assets – any vegetation causes	0.0000%	(consequence at A is constant, 6000)	0.00
Transformers - electrical/mechanical causes	0.0033%		0.02
Support Structures - mechanical causes	0.0033%		0.02
Conductors etc. - electrical/mechanical causes	0.0033%		0.02
Location B	0.0885%	2000	1.77
Location C	0.0500%	6000	3




## Location B

**Risk higher, largest reduction in risk from tree trimming**

Another area (B) with high winds may have a **higher chance of ignition of 0.0885%**, **primarily due to vegetation**

However, due to a **less dense population center**, the consequence and thus the **risk score is much lower (2000 compared to 6000)**

 **Mitigation<sub>vegetation</sub>** → **Cutting back vegetation (if 50% effective) reduces the risk score to 1.12 because vegetation is a primary driver of ignition**

 **Mitigation<sub>system hard.</sub>** → **Hardening system (if 50% effective) could reduce the risk score to 1.25 because equipment is also a large driver**


	Probability of ignition	Consequence of the ignition	Risk Score
Location A	0.0010%	6000	0.06
Location B	0.0885%	2000	1.77
All assets – any vegetation causes	0.0600%	(consequence at B is constant, 2000)	1.20
Transformers - electrical/mechanical causes	0.0225%		0.45
Support Structures - mechanical causes	0.0010%		0.02
Conductors etc. - electrical/mechanical causes	0.0025%		0.05
Location C	0.0010%	6000	3

# Transition Plan from v2 WDRM to v3 WDRM

In order to provide continuity for workplan execution, the **application of the V3 WDRM will be follow a phased approach over the next year**

Workplans with **shorter implementation cycles will be adjusted first in 2022**, followed by **emergent work during 2022**, and then for **longer term work for 2023 and beyond**

Further details will be provided in the 2022 WMP



# WDRM Multi-Year Schedule



**2021 WDRM established the framework or baseline for subsequent model evolution**

Future iterations will **add additional components and ignition drivers** to our composite framework

Full details will be provided in the 2022 WMP


Model	Components	2021	2022	2023	2024
WDRM	Conductor				
	Support Structure				
	Transformer	Veg	Animal		Unknown
	Capacitor Banks	Mitigations	3 <sup>rd</sup> Party		
	Fuses	P(out) & PIO for entire D-grid		Mitigations	
	Voltage Regulators	Automated Code Base		Entire D-Grid	
	Switches				
Consequence	Distribution Protection Devices			Mitigations	
	Same model output data set used for Transmission and Distribution Grid	WFC all burnable	Egress WFC	Entire D-Grid	Seismic
		Pub. Safety	Suppression WFC		
		Reliability			

# PSPS CIRCUIT CONSEQUENCE MODEL

## Need to Move to a More Granular Level

### Commitment Language

*“PG&E has also modeled PSPS consequences to customers at a program level in terms of MAVF as discussed in Section 4.1(e); and is currently developing a more granular, circuit level model, to assess the impacts of PSPS de-energizations. PG&E currently plans to complete this analysis in collaboration with the WSD and the other California utilities by September 30, 2021.”*



Determine the probability of PSPS circuit de-energization using historical look back analysis

Determining the consequences on each circuit based on frequency, customer scope, and duration, including customer type

### Improvements since 2021 WMP submission, based on collaboration with other IOUs:

- 1) Moving from using actual 2019/2020 PSPS data into a historical lookback analysis
- 2) Updating the PSPS consequences to include safety and financial consequences, expanding on the reliability only consequence of PSPS

# PSPS Circuit Level Framework



## Goal

To develop a 2021 PSPS circuit risk model, to evaluate the spatial/circuit variation in risk, to help inform PSPS mitigation efforts to prioritize high risk locations and customers.

## Objective

- *Enable risk assessment and mitigation quantification at a more precise, granular level*
- *Allow mitigation quantification at that level of granularity*
- *Create a framework for Risk Scores using MAVF values, allowing comparability between PSPS and Wildfire*
- *Ultimately, consistent measure on the level of consequence for customers experiencing PSPS*

### Baseline PSPS Circuit Consequence Model

- Utilize best available representation of meteorological impacts on PG&E system; currently, 10-Year Lookback for Potential PSPS
- Normalize the data to an average impact per year based on:
  - 1) number of events (frequency) per circuit
  - 2) number of customers (customer scope) per circuit
  - 3) average de-energization time (duration) per circuit
- Based on the combination of frequency, customer scope and duration, we can estimate the average customer minutes interrupted (CMI) on each circuit
- Based on total CMI across all circuits, the overall enterprise PSPS risk score is allocated across to each circuit to represent the risk score on each circuit

### Ongoing Development

#### **Mitigated PSPS Consequence**

- Identify existing mitigation programs that provide customer reduction (by circuit)
- Identify mitigation programs focused on duration reduction (weather, restoration, switching)
- Estimate the PSPS Consequence mitigated from mitigation activities

#### **Wildfire + PSPS Combined View**

- Since both Wildfire and PSPS models are represented as MAVF scores, the results of the models can be combined to understand the Wildfire + PSPS risk per circuit



# Modeling Framework – Baseline Consequence



**Align Risk Modeling of PSPS customer impact at the circuit level based on MAVF risk scoring**

**Developed framework using the 10-year lookback for potential PSPS consequence at the Circuit Level**

**Risk per circuit driven meteorology scope, customers affected from Distribution impact, Transmission impact, or both Transmission & Distribution impact**

**Incorporating weighting for critical customer types to consider elevated risk impacts to these communities**

Feeder Name	Cust. Count	Customer			Total Risk	Dx Risk	Tx Risk	Total Risk	Total Dx	Total Tx
		Events	Dx Risk %	Tx Risk %	Score	Score	Score	Rank	Rank	Rank
Circuit #1	4,555	122,655	59%	41%	30	18	12	1	4	18
Circuit #2	4,489	107,233	41%	59%	26	11	15	2	14	8
Circuit #3	5,152	118,916	52%	48%	26	14	12	3	8	17
Circuit #4	4,932	59,184	0%	100%	25	-	25	4	523	1
Circuit #5	4,223	107,070	53%	47%	23	12	11	5	11	25
Circuit #6	4,365	103,702	54%	46%	23	12	11	6	10	28
Circuit #7	3,668	87,169	41%	59%	21	9	13	7	19	15
Circuit #8	3,418	51,270	0%	100%	21	-	21	8	523	2
Circuit #9	2,823	83,288	59%	41%	21	12	8	9	12	43
Circuit #10	4,882	48,871	100%	0%	20	20	-	10	1	345
Circuit #11	4,022	48,264	0%	100%	20	-	20	11	523	3

Visuals shown are for demonstration purposes and may not reflect latest developments

# Modeling Framework – Mitigating Consequence



Identify top circuits based on PSPS risk ranking




Select mitigations over the planning horizon




Account for mitigation effectiveness based on upstream impacts



For each circuit, identify mitigation solutions focused on risk reduction & risk spend efficiencies



PSPS Location	Scope #	Scope Cost	Total Cust Saved	Regular Customer	Critical Customer	Cost/Customer	Grid Solution PSPS RSE	Grid Solution PSPS+WF Grid RSE	BTM RSE
10*	Alternative	\$385,000	67	55	12	\$5,746	12.75	13.57	
2	PIH (A)	\$789,000	7	7	0	\$12,457	2.25	2.44	
1*	Alternative	\$131,000	5	5	0	\$26,200	1.07	1.80	
13*	Alternative	\$1,724,000	32	30	2	\$53,875	0.81	1.39	0.45
3	Preferred	\$22,000	1	1	0	\$22,000	1.28	1.28	
18*	Alternative	\$1,610,300	22	20	2	\$73,195	0.70	1.23	0.52
14*	Alternative	\$726,300	8	8	0	\$90,787	0.31	1.02	0.29
12	Preferred	\$6,961,000	67	62	5	\$103,895	0.45	1.02	0.48
23	Preferred	\$4,372,000	22	22	0	\$198,727	0.14	0.80	0.29



Visuals shown are for demonstration purposes and may not reflect latest developments




### **Process Development for PSPS Planning for 2022**

- Utilizing PSPS model to point teams to plan on high consequence circuits
- Testing out impacts of prioritization and RSE at the project level



### **Integration of lookback data based on 2021 PSPS Protocols**

- Due to the ongoing adjustments of the 2021 PSPS protocols, the same model framework will be updated based on latest available data



### **PSPS Circuit Segment Consequence Model**

- WMP Remedy PG&E 21-05
- Alignment to the Wildfire Distribution Risk Model circuit segments

# CALIFORNIA IOU COLLABORATION

**Since the 2019 WMP process, SCE, PG&E and SDG&E have conducted wildfire-related benchmarking sessions on various topics, including risk modeling, mitigation effectiveness, vegetation management activities, and PSPS operations:**

- PG&E, SCE and SDG&E collaborated on at least 10 occasions in 2021 on risk assessment and modeling alignment opportunities
- IOUs have evaluated elements of risk modeling where near-term alignment could be achieved
- Currently developing a common vision (end-state) for long-term alignment on risk modeling, while recognizing differences

# APPENDIX



## MODEL DETAIL

### Methodology



- Divide Ignition Events into distinct categories of Vegetative or Conductor Caused
- Make vegetative or conductor ignition predictions with MaxEnt model at a scale of 100m x 100m "pixels" along the Dx grid
- Rolls-up pixels to Circuit Protection Zones
- For each pixel, assign risk score based upon the product of: LoRE x CoRE

### Approach



- Use MaxEnt model technique due to its ability to predict rare and unique events in a given region and their probability of occurring both geospatially and under aggregated weather conditions
- Ignition probabilities calculated every 100m along conductor lines and then assigned to a pixel along Dx grid
- Ignition probabilities are combined with consequence (CoRE) to determine overall risk

### Ignition Probability



**Likelihood:** via ignition prediction (MaxEnt)

**Effect:** via:

- (1) Ignition spread (Technosylva FireSim)
- (2) Ignition consequence (Technosylva FireSim)




## MAXENT MODEL

**Training:** On California Public Utilities Commission (CPUC) Reportable Ignition Events and related geospatial and temporal weather data

**Vegetation/equipment Ignition Model:** Two models were developed based on two specific risk mitigation priorities and their associated, relevant risk drivers – EVM and SH

**Ignition likelihood:** The likelihood of ignition in 100m x 100m pixels determined by either Vegetation or Equipment



# Consequence Modeling Approach using Technosylva



## MODEL DETAIL

### Methodology



- Understand how a fire spreads in varying weather conditions and environments along PG&E resources
- Results tied back to RAMP model with MAVF scores
- Predict fire spread along all HFTD assets with an ignition event

### Approach



- Fire spread simulations conducted at regular intervals along assets in HFTD
- Utilize Technosylva Firesim, an industry standard for fire burn simulations, taking into account environment and weather effects
- Consult with Fire Experts to review results

### Consequence Components



**Spread:** via 8 hour burn simulation (Technosylva Firesim)


**Effect:** via:

- (1) Ignition spread (Technosylva FireSim Acres Burned)
- (2) Rate of Spread (Technosylva Firesim FBI)
- (3) Burn Intensity (Technosylva Firesim FBI)
- (4) Buildings Impacted (Technosylva Firesim Structures Impacted)



## TECHNOSYLVA BURN SIMULATION

- Technosylva simulation of 8-hour burn every 200m along HFTD lines
- Simulations conducted with weather data from 452 worst historical fire weather days
- Outputs key consequence metrics: acres burned, population and structures impacted, and fire behavior index (FBI)
- FBI score based on flame length (burn intensity metric) and rate of spread (ROS)




FBI Class	Description
1 LOW	Fire will burn and will spread however it presents very little resistance to control and direct attack with firefighters is possible
2 MODERATE	Fire spreads rapidly presenting moderate resistance to control but can be countered with direct attack by firefighters
3 ACTIVE	Fire spreads very rapidly presenting substantial resistance to control. Direct attack with firefighters must be supplemented with equipment and/or air support.
4 VERY ACTIVE	Fire spreads very rapidly presenting extreme resistance to control. Indirect attack may be effective. Safety of firefighters in the area becomes a concern
5 EXTREME	Fire spreads very rapidly presenting extreme resistance to control. Any form of attack will probably not be effective. Safety of firefighters in the area is of critical concern.



## Progression of Wildland Fire Ladder Effect

Ladder effect in wildland fires create the conditions for low **lying fast burning fuels to intensify** as they move from up the canopy and into more energy dense fuel sources. Accounting for this effect in wildfire modeling **de-emphasizes areas of dense fuels** as high risk for ignition, due to lack of potential surface fuels.

Additionally, locations that have large amounts of surface fuels that can **sustain high temperatures** are rated more highly as these are more likely to ladder into difficult to contain crown fires.



Source: Idyllwild Fire <https://idyllwildfire.com/defensible-space.html>

LiDAR data, specifically tree heights and distances from lines, **has powered a ~10% improvement in predictive performance**

LiDAR data is only **recorded for distribution segments in the HFTD**

Salo Sciences has developed a model to ingest Satellite data and predict LiDAR **level tree height and distances estimates for the rest of the OH distribution locations.**

