

Link to Discovery Responses: https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan-discovery-data-requests.page

Count	Party Name	Data Set	Data Request	Question No.	Question ID	Question Text	Requestor	Date Rec'd	Final Due Date	Date Sent	Number of Atchs	NDA Required	WMP Section	Category	Subcategory
1	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	1	CalAdvocate s-PGE-2022WMP-12_1	In response to Data Request CalAdvocates-PGE-2022WMP-03, Question 5, PG&E stated with regard to detailed ground inspections of transmission towers, "The average number of inspections completed per day in 2021 was 10.9 for contractors, and 7.6 for internal PG&E inspectors."	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections of Transmission electric lines and equipment
2	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	2	CalAdvocate s-PGE-2022WMP-12_2	In response to Data Request CalAdvocates-PGE-2022WMP-03, Questions 9-11, PG&E responded that "PG&E's search of LC tags issued as a result of both desktop and field Quality Control reviews did not identify any Priority A or Priority B LC tags issued" for climbing, drone, or detailed ground inspections of transmission structures.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	1		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
3	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	3	CalAdvocate s-PGE-2022WMP-12_3	For desktop Quality Control reviews of transmission drone inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
4	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	4	CalAdvocate s-PGE-2022WMP-12_4	For desktop Quality Control reviews of transmission detailed ground inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
5	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	5	CalAdvocate s-PGE-2022WMP-12_5	For field Quality Control reviews of transmission climbing inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
6	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	6	CalAdvocate s-PGE-2022WMP-12_6	For field Quality Control reviews of transmission drone inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
7	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	7	CalAdvocate s-PGE-2022WMP-12_7	For field Quality Control reviews of transmission detailed ground inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
8	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	8	CalAdvocate s-PGE-2022WMP-12_8	In response to Data Request CalAdvocates-PGE-2022WMP-08, G3Question 4, PG&E stated that PG&E System Inspection Quality Control found through Desktop Reviews that 60% of inspections had no mistakes and 13% of inspections resulted in a "Failed Review." Through Field Reviews, Quality Control found that 45% of inspections had	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
9	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	9	CalAdvocate s-PGE-2022WMP-12_9	For Desktop Quality Control reviews of detailed distribution inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
10	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	10	CalAdvocate s-PGE-2022WMP-12_10	For Field Quality Control reviews of detailed distribution inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
11	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	11	CalAdvocate s-PGE-2022WMP-12_11	In response to Data Request CalAdvocates-PGE-2022WMP-04, Question 2, PG&E stated that "The requested information is provided in PG&E's 2022 WMP in Section 7.1.F. PG&E is providing attachment "WMP-Discovery2022_DR_CalAdvocates_004-Q02Atch01.zip" which has been prepared with the same information in the requested shapefile format." Cal	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.1.F	Wildfire Mitigation Strategy	Wildfire Risk Data
12	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	12	CalAdvocate s-PGE-2022WMP-12_12	The file "WMP_section_71F.gdb" submitted with PG&E's 2022 WMP contains a layer titled "WMP_section_71F Distribution_Wildfire_Risk." This layer has the following attributes: OBJECTID, mean_mavf_core_risk	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	1		7.1.F	Wildfire Mitigation Strategy	Wildfire Risk Data
13	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	13	CalAdvocate s-PGE-2022WMP-12_13	In response to Data Request CalAdvocates-PGE-2022WMP-04, Question 10, PG&E stated, "At this time, the program cannot forecast with accuracy the split of the 2022 budget forecast into Covered Conductor, Underground, and Line Removal." a) Please explain how PG&E developed the forecast total expenditure of	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.3.17.1	Grid Design and System Hardening	updates to grid topology to minimize risk of ignition in HFTDs, System Hardening, Distribution
14	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	14	CalAdvocate s-PGE-2022WMP-12_14	In response to Data Request CalAdvocates-PGE-2022WMP-08, Question 7, PG&E stated, "We did not change the priority of the corrective notification during the period of February 19, 2020 to June 16, 2021 because none of the inspectors who reviewed this location during this time period recommended a priority change of the corrective	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.3.12.4	Grid Design and System Hardening	Other corrective action, Maintenance, Distribution
15	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	1	CalAdvocate s-PGE-2022WMP-13_1	PG&E's 2021 Q4 Quarterly initiative update states the following regarding 2021 WMP Initiative 7.3.3.17.4 Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter: The current REFCL pilot project at Calistoga experienced unsuccessful technology integration and implementation to date. We have encountered	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	1		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
16	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	2	CalAdvocate s-PGE-2022WMP-13_2	a) What is the status of PG&E's REFCL program as of the issuance date of this DR? b) Does PG&E plan to continue the REFCL program? c) If the answer to subpart (b) is "yes", please describe PG&E's current plans (with specific project timelines and milestones) for the REFCL	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
17	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	3	CalAdvocate s-PGE-2022WMP-13_3	PG&E's 2022 WMP states: While we have not set specific targets for this Initiative and will not provide ongoing reporting each quarter on it, we are still doing the work as part of our overall plan. We do not currently plan to install any additional REFCL systems at this time. PG&E plans to repair and rebuild the REFCL	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
18	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	4	CalAdvocate s-PGE-2022WMP-13_4	PG&E's 2022 WMP states: The Calistoga REFCL pilot project finished construction in 2020. In 2021, PG&E attempted to commission and test the REFCL technology in Calistoga. PG&E completed an elevated voltage stress test and one field ground fault test which demonstrated that REFCL technology can be	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
19	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	5	CalAdvocate s-PGE-2022WMP-13_5	PG&E's 2022 WMP states: After the initial positive tests, the Calistoga REFCL pilot demonstration was stalled due to the failure of the substation REFCL equipment. In addition, PG&E had difficulty obtaining replacement equipment from various overseas suppliers due to supply chain issues and the ongoing COVID-19	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
20	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	6	CalAdvocate s-PGE-2022WMP-13_6	a) How effective is REFCL compared to covered conductor installation in reducing wildfire risks? b) Please provide any available supporting documentation regarding your response to subpart (a) above. c) How effective is REFCL compared to undergrounding in reducing wildfire	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
21	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	7	CalAdvocate s-PGE-2022WMP-13_7	PG&E's 2022 WMP states: REFCL technology could not be fully evaluated beyond the initial testing because of the equipment failure and supply chain issues. As a result, PG&E is looking to further study REFCL capabilities after obtaining replacement supplies and making repairs and modifications at the	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
22	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	8	CalAdvocate s-PGE-2022WMP-13_8	PG&E's 2022 WMP provides the following "Lessons Learned" from the REFCL initiative in 2021: • PG&E should use gang operated switchgear and protective devices instead of single pole operated devices for REFCL installations. • PG&E should consider the use of domestically available equipment for	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
23	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	9	CalAdvocate s-PGE-2022WMP-13_9	PG&E's 2022 WMP states: Based on our initial testing and the successful implementation in Australia, PG&E has developed a short-term strategy to install REFCLs in HFTD areas. PG&E forecasts deploying REFCLs at an additional two substations	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
24	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	10	CalAdvocate s-PGE-2022WMP-13_10	7.3.3.17.4 - Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter11 • 7.3.6.8 - Protective Equipment and Device Settings" 12 Please explain:	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
25	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	11	CalAdvocate s-PGE-2022WMP-13_11	a) Please explain why PG&E is not providing RSE information for this initiative in the 2022 WMP or relevant supporting attachments.	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	1		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
26	OEIS	Set 003	OEIS-PG&E-22-003	1	OEIS-PG&E-22-003_1	Considering Maturity Model Survey question E.IV.h, how would PG&E answer this modified version? Does the utility work with landowners to provide a use(s) for vegetation cut on the landowner's property? (Y/N)	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0		7.3.5	Vegetation Management (VM) and Inspections	Vegetation grow-in mitigation
27	OEIS	Set 003	OEIS-PG&E-22-003	2	OEIS-PG&E-22-003_2	Considering Maturity Model Survey question E.V.i, how would PG&E answer this modified version? Does the utility work with landowners to provide a use(s) for vegetation cut on the landowner's property? (Y/N)	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0		7.3.5	Vegetation Management (VM) and Inspections	Vegetation fall-in mitigation
28	OEIS	Set 003	OEIS-PG&E-22-003	3	OEIS-PG&E-22-003_3	From the maturity survey, in Category E (vegetation management) it is apparent that PG&E is building a granular, frequently updated inventory (Capability 21) and moving towards using "predictive modeling of vegetation growth" to schedule vegetation inspections (E.II.c). However,	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0		7.3.5	Vegetation Management (VM) and Inspections	Vegetation inspection effectiveness
29	OEIS	Set 003	OEIS-PG&E-22-003	4	OEIS-PG&E-22-003_4	ignition and propagation risk modeling to guide clearances around lines and equipment? a) How does and will PG&E's ignition and propagation risk modeling	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0		7.3.5	Vegetation Management (VM) and Inspections	Vegetation grow-in mitigation
30	OEIS	Set 003	OEIS-PG&E-22-003	5	OEIS-PG&E-22-003_5	answer 41 2022 Maturity Survey questions it said it benchmarked through consultation with other utilities in 2022 by the same standard of interpretation it used to answer the same 41 questions in 2021 and 2020. In its response, PG&E indicated that it also used, however, to look in time	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0		N/A	Miscellaneous	Maturity Survey

Table with 13 columns: Row Number, OEIS, Set, PG&E ID, Request Number, Request Description, Assigned To, Start Date, End Date, Status, Score, Comments, and Category. The table contains 13 rows of data, each detailing a specific request for information or action related to PG&E operations and wildfire mitigation efforts.

197	Will Abrams	Set 02	WillAbrams-Set 02	6	WillAbrams-Set 02_6	Q: How has PG&E modified their vegetation management practices to accommodate slope as a factor that could lead to fire spread from their infrastructure? If a pole, tower or line segment is situated on a similar "upslope" how is PG&E mitigating the increased fire risk?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
198	Will Abrams	Set 02	WillAbrams-Set 02	7	WillAbrams-Set 02_7	Q: Given these findings and the increased fire risk on "south-facing slopes", has PG&E modified their vegetation management practices to ensure this type of topography is treated differently or more regularly given the lower moisture content?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.2.1.2	Situational Awareness and Forecasting	Fuel Moisture Sampling and Modeling [could also go to VM?]
199	Will Abrams	Set 02	WillAbrams-Set 02	8	WillAbrams-Set 02_8	Q: It is clear that the rust and neglect of the line caused a "shower of sparks." What has PG&E done to mitigate rust and corrosion on infrastructure that causes this shower effect with multiple ignition sources?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
200	Will Abrams	Set 02	WillAbrams-Set 02	9	WillAbrams-Set 02_9	Q: Given this evidence that ember cast from transmission towers are "going to drift", what has PG&E done to alter their vegetation management practices around transmission towers? Where is this within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
201	Will Abrams	Set 02	WillAbrams-Set 02	10	WillAbrams-Set 02_10	Q: What additional risk mitigation practices has PG&E implemented to ensure that jumpers are secured and not left "dangling" and susceptible to wind? Are rigid jumpers now more often used? What added inspection criteria have been added so this never leads to another catastrophic fire again?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair, and Replacement
202	Will Abrams	Set 02	WillAbrams-Set 02	11	WillAbrams-Set 02_11	Q: How has PG&E mitigated these wildfire risks to ensure cooling towers are properly decommissioned or moth balled in response to these failures?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
203	Will Abrams	Set 02	WillAbrams-Set 02	12	WillAbrams-Set 02_12	Q: Given this "primary address," what added risk mitigation practices has PG&E implemented to address power plant vegetation management and metal recycling procedures?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
204	Will Abrams	Set 02	WillAbrams-Set 02	13	WillAbrams-Set 02_13	Q: What risk mitigation has PG&E done to ensure decommissioned or moth balled lines are not energized and connected to power plants? How have inspection practices changed to ensure these failures are not repeated?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
205	Will Abrams	Set 02	WillAbrams-Set 02	14	WillAbrams-Set 02_14	Q: Given that this "low cycle fatigue" was identified as a primary cause of the Kincaide Fire, has PG&E reflected and corrected that issue within their WMP? Is added testing performed and/or different quality assurance checks to mitigate these risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	N/A	N/A	N/A
206	Will Abrams	Set 02	WillAbrams-Set 02	15	WillAbrams-Set 02_15	Q: Given these failures to deal with abandoned infrastructure, how has PG&E identified the added mitigation activities since the Kincaide Fire? How does PG&E now treat "abandoned" infrastructure differently within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
207	Will Abrams	Set 02	WillAbrams-Set 02	16	WillAbrams-Set 02_16	Q: What has PG&E done to ensure security fencing around their infrastructure is inspected and maintained given these findings? How does PG&E mitigate the security dangers of poorly maintained fencing?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
208	Will Abrams	Set 02	WillAbrams-Set 02	17	WillAbrams-Set 02_17	Q: What has PG&E done to mitigate the risks of misconfigured jumpers? Does PG&E now cut these within the manufacturing facility to ensure proper length and configuration?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair, and Replacement
209	Will Abrams	Set 02	WillAbrams-Set 02	18	WillAbrams-Set 02_18	Q: What has PG&E done to mitigate these risks and ensure that wires are secured and inspected within the shoe and do not come loose to cause future catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.12	Asset Management and Inspections	Patrol inspections of transmission electric lines and equipment
210	Will Abrams	Set 02	WillAbrams-Set 02	19	WillAbrams-Set 02_19	Q: Given that the Saw Mill Fire pointed to the same or very similar infrastructure failures and mismanagement patterns as the Kincaide Fire has PG&E finally included mitigation activities for these issues within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
211	Will Abrams	Set 02	WillAbrams-Set 02	20	WillAbrams-Set 02_20	Q: Given that wind readings were different on the surface vs. up on poles and towers and these differences contributed to the miscalculations and causes of both the Sawmill and Kincaide Fires, has PG&E accounted for different wind sensor placement of wind (ground-level vs. high up on tower) within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.2.1.3	Situational Awareness and Forecasting	Weather Stations
212	Will Abrams	Set 02	WillAbrams-Set 02	21	WillAbrams-Set 02_21	Q: Given all these similar causes (loose wires, low-cycle fatigue, wind conditions, etc.) between the Sawmill Fire and the Kincaide Fire why did PG&E still not mitigate these causes and include those mitigation tactics within their WMP? Given this failure pattern, why did PG&E state over and over again that the Kincaide Fire was a "black swan"? Why did Bill Johnson, CEO dismissively state that "sometimes things just break" in reference to the Kincaide Fire given this pattern and the clear failure of PG&E policies and practices?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
213	Will Abrams	Set 02	WillAbrams-Set 02	22	WillAbrams-Set 02_22	Q: When outside oversight agencies provide direction like "make sure those wires are secured" how does PG&E now make sure those instructions are documented and addressed? Where are these issues addressed in the PG&E WMP given that staff repeatedly did not heed these instructions?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.12	Asset Management and Inspections	Patrol inspections of transmission electric lines and equipment
214	Will Abrams	Set 02	WillAbrams-Set 02	23	WillAbrams-Set 02_23	Q: How has PG&E modified their inspection practices and noted those changes within their WMP given that these inspections did not successfully catch the many failures in configuration and maintenance practices that caused the Kincaide Fire?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.10	Asset Management and Inspections	Other discretionary inspection of transmission electric lines and equipment, beyond inspections mandated by rules and regulations
215	Will Abrams	Set 02	WillAbrams-Set 02	24	WillAbrams-Set 02_24	Q: How has PG&E improved their policies and wildfire mitigation practices to more closely work with partners like CalPine to ensure access and maintenance issues do not impact safe operations of PG&E equipment?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
216	Will Abrams	Set 02	WillAbrams-Set 02	25	WillAbrams-Set 02_25	Q: Given the ambiguity of "NA" meaning "not present" has PG&E revised their inspection forms to have less ambiguous and more accurate infrastructure evaluation and risk scoring? Are any changes reflected within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
217	Will Abrams	Set 02	WillAbrams-Set 02	26	WillAbrams-Set 02_26	Q: How has PG&E mitigated these risks to ensure "spewing steam" from cooling towers doesn't cause arcing as was identified as a "constant source of entertainment"? Where in the PG&E WMP does it reference changed mitigation practices due to this new information?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
218	Will Abrams	Set 02	WillAbrams-Set 02	27	WillAbrams-Set 02_27	Q: Is this practice of "covering the insulators with silicone grease" the approved mitigation tactic of PG&E? If so, how is that reflected in their WMP and if not how has this poor maintenance practice been corrected?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
219	Will Abrams	Set 02	WillAbrams-Set 02	28	WillAbrams-Set 02_28	Q: Is this practice of waiting till there is a "solid line of arcing" a prudent wildfire mitigation practice during the nighttime when moisture content causes frequent arcing? If so, where is this referenced in the PG&E WMP? If not, how has PG&E corrected this flawed practice?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	1	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
220	Will Abrams	Set 02	WillAbrams-Set 02	29	WillAbrams-Set 02_29	Q: Is PG&E comfortable with this haphazard alerting practice or does a more standardized arcing alert need to be ingrained within their WMP and associated operations?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
221	Will Abrams	Set 02	WillAbrams-Set 02	30	WillAbrams-Set 02_30	Q: Is PG&E still injecting iron into cooling systems? If so, how is PG&E mitigating these "higher level" contamination risks and wildfire risks? How is this reflected within their WMP given that is a cause or a contributor of catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
222	Will Abrams	Set 02	WillAbrams-Set 02	31	WillAbrams-Set 02_31	Q: Given that extreme corrosiveness is associated with towers close to power plants, how has PG&E mitigated risks specific to these towers? What WMP standards have been created to mitigate these risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3 (and possible 1.1 Verification; Group B section 1)	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
223	Will Abrams	Set 02	WillAbrams-Set 02	32	WillAbrams-Set 02_32	Q: Are these "Scotch-Brite" and "heliwash" practices still employed for cleaning insulators? Has this been standardized or do crew supervisors still have discretion of when to wash or replace? What WMP practices have standardized these practices given the known wildfire risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	2	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
224	Will Abrams	Set 02	WillAbrams-Set 02	33	WillAbrams-Set 02_33	Q: Has PG&E standardized around polymer insulators as part of their wildfire mitigation activities? What percentage of PG&E insulators are still the old ceramic type? Why is this not mentioned within the WMP when it was a leading cause or contributing factor of catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
225	Will Abrams	Set 02	WillAbrams-Set 02	34	WillAbrams-Set 02_34	Q: Has PG&E standardized to 2 year lifecycle for changing insulators? Has PG&E set standards in their WMP for insulator inspections to determine replacement given the risk of wildfire ignitions?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
226	Will Abrams	Set 02	WillAbrams-Set 02	35	WillAbrams-Set 02_35	Q: Do line crew supervisors still have the authority to "mothball" infrastructure with direction from outside sources? How has PG&E implemented corrective actions given the wildfire risks associated with how infrastructure is decommissioned or mothballed?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
227	Will Abrams	Set 02	WillAbrams-Set 02	36	WillAbrams-Set 02_36	Q: Why isn't decommissioning infrastructure requiring an engineering consult? Given the evident wildfire risk has PG&E required engineering consults and direction on a going forward basis as part of their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
228	Will Abrams	Set 02	WillAbrams-Set 02	37	WillAbrams-Set 02_37	Q: Given that this motion of the insulator string caused or contributed to the Kincaide Fire has PG&E now measured these movements and identified wildfire mitigation practices and quality controls to remedy?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
229	Will Abrams	Set 02	WillAbrams-Set 02	38	WillAbrams-Set 02_38	Q: Is engineering design now required for these types of mothballing practices? Why is this not reflected within the WMP given the wildfire risk?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
230	Will Abrams	Set 02	WillAbrams-Set 02	39	WillAbrams-Set 02_39	Q: Given the subsequent catastrophic fire, does PG&E now require an "engineering reference" for this type of line configuration work? Why are these standards not set in the WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
231	OEIS	Set 10	OEIS-PG&E-22-010	1	OEIS-PG&E-22-010_1	In the Section 8.2.3.7 PG&E describes its use of the risk vs. benefit tool in four events in 2021 to support the evaluation of the potential public safety risk due to a PSPS event against the forecasted potential wildfire risk. a. To date, did PG&E use the risk-benefit tool for determining to initiate any events that did not result in a PSPS event?	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	0	8.2.3.7	PSPS	PSPS Risk-Benefit Tool

232	OEIS	Set 10	OEIS-PG&E-22-010	2	OEIS-PG&E-22-010_2	<p>Regarding PG&E's attachment CONFIDENTIAL_PGE_2022-WMP_Section_46_Remedies_2114_Arch01_CONF to the 2022 WMP Update:</p> <p>a. Concerning the project type "Community Wildfire Safety Program for projects aimed for 2022-2023":</p> <p>i. Describe this project type, including where more information about this project type is described within the 2022 WMP (or previous WMPs, if applicable).</p> <p>ii. How were the projects that fall under this project type selected and prioritized?</p> <p>iii. How does this project type overlap and/or align with risk model output?</p> <p>iv. Provide a percentage of projects under CWSP that align with the top 20% risk score output from the 2021 Wildfire Distribution Risk Model</p> <p>b. How does this project type differ from the following: Top 20% MAVF CPZ, Top 250 miles, and Top 50 Miles? Currently, this data is showing around 0.82 miles planned for undergrounding in 2024.</p> <p>i. Is this still accurate?</p> <p>ii. If not, provide the updated mileage.</p> <p>iii. If so, when does PG&E intend to select locations for additional undergrounding miles?</p> <p>iv. If locations are not currently selected, how is PG&E planning on expediting undergrounding for completion in 2024?</p> <p>v. Are the locations for grid hardening, as a whole, selected for 2024 (i.e., know the hardening location, but don't know the hardening initiative that will be used, UG vs. OH)?</p> <p>vi. If so, is it possible to provide an amended response including these projects?</p>	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	0	4.6	Grid Design and System Hardening	System Hardening
233	OEIS	Set 10	OEIS-PG&E-22-010	3	OEIS-PG&E-22-010_3	<p>On page 870, PG&E indicates potential reductions in PSPS event size in 2022 are expected to come from planned mitigations and "PG&E is currently still in the process of finalizing locations for certain 2022 mitigations but anticipates the following mitigations to come online in 2022. These include:</p> <ul style="list-style-type: none"> - Distribution Sectionalizing Devices - Transmission Sectionalizing Devices - Temporary Distribution Microgrids - Distribution System Hardening - Fixed Power Solutions (FPS) <p>In a footnote on the same page, PG&E indicates "Some mitigation programs require more than a year of lead time to execute. As a result, some of the mitigations expected to be available in 2022 were identified using earlier data, including the 2020 lookback." This would seem to indicate at least some selections would have had to have been made previously.</p> <p>a. When does PG&E plan to have these remaining locations finalized?</p> <p>b. Please provide currently available locations for those which have been finalized as a GIS file (.gdb)?</p> <p>c. How will it determine locations are in the highest risk areas for PPS?</p> <p>d. For each of the above-listed mitigations, please provide a percentage of projects that align with top risk, defined as:</p> <p>i. The top 20% risk score output from the 2021 Wildfire Distribution Risk Model</p> <p>ii. PPS Impacted Locations</p> <p>iii. Locations where risk has materialized</p> <p>iv. PSS Identified Locations</p>	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	1	8.1.4	PSPS	Future Plans
234	OEIS	Set 11	OEIS-PG&E-22-011	1	OEIS-PG&E-22-011_1	<p>In response to OEIS-PG&E-22-007 Question 16, PG&E states that it "utilized the decision tree presented in 2021 for the 2022 scope of work."</p> <p>a. Is this in reference to the decision-tree provided in response to PG&E-Remedies-21-14 as part of the 2021 WMP Progress Report?</p> <p>b. How and where does PG&E's risk modeling output inform decision-making in relation to the decision-tree discussed in part (a)?</p> <p>c. When was this decision-making process first implemented?</p> <p>d. How does this align and/or differ with the system hardening decision-making methodology presented on May 21, 2021, to the Wildfire Safety Division (titled PG&E's System Hardening Program)?</p> <p>e. What changes to PG&E's decision-making have been made since the May 21, 2021 presentation to the Wildfire Safety Division?</p>	Kevin Miller	4/22/2022	4/27/2022	4/27/2022	1	7.3.3	Grid Design and System Hardening	Additional Detail
235	OEIS	Set 11	OEIS-PG&E-22-011	2	OEIS-PG&E-22-011_2	<p>Regarding the 2022 WMP, PG&E indicates a decrease in targets for implementing sectionalizing devices both at the distribution and transmission levels. For distribution, PG&E's targets decreased from 250 in 2021 to 100 in 2022. For transmission, PG&E's targets decreased from 300 in 2021 to 75 in 2022.</p>	Kevin Miller	4/22/2022	4/27/2022	4/27/2022	0	7.3.3.8.1 7.3.3.8.2	Grid Design and System Hardening	Distribution & Transmission Line Sectionalizing
236	OEIS	Set 11	OEIS-PG&E-22-011	3	OEIS-PG&E-22-011_3	<p>a. Please explain how PG&E has determined 1300 weather stations as its long-term goal for weather stations density.</p>	Kevin Miller	4/22/2022	4/29/2022	4/29/2022	1	7.3.2.1.3	Situational Awareness and Forecasting	Weather monitoring
237	OEIS	Set 12	OEIS-PG&E-22-012	1	OEIS-PG&E-22-012_1	<p>Regarding the 2022 WMP, PG&E's "milestones for 2022 WMP Update" provided April 25, 2022:</p> <p>a. PG&E has modified its pole clearing program target to inspect and clear (where clearance is needed) all poles identified in PG&E's VM Database, including poles in the 2022 WMP Update.</p>	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0	7.3.5.2	Operational Inspections and Management Practices for Vegetation Clearance	Pole Clearing
238	OEIS	Set 12	OEIS-PG&E-22-012	2	OEIS-PG&E-22-012_2	<p>a. How many customer complaints has PG&E received regarding EPSS since implementation in June 2021? Provide a breakdown of number by month.</p>	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0	7.3.6.8	Grid Operations and Protocols	EPSS
239	OEIS	Set 12	OEIS-PG&E-22-012	3	OEIS-PG&E-22-012_3	<p>Regarding the 2022 WMP, PG&E's "milestones for 2022 WMP Update" provided April 29, 2022:</p> <p>a. Why does PG&E project an overall increase in ignitions from 2022 to 2023?</p> <p>b. Why does PG&E project a slight increase in overall ignitions for Tier 2 on April 29, 2022?</p>	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0	6.7	Performance Metrics and Underlying Data	Recent and Projected Drivers of Ignition Probability
240	OEIS	Set 12	OEIS-PG&E-22-012	4	OEIS-PG&E-22-012_4	<p>On page 700, PG&E lists short-term improvements (2023-2026). PG&E lists the vegetation management programs which will use the One VM Tool. Energy Safety acknowledges it defined "Future improvements to initiative" as "the next 5 years," i.e., 2022-2028 (2022 Guidelines, Attachment 2, Chapter 5) under the preparation of the 2022 WMP Update.</p>	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0	7.3.5.19	Vegetation Management (VM) and Inspections	Vegetation Management Enterprise System
241	OEIS	Set 12	OEIS-PG&E-22-012	5	OEIS-PG&E-22-012_5	<p>On page 700, PG&E lists short-term improvements (2023-2026). PG&E lists the restoration team's activities leading up to re-energization, including "Determine if any Customer Owned Lines identified as being at risk are within the event footprint (both transmission and distribution) as detailed in the 2022 WMP Update."</p>	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0	8.2.4	Protocols on PPS	Re-Energization Strategy
242	OEIS	Set 13	OEIS-PG&E-22-013	1	OEIS-PG&E-22-013_1	<p>Regarding the 2022 WMP, PG&E's "milestones for 2022 WMP Update" provided April 29, 2022, PG&E has modified the number of circuits from 988 to 1,018 and introduced language to indicate that the May 1st and August 1st target dates measure the number of line devices loaded with the WDRM V3 Validation Report.</p>	Kevin Miller	5/6/2022	5/11/2022	5/11/2022	0	7.3.6.8	Grid Operations and Protocols	Protective Equipment and Device Settings
243	OEIS	Set 14	OEIS-PG&E-22-014	1	OEIS-PG&E-22-014_1	<p>The WDRM V3 Validation Report (WDRM V3) is undergoing internal review to check for validation. PG&E previously conveyed that the WDRM V3 Validation Report would be published April 29, 2022. Energy Safety requests a copy of this report as soon as it is available.</p>	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0	4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
244	OEIS	Set 14	OEIS-PG&E-22-014	2	OEIS-PG&E-22-014_2	<p>Energy Safety would like to know whether there were changes in personnel costs related to WMP between 2021 and 2022.</p> <p>a. If so, please provide this cost differential information.</p> <p>i. Overall</p>	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0	3.1	Actuals and Planned Spending for Mitigation Plan	Summary of WMP initiative expenditures
245	OEIS	Set 14	OEIS-PG&E-22-014	3	OEIS-PG&E-22-014_3	<p>Regarding the 2022 WMP, PG&E's "milestones for 2022 WMP Update" provided April 29, 2022:</p> <p>a. Does PG&E have a plan and resources to hire 100 employees for North Counties and another 100 for Sonoma County for WMP implementation?</p> <p>b. To which departments or programs would these positions be allocated?</p>	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0	N/A	N/A	N/A
246	OEIS	Set 14	OEIS-PG&E-22-014	4	OEIS-PG&E-22-014_4	<p>Regarding PG&E's Public Safety Specialists program:</p> <p>a. Provide how many total Public Safety Specialist positions have been filled for the following years and the counties they were assigned to.</p> <p>i. 2020</p>	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	4	7.3.9	Emergency Planning and Preparedness	Additional Detail
247	OEIS	Set 14	OEIS-PG&E-22-014	5	OEIS-PG&E-22-014_5	<p>In its discussion of its EPSS initiative 7.3.6.8 Protective equipment and Device Settings (pp. 730-739) SCADA is not mentioned.</p> <p>a. Please discuss how SCADA is being implemented with EPSS enablement.</p>	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	1	7.3.6.8	Grid Operations and Protocols	Protective equipment and device settings
248	OEIS	Set 14	OEIS-PG&E-22-014	6	OEIS-PG&E-22-014_6	<p>Regarding PG&E's work orders:</p> <p>a. How many work orders within the HFTD in the past three years have decreased in priority levels? What percentage of total work orders within the HFTD in the past three years does this account for?</p> <p>b. How many work orders within the HFTD in the past three years have increased in priority levels? What percentage of total work orders within the HFTD in the past three years does this account for?</p> <p>c. Provide a spreadsheet of all work orders discussed in parts a and b.</p>	Kevin Miller	5/13/2022	5/18/2022	5/19/2022	1	7.3.4	Asset Management and Inspections	Additional Detail
249	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	1	CalAdvocates-PGE-2022WMP-21_1	<p>With regard to PG&E's undergrounding efforts in the HFTD for wildfire mitigation purposes:</p> <p>a) Describe PG&E's current policy regarding undergrounding of existing service connections when the main lines are moved underground.</p> <p>b) Describe PG&E's current policy regarding the installation of new service connections underground when new main lines are installed underground (e.g. in a fire rebuild project or in new construction).</p> <p>c) Please provide a list of situations in which PG&E would underground the main line, but install or leave the service connection aboveground.</p> <p>d) For each situation in part (c), please explain the factors that would contribute to PG&E's decision not to underground the service connections.</p>	Holly Wherman Carolyn Chen	5/31/2022	6/17/2022	6/15/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail
250	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	2	CalAdvocates-PGE-2022WMP-21_2	<p>What is the average actual cost of installing service connections underground? Please provide this as a cost per foot (or a range of costs per foot, if variable) and state the time period from which this data is drawn.</p>	Holly Wherman Carolyn Chen	5/31/2022	6/14/2022	6/14/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail
251	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	3	CalAdvocates-PGE-2022WMP-21_3	<p>Section 7.3.3.10 of PG&E's 2022 WMP discusses PG&E's plan to underground approximately 10,000 distribution circuit miles in HFTDs.</p> <p>a) When PG&E undergrounds a segment of distribution circuit as part of its 10,000 mile undergrounding plan, does it plan to also underground that circuit's associated service connections?</p> <p>b) When PG&E places or plans to place a circuit's associated service connections underground, does PG&E include the length of those service connections in the 10,000 circuit mile forecast?</p> <p>c) Does the forecasted cost of undergrounding the 10,000 circuit miles discussed in your 2022 WMP include costs of undergrounding associated service connections?</p> <p>d) If the answer to part (c) is yes, please provide a cost estimate for the undergrounding of all service connections included as part of the 10,000</p>	Holly Wherman Carolyn Chen	5/31/2022	6/17/2022	6/15/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail

252	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	4	CalAdvocate s-PGE-2022WMP-21_4	Section 7.3.3.17.6 of PG&E's 2022 WMP discusses PG&E's Butte County Rebuild Program, which involves undergrounding the distribution within the town of Paradise and lower Magalia. a) Does PG&E install service connections underground as part of the Butte County Rebuild Program? b) If the answer to part (a) is yes, please provide the actual to-date costs of undergrounding service connections as part of the Butte County Rebuild Program. c) If the answer to part (a) is yes, please provide the actual to-date linear feet of service connections that have been undergrounded as part of the Butte County Rebuild Program. d) Please provide the approximate percentage of service connections that have been (to date) installed above ground or left above ground as part of the Butte County Rebuild Program. e) Please provide an Excel table with the following information in new columns added to the Excel table PG&E submitted in response to CalAdvocates-PGE-2022WMP-09: Questions 1, 2, and 3: i. Reason for reinspection (if applicable) ii. New due date post-reinspection (if applicable) iii. New prioritization of work order (if it changed) iv. Equipment type b) Also provide a process flow chart illustrating the inspection process or a description of the inspection process from identification of an issue through to resolving it, including the typical timescale. i. Include the length of time between identification to initiation of repair and what triggers initiation of the repair. c) Additionally, identify any interactions with external agencies, including for permitting, including the following for each agency: i. Any barriers to completing work orders due to permitting. ii. A list of all work orders that have been initiated but have been delayed due to permitting. iii. A list of all work orders for which repair has not been initiated due to permitting concerns. iv. A list of all work orders dated in the past year that have been marked as urgent for which a permit was required. (1) Provide the amount of time that elapsed from the identification of the issue to when it became urgent. (2) Note whether the repair was initiated prior to it being marked as urgent.	Holly Wherman Carolyn Chen	5/31/2022	6/14/2022	6/14/2022	0	7.3.3.17.6	Butte County Rebuild Program	Additional Detail
253	OEIS	Set 15	OEIS-P&GE-22-015	1	OEIS-P&GE-22-015_1	a) On December 9, 2021, was PG&E using the Heli-Saw for wildfire mitigation purposes? b) If the answer to part (a) is yes, please identify the WMP initiative that this activity was part of.	Kevin Miller	6/3/2022	6/15/2022	6/15/2022	6	7.3.4	Asset Management and Inspections	Additional Detail
254	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	1	CalAdvocate s-PGE-2022WMP-22_1	a) On December 9, 2021, was PG&E using the Heli-Saw for wildfire mitigation purposes? b) If the answer to part (a) is yes, please identify the WMP initiative that this activity was part of.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
255	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	2	CalAdvocate s-PGE-2022WMP-22_2	When did PG&E first become aware that the Heli-Saw had operated within Wunderlich County Park on December 9, 2021?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
256	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	3	CalAdvocate s-PGE-2022WMP-22_3	a) Which public agencies (e.g., CPUC, OEIS, Cal Fire, San Mateo County) did PG&E notify (prior to December 9, 2021) that it planned to operate a Heli-Saw in Wunderlich County Park? b) For each agency in response to part (a), list the date PG&E gave notice to that agency.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
257	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	4	CalAdvocate s-PGE-2022WMP-22_4	a) To which public agencies (e.g., CPUC, OEIS, Cal Fire, San Mateo County) did PG&E report that it had operated a Heli-Saw in Wunderlich County Park on December 9, 2021? b) For each agency in response to part (a), list the date PG&E made its report to that agency. c) Please provide copies of all reports to the agencies in response to part (a).	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
258	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	5	CalAdvocate s-PGE-2022WMP-22_5	The article states that "PG&E said its Heli-Saw contractor 'mistakenly' strayed several hundred feet into parkland after doing permitted work on nearby private land." a) Who is the Heli-Saw contractor referenced above? b) Please list all Heli-Saw contractors PG&E currently employs. c) Please describe why the Heli-Saw pilot was not aware that the Heli-Saw had passed into county parkland until the Heli-Saw had traveled "several hundred feet into parkland." d) Please describe the specific sequence of events that led to the contractor "mistakenly" straying into Wunderlich County Park. e) Please describe any and all operational failures (including but not limited	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
259	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	6	CalAdvocate s-PGE-2022WMP-22_6	Please provide copies of the results of any internal audits or investigations that PG&E has performed in relation to the operation of the Heli-Saw in Wunderlich County Park on December 9, 2021.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	2	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
260	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	7	CalAdvocate s-PGE-2022WMP-22_7	a) Describe PG&E's current protocol for keeping members of the public out of an area where the Heli-Saw is operating. b) Describe all precautions that PG&E takes to protect public safety while the Heli-Saw is operating. c) Describe all precautions the Heli-Saw contractor takes to protect public safety while the Heli-Saw is operating. d) Has PG&E changed its procedures or protocols related to Heli-Saw operation since receiving the Cal Fire notice of violation described in the news story? e) If the answer to part (d) is yes, please list all changes made to the procedures or protocols related to Heli-Saw operation since receiving the Cal Fire notice of violation described in the news story. f) Please provide a copy of all PG&E procedures, job aids, or other guidance documentation related to operation of the Heli-Saw.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
261	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	8	CalAdvocate s-PGE-2022WMP-22_8	a) Does PG&E utilize the Heli-Saw in HFTD areas for the purposes of wildfire mitigation? b) If the answer to part (a) is yes, please list all initiatives from PG&E's 2022 WMP Update in which the Heli-Saw has been utilized to date. c) If the answer to part (a) is yes, please list all initiatives from PG&E's 2022 WMP Update in which it expects to utilize the Heli-Saw in the future. d) If the answer to part (a) is yes, why didn't PG&E mention the Heli-Saw in its 2022 WMP Update?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
262	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	9	CalAdvocate s-PGE-2022WMP-22_9	Pages 825-826 of PG&E's 2022 WMP Update discuss community outreach about wildfire mitigation activities, including helicopter operations. To set expectations with customers and with the goal of limiting work refusals or access issues, PG&E uses various communication methods, such as letters, postcards, text messages, e-mails, and automated calls through Interactive Voice Recordings. a) For normal Heli-Saw operations, which of these communication methods does PG&E use? b) For normal Heli-Saw operations, how does PG&E determine which customers should be notified? c) For the Heli-Saw operation on December 9, 2021, which of these communication methods did PG&E use? d) For the Heli-Saw operation on December 9, 2021, how did PG&E determine which customers should be notified?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
263	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	10	CalAdvocate s-PGE-2022WMP-22_10	The news story states, "Sampson estimated that branches of up to eight inches in diameter fell as much as 150 feet to the ground in the park." a) In normal operation of the Heli-Saw, how does PG&E protect the public from heavy branches falling, as described above? b) In normal operation of the Heli-Saw, how does PG&E protect employees and contractors working with the Heli-Saw from heavy branches falling, as described above?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
264	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	11	CalAdvocate s-PGE-2022WMP-22_11	The news story states, "The operation, according to Sampson, created hundreds of 2-foot to 6-foot-long stubbed limbs that littered the forest floor, that will likely die and create a fire hazard." a) Does PG&E dispute Sampson's statement about the fallen branches from the Heli-Saw operation creating a fire hazard, quoted above? Please explain if yes. b) Has PG&E taken any action to remove the limbs described above from Wunderlich County Park? Please describe all such actions if yes. c) Does PG&E plan to take any action in the future to remove the limbs described above from Wunderlich County Park? Please describe all such actions if yes. d) Describe PG&E's current practices regarding how it deals with fallen limbs from normal Heli-Saw operations.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
265	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	12	CalAdvocate s-PGE-2022WMP-22_12	The news story states, "The ground crews were on mano opere and after the operation at the park, the utility said, there were 'no safety issues... nor was the public in danger at any time.'" a) In normal Heli-Saw operations, what are the duties of the ground crews mentioned above? b) How many ground crews are involved in a typical Heli-Saw operation? c) How many people, on average, are in each ground crew for a typical Heli-Saw operation? d) How do Heli-Saw ground crews determine the location of the Heli-Saw relative to the planned flight path? e) How does the Heli-Saw pilot ensure that they follow the planned flight path? f) Please describe why the ground crews on December 9, 2021 were not aware that the Heli-Saw had passed into Wunderlich County Park until the news story states that Cal Fire released a notice of violation in February 2022.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
266	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	13	CalAdvocate s-PGE-2022WMP-22_13	a) Provide a copy of the notice of violation described above. b) Provide a copy of PG&E's response to the Cal Fire notice of violation described above. c) Provide a copy of any other notices of violation from any government agency related to the usage of the Heli-Saw on December 9, 2021. d) Provide a copy of all of PG&E's response to any notifications of violation from non-pat (c).	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	3	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
267	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	14	CalAdvocate s-PGE-2022WMP-22_14	The news story states, "PG&E says it is conferring with Cal Fire over the Heli-Saw related violation notice as well as the permit dispute." a) What is the current status of discussions between Cal Fire and PG&E, related to the violation, noted above? b) What is the current status of the permit dispute, noted above?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment

268	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	15	CalAdvocate s-PGE-2022WMP-22_15	a) Is PG&E engaged in any legal or administrative proceedings related to its use of the Heli-Saw in Wunderlich County Park on December 9, 2021? b) If the answer to part (a) is yes, please list all such proceedings and the venue.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0		7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
270	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	1Supp	CalAdvocate s-PGE-2022WMP-03_1Supp	lease note that the geographical regions are mutually exclusive (i.e., "Other HFTD" excludes areas that are in either Tier 2 or Tier 3). Therefore, for any given circuit, the following relationships should hold: Tier 2 miles + Tier 3 miles + Other HFTD miles = total HFTD miles. Tier 2 miles + Tier 3 miles + Other HFTD miles + non-HFTD miles = total circuit miles. Provide an Excel table of all distribution circuits existing as of January 1, 2022 (as rows) that includes the following information in separate columns: bbbb.Miles of LiDAR inspection in Non-HFTD in 2020cccc.Miles of LiDAR inspection in Non-HFTD in 2021dddd.Miles of LiDAR inspection Other HFTD in 2020eeee.Miles of LiDAR inspection Other HFTD in 2021ffff.Miles of LiDAR	Alan Wehrman	1/25/2022	8/3/2022	8/3/2022	1		N/A	Miscellaneous	Additional Detail
271	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	1	CalAdvocate s-PGE-2022WMP-23_1	State how many customer accounts PG&E has as of June 29, 2022, and disaggregate the total by HFTD tier (as defined above).	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		8	PSPS	Additional Detail
272	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	2	CalAdvocate s-PGE-2022WMP-23_2	Please provide the protective device settings that PG&E plans on using in HFTD areas during high fire-risk weather in 2022, including the following parameters: a) The minimum to trip current; b) Definite time delay; c) Time curve; and d) Coordination parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		7.3.6.8	EPSS	Device settings
273	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	3	CalAdvocate s-PGE-2022WMP-23_3	If any of the parameters identified in question 2 depend on the normal operating parameters for its protective devices (i.e., device settings such as the minimum to trip during ordinary weather), please describe how PG&E determines those normal operating parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		7.3.6.8	EPSS	Device settings
274	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	4	CalAdvocate s-PGE-2022WMP-23_4	a) Please state whether PG&E plans (in 2022) to coordinate protective devices with fuses' time overcurrent curves, or plans on operating protective devices in a fuse-saving mode (i.e. the recloser/circuit breaker trips before the fuse operates) while fast curve settings are in effect. b) Please explain the reasoning for PG&E's choice(s) in part (a) of this question.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		7.3.6.8	EPSS	Device settings
275	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	5	CalAdvocate s-PGE-2022WMP-23_5	Please provide: a) Any studies that show how PG&E determined that the protective device settings identified in question 2 are the best settings to use during high fire-risk weather; and b) Any studies of the expected impact to reliability due to the settings identified in question 2.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	6		7.3.6.8	EPSS	Device settings
276	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	6	CalAdvocate s-PGE-2022WMP-23_6	Please provide the protective device settings that PG&E normally uses (i.e., outside of HFTD or outside of high fire risk weather) in 2022, including the following parameters: a) The minimum to trip current; b) Definite time delay; c) Time curve; and d) Coordination parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		7.3.6.8	EPSS	Device settings
277	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	7	CalAdvocate s-PGE-2022WMP-23_7	Please provide the following details regarding fast curve settings that PG&E used in 2021 during high fire-risk weather: a) How PG&E calculates the fault duty of the next downstream recloser, including what type of faults PG&E calculates (e.g. line-to-ground, line-to-line, triple-line-to-ground); b) How PG&E coordinated circuit breakers and main line reclosers with fuses; c) What the instantaneous tripping currents in 2021 were for the hot-line tan (HLTI) settings mode.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0		7.3.6.8	EPSS	Device settings
278	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	8	CalAdvocate s-PGE-2022WMP-23_8	Please provide an unredacted version of the spreadsheet "WMP-Discovery2022_DR_OEIS_005-Q10A1ch01_CONF.xlsx".	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	1		7.3.6.8	EPSS	EPSS
279	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	1	CalAdvocate s-PGE-2022WMP-24_1	Regarding transmission structures and transmission connecting hardware ("these facilities"): a) How does PG&E detect defects in these facilities that may be difficult or impossible to detect using the unaided eye (such as a broken jumper within a steel shoe)? b) Does the answer to part (a) of this question differ in HFTD areas, compared to non-HFTD areas? c) If the answer to part (b) is yes, please explain the differences.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0		7.3.4	Asset Management and Inspections	Additional Detail
280	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	2	CalAdvocate s-PGE-2022WMP-24_2	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Does PG&E use x-raysto examine these facilities while in operation? b) If the answer to part (a) is yes, please describe how and where PG&E does this. c) Does PG&E use gamma raysto examine these facilities while in operation? d) If the answer to part (c) is yes, please describe how and where PG&E does this.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0		7.3.4	Asset Management and Inspections	Additional Detail
281	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	3	CalAdvocate s-PGE-2022WMP-24_3	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Please provide all current PG&E procedures for using x-rays or gamma rays to examine these facilities. b) Please provide all available studies documenting the feasibility and effectiveness of using x rays and gamma rays to nondestructively examine these facilities. c) If there are any studies documenting the feasibility and effectiveness of using x-rays and gamma rays to nondestructively examine these facilities that you are aware of but do not possess, please identify each such document.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	1		7.3.4	Asset Management and Inspections	Additional Detail
282	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	4	CalAdvocate s-PGE-2022WMP-24_4	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Please provide all current PG&E procedures for nondestructive examination of these facilities, other than using the visible spectrum and any procedures covered in question 3(a). b) Please provide all current PG&E procedures for destructive examination of these facilities.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	7		7.3.4	Asset Management and Inspections	Additional Detail
283	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	5	CalAdvocate s-PGE-2022WMP-24_5	Regarding distribution structures and hardware in HFTD areas ("these facilities"): a. Please provide all current PG&E procedures for nondestructive examination of these facilities, other than using the visible spectrum. b. Please provide all current PG&E procedures for destructive examination of these facilities.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0		7.3.4	Asset Management and Inspections	Additional Detail
284	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	1	CalAdvocate s-PGE-2022WMP-25_1	Page 5 of PG&E's response states regarding the 2017 Railroad Fire, "PG&E tree contractor inadvertently dropped dead Cedar tree that the contractor was working on into a PG&E distribution line," and, "PG&E did not perform a specific lessons learned analysis for the Railroad Fire." a) Why did PG&E not perform a specific lessons learned analysis for the Railroad Fire? b) Following the Railroad Fire on August 29, 2017, through July 1, 2022, has PG&E experienced any other ignitions in its HFTD where an individual performing tree work for PG&E inadvertently dropped a tree into the distribution line? c) If the answer to part (b) is yes, please list the ignitions, including the date of the ignition, geographic latitude of the ignition, geographic longitude of the ignition, and the final size of the fire.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
285	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	2	CalAdvocate s-PGE-2022WMP-25_2	Page 5 of PG&E's response states regarding the 2018 Airline Fire, "We are currently in the process of reviewing our existing maintenance tags for tags that identify missing vibration dampers and are also reviewing our guidance to inspectors so that they properly identify missing vibration dampers during inspections." a) When did PG&E initiate the review of existing maintenance tags referenced above? b) Does the review of existing maintenance tags encompass all open maintenance tags on the electric system or some subset? If the scope is limited to a subset, please describe the scope. c) When does PG&E expect to complete the review of existing maintenance tags referenced above? d) When did PG&E initiate the review of its guidance to inspectors referenced above? e) When does PG&E expect to complete the review of its guidance to inspectors referenced above? f) Has PG&E initiated any review of design standards, engineering practices, or construction practices to ensure that vibration dampeners are installed appropriately? g) If the answer to part (f) is yes, please describe the scope and timeline for this review. h) Does PG&E have equipment in service that predates the practice of utilizing vibration dampeners? i) If the answer to part (h) is yes, please list all actions PG&E has taken to assess such legacy equipment and mitigate the issue of missing vibration dampeners.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
286	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	3	CalAdvocate s-PGE-2022WMP-25_3	Pages 5-6 of PG&E's response regarding the 2018 Airline Fire identify several actions PG&E is undertaking to ensure that the issue of missing vibration dampeners is found and remediated. Please list all actions PG&E has undertaken since the Airline Fire ignited on June 4, 2018 to ensure that the issue of missing vibration dampeners does not occur in the first place.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	1		4.1	Lessons Learned and Risk Trends	Additional Details
287	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	4	CalAdvocate s-PGE-2022WMP-25_4	Page 9 of PG&E's response states regarding the 2019 Lonoak Fire, "Corrective Action Program (CAP) event assigned to determine ongoing risk from vibration dampers in the field and deployed on #2 ACSR and #4 ACSR conductor wires. Specifically, the team evaluated extent of risk between 2 ACSR and Alcoa Stockbridge dampers." a) Please briefly describe the findings from PG&E's evaluation of the extent of the risk between ACSR and Alcoa Stockbridge dampers, described above. b) Has PG&E determined that utilizing Alcoa Stockbridge dampers presents a wildfire risk? c) If the answer to part (b) is yes, has PG&E initiated an effort to proactively identify and remove or replace Alcoa Stockbridge dampers? d) If the answer to part (c) is no, please explain why not.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	1		4.1	Lessons Learned and Risk Trends	Additional Details

288	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	5	CalAdvocate s-PGE-2022WMP-25_5	Page 12 of PG&E's response states regarding the 2021 Dixie Fire, "We have revised our response time standard to respond to outages in HFTD areas, where we can safely do so, within 60 minutes as compared to the prior standard which required a response within 24 hours to a low level outage such as the one experienced on the circuit associated with the Dixie Fire." a) Please define "respond" as used in this context. b) In the event that an outage occurs and a PG&E troubleperson cannot physically reach the site within 60 minutes due to factors beyond their control, please describe how PG&E would meet its standard to respond to the outage within 60 minutes.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0	4.1	Lessons Learned and Risk Trends	Additional Details
289	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	6	CalAdvocate s-PGE-2022WMP-25_6	Page 14 of PG&E's response states, "For clarification, the revision Notice reference to increases in equipment-related ignitions from 2020 to 2021 refers to system-wide ignitions. However, in 2021, PG&E observed a 12.9% decrease in California Public Utilities Commission (CPUC) reportable ignitions in HFTD areas where the suspected cause was PG&E equipment failure." Page 16 of Energy Safety's Revision Notice includes the following chart, which shows a steady increase in non-HFTD ignitions from 2018 through 2021: [GRAPHIC TABLE] a) Please list all causal factors to which PG&E attributes the increase in equipment-related ignitions from 2018 to 2021 in non-HFTD. b) Please list and briefly describe all actions PG&E is taking in 2022 to reduce the number of equipment-related ignitions in non-HFTD.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0	4.1	Lessons Learned and Risk Trends	Additional Details
290	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	7	CalAdvocate s-PGE-2022WMP-25_7	Page 20 of PG&E's response describes its Enhanced Ignition Analysis (EIA) program. a) Does the EIA process apply to non-HFTD ignitions? b) If the answer to part (a) is no, please explain why not.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0	4.1	Lessons Learned and Risk Trends	Additional Details
291	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	8	CalAdvocate s-PGE-2022WMP-25_8	Pages 33-35 of PG&E's response include Table RN-PG&E-22-08-01: Timeline and Update on Actions To Increase Asset Inspection Quality. Please provide an updated copy of this Table with the following additional information in the "Timeline for Implementation" column: a) Date the action was initiated. b) Date the action was completed (if applicable).	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0	7.3.4.19	Asset Management and Inspections	Response to RN-PGE-22-08
291	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	9	CalAdvocate s-PGE-2022WMP-25_9	Pages 37 of PG&E's response states, "Continued incidents of fraudulent activity (timecards, inspections) will result in discipline and up to termination." a) From January 1, 2021, through July 1, 2022, how many incidents of fraudulent activity has PG&E recorded? b) Of the incidents in part (a), how many involved fraud in relation to asset inspections? c) Of the incidents in part (b), how many inspectors have been terminated as of July 1, 2022?	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0	7.3.4	Asset Management and Inspections	Response to RN-PGE-22-08
292	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	1	CalAdvocate s-PGE-2022WMP-26_1	a) Has PG&E studied the possibility of coordinating distribution protection in a manner where the substation feeder circuit breaker trips first and then the unfaulted line segments are re-energized to increase coordination and decrease protection delay? b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the use of cumulative distribution functions to impedance fault detection to achieve the desired tradeoff between risk mitigation and reliability? This would entail measuring the frequencies of various trip thresholds (i.e. if the threshold is surpassed every month, three months, year, etc.) to control the number of nuisance trips for high-impedance relay functions.	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0	7.3.3	Grid Design and System Hardening	Additional Detail
293	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	2	CalAdvocate s-PGE-2022WMP-26_2	a) Has PG&E studied the possibility of coordinating distribution protection in a manner where the substation feeder circuit breaker trips first and then the unfaulted line segments are re-energized to increase coordination and decrease protection delay? b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the distribution protection scheme described in part (a), please identify each such document.	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0	7.3.3	Grid Design and System Hardening	Additional Detail
294	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	3	CalAdvocate s-PGE-2022WMP-26_3	a) Has PG&E studied the possibility of coordinating distribution protection in a manner where the substation feeder circuit breaker trips first and then the unfaulted line segments are re-energized to increase coordination and decrease protection delay? b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the distribution protection scheme described in part (a), please identify each such document.	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0	7.3.3	Grid Design and System Hardening	Additional Detail
295	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	1	CalAdvocate s-PGE-2022WMP-27_1	Regarding Figure RN-PG&E-22-02-01 on p. 32 of PG&E's response, a) Please state the source(s) of data for the left-hand map, "PSPS Frequency of Circuit Segment." For example, are the frequencies based on actual PSPS events, PG&E's PSPS lookback analysis, or something else? In your answer, please include the date range for the data. b) Please state the source(s) of data for the right-hand map, "Wildfire Risk by Circuit Segment." For example, are the frequencies based on PG&E's Wildfire Risk by Circuit Segment data, or something else? In your answer, please include the date range for the data.	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	8	PSPS	Additional Detail
296	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	2	CalAdvocate s-PGE-2022WMP-27_2	Table RN-PG&E-22-03-02 on page 38 of PG&E's July 11, 2022 response states that 59 miles of undergrounding work will be performed in the top 20% risk-ranked circuit segments in 2022. Cal Advocates reviewed attachment "2022-02-25_PGE_2022_WMP-Update_R0_Section 4.6_Remedies 21-14_Atch01_CONF_R1.xlsx" to PG&E's 2022 WMP Update to estimate the percentage of undergrounding work that is planned for the top 20% risk-ranked circuit segments. Question 3 related to PG&E's response to Critical Issue RN-PG&E-22-03 (hereinafter PG&E's July 11, 2022 response).	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	4.6	Grid Design and System Hardening	System Hardening
297	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	3	CalAdvocate s-PGE-2022WMP-27_3	Page 39 of PG&E's July 11, 2022 response states, "In order to focus undergrounding projects in locations to both address wildfire risk over the entire year and locations where wind driven events pose high wildfire risk, both the WDRM and PSPS models are referenced in identifying candidate miles for undergrounding." Page 39 additionally states, "Other models, which are categorized as 'Operational' such as PG&E's EPI and DMI Models for Fire Mitigation." Question 4 relates to PG&E's response to Critical Issue RN-PG&E-22-05 (hereinafter PG&E's response).	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	8	PSPS	Additional Detail
298	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	4	CalAdvocate s-PGE-2022WMP-27_4	Table RN-PG&E-22-05-03 on pages 55 and 56 of PG&E's response outlines PG&E's planned timeline for addressing Ignition Risk tags. PG&E plans to close out 8,300 tags in Q1 of 2023, 26,700 tags in Q2, 40,000 tags in Q3, and 8,300 tags in Q4. a) Please explain the resources and plans PG&E will have in place in order to ramp up from addressing 8,300 tags in Q1 to 26,700 tags in Q2. b) Q3 is historically a slower wildfire season. Does PG&E anticipate any changes to its wildfire season in 2023? Question 5 relates to PG&E's response to data request CalAdvocates-PGE-2022WMP-25.	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	7.3.4.17	Asset Management and Inspections	Response to Critical Issue RN-PG&E-22-05
299	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	5	CalAdvocate s-PGE-2022WMP-27_5	In response to data request CalAdvocates-PGE-2022WMP-25, Question 9, PG&E stated that seven inspectors had committed fraudulent activity related to asset inspections between January 1, 2021 and July 1, 2022. a) Did PG&E perform any reinspections of the assets inspected by the seven inspectors referenced above? b) If the answer to part (a) of this question is yes, please describe the scope of the reinspections described in part (a). For example, did PG&E	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	1	7.3.4	Asset Management and Inspections	Additional Detail
300	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	1	CalAdvocate s-PGE-2022WMP-28_1	a) How many total ignitions has PG&E experienced related to underground distribution lines from January 1, 2015 through June 30, 2022? b) How many total ignitions has PG&E experienced related to overhead distribution lines from January 1, 2015 through June 30, 2022?	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	4.1	Lessons Learned and Risk Trends	Lessons Learned
301	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	2	CalAdvocate s-PGE-2022WMP-28_2	For questions 2 and 3, please refer to the definitions of HFTD areas above. If you have any questions about these definitions, contact the originators of this data request. Note that the HFTD areas are defined to be both mutually exclusive and exhaustive. Therefore, in the tables below, the systemwide total for each time period should equal the sum of the cells in that column. a) Please complete Table 2a below, including only ignitions related to underground distribution lines. [see PDF for table] Please complete Table 3a below, stating the total circuit-miles of underground distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column). [see PDF for table]	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.4.18	Asset Management and Inspections	Response to RN-PGE-22-06
302	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	3	CalAdvocate s-PGE-2022WMP-28_3	Please complete Table 3b below, stating that total circuit-miles of overhead distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column). [see PDF for table]	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.4.18	Asset Management and Inspections	Response to RN-PGE-22-06
303	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	4	CalAdvocate s-PGE-2022WMP-28_4	Page 2 of PG&E's response to the revision notice states, "PG&E's subject matter experts estimate that placing overhead lines underground reduces ignition risk by approximately 99% in that location." a) Please describe PG&E's validation process for your estimate of 99% ignition risk reduction, referenced in the quote above. b) Has PG&E compared the number of ignitions on a given circuit segment both prior to and after undergrounding the segment? c) If the answer to part (b) of this question is yes, please explain how PG&E	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
304	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	5	CalAdvocate s-PGE-2022WMP-28_5	On July 11, 2022, in response to Critical Issue RN-PG&E-22-03, PG&E provided Table RN-PG&E-22-03-02. This table states that, in 2023, PG&E's 2023 undergrounding workplan includes 662 miles, of which 419 miles are in the top 20% risk-ranked circuit segments. On July 26, 2022, in response to Critical Issue RN-PG&E-22-04, PG&E provided attachment 2022-07-26_PGE_22_04_RNR_R3_Atch01CONF.xlsx.2 Cal Advocates filtered Column J (2023 Estimated Miles) to include only 2023 values. The resulting lines contain Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by internal entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update.	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
Pre-Discovery 01	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	1	CalAdvocate s-PGE-2022WMP-02_1	Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by internal entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update.	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	17	7.3.4	Asset Management and Inspections	QA/QC Reports
Pre-Discovery 02	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	2	CalAdvocate s-PGE-2022WMP-02_2	Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by external entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update. External entities include, but are not limited to, contractors, auditors, the Federal Monitor, and Independent	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	27	7.3.4	Asset Management and Inspections	QA/QC Reports
Pre-Discovery 03	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	3	CalAdvocate s-PGE-2022WMP-02_3	Provide an Excel table of all defects in the year 2021 found by Energy Safety's Compliance Branch (or, previously, the CPUC's Wildfire Safety Division)1 (as rows) that includes the following information in separate columns: a) Associated circuit name b) Defect type c) Description of defect d) WMP initiative associated with defect e) Date that the defect was identified f) Date that the defect was corrected g) Priority level of	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	1	N/A	Miscellaneous	Additional Detail

Pre-Discovery 54	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	3	CalAdvocate s-PGE-2022WMP-10_3	How many tree attachments does PG&E plan to remediate in calendar year 2022 in each of the following categories: a) Total b) HFTD Tier 3 c) HFTD Tier 2 d) Other HFTD e) Non-HFTD	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0		7.3.3	Grid Design and System Hardening	Tree Attachments
Pre-Discovery 55	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	4	CalAdvocate s-PGE-2022WMP-10_4	When PG&E performs undergrounding in the HFTD for wildfire mitigation purposes, in places where other utilities (such as telecommunications providers) share PG&E's poles: a) Please describe PG&E's current policy regarding undergrounding the other utilities' equipment. b) Please describe PG&E's current policy regarding removal of the shared poles. c) Please describe PG&E's current policy regarding the shared poles. During the field visit to PG&E facilities on November 2, 2021, Cal	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0		7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 56	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	5	CalAdvocate s-PGE-2022WMP-10_5	Advocates visited an undergrounding project in El Dorado County, which was referred to as "Undergrounding Project El Dorado 2101 Phase 4." During the visit PG&E representatives represented that, after the powerline was moved underground, the poles would be "topped," which would remove a portion of the pole but leave the remainder of the pole intact. During the field visit to PG&E facilities on November 2, 2021, Cal	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0		7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 57	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	6	CalAdvocate s-PGE-2022WMP-10_6	Advocates visited an undergrounding project in El Dorado County, which was referred to as "Undergrounding Project El Dorado 2101 Phase 4." During the visit PG&E representatives represented that, after the powerline was moved underground, the poles would be "topped," which would remove a portion of the pole but leave the remainder of the pole intact. During the field visit to PG&E facilities on November 2, 2021, Cal	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0		7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 58	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	7	CalAdvocate s-PGE-2022WMP-10_7	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-10_3, Question 1, PG&E installed approximately 109 circuit-miles of underground conductor in HFTDs in 2021. a) Please verify that the above number of circuit-miles is accurate. b) Noting that multiple circuits may sometimes run in parallel through the same right-of-way, how many miles of right-of-way did PG&E's 2021 undergrounding project affect in HFTDs? c) How many miles of PG&E's 2021 undergrounding project affected in HFTDs that are in areas where falling or failing lines or poles could currently limit egress and/or ingress during an emergency? b) If the answer to part (a) is yes, please describe how PG&E identifies such transportation corridors. c) If available, please provide a geospatial data file that contains all current identified transportation corridors in the HFTD areas.	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0		7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 59	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	8	CalAdvocate s-PGE-2022WMP-10_8	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-10_3, Questions 3 and 4, PG&E stated that it is performing Quality Reviews of past inspections, both of which were expected to be complete by February 28, 2022. Please provide copies of these Quality Reviews, if available. If the Quality Reviews have not been completed as of the date of your request, please provide a timeline for completion. In its responses to Data Request CalAdvocates-PGE-2022WMP-10_7, PG&E's cover letter to its Submission of 2022 Wildfire Mitigation Plan Maturity Model Assessment submitted February 4, 2022, PG&E states: "in addition to our internal review of the questions and the scores, this year we have conducted an external review of the Southern California Edison Company's risk modeling and simulation."	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0		7.3.9	Emergency Planning and Preparedness	Additional Detail
Pre-Discovery 60	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	9	CalAdvocate s-PGE-2022WMP-10_9	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-10_7, Questions 3 and 4, PG&E stated that it is performing Quality Reviews of past inspections, both of which were expected to be complete by February 28, 2022. Please provide copies of these Quality Reviews, if available. If the Quality Reviews have not been completed as of the date of your request, please provide a timeline for completion. In its responses to Data Request CalAdvocates-PGE-2022WMP-10_7, PG&E's cover letter to its Submission of 2022 Wildfire Mitigation Plan Maturity Model Assessment submitted February 4, 2022, PG&E states: "in addition to our internal review of the questions and the scores, this year we have conducted an external review of the Southern California Edison Company's risk modeling and simulation."	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	2		7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
Pre-Discovery 61	OEIS	Set 002	OEIS-PG&E-22-002	1	OEIS-PG&E-22-002_1	PG&E's response to Maturity Survey question A.V.c (How are deviations from risk model to ignitions and propagation detected?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		N/A	Miscellaneous	Maturity Survey
Pre-Discovery 62	OEIS	Set 002	OEIS-PG&E-22-002	2	OEIS-PG&E-22-002_2	PG&E's response to Maturity Survey question A.V.b (How automated is the mechanism to determine whether to update algorithms based on deviations from risk model to ignitions and propagation detected?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.1	Risk Assessment and Mapping	Survey Responses
Pre-Discovery 63	OEIS	Set 002	OEIS-PG&E-22-002	3	OEIS-PG&E-22-002_3	PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.1	Risk Assessment and Mapping	Survey Responses
Pre-Discovery 64	OEIS	Set 002	OEIS-PG&E-22-002	4	OEIS-PG&E-22-002_4	PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 65	OEIS	Set 002	OEIS-PG&E-22-002	5	OEIS-PG&E-22-002_5	PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 66	OEIS	Set 002	OEIS-PG&E-22-002	6	OEIS-PG&E-22-002_6	PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 67	OEIS	Set 002	OEIS-PG&E-22-002	7	OEIS-PG&E-22-002_7	PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 68	OEIS	Set 002	OEIS-PG&E-22-002	8	OEIS-PG&E-22-002_8	PG&E's response to Maturity Survey question C.IV.d (What level of redundancy does the utility's transmission architecture have?): a. Provide the percentage of circuits that have n-1 redundancy.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 69	OEIS	Set 002	OEIS-PG&E-22-002	9	OEIS-PG&E-22-002_9	PG&E's response to Maturity Survey question D.I.a (What information is captured in the equipment inventory database?): a. Describe why PG&E moved from having an "accurate inventory of equipment in HFTD areas have the ability to detect and respond to malfunctions?": a. Why does PG&E only update asset condition annually?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.4	Asset Management and Inspections	Survey Responses
Pre-Discovery 70	OEIS	Set 002	OEIS-PG&E-22-002	10	OEIS-PG&E-22-002_10	PG&E's response to Maturity Survey question D.I.a (What information is captured in the equipment inventory database?): a. Describe why PG&E moved from having an "accurate inventory of equipment in HFTD areas have the ability to detect and respond to malfunctions?": a. Why does PG&E only update asset condition annually?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.4	Asset Management and Inspections	Survey Responses
Pre-Discovery 71	OEIS	Set 002	OEIS-PG&E-22-002	11	OEIS-PG&E-22-002_11	PG&E's response to Maturity Survey question D.II.a (What level of electrical lines and equipment maintained at?): a. Why is PG&E not currently meeting consistent maintenance, as required?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	1		7.3.3	Grid Design and System Hardening	Survey Responses
Pre-Discovery 72	OEIS	Set 002	OEIS-PG&E-22-002	12	OEIS-PG&E-22-002_12	PG&E's response to Maturity Survey question F.III.d (During PSPS events does the utility's website go down?): a. How many times did PG&E's website go down during PSPS events in 2021?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		7.3.6	Grid Operations and Protocols	Survey Responses
Pre-Discovery 73	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	1	CalAdvocate s-PGE-2022WMP-11_1	On February 2, 2022, PG&E made the study report in response to the Enhanced Oversight and Enforcement Process. Please provide Excel versions of the following attachments to this report: a) Attachment A: 2021 EVM Scope of Work - Year End Summary b) Attachment B: 2021 EVM Work Performed Outside the 2021 EVM	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	3		N/A	Miscellaneous	Additional Detail
Pre-Discovery 74	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	2	CalAdvocate s-PGE-2022WMP-11_2	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-10, Question 5, March 3, 2021, PG&E provided its 2021 EVM workplan. Please provide an updated version of this workplan that lists the actual EVM mileage performed in each circuit-segment in 2021 as a new column. Rows should be added as needed to cover all circuit-segments where	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	0		7.3.5.2	Vegetation Management (VM) and Inspections	Enhanced Vegetation Management
Pre-Discovery 75	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	3	CalAdvocate s-PGE-2022WMP-11_3	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-10, Question 6, March 3, 2021, PG&E provided its 2021 system hardening workplan for the categories referred to in parts (a)-(d) below. Please provide an updated version of this workplan with additional columns to show the actual system hardening work performed in each circuit-segment in 2021 for each of	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	1		7.3.3.17	Grid Design and System Hardening	System Hardening
Pre-Discovery 76	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	4	CalAdvocate s-PGE-2022WMP-11_4	PG&E's 2021 Q4 Quarterly Initiative Update, PG&E stated that, as of 2021 Q4, PG&E had hardened 210.5 distribution line miles under initiative "C.13 - System Hardening (Distribution)." As stated in PG&E's response to Data Request CalAdvocates-PGE-2022WMP-03, February 15, 2022, attachment "WMP-Discover2022_DR_CalAdvocates_003-003Supp014ch01CONE.xlsx"	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	0		7.3.3.17	Grid Design and System Hardening	System Hardening