

Link to Discovery Responses: https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan-discovery-data-requests.page															
Count	Party Name	Data Set	Data Request	Question No.	Question ID	Question Text	Requestor	Date Rec'd	Final Due Date	Date Sent	Number of Atchs	NDA Required	WMP Section	Category	Subcategory
1	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	1	CalAdvocate s-PGE-2022WMP-12_1	In response to Data Request CalAdvocates-PGE-2022WMP-03, Question 5, PG&E stated with regard to detailed ground inspections of transmission towers, "The average number of inspections completed per day in 2021 was 10.9 for contractors, and 7.6 for internal PG&E inspectors." a) State the factors that explain why contractors performed more inspections per day on average than PG&E inspectors in 2021. b) With regard to detailed ground inspections of transmission towers performed by contractors in 2021, what was the percentage of inspections that resulted in a "Failed Review" by Quality Control? c) With regard to detailed ground inspections of transmission towers performed by PG&E employee inspectors in 2021, what was the percentage of inspections that resulted in a "Failed Review" by Quality Control?	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections of Transmission electric lines and equipment
2	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	2	CalAdvocate s-PGE-2022WMP-12_2	In response to Data Request CalAdvocates-PGE-2022WMP-03, Questions 9-11, PG&E responded that "PG&E's search of LC tags issued as a result of both desktop and field Quality Control reviews did not identify any Priority A or Priority B LC tags issued" for climbing, drone, or detailed ground inspections of transmission structures. Provide the following data for desktop Quality Control reviews of transmission climbing inspections: a) Number of inspections reviewed by Quality Control (population size) in 2018 b) Number of inspections with no mistakes in 2018 c) Number of inspections that resulted in a "Failed Review" in 2018 d) Number of inspections reviewed by Quality Control (population size) in 2019 e) Number of inspections with no mistakes in 2019 f) Number of inspections that resulted in a "Failed Review" in 2019 g) Number of inspections reviewed by Quality Control (population size) in 2020 h) Number of inspections with no mistakes in 2020 i) Number of inspections that resulted in a "Failed Review" in 2020 j) Number of inspections reviewed by Quality Control (population size) in 2021 k) Number of inspections with no mistakes in 2021 l) Number of inspections that resulted in a "Failed Review" in 2021 For desktop Quality Control reviews of transmission drone inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	1		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
3	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	3	CalAdvocate s-PGE-2022WMP-12_3	For desktop Quality Control reviews of transmission detailed ground inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
4	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	4	CalAdvocate s-PGE-2022WMP-12_4	For field Quality Control reviews of transmission climbing inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
5	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	5	CalAdvocate s-PGE-2022WMP-12_5	For field Quality Control reviews of transmission drone inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
6	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	6	CalAdvocate s-PGE-2022WMP-12_6	For field Quality Control reviews of transmission detailed ground inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
7	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	7	CalAdvocate s-PGE-2022WMP-12_7	In response to Data Request CalAdvocates-PGE-2022WMP-08, G3Question 4, PG&E stated that PG&E System Inspection Quality Control found through Desktop Reviews that 60% of inspections had no mistakes and 13% of inspections resulted in a "Failed Review." Through Field Reviews, Quality Control found that 45% of inspections had no mistakes and 20% of inspections resulted in a "Failed Review." a) Define the population reviewed through Desktop Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within. b) Define the population reviewed through Field Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
8	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	8	CalAdvocate s-PGE-2022WMP-12_8	For Desktop Quality Control reviews of detailed distribution inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
9	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	9	CalAdvocate s-PGE-2022WMP-12_9	For Field Quality Control reviews of detailed distribution inspections, please provide the same data as requested in Question 2.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
10	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	10	CalAdvocate s-PGE-2022WMP-12_10	In response to Data Request CalAdvocates-PGE-2022WMP-04, Question 2, PG&E stated that "The requested information is provided in PG&E's 2022 WMP in Section 7.1.F. PG&E is providing attachment "WMP-Discovery2022_DR_CalAdvocates_004-Q02Atch01.zip" which has been prepared with the same information in the requested shapefile format." Cal Advocates understands "The requested information is provided in PG&E's 2022 WMP in Section 7.1.F" to refer to the file "WMP_section_71F.gdb." Is the file "WMP_section_71F.gdb" submitted with PG&E's 2022 WMP contains a layer titled "WMP_section_71F Distribution_Wildfire_Risk." This layer has the following attributes: OBJECTID mean_mavf_core_risk Shape_Length Circuit_Segment_name Per PG&E's 2022 WMP, p. 330, the "mean_mavf_core_risk" attribute was derived from the 2021 WDRM v2 model. Cal Advocates understands that the 2021 WDRM v2 model includes separate risk scores for vegetation-caused ignitions and conductor-involved ignitions. a) Is the understanding above correct? Please explain if not. b) If the answer to part (a) is yes, please provide an updated version of the file "WMP_section_71F.gdb" that contains risk scores associated with vegetation and conductor as separate attributes. c) Please define the attribute "mean_mavf_core_risk" as currently used in "WMP_section_71F.gdb".	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	1		7.1.F	Wildfire Mitigation Strategy	Wildfire Risk Data
11	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	11	CalAdvocate s-PGE-2022WMP-12_11	In response to Data Request CalAdvocates-PGE-2022WMP-04, Question 10, PG&E stated, "At this time, the program cannot forecast with accuracy the split of the 2022 budget forecast into Covered Conductor, Underground, and Line Removal." a) Please explain how PG&E developed the forecast total expenditure of \$819.1 million for 2022 system hardening, reported in response to that Data Request. b) Please provide any workpapers that PG&E used to develop the forecast.	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.3.17.1	Grid Design and System Hardening	Updates to grid topology to minimize risk of ignition in HFTDs, System Hardening, Distribution
12	CalPA	Set WMP-12	CalAdvocates-PGE-2022WMP-12	12	CalAdvocate s-PGE-2022WMP-12_12	In response to Data Request CalAdvocates-PGE-2022WMP-08, Question 7, PG&E stated, "We did not change the priority of the corrective notification during the period of February 19, 2020 to June 16, 2021 because none of the inspectors who reviewed this location during this time period recommended a priority change of the corrective notification." With that context: a) Do PG&E's inspection procedures require inspectors to recommend priority changes to an existing corrective notification if the inspector finds conditions in the field that warrant a higher priority? b) Do PG&E's inspection procedures require inspectors to re-inspect conditions noted in existing corrective notifications associated with a given asset? c) In the past year, has PG&E made any changes to its inspection procedures to improve the likelihood of inspectors recommending priority changes to existing corrective notifications based on changed field conditions?	Holly Wehrman Carolyn Chen Layla Labagh	3/3/2022	3/8/2022	3/8/2022	0		7.3.3.12.4	Grid Design and System Hardening	Other corrective action, Maintenance, Distribution
13	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	1	CalAdvocate s-PGE-2022WMP-13_1	PG&E's 2021 Q4 Quarterly Initiative Update states the following regarding 2021 WMP Initiative 7.3.3.17.4 Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter: The current REFCL pilot project at Calistoga experienced unsuccessful technology integration and implementation to date. We have encountered challenges with successfully implementing the REFCL technology, and reported final results based on this pilot. Please refer to final report for detailed information. a) Please provide the "final report" referred to above. b) Please describe in detail the "unsuccessful technology integration and implementation to date" that the "current REFCL pilot project at Calistoga" experienced. c) Please cite to specific pages in the final report supporting your response to part (b) of this question. d) Please describe the "challenges with successfully implementing the REFCL technology" referred to above. e) Please cite to specific pages in the final report supporting your response to part (d) of this question. f) What do the "final results" refer to above? g) Please cite to specific pages in the final report supporting your response to part (f) of this question. h) What is the status of PG&E's REFCL program as of the issuance date of this DR? i) Does PG&E plan to continue the REFCL program? j) If the answer to subpart (i) is "yes", please describe PG&E's current plans (with specific project timelines and milestones) for the REFCL program.	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	1		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
14	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	2	CalAdvocate s-PGE-2022WMP-13_2	PG&E's 2021 Q4 Quarterly Initiative Update states the following regarding 2021 WMP Initiative 7.3.3.17.4 Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter: The current REFCL pilot project at Calistoga experienced unsuccessful technology integration and implementation to date. We have encountered challenges with successfully implementing the REFCL technology, and reported final results based on this pilot. Please refer to final report for detailed information. a) Please provide the "final report" referred to above. b) Please describe in detail the "unsuccessful technology integration and implementation to date" that the "current REFCL pilot project at Calistoga" experienced. c) Please cite to specific pages in the final report supporting your response to part (b) of this question. d) Please describe the "challenges with successfully implementing the REFCL technology" referred to above. e) Please cite to specific pages in the final report supporting your response to part (d) of this question. f) What do the "final results" refer to above? g) Please cite to specific pages in the final report supporting your response to part (f) of this question. h) What is the status of PG&E's REFCL program as of the issuance date of this DR? i) Does PG&E plan to continue the REFCL program? j) If the answer to subpart (i) is "yes", please describe PG&E's current plans (with specific project timelines and milestones) for the REFCL program.	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0		7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter

17	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	3	CalAdvocates-PGE-2022WMP-13_3	<p>PG&E's 2022 WMP states: While we have not set specific targets for this Initiative and will not provide ongoing reporting each quarter on it, we are still doing the work as part of our overall plan. We do not currently plan to install any additional REFCL systems at this time. PG&E plans to repair and rebuild the REFCL installation at Calistoga to complete additional pilot evaluation. If the additional pilot is successful, PG&E will look for opportunities to place REFCL into full service as well as evaluate whether any additional sites are appropriate for future installations.</p> <p>a) State the reasons PG&E has not "set specific targets for this initiative and will not provide ongoing reporting each quarter on it."</p> <p>b) Explain what PG&E means by "we are still doing the work as part of our overall plan."</p> <p>c) State the reasons PG&E does not "currently plan to install any additional REFCL systems at this time."</p> <p>d) Explain what the above "additional pilot evaluation" consists of.</p> <p>e) When does PG&E expect to complete the "additional pilot evaluation"?</p> <p>f) When does PG&E expect to "look for opportunities to place REFCL into full service"?</p> <p>g) When does PG&E expect to "evaluate whether any additional sites are appropriate for future installations"?</p> <p>h) What are the criteria which PG&E will use when evaluating "whether any additional sites are appropriate for future installations"?</p> <p>i) If PG&E finds more sites that are "appropriate for future installations", what will be the next steps?</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
18	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	4	CalAdvocates-PGE-2022WMP-13_4	<p>The Calistoga REFCL pilot project finished construction in 2020. In 2021, PG&E attempted to commission and test the REFCL technology in Calistoga. PG&E completed an elevated voltage stress test and one field ground fault test which demonstrated that REFCL technology can be effective at reducing fault currents to below fire ignition levels.</p> <p>a) Please explain what you mean by "REFCL technology can be effective at reducing fault currents to below fire ignition levels."</p> <p>b) Please define "fire ignition levels" as used in the quotation above.</p> <p>c) In PG&E's testing of the Calistoga REFCL, to what extent did it reduce PG&E's 2022 WMP states.</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
19	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	5	CalAdvocates-PGE-2022WMP-13_5	<p>After the initial positive tests, the Calistoga REFCL pilot demonstration was stalled due to the failure of the substation REFCL equipment. In addition, PG&E had difficulty obtaining replacement equipment from various overseas suppliers due to supply chain issues and the ongoing COVID-19 pandemic.</p> <p>a) Please describe the nature of the "failure of the substation REFCL equipment".</p> <p>b) How long has the REFCL pilot been stalled?</p> <p>c) Has PG&E obtained the necessary replacement equipment from any suppliers in order to continue with the REFCL pilot?</p> <p>d) What is the status of the REFCL pilot as of the issuance date of this DR?</p> <p>e) What are PG&E's next planned steps regarding the REFCL pilot?</p> <p>f) Describe what an "elevated voltage stress test" involves.</p> <p>g) Describe what a "field ground fault test" involves.</p> <p>h) Is it correct that PG&E completed only a single field ground fault test?</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
20	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	6	CalAdvocates-PGE-2022WMP-13_6	<p>a) How effective is REFCL compared to covered conductor installation in reducing wildfire risks?</p> <p>b) Please provide any available supporting documentation regarding your response to subpart (a) above.</p> <p>c) How effective is REFCL compared to undergrounding in reducing wildfire risks?</p> <p>d) Please provide any available supporting documentation regarding your response to subpart (c) above.</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
21	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	7	CalAdvocates-PGE-2022WMP-13_7	<p>REFCL technology could not be fully evaluated beyond the initial testing because of the equipment failure and supply chain issues. As a result, PG&E is looking to further study REFCL capabilities after obtaining replacement supplies and making repairs and modifications at the Calistoga site in 2022.</p> <p>a) When does PG&E expect to obtain these replacement supplies?</p> <p>b) What will PG&E do to fully evaluate the REFCL technology beyond the initial testing?</p> <p>c) How have PG&E's plans changed given the equipment failure?</p> <p>d) How have PG&E's plans changed given the supply chain issues?</p> <p>e) Please describe the nature of the "repairs and modifications at the Calistoga site" referred to above.</p> <p>f) Does PG&E intend to finish the "repairs and modifications" in 2022?</p> <p>g) If the your answer to subpart (f) is no, what is PG&E's timetable to finish them in 2022, and how are you accounting for lessons learned from the REFCL initiative in 2021?</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
22	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	8	CalAdvocates-PGE-2022WMP-13_8	<p>PG&E should use gang operated switchgear and protective devices instead of single pole operated devices for REFCL installations.</p> <p>PG&E should consider the use of domestically available equipment for future REFCL installation to avoid foreign supply chain issues.</p> <p>a) Does PG&E intend to use "gang operated switchgear and protective devices instead of single pole operated devices for REFCL installations" going forward, including this Calistoga pilot?</p> <p>b) Why does PG&E conclude that it "should use gang operated switchgear and protective devices instead of single pole operated devices for REFCL installations" going forward?</p> <p>c) Does PG&E intend to use "domestically available equipment for future REFCL installation" going forward, including this Calistoga pilot?</p> <p>d) Has PG&E identified domestically available suppliers for REFCL equipment?</p> <p>e) If the answer to subpart (d) is "no", has PG&E identified any feasible alternatives to the current suppliers?</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
23	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	9	CalAdvocates-PGE-2022WMP-13_9	<p>PG&E's 2022 WMP states that, under the "short-term" strategy, Exhibit PG&E-4, states the following regarding the REFCL program: Based on our initial testing and the successful implementation in Australia, PG&E has developed a short-term strategy to install REFCLs in HFTD areas. PG&E forecasts deploying REFCLs at an additional two substations each year, but these plans could change pending pilot results and integration with other enhanced automation and wildfire mitigation efforts described in this chapter. In coordination with deployments of other technologies, future REFCL deployments will utilize PG&E's 2021 Wildfire Distribution Risk Model in combination with feasibility screens to help prioritize highest-risk locations for installations.</p> <p>a) Is the REFCL program above the same as 2022 WMP Initiative #7.3.3.17.4—Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter?</p> <p>b) How does PG&E define "short-term" in terms of the number of years involved?</p> <p>c) According to this "short-term strategy," at how many substations will have REFCL installed, and by what date?</p> <p>d) According to this "short-term strategy," how many circuit-miles in the HFTD areas will be served by REFCLs?</p> <p>e) Please provide the "pilot results."</p> <p>f) What does "integration with other enhanced automation and wildfire mitigation efforts described in this chapter" mean?</p> <p>g) What does PG&E mean by "in coordination with deployments of other technologies"?</p> <p>h) Which technologies constitute the "other technologies" as used in the passage quoted?</p> <p>i) How will PG&E utilize the 2021 Wildfire Risk Model to "help prioritize highest-risk locations for installations"?</p> <p>j) How does PG&E's 2021 Wildfire Distribution Risk Model determine the use of REFCL as opposed to other wildfire mitigations (such as covered conductors)?</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
24	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	10	CalAdvocates-PGE-2022WMP-13_10	<p>Regarding these two 2022 WMP Initiatives:</p> <ul style="list-style-type: none"> 7.3.3.17.4 – Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter 7.3.6.8 – Protective Equipment and Device Settings <p>12 Please explain:</p> <p>a) How do these two initiatives differ?</p> <p>b) How do these two initiatives compare in terms of expected risk reduction?</p> <p>c) How do these two initiatives compare in terms of impacts to customers from loss of power?</p> <p>d) Have you performed a comparative cost-benefit analysis of these two initiatives?</p> <p>e) If the answer to part (d) is yes, please provide this analysis.</p> <p>f) Are aware of any external (non-PG&E) comparative cost-benefit analysis of these two initiatives?</p> <p>g) If the answer to part (f) is yes, please provide this analysis or a link to it.</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	0	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
25	CalPA	Set WMP-13	CalAdvocates-PGE-2022WMP-13	11	CalAdvocates-PGE-2022WMP-13_11	<p>In its 2022 WMP and supporting attachments, PG&E does not appear to provide a Risk Spend Efficiency (RSE) score for 2022 WMP Initiative 7.3.3.17.4—Updates to grid topology to minimize risk of ignition in HFTDs, Rapid Earth Current Fault Limiter.</p> <p>a) Please explain why PG&E is not providing RSE information for this initiative in the 2022 WMP or relevant supporting attachments.</p> <p>b) Has PG&E calculated an RSE score for this initiative?</p> <p>c) If the answer to subpart (b) is "yes", please provide said RSE and all supporting workpapers for said RSE.</p> <p>d) If the answer to subpart (b) is "no", please explain why PG&E has not calculated an RSE for this initiative.</p>	Miles Gordon Holly Wehrman Carolyn Chen Layla Labagh	3/4/2022	3/9/2022	3/9/2022	1	7.3.3.17.4	Grid Design and System Hardening	Rapid Earth Current Fault Limiter
26	OEIS	Set 003	OEIS-PG&E-22-003	1	OEIS-PG&E-22-003_1	<p>Considering Maturity Model Survey question E.IV.h, how would PG&E answer this modified version? Does the utility work with landowners to provide a use(s) for vegetation cut on the landowner's property? (Y/N)</p>	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Vegetation grow-in mitigation
27	OEIS	Set 003	OEIS-PG&E-22-003	2	OEIS-PG&E-22-003_2	<p>Considering Maturity Model Survey question E.V.f, how would PG&E answer this modified version? Does the utility work with landowners to provide a use(s) for vegetation cut on the landowner's property? (Y/N)</p>	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Vegetation fall-in mitigation

28	OEIS	Set 003	OEIS-PG&E-22-003	3	OEIS-PG&E-22-003_3	From the Maturity Survey, in Category E (Vegetation Management) it is apparent that PG&E is building a granular, frequently updated inventory (Capability 21) and moving towards using "predictive modeling of vegetation growth" to schedule vegetation inspections (E.II.c). However, PG&E still (and will as of Jan 1, 2023) schedule VM inspections based on annual or periodic schedules (E.II.b) and determine procedures/checklists based on status and regulatory guidelines only (E.III.b). a) Explain why PG&E is developing predictive modeling capabilities for VM (E.II.c) but not using those models to schedule inspections and determine procedures/checklists? b) When will predictive modeling be used to schedule inspections and create procedures/checklists?	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Vegetation inspection effectiveness
29	OEIS	Set 003	OEIS-PG&E-22-003	4	OEIS-PG&E-22-003_4	Concerning Maturity Survey question E.IV.c, why is PG&E not using ignition and propagation risk modeling to guide clearances around lines and equipment? a) How does and will PG&E's ignition and propagation risk modeling guide clearances? b) When?	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Vegetation grow-in mitigation
30	OEIS	Set 003	OEIS-PG&E-22-003	5	OEIS-PG&E-22-003_5	In data request OEIS-PG&E-22-002, Energy Safety asked PG&E to answer 41 2022 Maturity Survey questions it said it benchmarked through consultation with other utilities in 2022 by the same standard of interpretation it used to answer the same 41 questions in 2021 and 2020. In its response, PG&E indicated that "We cannot, however, go back in time to determine how we would have answered the same question in 2020 or 2021 in light of changes that have occurred since that time." Energy Safety understands that PG&E cannot go back in time to change its answers from 2021 or 2020, and that other factors have changed, however Energy Safety is asking PG&E to answer those questions in the same way in 2022 as they did in 2021 and 2020 in order to understand the true progression of PG&E's maturity not attributed to re-interpretation of questions. Prior to benchmarking its 2022 answers with other utilities and re-interpreting these questions, what was PG&E's answer to those questions?	Kevin Miller	3/4/2022	3/10/2022	3/10/2022	0	N/A	Miscellaneous	Maturity Survey
31	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	1	CalAdvocates-PGE-2022WMP-14_1	On Pg. 436 of PG&E's 2022 WMP, table 7.3.3-1 highlights the average time it takes PG&E to complete a system hardening project that spans 1-2 miles. a) Please provide a list of all types of system hardening projects that are included in this table's data. b) Please provide a separate table highlighting the average time frame to complete a covered conductor project spanning 1-2 miles. If you are unable to do so, please describe your reasoning.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.3	Grid Design and System Hardening	Covered Conductor Installation
32	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	2	CalAdvocates-PGE-2022WMP-14_2	Pg. 435 of your 2022 WMP Update states, "The table represents base overhead System Hardening projects after scoping is completed. As mentioned above, Fire Rebuild occurs on a faster cycle." Therefore, please disaggregate table 7.3.3-1 into separate data according to the following project types (assuming that projects are comparable in scale): a) Covered conductor, Fire Rebuild b) Covered conductor, not Fire Rebuild c) Undergrounding, Fire Rebuild d) Undergrounding, not Fire Rebuild	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.3	Grid Design and System Hardening	Covered Conductor Installation
33	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	3	CalAdvocates-PGE-2022WMP-14_3	On Pg. 442 of PG&E's 2022 WMP, PG&E states, "In 2021, PG&E identified and completed repairs or replacements of approximately 10,946 deteriorated crossarms." a) Please provide a .gdb spatial file showing where PG&E completed repairs of the deteriorated crossarms noted above. b) Please provide a .gdb spatial file showing where PG&E completed replacements of the deteriorated crossarms noted above.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	1	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair and Replacement
34	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	4	CalAdvocates-PGE-2022WMP-14_4	On Pg. 445 of PG&E's 2022 WMP, PG&E states, "In 2021, PG&E replaced 16,359 poles and reinforced 3,012 poles." a) Please provide a .gdb spatial file showing where PG&E replaced poles. b) Please provide a .gdb spatial file showing where PG&E reinforced poles.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	1	7.3.3.6	Grid Design and System Hardening	Distribution Pole Replacement
35	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	5	CalAdvocates-PGE-2022WMP-14_5	On Pg. 451 of PG&E's 2022 WMP, PG&E states, "Recently, moisture intrusion issues have been identified in some of the "Viper" branded reclosers that have been installed on the PG&E system. After significant rains in the fall of 2021, this issue, which impacts the functionality but not the safety of these devices, was identified in several locations." a) Please describe the moisture intrusion issue occurring on the Viper reclosers. b) Please state the basis for PG&E's assertion that the issue "impacts the functionality but not the safety of these devices." c) Please describe the functionality issues occurring on the Viper reclosers.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.8.1	Grid Design and System Hardening	Distribution Line Sectionalizing
36	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	6	CalAdvocates-PGE-2022WMP-14_6	On Pg. 452 of PG&E's 2022 WMP, PG&E states, "We achieved our 2021 target to install 29 switches by September 1, 2021. In addition, we installed 12 T-Line SCADA switches benefiting PPS operations after September 1, 2021, for a 2021 total of 41." a) Please provide GIS point location data (in .gdb format) showing where PG&E completed installations of the 29 switches in 2021. b) Please provide GIS point location data (in .gdb format) showing where PG&E completed installations of the 12 T-Line SCADA switches in 2021.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	2	7.3.3.8.2	Grid Design and System Hardening	Transmission Line Sectionalizing
37	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	7	CalAdvocates-PGE-2022WMP-14_7	On Pg. 472 of PG&E's 2022 WMP, PG&E states, "Due to the weather conditions in 2021, none of the substations where generation was staged were utilized in the 2021 PPS season." a) What lessons did PG&E learn about staging temporary generation from its experience in 2021? b) How will PG&E improve its staging of generation in 2022 to ensure that it is useful during the PPS season?	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.11.1	Grid Design and System Hardening	Generation for PPS Mitigation
38	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	8	CalAdvocates-PGE-2022WMP-14_8	On Pg. 514 of PG&E's 2022 WMP, PG&E states, "PG&E switched vendors for this work in 2021. Contracts took longer than expected and the new vendor had to complete an extensive pilot to establish a solid foundation based on high quality pole loading calculations." a) Please describe why PG&E switched vendors for this work in 2021. b) Please provide all supporting documents and claims that describes PG&E's reasoning related to its response to subsection a) above. c) Describe the nature of the "extensive pilot" the new vendor completed. d) What was the approximate cost of the "extensive pilot"?	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	2	7.3.3.13	Grid Design and System Hardening	Pole Loading Infrastructure Hardening and Replacement
39	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	9	CalAdvocates-PGE-2022WMP-14_9	On Pg. 551 of PG&E's 2022 WMP, PG&E states that it will complete 32 circuit-miles of transmission system hardening in 2022. a) Please disaggregate these circuit-miles of transmission hardening into the following types: bare-wire overhead hardening, conductor removal, other. b) Please state how many total circuit-miles of transmission system hardening you plan to complete in 2022, excluding the work that resulted from the Administrative Consent Order attached to Resolution SED-6. c) Please disaggregate your response to part (b) into the following types: bare-wire overhead hardening, conductor removal, other. d) In 2021, PG&E completed 93 miles. Please explain the factors that are causing PG&E to decrease this output to 32 miles in 2022.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
40	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	10	CalAdvocates-PGE-2022WMP-14_10	On Pg. 564 of PG&E's 2022 WMP regarding Remote Grid Standalone Power Systems (SPS), PG&E states, "The program expects to grow from 1 SPS unit deployed in 2021 to 2 SPS units deployed in 2022 and on towards approximately 15 projects in 2023, followed by additional growth in the overall number of systems deployed annually in 2024-2025." a) Please describe the planning, scoping, and pre-construction work PG&E will be performing in 2022 to facilitate the planned scaling up from 2 projects in 2022 to 15 projects in 2023. b) What is the forecast number of circuit-miles to be removed due to the deployment of 2 SPS units in 2022? c) What is the forecast number of circuit-miles to be removed due to the deployment of 15 SPS units in 2023?	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.17.5	Grid Design and System Hardening	Remote Grid
41	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	11	CalAdvocates-PGE-2022WMP-14_11	On Pg. 567 of PG&E's 2022 WMP, PG&E uses three different terms, "trench miles", "circuit miles" and "underground miles". a) Please define each of these terms. b) How does each term differ from one another? c) Please provide a conversion between these units of measure for a 1-phase circuit (i.e., x trench miles = y circuit miles = z underground miles). d) Please provide a conversion between these units of measure for a 2-phase circuit (i.e., x trench miles = y circuit miles = z underground miles). e) Please provide a conversion between these units of measure for a 3-phase circuit (i.e., x trench miles = y circuit miles = z underground miles). f) Please provide a conversion between these units of measure for a right-of-way where two 3-phase circuits run in parallel (i.e., x trench miles = y circuit miles = z underground miles). g) If any of your responses to parts (c) through (f) depend on whether or not the circuit has a neutral wire, please explain.	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.17.6	Grid Design and System Hardening	Butte County Rebuild Program
42	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	12	CalAdvocates-PGE-2022WMP-14_12	On Pg. 567 of PG&E's 2022 WMP, PG&E says, "This figure does not include a small volume (approximately 1.4 circuit miles) of previously hardened overhead lines that were placed underground." a) How many circuit-miles total (including non-Butte rebuild miles) were previously hardened overhead and were placed underground in 2020? b) How many circuit-miles total (including non-Butte rebuild miles) were previously hardened overhead and were placed underground in 2021? c) How many previously hardened overhead circuit-miles does PG&E expect to underground in 2022?	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	0	7.3.3.17.6	Grid Design and System Hardening	Butte County Rebuild Program

43	CalPA	Set WMP-14	CalAdvocates-PGE-2022WMP-14	13	CalAdvocate s-PGE-2022WMP-14_13	In response to Data Request CalAdvocates-PGE-2022WMP-11, Question 3, PG&E provided its 2021 system hardening workplan, updated with the actual work performed in 2021. This workplan lists the circuit name associated with each system hardening order but does not list the circuit protection zone. Please provide an updated version of this spreadsheet with the circuit protection zone (as a new column) for each order (row).	Dillon Copa Holly Wehrman Carolyn Chen Layla Labagh	3/10/2022	3/15/2022	3/15/2022	1		7.3.3.17	Grid Design and System Hardening	System Hardening
44	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	1	CalAdvocate s-PGE-2022WMP-15_1	PG&E's responses to Data Request CalAdvocates-PGE-2022WMP-10, Questions 1-3, are summarized in the following table: Tree Attachments Existing as of 2/1/2022 Tree Attachments Remediated in 2021 Tree Attachments to be removed in 2022 HFTD 19,214 247 588 Non-HFTD 749 139 245 a) Of the tree attachments PG&E remediated in 2021, approximately 36% were outside the HFTD. Please explain why PG&E selected these non-HFTD locations for remediation. b) Of the tree attachments PG&E plans to remediate in 2022, approximately 29% are outside the HFTD. Please explain why PG&E selected these non-HFTD locations for remediation. c) Please explain how PG&E determines where to remediate tree	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.3	Grid Design and System Hardening	Tree Attachments
45	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	2	CalAdvocate s-PGE-2022WMP-15_2	a) Does PG&E consider tree attachments to be a significant wildfire risk factor? Please explain your answer. b) Does PG&E analyze and track whether ignitions or other adverse outcomes are caused by tree attachments? c) Has PG&E identified any ignitions in the past five years that were caused by tree attachments? If so, how many? d) Has PG&E identified any other adverse outcomes (such as outages) in the past five years that were caused by tree attachments? If so, how many?	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.3	Grid Design and System Hardening	Tree Attachments
46	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	3	CalAdvocate s-PGE-2022WMP-15_3	In response to Data Request CalAdvocates-PGE-2022WMP-10, Question 9, PG&E provided its Quality Reviews of the potential exceptions identified in the Federal Monitor Report from November 19, 2021. Per the file "WMP-Discovery2022_DR_CalAdvocates_010-Q09Atch01.xlsx" PG&E agrees with the Federal Monitor (column J) in 1,576 findings. Of those 1,576 cases, the QC Action (column N) is "N/A" for 1,035 findings. a) Did PG&E perform any retraining in association with the 1,035 findings where QC Action is listed as "N/A" noted above? Please explain why or why not. b) Did PG&E perform other remedial action in association with the 1,035 findings where QC Action is listed as "N/A" noted above? Please explain why or why not.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
47	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	4	CalAdvocate s-PGE-2022WMP-15_4	In response to Data Request CalAdvocates-PGE-2022WMP-10, Question 9, PG&E provided its Quality Reviews of the potential exceptions identified in the Federal Monitor Report from November 19, 2021. Per the file "WMP-Discovery2022_DR_CalAdvocates_010-Q09Atch02.xlsx" PG&E agrees with the Federal Monitor (column K) in 636 findings. Of those 636 findings, the QC Review Action (column O) is "N/A" for 616. a) Did PG&E perform any retraining in association with the 616 findings where QC Review Action is listed as "N/A" noted above? Please explain why or why not. b) Did PG&E perform other remedial action in association with the 616 findings where QC Review Action is listed as "N/A" noted above? Please explain why or why not.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
48	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	5	CalAdvocate s-PGE-2022WMP-15_5	Page 129 of PG&E's 2022 WMP states the following: Finally, it is important to note that in this 2022 WMP, the model that is used for the development of workplans for the distribution system is the 2021 WDRM v2 which is described above and in the 2021 WMP. As described in (9) below, the 2022 WDRM v3 is still being reviewed prior to approval. Since workplans for the 2022 WMP needed to be developed prior to the beginning of the year, the 2021 WDRM v2 was used to inform these workplans. a) Does PG&E expect to see a significant re-prioritization of circuit segments as a result of the forthcoming change from the 2021 WDRM v2 to the 2022 WDRM v3? b) How does PG&E's planning for 2022 wildfire mitigation initiatives take into account expected changes in circuit-segment re-prioritization that may occur as a result of switching to 2022 WDRM v3 in the future? For example, if PG&E expects the risk-based prioritization of a given circuit segment to change, how does PG&E take that into account when scoping system hardening and other wildfire mitigations on the circuit-segment?	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
49	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	6	CalAdvocate s-PGE-2022WMP-15_6	In response to Data Request CalAdvocates-PGE-2022WMP-04, Question 8, PG&E provided its distribution system hardening workplan for 2022. Column P of attachment "WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx" lists the risk ranking of each CPZ where PG&E plans to perform system hardening work. Please provide an updated copy of this workplan with an additional column listing the risk ranking of each CPZ according to the current version of PG&E's 2022 WDRM v3.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.3.17.1	Grid Design and System Hardening	System Hardening - Distribution
50	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	7	CalAdvocate s-PGE-2022WMP-15_7	Page 140 of PG&E's 2022 WMP states the following: To avoid exposing the model to misleading data, the training events are restricted to June through November. This does not require the assumption that no wildfires are possible in other months, but only that any ignitions and wildfires that do occur would have the same relationship with the model covariates as the ones the model is already trained on. Please provide workpapers or other available supporting evidence to support the statement that "any ignitions and wildfires that do occur [in months other than June through November] would have the same relationship with the model covariates as the ones the model is already trained on."	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
51	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	8	CalAdvocate s-PGE-2022WMP-15_8	Page 145 of PG&E's 2022 WMP states, "As of the state of the 2022 WMP submission, E3's review of 2022 WDRM v3 and WFC Model has not been completed." a) When does PG&E expect this review to be complete? b) Please provide a copy of E3's review of PG&E's 2022 WDRM v3 and WFC Model when it is complete.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
51	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	8	CalAdvocate s-PGE-2022WMP-15_8	Page 145 of PG&E's 2022 WMP states, "As of the state of the 2022 WMP submission, E3's review of 2022 WDRM v3 and WFC Model has not been completed." a) When does PG&E expect this review to be complete? b) Please provide a copy of E3's review of PG&E's 2022 WDRM v3 and WFC Model when it is complete.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	6/2/2022	1		4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
52	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	9	CalAdvocate s-PGE-2022WMP-15_9	In response to Data Request CalAdvocates-PGE-2022WMP-09, PG&E refers to the Progress Report it filed on November 1, 2021. Page 39 of this Progress Report states the following with respect to development of the system hardening workplan: In addition, for some CPZs, although the CPZ is not itself the highest risk ranked CPZ, performing system hardening work may allow us to mitigate future PPS events. a) Please state the basis for PG&E's decision to prioritize PPS mitigation over wildfire mitigation in the situations described above. b) Please provide example workpapers to support PG&E's response to part (a), if available. c) To the extent that PG&E chooses to perform system hardening "to mitigate future PPS events," how does PG&E evaluate the PPS risk of each CPZ and determine how to prioritize CPZs?	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		4.6	Progress Reporting on Key Areas of Improvement	Progress on Twenty-Nine Remedies
53	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	10	CalAdvocate s-PGE-2022WMP-15_10	Page 316 of PG&E's 2022 WMP states, "In 2021, PG&E implemented a program to proactively reduce the backlog of EC tags generated during the enhanced system inspections performed in recent years." Please describe this program.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.1.B	Wildfire Mitigation Strategy	Risk Modeling Outcomes in Decision-Making and Mitigations
54	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	11	CalAdvocate s-PGE-2022WMP-15_11	PG&E's response to data request CalAdvocates-PGE-2022WMP-09, Question 1, shows three open Priority A corrective notifications on PG&E's distribution system in HFTD with "Authorized End Dates" earlier than February 1, 2022. a) Why hasn't PG&E resolved these notifications yet? b) What is PG&E's timetable to resolve these notifications?	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0		7.3.4	Asset Management and Inspections	Additional Detail - Distribution
55	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	12	CalAdvocate s-PGE-2022WMP-15_12	PG&E's response to data request CalAdvocates-PGE-2022WMP-09, Question 1, shows 785 open Priority B corrective notifications on PG&E's distribution system in HFTD with "Authorized End Dates" earlier than February 1, 2022. a) Why hasn't PG&E resolved these notifications yet? b) What is PG&E's timetable to resolve these notifications?	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/18/2022	3/18/2022	0		7.3.4	Asset Management and Inspections	Additional Detail - Distribution

56	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	13	CalAdvocates-PGE-2022WMP-15_13	PG&E's response to data request CalAdvocates-PGE-2022WMP-09, Question 1, shows 111,502 open corrective notifications on PG&E's distribution system in HFTD with "Authorized End Dates" earlier than February 1, 2022 (that is, overdue notifications). Cal Advocates understands that the majority of these were opened in 2019 and later years as a result of enhanced inspections. Year corrective notification opened Number of overdue corrective notifications 2001 1 2013 1 2014 189 10 2015 2,698 2016 4,006 2017 333 2018 658 2019 51,729 2020 33,551 2021 18,334 2022 2	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/18/2022	3/18/2022	0	7.3.4	Asset Management and Inspections	Additional Detail - Distribution
57	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	14	CalAdvocates-PGE-2022WMP-15_14	Regarding PG&E's response to data request CalAdvocates-PGE-2022WMP-09: a) Does PG&E regularly monitor how many overdue, unresolved corrective notifications it has? b) Does PG&E take any special action when a corrective notification is years past its due date? c) Does PG&E analyze and track whether adverse outcomes (such as outages, wires down, and ignitions) are causally linked to overdue maintenance? d) Does PG&E regularly report any of the information addressed in parts (a) through (c) to its executives or its Board of Directors? If so, please describe this reporting, including when and how this reporting occurs and what information is included. e) Does PG&E regularly report any of the information addressed in parts (a) through (c) to the Commission? If so, please describe this reporting, including when and how this reporting occurs and what information is included. f) Does PG&E regularly report any of the information addressed in parts (a) through (c) to OEIS? If so, please describe this reporting, including when and how this reporting occurs and what information is included.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0	7.3.4	Asset Management and Inspections	Additional Detail
58	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	15	CalAdvocates-PGE-2022WMP-15_15	PG&E's non-spatial data tables appears to aggregate routine vegetation management and Enhanced Vegetation Management (EVM) under initiative "7.3.5.2 Detailed inspections and management practices for vegetation clearances around distribution electrical lines and equipment." Previously, EVM was listed separately from routine vegetation management. Please provide disaggregated costs for initiative 7.3.5.2, with separate numbers for routine VM, enhanced VM, and any other program currently annotated under initiative 7.3.5.2. Please provide the Model Documentation and User Guide or available technical paper for each of the following from Table 9.5-1 Glossary of Primary Models (p. 1038): a) Fire Potential Index (FPI) Model b) Public Safety Power Shutoff (PSPS) Consequence Model	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/16/2022	3/16/2022	0	7.3.a	Detailed Wildfire Mitigation Initiatives	Financial Data on Mitigation Activities
59	CalPA	Set WMP-15	CalAdvocates-PGE-2022WMP-15	16	CalAdvocates-PGE-2022WMP-15_16	While PG&E provided undergrounding information in its GIS data, PG&E did not specifically report underground circuit miles in the nonspatial tables. Underground circuit miles were obtained from the GIS submission. a) Please provide updated data for rows 1a, 2a, and 3a in Table 8, which include underground circuits.	Holly Wehrman Carolyn Chen Layla Labagh	3/11/2022	3/18/2022	3/18/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Program Costing
60	OEIS	Set 004	OEIS-PG&E-22-004	1	OEIS-PG&E-22-004_1	While PG&E provided undergrounding information in its GIS data, PG&E did not specifically report underground circuit miles in the nonspatial tables. Underground circuit miles were obtained from the GIS submission. a) Please provide updated data for rows 1a, 2a, and 3a in Table 8, which include underground circuits.	Kevin Miller	3/11/2022	3/16/2022	3/16/2022	2	4.5	Model and Metric Calculation Methodologies	Fire Potential Index (FPI) Model / PSPS Consequence Model
61	OEIS	Set 004	OEIS-PG&E-22-004	2	OEIS-PG&E-22-004_2	Regarding Section 7.3.2 – Risk assessment and mapping, and Section 9.1 – Risk mapping and simulation a) Section 7.3.2 of the 2022 Guidelines requires the inclusion of a "climate-driven risk map and modeling based on various relevant weather scenarios relevant maps within the report or appendices" for every risk assessment and mapping initiative. Section 9.1 defines "climate-driven risk map and modeling based on various relevant weather scenarios" as: "Development and use of tools and processes demonstrating medium and long-term climate trends based on the best available climate models demonstrating the most wildfire-relevant impacts (e.g., warming trends, fuel moisture trends, soil moisture trends, vegetation distribution trends). Describe how these trends are being incorporated into risk modeling or other risk-informed analyses." i) Provide the page number(s) within the 2022 WMP update that fulfills the requirement for the provision of climate-driven risk map and modeling demonstrating medium and long-term climate trends for the risk assessment and mapping initiatives. ii) If there are no, or any missing, climate-driven risk maps incorporating medium and long-term climate trends for the risk assessment and mapping initiatives (see Q07a), please submit those maps. iii) Provide the page number(s) within the 2022 WMP update that describes how medium and long-term climate trends are being incorporated into risk modeling or other risk-informed analyses. iv) If there is no description of how medium and long-term climate trends are being incorporated into risk modeling or other risk-informed analyses in	Kevin Miller	3/11/2022	3/16/2022	3/16/2022	1	7.3.a	Detailed Wildfire Mitigation Initiatives	Financial Data on Mitigation Activities
62	OEIS	Set 004	OEIS-PG&E-22-004	3	OEIS-PG&E-22-004_3	How has PG&E changed its mitigation plans to address lessons learned from past catastrophic fires? a) Include page numbers in the 2022, 2021, or 2020 WMP for discussion of each of the following applied lessons and a description of such changes: i) 2017 – Railroad Fire, Atlas Fire, Cascade Fire, Redwood Fire, and Nuns Fire ii) 2018 – Camp Fire iii) 2019 – Camino Fire, Bethel Island Fire, and Kincadee Fire iv) 2020 – Zogg Fire v) 2021 – Dixie Fire and Fly Fire	Kevin Miller	3/11/2022	3/16/2022	3/16/2022	0	7.3.1	Risk Assessment and Mapping	Climate Trends
63	OEIS	Set 004	OEIS-PG&E-22-004	4	OEIS-PG&E-22-004_4	Regarding Table 7.1: a) Provide the number of events broken down by equipment type that fall in the "Other" category in Rows 20, 39, 65, and 91. b) Why is PG&E expecting an increase in wire-down events for the following from 2022 to 2023?: i) Vegetation contacts ii) Connectors c) How is PG&E planning on addressing the wildfire risk presented by the following equipment failures/event causes at the distribution level, which showed increase wire down and/or outage events in 2021? Describe any failure mode analyses evaluating the cause for the increases in 2021, and any associated changes in maintenance or inspections from lesson learned in 2021: i) Transformers ii) Conductors iii) Fuses iv) Poles v) Crossarms vi) Connection devices vii) Other, including specific equipment types as delineated in part (a) viii) Wire-to-wire contacts	Kevin Miller	3/11/2022	3/16/2022	3/16/2022	0	4.2	Lessons Learned and Risk Trends	Wildfire
64	OEIS	Set 004	OEIS-PG&E-22-004	5 (incorrectly marked as 4)	OEIS-PG&E-22-004_5 (incorrectly marked as 4)	Regarding Table 7.2: a) Why is PG&E expecting an increase in ignitions for the following from 2022 to 2023?: i) Vegetation contacts ii) Connectors iii) Conductor damage iv) Transformers v) Wire-to-wire contacts	Kevin Miller	3/11/2022	3/17/2022	3/17/2022	0	7.3.a	Detailed Wildfire Mitigation Initiatives	Financial Data on Mitigation Activities
65	OEIS	Set 004	OEIS-PG&E-22-004	6 (incorrectly marked as 5)	OEIS-PG&E-22-004_6 (incorrectly marked as 5)	Page 632 of PG&E's 2022 WMP states, "PG&E has finished the development of our new process to standardize and enhance customer and community engagement for electric VM work." a) Please provide further information on the new process referred to above. b) What process was in place prior to the new process referred to above? c) How do the new and previous processes differ?	Kevin Miller	3/11/2022	3/16/2022	3/16/2022	0	7.3.a	Detailed Wildfire Mitigation Initiatives	Financial Data on Mitigation Activities
66	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	1	CalAdvocates-PGE-2022WMP-16_1	Page 631 of PG&E's 2022 WMP states, "Pacific Gas and Electric Company (PG&E) works to inform customers, landowners, and communities about VM work taking place and our role in increasing public safety as well as reducing fire risk." a) What communication methods are PG&E employing to effectively communicate to the public? b) Please provide the average time it takes PG&E to communicate to the following groups: a. Homeowners b. Small businesses c. Medical baseline customers	Dillon Copa Carolyn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Additional Efforts to Manage Community and Environmental Impacts
67	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	2	CalAdvocates-PGE-2022WMP-16_2	Page 632 of PG&E's 2022 WMP states, "PG&E has finished the development of our new process to standardize and enhance customer and community engagement for electric VM work." a) Please provide further information on the new process referred to above. b) What process was in place prior to the new process referred to above? c) How do the new and previous processes differ?	Dillon Copa Carolyn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Additional Efforts to Manage Community and Environmental Impacts

68	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	3	CalAdvocates-PGE-2022WMP-16_3	Page 637 of PG&E's 2022 WMP states, "As of December 31, 2021, PG&E's internal resources and contractor partners had worked approximately 1,486,330 trees in our Routine VM program and 34,189 trees in our Tree Mortality program. In addition, we completed 1,983 miles of EVM work." a) Please provide total miles completed in PG&E's Routine VM program in 2021, disaggregated by HFTD region (see definitions P through S). b) Please provide total miles completed in PG&E's Tree Mortality program in 2021, disaggregated by HFTD region (see definitions P through S).	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Detailed Inspections and Management Practices for Vegetation Clearances Around Distribution Electrical Lines and Equipment
69	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	4	CalAdvocates-PGE-2022WMP-16_4	Page 637 of PG&E's 2022 WMP states, "In September 2021, we began to transition the maintenance of EVM work that has already been performed to Routine VM patrols." a) How did PG&E come to the decision to begin to transition the maintenance of EVM work to Routine EVM patrols? b) Please describe how PG&E is transitioning the maintenance of EVM work to Routine EVM patrols. c) Describe what "maintenance of EVM work" entails.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Detailed Inspections and Management Practices for Vegetation Clearances Around Distribution Electrical Lines and Equipment
70	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	5	CalAdvocates-PGE-2022WMP-16_5	Page 645 of PG&E's 2022 WMP states, "Vegetation identified as pending Priority 2 work within the Red Flag Warning (RFW) area will be reviewed and re-prioritized if determined necessary by the local PG&E VM Point of Contact." a) Please describe the steps PG&E takes to review and re-prioritize vegetation identified as pending Priority 2 work within the RFW area. b) On average, how long does it take PG&E to review and re-prioritize such vegetation?	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Emergency Response Vegetation Management Due to Red Flag Warning or Other Urgent Weather Conditions
71	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	6	CalAdvocates-PGE-2022WMP-16_6	Section 7.3.5.7 of PG&E's 2022 WMP discuss remote sensing inspections of vegetation around distribution electric lines and equipment. a) Please describe the circumstances in which PG&E employs ground-based LIDAR inspections. b) Please describe the circumstances in which PG&E employs aerial LIDAR inspections. c) If PG&E uses ground-based LIDAR inspections more often than aerial LIDAR, please explain why. d) What is the approximate total cost per circuit-mile to perform ground-based LIDAR inspections on distribution circuits? e) What is the approximate total cost per circuit-mile to perform aerial LIDAR inspections on distribution circuits? f) When PG&E performs ground-based LIDAR inspections, is this work performed at the same time as VM patrols, inspection patrols, or other patrol work, in order to minimize costs? Please explain your response.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Distribution Electric Lines and Equipment
72	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	7	CalAdvocates-PGE-2022WMP-16_7	On page 657, PG&E provides Table 7.3.5-2, which shows planned mileage of ground-based LIDAR on distribution facilities. Please supplement this table by: a) Adding a column for planned mileage of aerial LIDAR. b) Adding a row with data on actual mileage completed in 2021.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Distribution Electric Lines and Equipment
73	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	8	CalAdvocates-PGE-2022WMP-16_8	Section 7.3.5.8 of PG&E's 2022 WMP discuss remote sensing inspections of vegetation around transmission electric lines and equipment. a) Please describe the circumstances in which PG&E employs ground-based LIDAR inspections. b) Please describe the circumstances in which PG&E employs aerial LIDAR inspections. c) If PG&E uses ground-based LIDAR inspections more often than aerial LIDAR, please explain why. d) What is the approximate total cost per circuit-mile to perform ground-based LIDAR inspections? e) What is the approximate total cost per circuit-mile to perform aerial LIDAR inspections? f) When PG&E performs ground-based LIDAR inspections, is this work performed at the same time as VM patrols, inspection patrols, or other patrol work, in order to minimize costs? Please explain your response.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Transmission Electric Lines and Equipment
74	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	9	CalAdvocates-PGE-2022WMP-16_9	For Section 7.3.5.8 (regarding remote sensing on transmission facilities), please provide a table equivalent to Table 7.3.5-2, with the additions specified above in Question 7.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Transmission Electric Lines and Equipment
75	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	10	CalAdvocates-PGE-2022WMP-16_10	Table 12 of PG&E's 2022 WMP shows the costs for sections 7.3.5.2 and 7.3.5.3. a) Please explain why section 7.3.5.2 entails CAPEX and OPEX spending as opposed to only OPEX spending for 7.3.5.3. b) Please describe the capital expenditures planned in 2022 for section 7.3.5.2.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	VM Spend
76	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	11	CalAdvocates-PGE-2022WMP-16_11	On March 2, 2022, PG&E presented its 2023 general rate case witness Supplemental Testimony Overview. Slide 17 of this presentation includes the following chart, which appears to show a significant decrease in planned EVM spending from 2022 to 2023. a) Does PG&E expect to significantly reduce spending on EVM beginning in 2023, as indicated in this chart? b) If the answer to part (a) is yes, please explain the reasoning for the forecasted decrease in EVM spending. c) If the answer to part (a) is no, please explain the above chart. d) Does PG&E plan to reduce the annual mileage target for its EVM program after 2022? Please explain your answer. e) Does PG&E plan to reduce the scope of work covered by its EVM program after 2022? Please explain your answer. f) Please explain the apparent increase in planned Routine VM spending from 2022 to 2023.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	EVM Spend
77	CalPA	Set WMP-16	CalAdvocates-PGE-2022WMP-16	12	CalAdvocates-PGE-2022WMP-16_12	Table 5.3-1 on page 271 of PG&E's Revised 2021 WMP, June 3, 2021, showed a mileage target of 111 miles for initiative 7.3.3.17.2 "System Hardening - Transmission Conductor." Table PG&E-5.3-1(A) on page 267 of PG&E's 2022 WMP shows a mileage target of 32 miles for the same initiative. Please explain the reason for the decrease in the mileage target for this initiative, compared to last year's forecast.	Dillon Copa Carlynn Chen Layla Labagh	3/18/2022	3/23/2022	3/23/2022	0	7.3.3	Grid Design and System Hardening	System Hardening - Transmission
78	OEIS	Set 005	OEIS-PG&E-22-005	1	OEIS-PG&E-22-005_1	Q01. Provide and describe the "EPSS Reliability Impact analysis" as mentioned on page 494 of PG&E's 2022 WMP Update.	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	1	7.3.3	Grid Design and System Hardening	EPSS Reliability Impact analysis
79	OEIS	Set 005	OEIS-PG&E-22-005	2	OEIS-PG&E-22-005_2	Q02. How many poles in PG&E's territory are subject to PRC 4292? a) How many of these poles does PG&E intend to inspect and work (as necessary) in 2022?	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	PRC 4292 Applicability
80	OEIS	Set 005	OEIS-PG&E-22-005	3	OEIS-PG&E-22-005_3	Q03. PG&E noted during the workshop that it has hired pre-inspectors as union employees. a) What percentage of pre-inspectors are contractors and what percentage are PG&E employees? b) Has PG&E found a difference in performance between contractor and PG&E employee pre-inspectors? i. If so, describe the observed differences in performance c) Provide relevant metrics, including QA/QV findings demonstrating performance, broken down by type of inspector (contractor v. PG&E employee) to show any differences between contractor and PG&E employee pre-inspector performance.	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Contractor/Employee Performance
80	OEIS	Set 005	OEIS-PG&E-22-005	3 REV	OEIS-PG&E-22-005_3 REV	Q03. PG&E noted during the workshop that it has hired pre-inspectors as union employees. a) What percentage of pre-inspectors are contractors and what percentage are PG&E employees? b) Has PG&E found a difference in performance between contractor and PG&E employee pre-inspectors? i. If so, describe the observed differences in performance c) Provide relevant metrics, including QA/QV findings demonstrating performance, broken down by type of inspector (contractor v. PG&E employee) to show any differences between contractor and PG&E employee pre-inspector performance.	Kevin Miller	3/18/2022	4/1/2022	4/1/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Contractor/Employee Performance
81	OEIS	Set 005	OEIS-PG&E-22-005	4	OEIS-PG&E-22-005_4	Q04. Provide the QA/QV results for vegetation management broken down by inspection type completed in 2019, 2020, and 2021. This should include: a) Percentage of inspections with infractions found (e.g., under-trimming, over-trimming, missed hazard tree, improper clean-up etc.). b) Percentage of (a) which required remediation (e.g., re-inspection, additional trimming, removal of a tree). c) List of lessons learned from infractions and associated changes made to inspections moving forward.	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	1	7.3.5	Vegetation Management (VM) and Inspections	Quality Assurance/Quality Control of Vegetation Management
82	OEIS	Set 005	OEIS-PG&E-22-005	5	OEIS-PG&E-22-005_5	Q05. According to Section 7.3.5.13, out of the 7 QA/QV programs PG&E describes, 4 programs fall short of targets. PG&E cites various reasons for the shortfall including resource constraints. How is PG&E: a) Addressing resource constraints for QA/QV? b) Minimizing turnover and loss of talent for QA/QV? c) Ensuring QA/QV targets are met in 2022?	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Quality Assurance/Quality Control of Vegetation Management
83	OEIS	Set 005	OEIS-PG&E-22-005	6	OEIS-PG&E-22-005_6	Q06. In Section 7.3.5.13, PG&E provides the number of QA/QV audits it intended to perform in 2021 (e.g., for QAVM-Distribution Audits, PG&E had planned to complete 65 audits). Provide the number of audits PG&E plans to perform in 2022 for each QA/QV program: a) QAVM - Distribution Audits b) QAVM - Vegetation Pole Clearing Audit c) QAVM - Transmission Audits d) QAVM - Procedure Audits e) QVVM - Distribution f) QVVM - Vegetation Pole Clearing g) QVVM - Transmission	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Quality Assurance/Quality Control of Vegetation Management
84	OEIS	Set 005	OEIS-PG&E-22-005	7	OEIS-PG&E-22-005_7	Q07. Regarding PSPS, on p. 863, PG&E describes "...the January 19, 2021, event that resulted in a massive level of damages that severely impacted restoration." a) Explain the types of damage. b) Quantify the damage observed, by type indicated in Q07.a).	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	1	8	PSPS	Jan. 19, 2021 Event

85	OEIS	Set 005	OEIS-PG&E-22-005	8	OEIS-PG&E-22-005_8	Q08. Regarding PSPS notification, discussing lessons learned from 2021, on p. 866 PG&E indicates "external communications and customer notification processes showed large improvements in 2021. PG&E will continue to work on this as an area for further improvement in 2022, focusing on decreasing the amount of time required to send customer notifications, accuracy of notifications, automating processes, and for issuing updated notifications based on scope changes due to weather." a) To what granularity is customer notification correlated with circuit sectionalization? b) Is PG&E able to send Initial Notifications of a Potential PSPS De-Energization and Notifications of Cancellation of PSPS De-Energization to customers on a discrete circuit segment, as opposed to an entire circuit? c) If a) and b) are not currently true, are there plans to notify customers regarding PSPS events at the segment level? d) If there are plans to notify customers regarding PSPS events at the segment level, what is the timeline for implementing segment-level notification? e) If there are no plans to notify customers regarding PSPS events at the segment level, what is the reasoning behind this decision? f) If there are one or more technical issues that prohibit or otherwise make segment-level notification impossible or impractical, explain those issues.	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	8	PSPS	Additional Detail
86	OEIS	Set 005	OEIS-PG&E-22-005	9	OEIS-PG&E-22-005_9	Q09. As reported in Table 3-2, PG&E's increase in electric costs to ratepayer due to wildfire mitigation activities (total) is markedly higher than the ratepayer impact provided by PG&E's direct utility peers: - 2021 for PG&E \$11.63, SCE \$1.60, and SDG&E \$0.00 - 2022 for PG&E \$6.13, SCE \$6.90, SDG&E \$1.92 (projected) a) How does PG&E explain this vast discrepancy in electric costs to ratepayers due to wildfire mitigation activities? b) How is PG&E justifying the increase to ratepayers at a cumulative rate so much higher than its peers?	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	0	3.2	Summary of Ratepayer impact	VM Spend
87	OEIS	Set 005	OEIS-PG&E-22-005	10	OEIS-PG&E-22-005_10	Q10. PG&E noted in its WMP that the deployment of EPSS throughout pilot areas in its service area led to a significant reduction in ignitions. After reviewing the ignition data submitted by PG&E, the basis of this claim is unclear (i.e., the total ignitions and annual ignitions normalized by environmental conditions were similar to 2020). Please provide the following: a) Geospatial data showing the locations of circuits/circuit segments which were protected by fast trip settings/EPSS in 2021, the date each was installed, and the number of de-energizations (and customer hours) resulting from each EPSS system b) Geospatial data showing the locations of circuits/circuit segments which are currently protected by fast trip settings/EPSS, the date each was installed, and the number of de-energizations (and customer hours) resulting from each EPSS system c) A summary for each automated de-energization, including whether it was a true hazard (i.e., resulting from object contact, equipment failure, etc.) or a false alarm/nuisance de-energization d) An explanation of the criteria used to determine when to enable fast trip settings/EPSS on these circuits (during extreme FPI, RFWs, fire season, etc.) e) Geospatial data showing the locations, cause codes, dates and times for ignitions, wires-down events, and outages that occurred along circuit	Kevin Miller	3/18/2022	3/23/2022	3/23/2022	1	7.3.6.8	EPSS	Ignition Trends
88	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	1	CalAdvocates-PGE-2022WMP-17_1	Table 12 of PG&E's 2022 WMP, the operating expenses for initiative 7.3.6.8 "Protective equipment and device settings" are as follows: 2021: \$18.2 million (actual) 2022: \$142.6 million (projected) 2023: \$140.5 million (projected) Pages 730-739 of PG&E's 2022 WMP describe how PG&E will increase the mileage covered under this initiative from approximately 11,500 miles in 2021 to approximately 25,500 miles in 2022. a) Please explain the projected increase in operating expenses of approximately 7.8 times for corresponding mileage increase of approximately 2.2 times. b) Describe the work that will be funded under the operating expenses for this initiative in 2022. c) Describe the work that will be funded under the operating expenses for this initiative in 2023. d) Please provide any workpapers you used to develop the forecasts of operating expenses for this initiative.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.6.8	EPSS	EPSS Spend
89	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	2	CalAdvocates-PGE-2022WMP-17_2	a) Please provide an estimate for the number of EPSS-related outages that you currently forecast to occur in 2022. Provide a range if a specific estimate is not available. b) Please provide an estimate for the average duration of EPSS-related outages that you currently forecast to occur in 2022. Provide a range if a specific estimate is not available. c) Please describe the methods used to develop the forecasts noted in parts (a) and (b). d) Please describe the assumptions used to develop the forecasts noted in parts (a) and (b), including but not limited to assumptions regarding the sensitivity of EPSS settings, the period and geography where those settings will be in effect, and weather conditions. e) Describe PG&E's plan to minimize the duration of EPSS-related outages in 2022.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.6.8	EPSS	EPSS-related outages
90	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	3	CalAdvocates-PGE-2022WMP-17_3	SDG&E and SCE each have implemented fast recloser settings to re-energize a line rapidly upon detecting a fault. SCE's program is referred to here as "Fast Curve." SDG&E's program is referred to here as "Sensitive relay settings." a) When did PG&E first become aware of SCE's fast curve settings? b) When did PG&E first become aware of SDG&E's sensitive relay settings? c) Did PG&E consider implementing a similar program prior to 2021? d) If the answer to part (c) is yes, why did PG&E not implement such a program prior to 2021? e) If the answer to part (c) is no, please state the basis for PG&E's decision not to provide such a program prior to 2021.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.6.8	EPSS	Device settings
91	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	4	CalAdvocates-PGE-2022WMP-17_4	a) Has PG&E engaged in benchmarking, data-sharing, or other collaboration with SCE with regards to PG&E's EPSS program? b) If the answers to parts (a) is yes, please describe the collaboration(s). c) If the answers to parts (a) is no, please explain why not.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.6.8	EPSS	Benchmarking
92	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	5	CalAdvocates-PGE-2022WMP-17_5	a) Has PG&E engaged in benchmarking, data-sharing, or other collaboration with SDG&E with regards to PG&E's EPSS program? b) If the answers to parts (a) is yes, please describe the collaboration(s). c) If the answers to parts (a) is no, please explain why not.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.6.8	EPSS	Benchmarking
93	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	6	CalAdvocates-PGE-2022WMP-17_6	On November 2, 2021, Cal Advocates staff (and other stakeholders) visited the site of an overhead system hardening project, Diamond Springs 1107. At this site, Cal Advocates discussed the installation of covered conductor with PG&E staff. Cal Advocates was informed that, for this project, new poles with intumescent wrap were being installed. a) Is the above understanding correct with regard to the installation of wider crossarms in this project? b) What is PG&E's typical practice regarding installation or replacement of crossarms when installing covered conductor? c) Do PG&E's current design and construction standards typically call for different crossarm widths on poles that carry covered conductors than poles that carry bare conductors, for circuits of similar voltage? d) If the answer to part (c) is yes, please describe the differences. e) Regarding covered conductor projects completed in 2021, approximately what percentage of crossarms were replaced with wider crossarms as part of these projects?	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.3.3	Grid Design and System Hardening	Covered Conductor Installation
94	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	7	CalAdvocates-PGE-2022WMP-17_7	On November 2, 2021, Cal Advocates staff (and other stakeholders) visited the site of an overhead system hardening project, Diamond Springs 1107. At this site, Cal Advocates discussed the installation of covered conductor with PG&E staff. Cal Advocates was informed that, for this project, new poles with intumescent wrap were being installed. a) What factors contribute to PG&E replacing poles during covered conductor installation projects? b) Regarding covered conductor projects completed in 2021, approximately what percentage of poles were replaced as part of these projects? c) What type(s) of new poles (e.g., wood, wood with intumescent wrap, steel, composite, or concrete) does PG&E currently install when installing covered conductor on distribution circuits? If PG&E uses more than one type of pole, please explain the circumstances and types of projects in which each type is preferred.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/25/2022	3/25/2022	0	7.3.3.6	Grid Design and System Hardening	Distribution Pole Replacement and Reinforcement, Including with Composite Poles
94	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	7 SUPP	CalAdvocates-PGE-2022WMP-17_7 SUPP	On November 2, 2021, Cal Advocates staff (and other stakeholders) visited the site of an overhead system hardening project, Diamond Springs 1107. At this site, Cal Advocates discussed the installation of covered conductor with PG&E staff. Cal Advocates was informed that, for this project, new poles with intumescent wrap were being installed. a) What factors contribute to PG&E replacing poles during covered conductor installation projects? b) Regarding covered conductor projects completed in 2021, approximately what percentage of poles were replaced as part of these projects? c) What type(s) of new poles (e.g., wood, wood with intumescent wrap, steel, composite, or concrete) does PG&E currently install when installing covered conductor on distribution circuits? If PG&E uses more than one type of pole, please explain the circumstances and types of projects in which each type is preferred.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	4/1/2022	4/1/2022	0	7.3.3.6	Grid Design and System Hardening	Distribution Pole Replacement and Reinforcement, Including with Composite Poles

95	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	8	CalAdvocates-PGE-2022WMP-17_8 Pages 12-77 of document "2022-02-25_PGE_2022_WMP-Update_R0_Section 4.6_Arch01.pdf" contain the joint response by PG&E, SCE, and SDG&E to the issue identified by Energy Safety titled "Limited evidence to support the effectiveness of covered conductor." Page 52 of this document states, with regard to risk event mitigation, "In general, a spacer cable system and an ABC [aerial bundled cable] system provide higher effectiveness than a covered conductor system due to their strength and in the case of ABC both its strength and greater insulation properties." Page 62 of this document states, with regard to PPS event mitigation, "Similar to the assessment in the section above, a spacer cable system and an ABC system provide could provide higher benefits than a covered conductor system due to their strength and in the case of ABC both its strength and greater insulation properties." a) Does PG&E have any spacer cable installed in its system currently? If so, state the approximate number of miles, disaggregated by HFTD tier (see definitions P through S). b) If PG&E has any spacer cable installed in its system, please provide the actual cost per mile to install the spacer cable, disaggregated by installation year. c) Please provide an estimate of the current cost per mile to install spacer cable in PG&E's HFTD. d) If PG&E were to install a spacer cable system, would the percentage of poles replaced as part of the installation be higher, lower, or comparable to PG&E's current pole replacement rate in covered conductor projects? e) Please state PG&E's reasons for installing covered conductor instead of spacer cable in its HFTD, despite the apparent benefits of spacer cable described above.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	4.6	Progress Reporting on Key Areas of Improvement	Additional Detail
96	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	9	CalAdvocates-PGE-2022WMP-17_9 a) What is the average trench depth PG&E employs in undergrounding projects? b) Has PG&E examined the potential benefits or drawbacks of shallower trenches? c) Please explain your response to part (b).	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
97	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	10	CalAdvocates-PGE-2022WMP-17_10 project completed during the period of January 1, 2020, through March 1, 2022. For each project, please provide the following information (as columns): a) Project ID number or other identifier b) Circuit ID c) ID number of each CPZ that was entirely undergrounded in the project d) ID number of each CPZ that was partially undergrounded in the project e) Circuit voltage f) County or counties where undergrounding took place g) Project start date h) Project completion date i) Total circuit-miles undergrounded j) Total miles of trenching required k) Total life-cycle electric costs of the project (i.e., costs attributed to PG&E's electric facilities), including costs for planning, design, permitting, and construction. l) Total life-cycle costs of the project, including costs attributed to non-electric utilities, including costs for planning, design, permitting, and construction. m) Whether this was a Rule 20 project (yes/no) n) Whether this was a WMP project (yes/no) o) Whether this was a post-wildfire rebuild project (yes/no) p) Whether PG&E shared trenches for this project with any telecommunications utilities (yes/no) q) Whether PG&E shared trenches for this project with gas facilities (yes/no)	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/29/2022	3/29/2022	2	7.3.3.16	Grid Design and System Hardening	Undergrounding
98	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	11	CalAdvocates-PGE-2022WMP-17_11 Please provide a file geodatabase with a polyline feature for each undergrounding project completed during the period of January 1, 2020, through March 1, 2022. In addition to the spatial location, please provide the following attributes for each project: a) Project ID number or other identifier, matching part (a) of Question 10 b) Circuit ID c) Project completion date	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/29/2022	3/29/2022	1	7.3.3.16	Grid Design and System Hardening	Undergrounding
99	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	12	CalAdvocates-PGE-2022WMP-17_12 Per the table on page 270 of PG&E's 2022 WMP, in 2022 PG&E plans to complete detailed ground inspections on a minimum of 396,000 distribution poles. In 2021, PG&E targeted completing inspections on 477,309 distribution poles, and completed inspections on 480,749 distribution poles. Please state the basis for the reduction in planned distribution inspections in 2022 compared to 2021.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.4	Asset Management and Inspections	Detailed Inspections of Distribution Electric Lines and Equipment
100	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	13	CalAdvocates-PGE-2022WMP-17_13 Per the table on page 270 of PG&E's 2022 WMP, in 2021 PG&E completed detailed distribution inspections on all assets in HFTD Tier 3 and Zone 1, and approximately one-third of assets in HFTD Tier 2. Please describe any changes to the above strategy for PG&E's detailed distribution inspections in 2022.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
101	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	14	CalAdvocates-PGE-2022WMP-17_14 Page 820 of PG&E's 2022 WMP states that Desktop QC activities are conducted based on "random selection," "targeted," or "probable cause." Random selection is described as "Determine the inspectors to evaluate using a simple random process methodology." Cal Advocates understands the above to mean that Desktop QC will perform QC checks on inspections performed by a subset of inspectors. That is, not every inspector's work will be reviewed through Desktop QC. a) Is this understanding correct?	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
102	CalPA	Set WMP-17	CalAdvocates-PGE-2022WMP-17	15	CalAdvocates-PGE-2022WMP-17_15 Per Table 12 of PG&E's 2022 WMP, the operating expenses for initiative 7.3.4.14 "Quality assurance/quality control of inspections" is as follows: 2021: \$27.3 million (actual) 2022: \$6.0 million (projected) a) Please state the basis for the reduction in forecasted operating expenditures related to this initiative. b) Please provide any workpapers you used to develop the forecast of 2022 operating expenses.	Holly Wherman Carolyn Chen Layla Labagh	3/21/2022	3/24/2022	3/24/2022	0	7.3.4.1	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
103	OEIS	Set 006	OEIS-PG&E-22-006	1	OEIS-PG&E-22-006_1 001. In response to WMP-Discovery2022_DR_CalAdvocates_003-Q02, PG&E, provided the below spreadsheet, an Excel table of all transmission circuits existing as of January 1, 2022. Energy Safety requests the below document and will adhere to established confidentiality requirements agreed to with PG&E, as set forth in the 2022 Wildfire Mitigation Plan Update Guidelines. a) Provide WMP-Discovery2022_DR_CalAdvocates_003-Q01 Arch01.CONF.xlsx	Kevin Miller	3/22/2022	3/25/2022	3/25/2022	1	N/A	Miscellaneous	Additional Detail
104	OEIS	Set 006	OEIS-PG&E-22-006	2	OEIS-PG&E-22-006_2 Q02. The frequently de-energized circuit map provided as "Section 8.6_Arch01" appears incomplete, as it does not show all circuits listed in Section 8.6, Table 8.6-1 as presented in the guidelines, to address Public Utilities Code Section 8386(c)(8) requiring the "Identification of circuits that have frequently been de-energized. For instance, by zooming in to 500%, no circuits are visible in the map for Amador, Calaveras, El Dorado, Glenn, or Tuolumne Counties, nor in various other counties with de-energized circuits listed in Table 8.6-1. a) Provide a map which displays all circuits listed in Table 8.6-1. b) If a territory-wide map is scaled inappropriately to visibly display all circuits indicated, break the map into more than one map and scale appropriately for visibility (e.g., 1:250K or 1:100K), and/or use call-out maps within the map to make all frequently de-energized circuits visible. c) Differentiate discrete circuits by color. d) Confirm the total number of frequently de-energized circuits in Table 8.6-1. e) Provide an excel table of Table 8.6-1 with the number of times (frequency) each circuit was de-energized, with Column 4 "Dates of	Kevin Miller	3/22/2022	3/25/2022	3/25/2022	2	8.6	PSPS	Identification of Frequently De-Energized Circuits
105	MGRA	2	MGRA Data Request No. 2	1	MGRA Data Request No. 2_1 Please provide a GIS file showing all EPSS outages and including an attribute for determined cause.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	N/A	EPSS	Outage History
106	MGRA	2	MGRA Data Request No. 2	2	MGRA Data Request No. 2_2 Please provide data for all ignitions that occurred while EPSS was active on a circuit, including size and attributed cause.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	N/A	EPSS	Ignition Trends
107	MGRA	2	MGRA Data Request No. 2	3	MGRA Data Request No. 2_3 Is SmartMeter Partial Voltage Detection used for emergency de-energization?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	N/A	EPSS	Additional Detail
108	MGRA	2	MGRA Data Request No. 2	4	MGRA Data Request No. 2_4 On p. 860, Figure PG&E 8.1-3, guideline categories are shown for Asset, Vegetation, and Consequence. Is the "Consequence" category the result of PG&E's application of its "Black Swan" criteria, in which it shuts off power under conditions of high fire spread without regard to ignition probability?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	8	PSPS	Additional Detail
109	MGRA	2	MGRA Data Request No. 2	5	MGRA Data Request No. 2_5 On p. 906, PG&E describes its decision-making process for PSPS. How does the existence of fires in or threatening the potential PSPS areas affect the decision to de-energize?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	8	PSPS	Additional Detail
110	MGRA	2	MGRA Data Request No. 2	6	MGRA Data Request No. 2_6 On page 8, PG&E discusses "new modeling" for ignition risk. Please provide the description of what this "new modeling" consists of or provide an appropriate reference.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail
111	MGRA	2	MGRA Data Request No. 2	7	MGRA Data Request No. 2_7 In Table PG&E-4.2-2; WILDFIRE RISK DRIVERS, the frequency of facility failures plus object contact in the HFTD is 60, compared to 74 for vegetation contact. Frequency of vegetation contact is 23% larger than the other two drivers. For the percentage of risk in the HFTD, equipment failures plus object contact represents 36.6% of the risk, while vegetation contact represents 59.3% of the risk. Frequency of vegetation contact is 62% larger than the other two drivers combined. How does PG&E account for this discrepancy?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Wildfire Risk Data
112	MGRA	2	MGRA Data Request No. 2	8	MGRA Data Request No. 2_8 On page 129, Figure PG&E-4.5-1-3, 2022 WDRM V3 COMPOSITE MODEL ARCHITECTURE, was the new WDRM V3 used in the GRC update provided in February?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Risk Model
113	MGRA	2	MGRA Data Request No. 2	9	MGRA Data Request No. 2_9 Please ask Technosylva to provide a table and plot of 8 hour fire sizes against final fire sizes for a large (reasonably complete) set of historical fires.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Additional Data
114	MGRA	2	MGRA Data Request No. 2	10	MGRA Data Request No. 2_10 Provide a non-confidential version of documentation describing the IPW model.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Additional Data
115	MGRA	2	MGRA Data Request No. 2	11	MGRA Data Request No. 2_11 On p. 189, PG&E states that the IPW model uses the Cat Boost Machine Learning model. What implementation of the Cat Boost Machine learning model was used for the IPW?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.1	Risk Assessment and Mapping	Additional Data

116	MGRA	2	MGRA Data Request No. 2	12	MGRA Data Request No. 2_12	On p. 191, PG&E states that with its IPW model "Operational Meteorologists used the dashboard to evaluate model performance against key historical storm events, evaluating timing of weather onset compared to modeled outage probability increases, and relative magnitude of outage probabilities." Please provide tabular and graphical analysis showing how the IPW finds that ignition probability increases versus wind speed for the five driver classes.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	2	7.3.1	Risk Assessment and Mapping	Additional Data	
117	MGRA	2	MGRA Data Request No. 2	13	MGRA Data Request No. 2_13	On p. 285 PG&E describes its undergrounding efforts "including a small volume of previously hardened overhead lines that are being placed underground, and any other undergrounding work performed in HFTD or fire rebuild areas." How many miles of previously hardened lines are being put underground and what is the motivation for this action?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.3	Undergrounding	Additional Data	
118	MGRA	2	MGRA Data Request No. 2	14	MGRA Data Request No. 2_14	Are the reviews of staff, management, or executives in any way tied to targets related to the successful completion of undergrounding projects?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.3	Undergrounding	Additional Data	
119	MGRA	2	MGRA Data Request No. 2	15	MGRA Data Request No. 2_15	In attachment TN10634-0_20220225T144600_Section_71H_Atch01_WorkMaps, PG&E provides maps for Covered conductor installation, Undergrounding of Electric lines or Equipment, and System hardening including line removal. Please provide these maps as a GIS file.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.3	Grid Design and System Hardening	Additional Data	
120	MGRA	2	MGRA Data Request No. 2	16	MGRA Data Request No. 2_16	Please provide a non-confidential version of Data request response WMP-Discovery2022_DR_CalAdvocates_003-Q01Atch01CONF(T) regarding PG&E's hardening program.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.3	Grid Design and System Hardening	Additional Data	
121	MGRA	2	MGRA Data Request No. 2	17	MGRA Data Request No. 2_17	On p. 319, PG&E states that it has "Developed a weather-station specific wind gust model with particular emphasis on Diablo winds". Please provide the documentation for this weather model.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.2	Situational Awareness and Forecasting	Additional Data	
122	MGRA	2	MGRA Data Request No. 2	18	MGRA Data Request No. 2_18	On how many weather stations is 30 second weather observations collected? Please provide a list if it is not the complete set of weather stations. How long is the 30 second data maintained on the weather station? Is the 30 second weather data available to the public and are there any plans to make it so?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.2	Situational Awareness and Forecasting	Additional Data	
123	MGRA	2	MGRA Data Request No. 2	19	MGRA Data Request No. 2_19	On p. 384 PG&E states that "The phase and magnitude of the Madden-Julian Oscillation was shown to be a potential predictor of upcoming Diablo wind events by both internal and external research. Provide appropriate citations."	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.2	Situational Awareness and Forecasting	Additional Data	
124	MGRA	2	MGRA Data Request No. 2	20	MGRA Data Request No. 2_20	On p. 765, PG&E states that its "EII team conducted audit of multiple work tracking databases to identify ignitions that had been missed in the past, increasing PG&E's reportable ignition record by 23 percent." Please provide a complete set of the newly identified ignitions in GIS format.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.7.4	Data Governance	Tracking and Analysis of Risk Event Data	
125	MGRA	2	MGRA Data Request No. 2	21	MGRA Data Request No. 2_21	Provide the EII "data dictionary/review guide for all collected [ignition] data points" with any confidential information removed.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	7.3.7.1	Data Governance	Centralized Repository for Data	
126	MGRA	2	MGRA Data Request No. 2	22	MGRA Data Request No. 2_22	Provide the contents of TABLE PG&E-8.6-1 LIST OF FREQUENTLY DE-ENERGIZED CIRCUITS in Excel format.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	1	8	PSPS	Additional Data	
127	MGRA	2	MGRA Data Request No. 2	23	MGRA Data Request No. 2_23	Followup, not Supp.	Joseph Mitchell on behalf of MGRA	3/23/2022	4/1/2022	4/1/2022	1	N/A	Miscellaneous	Ignition Trends	
127	MGRA	2	MGRA Data Request No. 2	23	MGRA Data Request No. 2_23	Followup, not Supp.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	N/A	Miscellaneous	Ignition Trends	
128	MGRA	2	MGRA Data Request No. 2	24	MGRA Data Request No. 2_24	On p. 7.1.E-Atch1-21, the RSE for REFCL is given as 40. Please explain the factors that go into reaching this low estimate.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	N/A	Miscellaneous	REFCL	
129	MGRA	2	MGRA Data Request No. 2	25	MGRA Data Request No. 2_25	In the data request response WMP-Discovery2022_DR_CalAdvocates_013-Q11Atch01.xlsx, please verify the following interpretation: For a REFCL deployment, PG&E projects a \$75M capex, plus \$141M operating cost through 2026, constituting 14% of its 25,000 miles, and that the protection is 58% effective.	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	N/A	Miscellaneous	REFCL	
130	MGRA	2	MGRA Data Request No. 2	26	MGRA Data Request No. 2_26	(Incorrectly labeled as MGRA-2-17 on page 3)	On p. 631 PG&E states that its Tree Assessment Tool (TAT) incorporates "local wind gust data". Is the local wind gust data specific to fire weather conditions (such as a Diablo corridor) or does it include winter storm conditions?	Joseph Mitchell on behalf of MGRA	3/23/2022	3/28/2022	3/28/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Additional Efforts to Manage Community and Environmental Impacts
131	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	1	CalAdvocate s-PGE-2022WMP-18_1	PG&E's response to data request CalAdvocates-PGE-2022WMP-16, Question 11 referred to Exhibit PG&E-4 from PG&E's February 25, 2022 GRC Update. Page 9-20 of this exhibit states, "The updated EVM scope of work focuses on overhang clearing only; other activities previously included in the EVM scope of work are now addressed in Routine VM." Page 9-30 and 9-31 state, "Ultimately, PG&E will conduct visual assessment of all sides of potential strike trees on routine vegetation management patrols in the entire 25,000 mile HFTD each year, whereas the existing hazard tree identification program under Enhanced VM addresses less than 2,000 miles annually." a) Please explain what is meant by "visual assessment of all sides of potential strike trees" on pages 9-30 and 9-31 of Exhibit PG&E-4 from PG&E's February 25, 2022 GRC Update. b) Beginning in 2023, will PG&E's Routine VM patrols use PG&E's Tree Assessment Tool to assess potential strike trees on all HFTD circuit-miles? c) Beginning in 2023, will PG&E's Routine VM program include remediation and removal of potential strike trees on all HFTD circuit-miles? Please explain your answer. d) In comparing EVM work planned for 2022 and Routine VM work planned for 2023, does PG&E expect to remediate or remove more, fewer, or a similar number of potential strike trees in 2023? Please explain your answer.	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Additional Detail	
132	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	2	CalAdvocate s-PGE-2022WMP-18_2	PG&E's response to data request CalAdvocates-PGE-2022WMP-15, Question 16 shows a reduction of approximately \$412 million in projected total vegetation management expenditures from 2022 to 2023. a) Does the reduction in total VM expenditure from 2022 to 2023 result primarily from PG&E's plan to combine aspects of the EVM program into routine VM? b) If the answer to part (a) is yes, please explain all the substantive ways in which vegetation management activities in 2023 will differ from vegetation management activities in 2022. c) If the answer to part (a) is no, please state the basis for the reduction in projected VM expenditures from 2022 to 2023. d) Please explain how PG&E will achieve comparable risk reduction in 2023 as in 2022 despite significantly reduced spending. Regarding PG&E's covered conductor and strategic undergrounding activities: a) What is PG&E's current estimate for the service life of newly installed distribution covered conductor? b) What is PG&E's current estimate for the service life of newly installed traditional (non-covered conductor) overhead distribution conductor? c) If the answers to parts (a) and (b) above differ, explain the factors that contribute to PG&E's varying estimates. d) What is PG&E's current estimate for the service life of newly installed distribution underground conductor?	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.5	Vegetation Management (VM) and Inspections	VM Spend	
133	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	3	CalAdvocate s-PGE-2022WMP-18_3	a) What is PG&E's current estimate for the service life of newly installed distribution covered conductor? b) What is PG&E's current estimate for the service life of newly installed traditional (non-covered conductor) overhead distribution conductor? c) If the answers to parts (a) and (b) above differ, explain the factors that contribute to PG&E's varying estimates. d) What is PG&E's current estimate for the service life of newly installed distribution underground conductor?	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.3	Grid Design and System Hardening	Service Life of Assets	
134	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	4	CalAdvocate s-PGE-2022WMP-18_4	PG&E's response to data request OEIS-PG&E-22-005, Question 3, states, "The QA/QV scope is currently focused on contract Pre-Inspectors and does not evaluate the performance of PG&E Pre-Inspector employees." a) Please describe the role of QA/QV as used in OEIS-PG&E-22-005, Question 3. b) Please explain why PG&E's QA/QV scope does not include evaluation of the performance of PG&E Pre-Inspector employees. c) How does PG&E currently evaluate the performance of PG&E Pre-Inspector employees? d) What quality assurance practices and procedures does PG&E currently use to ensure the quality of the work performed by PG&E Pre-Inspector employees?	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	11	7.3.5	Vegetation Management (VM) and Inspections	Quality Assurance/Quality Control of Vegetation Management	
135	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	5	CalAdvocate s-PGE-2022WMP-18_5	As part of PG&E's response to issue 5.4.B, PG&E included the following attachments to its 2022 WMP: 2022-02-25_PGE_2022_WMP-Update_R0_Section 4.6_Remedied 5.4.B_Atch02.xlsx 2022-02-25_PGE_2022_WMP-Update_R0_Section 4.6_Remedied 5.4.B_Atch03.xlsx With regard to these spreadsheets: a) Please explain the difference between "Notification Date" (column I) and "Notif Create Date" (column J). b) Please explain the difference between "Req End Date" (column L) and "Authorized End Date" (column M). c) Please explain what is meant by "Notif Ref Date" (column O).	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.4	Asset Management and Inspections	Additional Detail	
136	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	6	CalAdvocate s-PGE-2022WMP-18_6	PG&E's written response to issue 5.4.B.3 states that priority A is used for "Conditions that require immediate action." The following priority A correctives opened in 2021 have a required end date several months after the creation date. For each, please explain why the tag did not require immediate action. a) 121439605 (206 days) b) 121439803 (206 days) c) 121738117 (169 days) d) 122121787 (72 days) e) 122371526 (98 days) In general, please explain: a) Why PG&E's procedures allow a priority A corrective notification to be given a required end date more than 1 month after the date the condition is found in the field? b) In what circumstances it would be appropriate for an inspector to create a priority A corrective and assign a required end date more than 30 days in the future.	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.4	Asset Management and Inspections	Additional Detail	
137	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	7	CalAdvocate s-PGE-2022WMP-18_7	a) Why PG&E's procedures allow a priority A corrective notification to be given a required end date more than 1 month after the date the condition is found in the field? b) In what circumstances it would be appropriate for an inspector to create a priority A corrective and assign a required end date more than 30 days in the future.	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.4	Asset Management and Inspections	Additional Detail	
138	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	8	CalAdvocate s-PGE-2022WMP-18_8	PG&E's response to data request CalAdvocates-PGE-2022WMP-16, Question 5, states, "Pre-Inspectors follow Procedure TD-7102P-23 for Red Flag Warning procedure and TD-7102P-17 for Priority Tag Procedure to review and re-prioritize work within the RFW area." Please provide documents TD-7102P-23 and TD-7102P-17	Holly Wherman Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	2	7.3.5	Vegetation Management (VM) and Inspections	Emergency Response Vegetation Management Due to Red Flag Warning or Other Urgent Weather Conditions	

139	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	9	CalAdvocates-PGE-2022WMP-18_9	PG&E's response to data request CalAdvocates-PGE-2022WMP-16, Question 6, states, "The current use case for VM Distribution LIDAR is tied to the VM Routine Program. LIDAR collection in line with the VM Routine schedule requires more agility than is currently possible with aerial LIDAR collections." Please explain why aerial LIDAR inspections are not currently possible with the VM Routine Program schedule while they are possible for transmission-line inspections.	Holly Whermer Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Distribution Electric Lines and Equipment
140	CalPA	Set WMP-18	CalAdvocates-PGE-2022WMP-18	10	CalAdvocates-PGE-2022WMP-18_10	PG&E's response to data request CalAdvocates-PGE-2022WMP-10, Question 6, states, "GBL scanning costs are approximately \$400 per mile, including scanning, data processing and electrical asset and vegetation feature extraction." According to Table 12 of your WMP, the projected 2022 OPEX cost for initiative 7.3.5.7, "Remote sensing inspections of vegetation around distribution electric lines and equipment" is approximately \$37.1 million. The projected line miles to be treated is 2,000, for an average cost-per-mile of \$18,545. The projected 2022 OPEX cost for initiative 7.3.5.8, "Remote sensing inspections of vegetation around transmission electric lines and equipment" is approximately \$13 million. The projected line miles to be treated is 17,759, for an average cost-per-mile of \$732. a) Please provide a breakdown of the forecasted \$18,545 cost per mile for initiative 7.3.5.7. b) Please explain the per-mile cost difference between initiatives 7.3.5.7 and 7.3.5.8.	Holly Whermer Carolyn Chen Layla Labagh	3/25/2022	3/30/2022	3/30/2022	0	7.3.5	Vegetation Management (VM) and Inspections	Remote Sensing Inspections of Vegetation Around Distribution Electric Lines and Equipment
141	CalPA	Set WMP-19	CalAdvocates-PGE-2022WMP-19	1	CalAdvocates-PGE-2022WMP-19_1	Page 537 of PG&E's 2022 WMP states that, for 2022, the "highest wildfire risk miles" includes, among other definitions, "The top 20 percent of circuit segments as defined by PG&E's 2021 WDRM v2 for System Hardening." In response to data request CalAdvocates-PGE-2021WMP-19, question 3, on March 15, 2021, PG&E provided a list of circuit-segments with associated equipment risk scores. Cal Advocates sorted this list by the attribute "mean_mavf_core_risk_rank" and selected the top 20% (727 circuit-segments out of the total of 3635 circuit-segments). This list is included as "CalAdvocates-PGE-2022WMP-19 Atch01.xlsx." a) Do the 727 circuit-segments included in the attachment CalAdvocates-PGE-2022WMP-19 Atch01.xlsx represent the "The top 20 percent of circuit segments as defined by PG&E's 2021 WDRM v2 for System Hardening"? b) If the answer to part (a) is no, please explain why not. c) If the answer to part (a) is no, please revise and update the list of circuit-segments in attachment CalAdvocates-PGE-2022WMP-19 Atch01.xlsx as needed, so that the list in the attachment does match "The top 20 percent of circuit segments as defined by PG&E's 2021 WDRM v2 for System Hardening."	Holly Whermer Carolyn Chen Layla Labagh	3/25/2022	3/31/2022	3/31/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail
142	CalPA	Set WMP-19	CalAdvocates-PGE-2022WMP-19	2	CalAdvocates-PGE-2022WMP-19_2	Please add the following data to "CalAdvocates-PGE-2022WMP-19 Atch01.xlsx" (with changes to the attachment as required by Question 1c) as new columns. Provide this data as of 2/1/2022, or the most current verified data, whichever is more recent. a) The total number of HFTD circuit-miles (including both overhead and underground miles) on each circuit-segment. b) The number of HFTD circuit-miles within each circuit-segment that have been hardened in such a way as to mitigate wildfire risk (e.g. undergrounding, covered conductor, line removal, etc.). c) The number of HFTD circuit-miles within each circuit-segment that have not yet been hardened in such a way as to mitigate wildfire risk.	Holly Whermer Carolyn Chen Layla Labagh	3/25/2022	3/31/2022	3/31/2022	1	7.3.3	Grid Design and System Hardening	Additional Detail
143	OEIS	Set 007	OEIS-PG&E-22-007	1	OEIS-PG&E-22-007_1	Q01. On P. 870, PG&E indicates "Based on the 2021 10-year PSPS lookback analysis, PG&E identified potential locations for our transmission and distribution PSPS mitigation programs." a) In addition to PSPS risk is PG&E also evaluating prioritization for our transmission and distribution PSPS mitigation programs based on riskiest circuits in terms of ignition risk?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	8	PSPS	Additional Detail
144	OEIS	Set 007	OEIS-PG&E-22-007	2	OEIS-PG&E-22-007_2	Q02. With regard to maturity survey question F.IV.a Does the utility have explicit thresholds for initiating a PSPS? PG&E's answer has remained the same from 2021 to 2022. a) At what point in time does PG&E expect to have explicit policies for the thresholds above which PSPS is activated, but attain the goal to maintain its grid in sufficiently low risk condition to not require any PSPS activity though may de-energize specific circuits upon detection of damaged condition of electrical lines and equipment or contact with foreign objects?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	Maturity Survey
145	OEIS	Set 007	OEIS-PG&E-22-007	3	OEIS-PG&E-22-007_3	Q03. With regard to maturity survey question F.IV.c Under which circumstances does the utility de-energize circuits? Select all that apply. PG&E answered all options: i. Upon detection of damaged conditions of electric equipment; ii. When circuit presents a safety risk to suppression or other personnel; iii. When equipment has come into contact with foreign objects posing ignition risk; iv. Additional reasons not listed. a) Does PG&E foresee a time when one of options i., ii., or iii. could be excluded from consideration to de-energize?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	Maturity Survey
146	OEIS	Set 007	OEIS-PG&E-22-007	4	OEIS-PG&E-22-007_4	Q04. With regard to maturity survey question F.IV.d How automated is the process for inspecting de-energized sections of the grid prior to re-energizing? In the 2021 Survey, PG&E answered as of January 1, 2023 it would be "Partially automated, <50%" and this year changed that answer to "Manual process, not at all." a) Explain why PG&E expects the process for inspecting de-energized sections of the grid prior to re-energizing to be manual process, not at all, instead of partially automated, <50% b) When does PG&E expect to automate the process for inspecting de-energized sections of the grid prior to re-energizing?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	Maturity Survey
147	OEIS	Set 007	OEIS-PG&E-22-007	5	OEIS-PG&E-22-007_5	Q05. Regarding Table 5.3-1, provide the additional columns in WMP Discovery2022_DR_OEIS_005-Q01Atch01: a) The original number of Customers Experiencing Sustained Outages (CESO) from the actual outages that occurred (opposed to the predicted if EPSS was enabled) b) The original summed outage duration in minutes c) The predicted outage duration in minutes	Kevin Miller	3/25/2022	3/31/2022	3/31/2022	1	7.3.3	Grid Design and System Hardening	EPSS Reliability Impact analysis
148	OEIS	Set 007	OEIS-PG&E-22-007	6	OEIS-PG&E-22-007_6	Q06. Regarding Table 5.3-1, provide the additional columns in WMP Discovery2022_DR_CalAdvocates_012-Q02Atch01: a) Define the population of transmission detailed ground inspections reviewed through Desktop Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within. b) Define the population of transmission detailed ground inspections reviewed through Field Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within. c) Explain the QA/QC processes for Transmission, climbing inspections and Transmission, drone inspections. Information should include the following stats for every year applicable (i.e. 2019, 2020, 2021): i) Population of inspections eligible for QA/QC process ii) Number of inspections undergoing QA/QC process	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
148	OEIS	Set 007	OEIS-PG&E-22-007	6 REV	OEIS-PG&E-22-007_6 REV	Q06. Regarding Table 5.3-1, provide the additional columns in WMP Discovery2022_DR_CalAdvocates_012-Q02Atch01: a) Define the population of transmission detailed ground inspections reviewed through Desktop Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within. b) Define the population of transmission detailed ground inspections reviewed through Field Reviews, including but not limited to the number of inspections checked, and the date range that those inspections occurred within. c) Explain the QA/QC processes for Transmission, climbing inspections and Transmission, drone inspections. Information should include the following stats for every year applicable (i.e. 2019, 2020, 2021): i) Population of inspections eligible for QA/QC process ii) Number of inspections undergoing QA/QC process	Kevin Miller	3/25/2022	4/1/2022	4/1/2022	0	7.3.4.14	Asset Management and Inspections	Quality assurance / quality control of inspections
149	OEIS	Set 007	OEIS-PG&E-22-007	7	OEIS-PG&E-22-007_7	Q07. Provide the same information in the same format as supplied in Table 1, for climbing inspections, IR inspections, and drone inspections for detailed and transmission levels respectively: a) Number of total circuit miles inspected b) Level 1 findings c) Level 2 findings d) Level 3 findings e) Number of circuit miles inspected in HFTD f) Level 1 findings in HFTD g) Level 2 findings in HFTD h) Level 3 findings in HFTD	Kevin Miller	3/25/2022	4/8/2022	4/8/2022	1	7.3.4.14	Asset Management and Inspections	Detailed Inspections of Transmission Electric Lines and Equipment
150	OEIS	Set 007	OEIS-PG&E-22-007	8	OEIS-PG&E-22-007_8	Q08. Regarding Table 5.3-1, provide similar information for system hardening excluding undergrounding	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.3	Grid Design and System Hardening	Additional Detail
151	OEIS	Set 007	OEIS-PG&E-22-007	9	OEIS-PG&E-22-007_9	Q09. Provide a copy of E3's review of PG&E's 2022 WDRM v3 and WFC Model when it is complete.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
151	OEIS	Set 007	OEIS-PG&E-22-007	9Supp	OEIS-PG&E-22-007_9Supp	Q09. Provide a copy of E3's review of PG&E's 2022 WDRM v3 and WFC Model when it is complete.	Kevin Miller	3/25/2022	3/30/2022	6/2/2022	1	4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model

152	OEIS	Set 007	OEIS-PG&E-22-007	10	OEIS-PG&E-22-007_10	In Southern California Edison's 2022 WMP Update, the utility states that "in high and medium vibration susceptibility areas, vibration can reduce the covered conductor's useful life from 45 years to an average of 20 years if not addressed" and that "[i]nstalling dampers minimizes equipment failure ignition drivers, such as damage or failure of the conductor, connector, and/or splice" (Section 7.3.3.3.3 "Vibration Damper Retrofit [SH-16]," p. 202). a) Is PG&E including vibration dampers as part of its covered conductor installations? If so, provide the percentage of covered conductor installations that include vibration dampers, as well as a description of how PG&E determined where to install vibration dampers. b) Has PG&E done an analysis for determining what areas within its system would be susceptible to vibrations and potentially benefit from vibration dampers? If so, describe how SDG&E made such determinations, which areas are classified as potentially benefiting from vibration dampers, and what criteria or thresholds are used to determine if vibration dampers should be installed. c) If PG&E is not currently including vibration dampers as part of its covered conductor installations, please explain whether PG&E plans to do so in the future and what those plans are, including possible retrofits. d) Provide a description of any lessons learned regarding vibration damper installation for covered conductor, whether they be from SCE, lessons shared by SCE or other utilities during the joint utility covered conductor effort, or from broader industry experience or PG&E's own covered-conductor-specific failure modes that require operators to consider additional personnel training, augmented installation practices, and adoption of new mitigation strategies (e.g., additional lightning arrestors, conductor washing programs, etc.) (ps. 7-8): a) What additional training has PG&E implemented for personnel pertaining to these covered conductor failure modes? Please list all trainings, the frequency at which trainings are required to be taken, and which personnel are required to take the trainings. Include the trainings used to train personnel for inspections, maintenance, and installation of covered conductor. b) How has PG&E augmented its installation practices to prevent these covered conductor failure modes? c) What new mitigation strategies has PG&E adopted to prevent these covered conductor failure modes?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.3	Grid Design and System Hardening	Vibration Susceptibility
153	OEIS	Set 007	OEIS-PG&E-22-007	11	OEIS-PG&E-22-007_11	Regarding covered conductor inspections and maintenance. a) Provide the following job aids: i) TD-2305M-JA02 ii) TD-2305M-JA08 iii) TD-2305M-JA12 b) Provide a description and list of all changes made to inspections and maintenance procedures as it directly relates to covered conductor and all associated equipment. Regarding WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx and Discovery2022_DR_CalAdvocates_004-Q09Atch01.xlsx: a) Provide an additional column with the coinciding risk scores for each project in WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx, similar to WMP-Discovery2022_DR_CalAdvocates_004-Q09Atch01.xlsx b) Provide an additional column with the risk rankings for WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx, similar to Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx c) Do risk scores align and correspond with the top risk percentages presented in Table PG&E-5.3-1(A) from the 2022 WMP Update? If not, explain how the two correlate and/or differ. d) Provide the same information presented in these two Excel files for system hardening projects planned in 2023 and 2024. Provide WMP-Discovery2022_DR_CalAdvocates_003-Q01Atch01CONE.xlsx with the additional columns: a) Wildfire Risk Score – 2021 b) Wildfire Risk Score – 2022	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	1	7.3.3	Grid Design and System Hardening	Additional Detail
154	OEIS	Set 007	OEIS-PG&E-22-007	12	OEIS-PG&E-22-007_12	Regarding WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx and Discovery2022_DR_CalAdvocates_004-Q09Atch01.xlsx: a) Provide an additional column with the coinciding risk scores for each project in WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx, similar to WMP-Discovery2022_DR_CalAdvocates_004-Q09Atch01.xlsx b) Provide an additional column with the risk rankings for WMP-Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx, similar to Discovery2022_DR_CalAdvocates_004-Q08Atch01.xlsx c) Do risk scores align and correspond with the top risk percentages presented in Table PG&E-5.3-1(A) from the 2022 WMP Update? If not, explain how the two correlate and/or differ. d) Provide the same information presented in these two Excel files for system hardening projects planned in 2023 and 2024. Provide WMP-Discovery2022_DR_CalAdvocates_003-Q01Atch01CONE.xlsx with the additional columns: a) Wildfire Risk Score – 2021 b) Wildfire Risk Score – 2022	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	3	7.3.3	Grid Design and System Hardening	Covered Conductor Maintenance
155	OEIS	Set 007	OEIS-PG&E-22-007	13	OEIS-PG&E-22-007_13	In PG&E's response to WMP-Discovery2022_DR_OEIS_002-Q07, PG&E states that they "are also reviewing and evaluating the Risk Associated with Value Exposure (RAVE) module from Technosylva that has components for estimating egress considering location and community factors." a. Provide a list of the community factors evaluated, including associated weights of each factor when implemented into modeling b. What is PG&E's current status of implementing the RAVE module? c. What are PG&E's conclusions on its analysis of the RAVE module? d. What is PG&E's timeline for implementation of the RAVE module? e. How is PG&E accounting for community factors in the meantime? In particular, describe what factors PG&E considers regarding vulnerable communities, and how such are accounted for in its risk analysis and modeling, including weights.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	1	7.3.1	Risk Assessment and Mapping	Additional Detail
156	OEIS	Set 007	OEIS-PG&E-22-007	14	OEIS-PG&E-22-007_14	In PG&E's 2022 WMP Update, PG&E states the following (p. 531): Because system hardening work is generally identified 12 or more months before construction, the decision tree that was used for selecting between various distribution system hardening methods (e.g., undergrounding, covered conductor, line removal etc.) for 2022 work was not changed to incorporate our updated 2022 goals of expanding EPSS and undergrounding. Regarding PG&E's decision-making process for system hardening: a) Is PG&E currently using the 2021 methodology for decision-making, as presented on May 21, 2021 to the Wildfire Safety Division ("previous methodology")? b) When did/does PG&E intend to use the methodology outlined in the progress report in Figure PG&E-Remedy-21-14-01 ("new methodology")? c) For any circuits PG&E is planning on installing covered conductor based on the previous methodology: i) What percentage and number of circuit miles would have been determined to be undergrounded using the new methodology? ii) For any such miles, what additional initiative(s) in conjunction with	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail
157	OEIS	Set 007	OEIS-PG&E-22-007	15	OEIS-PG&E-22-007_15	PG&E states that it will "initiate reliability mitigations on 50 EPSS capable circuits in the HFTD areas, HFRA and non HFTD buffer zones based on highest projected Customer Experiencing Sustained Outage (CESO)." a) Explain a list of what "reliability mitigations" includes b) Provide calculations and explanations for how each mitigation is anticipated to improve reliability In section 7.3.2.2, PG&E states its utility distribution system (UDS) program and sets a target of 7,000 distribution poles in the HFTD a) To what standard does PG&E clear these poles? (i.e., to what radius and height?) i) Explain the rationale behind choosing this standard, including any scientific or wildfire safety rationales behind the extent of clearance. ii) Has PG&E considered the environmental impacts of this clearance radius? If so, what are environmental impacts, both positive and negative? (e.g., erosion, removal of invasive species, habitat fragmentation, water quality, etc.) b) Is PG&E considering alternative mitigation measures (i.e., ones that would negate the need for some or all of the UDS program)? i) If so, what are those mitigation measures? ii) If not, why not?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail
158	OEIS	Set 007	OEIS-PG&E-22-007	16	OEIS-PG&E-22-007_16	PG&E states that it will "initiate reliability mitigations on 50 EPSS capable circuits in the HFTD areas, HFRA and non HFTD buffer zones based on highest projected Customer Experiencing Sustained Outage (CESO)." a) Explain a list of what "reliability mitigations" includes b) Provide calculations and explanations for how each mitigation is anticipated to improve reliability In section 7.3.2.2, PG&E states its utility distribution system (UDS) program and sets a target of 7,000 distribution poles in the HFTD a) To what standard does PG&E clear these poles? (i.e., to what radius and height?) i) Explain the rationale behind choosing this standard, including any scientific or wildfire safety rationales behind the extent of clearance. ii) Has PG&E considered the environmental impacts of this clearance radius? If so, what are environmental impacts, both positive and negative? (e.g., erosion, removal of invasive species, habitat fragmentation, water quality, etc.) b) Is PG&E considering alternative mitigation measures (i.e., ones that would negate the need for some or all of the UDS program)? i) If so, what are those mitigation measures? ii) If not, why not?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.3	Grid Design and System Hardening	Additional Detail
159	OEIS	Set 007	OEIS-PG&E-22-007	17	OEIS-PG&E-22-007_17	PG&E states that it will "initiate reliability mitigations on 50 EPSS capable circuits in the HFTD areas, HFRA and non HFTD buffer zones based on highest projected Customer Experiencing Sustained Outage (CESO)." a) Explain a list of what "reliability mitigations" includes b) Provide calculations and explanations for how each mitigation is anticipated to improve reliability In section 7.3.2.2, PG&E states its utility distribution system (UDS) program and sets a target of 7,000 distribution poles in the HFTD a) To what standard does PG&E clear these poles? (i.e., to what radius and height?) i) Explain the rationale behind choosing this standard, including any scientific or wildfire safety rationales behind the extent of clearance. ii) Has PG&E considered the environmental impacts of this clearance radius? If so, what are environmental impacts, both positive and negative? (e.g., erosion, removal of invasive species, habitat fragmentation, water quality, etc.) b) Is PG&E considering alternative mitigation measures (i.e., ones that would negate the need for some or all of the UDS program)? i) If so, what are those mitigation measures? ii) If not, why not?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	EPSS	Additional Detail
160	OEIS	Set 007	OEIS-PG&E-22-007	18	OEIS-PG&E-22-007_18	PG&E states that it will "initiate reliability mitigations on 50 EPSS capable circuits in the HFTD areas, HFRA and non HFTD buffer zones based on highest projected Customer Experiencing Sustained Outage (CESO)." a) Explain a list of what "reliability mitigations" includes b) Provide calculations and explanations for how each mitigation is anticipated to improve reliability In section 7.3.2.2, PG&E states its utility distribution system (UDS) program and sets a target of 7,000 distribution poles in the HFTD a) To what standard does PG&E clear these poles? (i.e., to what radius and height?) i) Explain the rationale behind choosing this standard, including any scientific or wildfire safety rationales behind the extent of clearance. ii) Has PG&E considered the environmental impacts of this clearance radius? If so, what are environmental impacts, both positive and negative? (e.g., erosion, removal of invasive species, habitat fragmentation, water quality, etc.) b) Is PG&E considering alternative mitigation measures (i.e., ones that would negate the need for some or all of the UDS program)? i) If so, what are those mitigation measures? ii) If not, why not?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	1	7.3.5	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
161	OEIS	Set 007	OEIS-PG&E-22-007	19	OEIS-PG&E-22-007_19	PG&E states that it will "initiate reliability mitigations on 50 EPSS capable circuits in the HFTD areas, HFRA and non HFTD buffer zones based on highest projected Customer Experiencing Sustained Outage (CESO)." a) Explain a list of what "reliability mitigations" includes b) Provide calculations and explanations for how each mitigation is anticipated to improve reliability In section 7.3.2.2, PG&E states its utility distribution system (UDS) program and sets a target of 7,000 distribution poles in the HFTD a) To what standard does PG&E clear these poles? (i.e., to what radius and height?) i) Explain the rationale behind choosing this standard, including any scientific or wildfire safety rationales behind the extent of clearance. ii) Has PG&E considered the environmental impacts of this clearance radius? If so, what are environmental impacts, both positive and negative? (e.g., erosion, removal of invasive species, habitat fragmentation, water quality, etc.) b) Is PG&E considering alternative mitigation measures (i.e., ones that would negate the need for some or all of the UDS program)? i) If so, what are those mitigation measures? ii) If not, why not?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	8	PSPS	Additional Detail
162	OEIS	Set 007	OEIS-PG&E-22-007	20	OEIS-PG&E-22-007_20	Regarding section 7.3.2.1.3 weather stations: a) How many of PG&E's weather stations have been upgraded to give readings at 10 to 30-second intervals? b) How many (in percentages) of PG&E's weather stations are ground-based versus pole-mounted? c) Are any of PG&E's weather stations outfitted with 10hr fuel moisture sensors? d) What is the total number of weather stations PG&E plans to have deployed in its weather station network? e) Regarding PG&E's 2022 Program targets for weather stations: i. Please provide the number of new weather station installs for 2022. ii. Please provide the number of optimized weather station installs in 2022.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.2	Situational Awareness and Forecasting	Weather Stations
163	OEIS	Set 007	OEIS-PG&E-22-007	21	OEIS-PG&E-22-007_21	Regarding PG&E's response to Maturity Survey question B.III.c. a) Please describe how PG&E interprets span based.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	Maturity Survey
164	OEIS	Set 007	OEIS-PG&E-22-007	22	OEIS-PG&E-22-007_22	Regarding PG&E's response to Maturity Survey question B.III.c. a) Please describe what PG&E needs to do to improve weather data granularity to the span-based level.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	Maturity Survey
165	OEIS	Set 007	OEIS-PG&E-22-007	23	OEIS-PG&E-22-007_23	Regarding Safety and Infrastructure Protection Teams (SIPT) in section 7.3.2.5: a) In 2022, PG&E is planning on increasing staffing by 22 full-time employees. How many SIPT Crews and Engines will PG&E have after increasing this staffing?	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	7.3.2	Situational Awareness and Forecasting	Personnel Monitoring Areas of Electric Lines and Equipment in Elevated Fire Risk Conditions
166	OEIS	Set 007	OEIS-PG&E-22-007	24	OEIS-PG&E-22-007_24	Regarding DTS FAST on Page 874 a) Was the prototype field test installation at the Santa Cruz service center that was completed in 2021 on distribution or transmission? b) Please provide an explanation on what approving the final version of DTS FAST means? Please explain technically how PG&E's WDRM applies a conditional probability or makes any other adjustment to account for the fact the Technosylva consequence model is run on "worst weather days", while the Probability of Ignition model analyzes all ignitions whether they are on worst weather days or not.	Kevin Miller	3/25/2022	3/30/2022	3/30/2022	0	N/A	Miscellaneous	DTS FAST
167	MGRA	3	MGRA Data Request No. 3	1	MGRA Data Request No. 3_1	In the WDRM v3 model, has Cal Fire outcome data derived from VIIRS correlation now replaced the 8 hour Technosylva simulation?	Joseph Mitchell on behalf of MGRA	3/28/2022	3/31/2022	3/31/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail
168	MGRA	4	MGRA Data Request No. 4	1	MGRA Data Request No. 4_1	In the WDRM v3 model, has Cal Fire outcome data derived from VIIRS correlation now replaced the 8 hour Technosylva simulation?	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0	7.3.1	Risk Assessment and Mapping	Additional Detail

169	MGRA	4	MGRA Data Request No. 4	2	MGRA Data Request No. 4_2	What is the remaining role of Technosylva simulation in the v3 model?	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0		7.3.1	Risk Assessment and Mapping	Additional Detail
170	MGRA	4	MGRA Data Request No. 4	3	MGRA Data Request No. 4_3	If the Technosylva outputs are linked to the VIIRS data, how is this linkage performed?	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0		7.3.1	Risk Assessment and Mapping	Additional Detail
171	MGRA	4	MGRA Data Request No. 4	4	MGRA Data Request No. 4_4	Specify how consequences are assigned from the VIIRS fires to the Cal Fire fire outcome data set. Is this assignment based on a specific mapping, on averages, or on a Monte Carlo?	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0		7.3.1	Risk Assessment and Mapping	Additional Detail
172	MGRA	4	MGRA Data Request No. 4	5	MGRA Data Request No. 4_5	PG&E states that: "The seasonal P(ignition) value are the result of marginalizing daily P(ignition/outage) values across days from historic fire seasons (i.e. based on daily weather and fuel conditions) to produce a seasonal value derived from daily estimates." Is the seasonal P(ignition) multiplied by a seasonal estimate of consequence scores to obtain a seasonal risk score for each driver? Or is the daily (ignition/outage) multiplied by the daily consequence score, and the risk score averaged over season? If neither of these mechanisms explain risk scoring provide additional detail.	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0		7.3.1	Risk Assessment and Mapping	Additional Detail
173	MGRA	4	MGRA Data Request No. 4	6	MGRA Data Request No. 4_6	Q01. In section 7.3.2.2.6, Distribution Arcing Fault Signature Library, PG&E described completing an R&D project at the end of 2021, and the AH&PC team performed a strategic assessment of the results. PG&E then determined that the outcome of the pilot was not sufficient to develop a comprehensive fault signature library applicable to the larger incipient fault analytics tools that will be used to proactively detect and mitigate conditions that might result in a wildfire. And that no future actions are planned at this time. a) Please provide the details from the assessment of the results from the R&D project and what the limitations were that lead to the decision to no longer pursue the initiative.	Joseph Mitchell on behalf of MGRA	4/1/2022	4/5/2022	4/5/2022	0		7.3.1	Risk Assessment and Mapping	Additional Detail
174	OEIS	Set 008	OEIS-PG&E-22-008	1	OEIS-PG&E-22-008_1	Q02. In WMP-Discovery2022_DR_CalAdvocates_014-Q09 PG&E states that "some in-progress projects are forecasted in service towards the end of 2022" regarding transmission hardening projects. a) Provide the mileage of projects described to be forecasted. b) Explain why PG&E has decreased its transmission system hardening mileage from 104 in 2021 to 32 in 2022. i. Include any description of impacts from PG&E's 2021 reprioritization based on 2021 WMP model as well as resource changes to distribution. c) Regarding PG&E's asset inspections: a) What percentage of inspections are completed by contractors vs. internally by PG&E employees? b) Provide a list of contractors used for asset inspections. c) How does training for contractors performing inspections differ from internal PG&E personnel? d) Provide the find rate for QA/QC of inspections performed by contractors. e) Provide documentation and procedures for PG&E's QA/QC process for asset inspections. f) Provide the number of inspectors that performed detailed asset inspections in 2021. g) Provide the number of detailed asset inspections performed by inspectors in 2021. h) Provide the average circuit mile per inspector per day completed for detailed asset inspections in 2021.	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	0		7.3.2.2.6	Situational Awareness and Forecasting	Distribution Arcing Fault Signature Library
175	OEIS	Set 008	OEIS-PG&E-22-008	2	OEIS-PG&E-22-008_2	Q04. Provide the geospatial files for the HFRA modifications shown on pg. 77 of PG&E's 2022 WMP Update.	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	0		7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
176	OEIS	Set 008	OEIS-PG&E-22-008	3	OEIS-PG&E-22-008_3	Q05. In CalAdvocates_007-Q01, PG&E states that it "completed over 210 miles of distribution system hardening, with approximately 66% of these circuits falling within the highest risk miles defined as the top 20% of the risk buydown curve, fire re-build miles, and PSPS mitigation miles." a) What is the percentage specifically that falls into each of the following respective categories? i. Top 20% of the risk buydown curve ii. PSPS impacted locations iii. Locations where risk has materialized/historic wildfire locations iv. PSPS-identified locations. b) Where was the remaining 34% completed? c) What is PG&E's plan to meet the 80% threshold moving forward (i.e., approximate percentages in top risk per year)?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	1		7.3.4	Asset Management and Inspections	Additional Detail
177	OEIS	Set 008	OEIS-PG&E-22-008	4	OEIS-PG&E-22-008_4	Q06. In PG&E's 2022 WMP update, in section 7.3.7.4, PG&E discloses that it conducted an audit of work tracking databases which identified ignitions which had not been reported, "increasing PG&E's reportable ignition record by 23 percent." Regarding this audit, Energy Safety would like to know: a) Was any type of internal report on the audit prepared? i. If so, please provide a copy. b) PG&E's WMP update states that the audit led to "several corrective actions" but does not describe them - what were those specific actions? c) What is the temporal scope of ignitions not originally reported that were discovered? d) Does the spatial distribution of discovered ignitions show any pattern (are ignitions that were originally missed concentrated in certain areas, or distributed differently from ignitions that were originally reported)? e) Were the discovered ignitions attributable to a particular cause or set of causes? f) Was the distribution of causes different for ignitions that were missed compared to those that were originally reported? g) Were any of PG&E's models that use ignitions as an input re-run with these additional ignitions included? If so, did model results change? i. If so, what were any further effects of those changes?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	1		4.2.1	Lessons Learned and Risk Trends	Service Territory Fire-Threat Evaluation and Ignition Risk Trends
178	OEIS	Set 008	OEIS-PG&E-22-008	5	OEIS-PG&E-22-008_5	Q07. In response to Data Request OEIS-PG&E-2022-001, Question 5a, PG&E states that it re-evaluated its 2021 [Maturity Survey] response related to communications tools (Question F.VI.b). PG&E also states, "because of the communications challenges in certain parts of our service territory, the current and future state [maturity] scores were reduced back to (iii)." a) What "communications challenges", specifically, is PG&E having that resulted in its reduced maturity score? b) Which portions of PG&E's service territory do these communications challenges apply? c) What is PG&E doing to provide the best chance?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	0		7.3.3.17.1	Grid Design and System Hardening	System Hardening
179	OEIS	Set 008	OEIS-PG&E-22-008	6	OEIS-PG&E-22-008_6	Q08. On 7/7/2022 PG&E states that it projected a need to hire approximately 40 Linemen and 100 Apprentices each year for the next five years, based on an internal demand and supply review. On p. 788 of PG&E's 2022 WMP Update, PG&E states that its hired 41 Linemen and 123 Apprentice Linemen, exceeding its target for staffing for support service restoration by 1 Lineman and 23 Apprentice Linemen. a) Given that PG&E exceeded its 2021 target for service restoration staffing, will PG&E be reducing its hiring of Linemen and Apprentice Linemen in 2022? i. Or will PG&E continue its hiring goal of "40 Linemen and 100 Apprentices each year for the next five years?" b) How many Linemen and Apprentice Linemen has PG&E hired in 2022 so far and how many does PG&E plan to hire in 2022?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	2		7.3.7.4	Data Governance	Documentation and disclosure of wildfire-related data and algorithms
180	OEIS	Set 008	OEIS-PG&E-22-008	7	OEIS-PG&E-22-008_7	Q09. Based on analysis of information reported in the WMP, PG&E reports a \$530 million increase in vegetation management category initiatives over the amount projected for 2022 in the 2021 WMP Update. a) What accounts for the \$530 million increase in vegetation management category initiatives? b) Did it go up because of increase undergrounding miles?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	0		N/A	Miscellaneous	Maturity Survey
181	OEIS	Set 008	OEIS-PG&E-22-008	8	OEIS-PG&E-22-008_8	Q10. In response to data request CalAdvocates-PGE-2022-WMP-17, question 7, PG&E said, "For 2021, approximately 96% of covered conductor projects included pole replacements." Among the 96% of covered conductor projects in 2021 that did involve pole replacements, what percentage of poles were replaced, on average?	Kevin Miller	4/1/2022	4/6/2022	4/6/2022	0		7.3.9.1	Emergency Planning and Preparedness	Adequate and Trained Workforce for Service Restoration
182	CalPA	Set WMP-20	CalAdvocates-PGE-2022WMP-20	1	CalAdvocates-PGE-2022WMP-20_1	On average, how many poles per circuit-mile exist on bare-wire distribution circuits in HFTD?	Holly Wherman Carolyn Chen Layla Labagh	4/5/2022	4/8/2022	4/11/2022	0		7.3.3.6	Grid Design and System Hardening	Distribution Pole Replacement and Reinforcement, Including with Composite Poles
183	CalPA	Set WMP-20	CalAdvocates-PGE-2022WMP-20	2	CalAdvocates-PGE-2022WMP-20_2	On average, how many poles per circuit-mile exist on covered conductor distribution circuits in HFTD?	Holly Wherman Carolyn Chen Layla Labagh	4/5/2022	4/8/2022	4/11/2022	0		7.3.3.6	Grid Design and System Hardening	Distribution Pole Replacement and Reinforcement, Including with Composite Poles
184	OEIS	Set 009	OEIS-PG&E-22-009	1	OEIS-PG&E-22-009_1	Q01. Based on analysis of information reported in the WMP, PG&E reports a \$530 million increase in vegetation management category initiatives over the amount projected for 2022 in the 2021 WMP Update. a) What accounts for the \$530 million increase in vegetation management category initiatives?	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	0		7.3.5	Vegetation Management (VM) and Inspections	Program Cost Projection
185	OEIS	Set 009	OEIS-PG&E-22-009	2	OEIS-PG&E-22-009_2	Q02. Based on analysis of information reported in the WMP, PG&E reports an increase of \$198 million in Grid Design and System Hardening category initiatives over the amount projected for 2022 in the 2021 WMP Update. a) What accounts for the \$198 million increase in Grid Design and System Hardening category initiatives? b) Did it go up because of increase undergrounding miles?	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	1		7.3.3	Grid Design and System Hardening	Program Cost Projection
186	OEIS	Set 009	OEIS-PG&E-22-009	3	OEIS-PG&E-22-009_3	Q03. Table 12 shows zero spending for the undergrounding Grid Hardening Initiative 7.3.3.16 Undergrounding of electric lines and/or equipment (Row 61). a) What accounts for zero spending on undergrounding initiatives in Table 12? b) Provide expenditures for undergrounding initiatives for 2022. c) If this information is elsewhere in the WMP, please provide where it can be found. If it is aggregated with another program, please de-aggregate and provide this expenditure for undergrounding only.	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	0		7.3.3.16	Grid Design and System Hardening	Undergrounding
187	OEIS	Set 009	OEIS-PG&E-22-009	4	OEIS-PG&E-22-009_4	Q04. Table 12 shows zero spending for the undergrounding Grid Hardening 7.3.3.3 Covered conductor installation (Row 38). a) What accounts for zero spending on covered conductor initiatives in Table 12? b) Provide expenditures for undergrounding initiatives for 2022. c) If this information is elsewhere in the WMP, please provide where it can be found. If it is aggregated with another program, please de-aggregate and provide this expenditure for covered conductor only.	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	0		7.3.3.3	Grid Design and System Hardening	Covered Conductor Installation
188	OEIS	Set 009	OEIS-PG&E-22-009	5	OEIS-PG&E-22-009_5	Q05. Based on analysis of information reported in the WMP, spending in the data governance initiative category decreased by \$53 million compared to the amount projected for the 2021 WMP Update. a) What accounts for the \$53 million decrease in data governance initiative spending?	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	0		7.3.7	Data Governance	Program Cost Projection

189	OEIS	Set 009	OEIS-PG&E-22-009	6	OEIS-PG&E-22-009_6	Q06: Provide the following information regarding PSPS Distribution sectionalizing devices: a) The average number of sectionalizing devices per circuit mile. b) PG&E's goal for number of sectionalizing devices per circuit mile. c) The average number of customers per sectionalizing device. d) The range of numbers of customers per sectionalizing device (i.e., minimum and maximum). e) The median number of customers per sectionalizing device. f) PG&E's goal for maximum number of customers per sectionalizing device.	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	0	7.3.3.8.1	Grid Design and System Hardening	Distribution Sectionalizing Devices
190	OEIS	Set 009	OEIS-PG&E-22-009	7	OEIS-PG&E-22-009_7	Q07: In PG&E's 2022 WMP update, in section 7.3.7.4, PG&E reports that it conducted an audit of work tracking databases which identified ignitions which had not been reported. Energy Safety asked several questions pertaining to this audit in data request OEIS 008 Question #6, including the following (item b): "PG&E's WMP update states that the audit led to "several corrective actions" but does not describe them – what were those specific actions?" PG&E's response to this was as follows: To reduce the occurrence of missed ignitions, the following actions have been taken: • PG&E partnered with IT to implement revisions to Field Automation System (FAS) to better self-guide the restoration team to identify ignition events – these enhancements were deployed in June 2021; • PG&E partnered with Dispatch and Scheduling on upcoming communications to the field regarding the usage of FAS to capture ignition events; • PG&E partnered with the Asset Failure Analysis team on the field data collection improvement pilot; • PG&E worked with the academy to implement an annual training requirement related to the use of the CPUC fire tab per our standards (RISK-6306S); • PG&E incorporated the review of all potential ignition related FAS tags into the scope of the Ignitions Investigations Team; • PG&E revised the RISK 6306-01 standard to include lessons learned from this audit as well as processes related to the ongoing review of FAS for potential missed ignitions. Energy safety requests the following items: a) Provide any available documentation on the "field data collection" please, provide the name and title of the responding individuals (i.e., the person responsible for the content of your answer) for each piece of information requested. If the responding individual is not your employee, please provide their name, title, and employer, as well as the name and title of your employee who is directly responsible for the work of the responding individual. As part of the wildfire mitigation plan proceeding and in preparation for my reply comments, I am requesting information about all the work performed on the "Geysers #9 Lakeville" since the Kincade Fire in 2019. I am concerned that the causes of that wildfire were not sufficiently addressed and mitigated within the proposed 2022 Wildfire Mitigation Plan. This information should include but is not limited to the following work noted within attachment #1 ("2022-02-25_PGE_2022_WMP-Update_RO_Section 4.6_Remedies 5.4.B_Atch01"):	Kevin Miller	4/8/2022	4/13/2022	4/13/2022	2	7.3.7.4	Data Governance	Documentation and disclosure of wildfire related data and algorithms
191	Will Abrams	Set 01	WillAbrams-Set 01	1	WillAbrams-Set 01_1	1. Notification Date 2/15/2021 - All work pertaining to lines 217, 218, 219, 220 with "notification items_object" listed as "emergency" and "notification items_damage" listed as "fire" with "notification items_action" listed as "replace." 2. Notification date 2/16/2021 - All work pertaining to lines 221, 222 with "notification items_object" listed as "emergency" and "notification items_damage" listed as "fire" with "notification items_action" listed as "replace." 3. Notification date 4/23/2020 - All work pertaining to lines 227 with "notification items_object" listed as "Damper-Steel" and "notification items_damage" listed as "missing" with "notification items_action" listed as "install." 4. Notification date 9/16/2021 - All work pertaining to lines 672, 1532, 1533, 2618, 2619, 3519, 3520, 4450, 4451 with "notification items_object" listed as "Emergency" and "notification items_damage" listed as "Fire" with	Will Abrams	4/11/2022	4/14/2022	4/14/2022	1	4.6	Miscellaneous	5.4B Corrective Actions
192	Will Abrams	Set 02	WillAbrams-Set 02	1	WillAbrams-Set 02_1	Q: (a) How has PG&E mitigated this to ensure that isolators are secured throughout their infrastructure and not swinging and causing sparks and catastrophic wildfires? (b) Has PG&E made efforts to mitigate the swinging of vertical insulator strings now that this has been identified as a cause of catastrophic wildfire? (c) What has PG&E changed in terms of their inspections and other mitigation activities to ensure this type of wildfire ignition never happens again?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair, and Replacement
193	Will Abrams	Set 02	WillAbrams-Set 02	2	WillAbrams-Set 02_2	Q: How has PG&E mitigated these microclimate/wind effects by placing wind sensors at different elevations to pick up on these variations that contributed to Kincade Fire ignitions? Are wind sensors now placed closer to these towers to pick up these types of variations?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.2.1.3	Situational Awareness and Forecasting	Weather Stations
194	Will Abrams	Set 02	WillAbrams-Set 02	3	WillAbrams-Set 02_3	Q: Has PG&E identified how they have mitigated these issues associated with line terminations? How does PG&E now ensure line terminations are secured and not causing similar fires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	1	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
195	Will Abrams	Set 02	WillAbrams-Set 02	4	WillAbrams-Set 02_4	Q: What mitigation has PG&E done to ensure old "spaghetti" wires like those indicated are not left dangling and causing fire risk across their infrastructure?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
196	Will Abrams	Set 02	WillAbrams-Set 02	5	WillAbrams-Set 02_5	Q: What operational practices and QA has PG&E incorporated into their risk mitigation to ensure old wires are not left abandoned on the ground around infrastructure?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
197	Will Abrams	Set 02	WillAbrams-Set 02	6	WillAbrams-Set 02_6	Q: How has PG&E modified their vegetation management practices to accommodate slope as a factor that could lead to fire spread from their infrastructure? If a pole, tower or line segment is situated on a similar "upslope" how is PG&E mitigating the increased fire risk?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
198	Will Abrams	Set 02	WillAbrams-Set 02	7	WillAbrams-Set 02_7	Q: Given these findings and the increased fire risk on "south-facing slopes", has PG&E modified their vegetation management practices to ensure this type of topography is treated differently or more regularly given the lower moisture content?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.2.1.2	Situational Awareness and Forecasting	Fuel Moisture Sampling and Modeling [could also go to VM?]
199	Will Abrams	Set 02	WillAbrams-Set 02	8	WillAbrams-Set 02_8	Q: It is clear that the rust and neglect of the line caused a "shower of sparks." What has PG&E done to mitigate rust and corrosion on infrastructure that causes this shower effect with multiple ignition sources?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
200	Will Abrams	Set 02	WillAbrams-Set 02	9	WillAbrams-Set 02_9	Q: Given this evidence that ember cast from transmission towers are "going to drift", what has PG&E done to alter their vegetation management practices around transmission towers? Where is this within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
201	Will Abrams	Set 02	WillAbrams-Set 02	10	WillAbrams-Set 02_10	Q: What additional risk mitigation practices has PG&E implemented to ensure that jumpers are secured and not left "dangling" and susceptible to wind? Are rigid jumpers now more often used? What added inspection criteria have been added so this never leads to another catastrophic fire again?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair, and Replacement
202	Will Abrams	Set 02	WillAbrams-Set 02	11	WillAbrams-Set 02_11	Q: How has PG&E mitigated these wildfire risks to ensure cooling towers are properly decommissioned or moth balled in response to these failures?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
203	Will Abrams	Set 02	WillAbrams-Set 02	12	WillAbrams-Set 02_12	Q: Given this "primary concern," what added risk mitigation practices has PG&E implemented to address power plant vegetation management and metal recycling procedures?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.5.5	Vegetation Management (VM) and Inspections	Fuel Management and Management of All Wood and "Slash" From Vegetation Management Activities
204	Will Abrams	Set 02	WillAbrams-Set 02	13	WillAbrams-Set 02_13	Q: What risk mitigation has PG&E done to ensure decommissioned or moth balled lines are not energized and connected to power plants? How have inspection practices changed to ensure these failures are not repeated?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
205	Will Abrams	Set 02	WillAbrams-Set 02	14	WillAbrams-Set 02_14	Q: Given that this "low cycle fatigue" was identified as a primary cause of the Kincade Fire, has PG&E reflected and corrected that issue within their WMP? Is added testing performed and/or different quality assurance checks to mitigate these risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	N/A	N/A	N/A
206	Will Abrams	Set 02	WillAbrams-Set 02	15	WillAbrams-Set 02_15	Q: Given these failures to deal with abandoned infrastructure, how has PG&E identified the added mitigation activities since the Kincade Fire? How does PG&E now treat "abandoned" infrastructure differently within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
207	Will Abrams	Set 02	WillAbrams-Set 02	16	WillAbrams-Set 02_16	Q: What has PG&E done to ensure security fencing around their infrastructure is inspected and maintained given these findings? How does PG&E mitigate the security dangers of poorly maintained fencing?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
208	Will Abrams	Set 02	WillAbrams-Set 02	17	WillAbrams-Set 02_17	Q: What has PG&E done to mitigate the risks of misconfigured jumpers? Does PG&E now cut these within the manufacturing facility to ensure proper length and configuration?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.5	Grid Design and System Hardening	Crossarm Maintenance, Repair, and Replacement
209	Will Abrams	Set 02	WillAbrams-Set 02	18	WillAbrams-Set 02_18	Q: What has PG&E done to mitigate these risks and ensure that wires are secured and inspected within the shoe and do not come loose to cause future catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.12	Asset Management and Inspections	Patrol inspections of transmission electric lines and equipment
210	Will Abrams	Set 02	WillAbrams-Set 02	19	WillAbrams-Set 02_19	Q: Given that the Saw Mill Fire pointed to the same or very similar infrastructure failures and mismanagement patterns as the Kincade Fire has PG&E finally included mitigation activities for these issues within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
211	Will Abrams	Set 02	WillAbrams-Set 02	20	WillAbrams-Set 02_20	Q: Given that wind readings were different on the surface vs. up on poles and towers and these differences contributed to the miscalculations and causes of both the Sawmill and Kincade Fires, has PG&E accounted for different wind sensor placement of wind (ground-level vs. high up on tower) within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.2.1.3	Situational Awareness and Forecasting	Weather Stations

212	Will Abrams	Set 02	WillAbrams-Set 02	21	WillAbrams-Set 02_21	Q: Given all these similar causes (loose wires, low-cycle fatigue, wind conditions, etc.) between the Sawmill Fire and the Kincaide Fire why did PG&E still not mitigate these causes and include those mitigation tactics within their WMP? Given this failure pattern, why did PG&E state over and over again that the Kincaide Fire was a "black swan"? Why did Bill Johnson, CEO dismissively state that "sometimes things just break" in reference to the Kincaide Fire given this pattern and the clear failure of PG&E policies and practices?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
213	Will Abrams	Set 02	WillAbrams-Set 02	22	WillAbrams-Set 02_22	Q: When outside oversight agencies provide direction like "make sure those wires are secured" how does PG&E now make sure those instructions are documented and addressed? Where are these issues addressed in the PG&E WMP given that staff repeatedly did not heed these instructions?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.12	Asset Management and Inspections	Patrol inspections of transmission electric lines and equipment
214	Will Abrams	Set 02	WillAbrams-Set 02	23	WillAbrams-Set 02_23	Q: How has PG&E modified their inspection practices and noted those changes within their WMP given that these inspections did not successfully catch the many failures in configuration and maintenance practices that caused the Kincaide Fire?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.10	Asset Management and Inspections	Other discretionary inspection of transmission electric lines and equipment, beyond inspections mandated by rules and regulations
215	Will Abrams	Set 02	WillAbrams-Set 02	24	WillAbrams-Set 02_24	Q: How has PG&E improved their policies and wildfire mitigation practices to more closely work with partners like CalPine to ensure access and maintenance issues do not impact safe operations of PG&E equipment?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
216	Will Abrams	Set 02	WillAbrams-Set 02	25	WillAbrams-Set 02_25	Q: Given the ambiguity of "NA" meaning "not present" has PG&E revised their inspection forms to have less ambiguous and more accurate infrastructure evaluation and risk scoring? Are any changes reflected within their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
217	Will Abrams	Set 02	WillAbrams-Set 02	26	WillAbrams-Set 02_26	Q: How has PG&E mitigated these risks to ensure "spewing steam" from cooling towers doesn't cause arcing as was identified as a "constant source of entertainment"? Where in the PG&E WMP does it reference changed mitigation practices due to this new information?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
218	Will Abrams	Set 02	WillAbrams-Set 02	27	WillAbrams-Set 02_27	Q: Is this practice of "covering the insulators with silicone grease" the approved mitigation tactic of PG&E? If so, how is that reflected in their WMP and if not how has this poor maintenance practice been corrected?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
219	Will Abrams	Set 02	WillAbrams-Set 02	28	WillAbrams-Set 02_28	Q: Is this practice of waiting till there is a "solid line of arcing" a prudent wildfire mitigation practice during the nighttime when moisture content causes frequent arcing? If so, where is this referenced in the PG&E WMP? If not, how has PG&E corrected this flawed practice?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	1	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
220	Will Abrams	Set 02	WillAbrams-Set 02	29	WillAbrams-Set 02_29	Q: Is PG&E comfortable with this haphazard alerting practice or does a more standardized arcing alert need to be ingrained within their WMP and associated operations?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
221	Will Abrams	Set 02	WillAbrams-Set 02	30	WillAbrams-Set 02_30	Q: Is PG&E still injecting iron into cooling systems? If so, how is PG&E mitigating these "higher level" contamination risks and wildfire risks? How is this reflected within their WMP given that is a cause or a contributor of catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
222	Will Abrams	Set 02	WillAbrams-Set 02	31	WillAbrams-Set 02_31	Q: Given that extreme corrosiveness is associated with towers close to power plants, how has PG&E mitigated risks specific to these towers? What WMP standards have been created to mitigate these risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3 (and possible 1.1 Verification; Group B section 1)	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
223	Will Abrams	Set 02	WillAbrams-Set 02	32	WillAbrams-Set 02_32	Q: Are these "Scotch-Brite and heliwash" practices still employed for cleaning insulators? Has this been standardized or do crew supervisors still have discretion of when to wash or replace? What WMP practices have standardized these practices given the known wildfire risks?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	2	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
224	Will Abrams	Set 02	WillAbrams-Set 02	33	WillAbrams-Set 02_33	Q: Has PG&E standardized around polymer insulators as part of their wildfire mitigation activities? What percentage of PG&E insulators are still the old ceramic type? Why is this not mentioned within the WMP when it was a leading cause or contributing factor of catastrophic wildfires?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
225	Will Abrams	Set 02	WillAbrams-Set 02	34	WillAbrams-Set 02_34	Q: Has PG&E standardized to 2 year lifecycle for changing insulators? Has PG&E set standards in their WMP for insulator inspections to determine replacement given the risk of wildfire ignitions?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.4.3	Asset Management and Inspections	Improvement of Inspections
226	Will Abrams	Set 02	WillAbrams-Set 02	35	WillAbrams-Set 02_35	Q: Do line crew supervisors still have the authority to "mothball" infrastructure with direction from outside sources? How has PG&E implemented corrective actions given the wildfire risks associated with how infrastructure is decommissioned or mothballed?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Other corrective action, Maintenance, Transmission
227	Will Abrams	Set 02	WillAbrams-Set 02	36	WillAbrams-Set 02_36	Q: Why isn't decommissioning infrastructure requiring an engineering consult? Given the evident wildfire risk has PG&E required engineering consults and direction on a going forward basis as part of their WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
228	Will Abrams	Set 02	WillAbrams-Set 02	37	WillAbrams-Set 02_37	Q: Given that this motion of the insulator string caused or contributed to the Kincaide Fire has PG&E now measured these movements and identified wildfire mitigation practices and quality controls to remedy?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
229	Will Abrams	Set 02	WillAbrams-Set 02	38	WillAbrams-Set 02_38	Q: Is engineering design now required for these types of mothballing practices? Why is this not reflected within the WMP given the wildfire risk?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
230	Will Abrams	Set 02	WillAbrams-Set 02	39	WillAbrams-Set 02_39	Q: Given the subsequent catastrophic fire, does PG&E now require an "engineering reference" for this type of line configuration work? Why are these standards not set in the WMP?	Will Abrams	4/13/2022	4/25/2022	4/25/2022	0	7.3.3.12.3	Grid Design and System Hardening	Maintenance, Transmission
231	OEIS	Set 10	OEIS-PG&E-22-010	1	OEIS-PG&E-22-010_1	In the Section 8.2.3.7 PG&E describes its use of the risk vs. benefit tool in four events in 2021 to support the evaluation of the potential public safety risk due to a PSPS event against the forecasted potential wildfire risk. a. To date, did PG&E use the risk-benefit tool for determining to initiate any events that did not result in a PSPS event?	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	0	8.2.3.7	PSPS	PSPS Risk-Benefit Tool
232	OEIS	Set 10	OEIS-PG&E-22-010	2	OEIS-PG&E-22-010_2	Regarding PG&E's attachment CONFIDENTIAL_PGE_2022-WMP_Section_46_Remedies_2114_Atch01_CONF to the 2022 WMP Update: a. Concerning the project type "Community Wildfire Safety Program for projects aimed for 2022-2023": i. Describe this project type, including where more information about this project type is described within the 2022 WMP (or previous WMPs, if applicable). ii. How were the projects that fall under this project type selected and prioritized? iii. How does this project type overlap and/or align with risk model output? iv. Provide a percentage of projects under CWSP that align with the top 20% risk score output from the 2021 Wildfire Distribution Risk Model. b. How does this project type differ from the following: Top 20% MAVF CPZ, Top 250 miles, and Top 50 Miles? Currently, this data is showing around 0.82 miles planned for undergrounding in 2024. i. Is this still accurate? ii. If not, provide the updated mileage. iii. If so, when does PG&E intend to select locations for additional undergrounding miles? iv. If locations are not currently selected, how is PG&E planning on expediting undergrounding for completion in 2024? v. Are the locations for grid hardening, as a whole, selected for 2024 (i.e., know the hardening location, but don't know the hardening initiative that will be used, UG vs. OH)? vi. If so, is it possible to provide an amended response including these changes? On page 870, PG&E indicates potential reductions in PSPS event size in 2022 are expected to come from planned mitigations and "PG&E is currently still in the process of finalizing locations for certain 2022 mitigations but anticipates the following mitigations to come online in 2022. These include: - Distribution Sectionalizing Devices - Transmission Sectionalizing Devices - Temporary Distribution Microgrids - Distribution System Hardening - Fixed Power Solutions (FPS) In a footnote on the same page, PG&E indicates "Some mitigation programs require more than a year of lead time to execute. As a result, some of the mitigations expected to be available in 2022 were identified using earlier data, including the 2020 lookback." This would seem to indicate at least some selections would have had to have been made previously. a. When does PG&E plan to have these remaining locations finalized? b. Please provide currently available locations for those which have been finalized as a GIS file (.gdb)? c. How will it determine locations are in the highest risk areas for PSPS? d. For each of the above-listed mitigations, please provide a percentage of projects that align with top risk, defined as: i. The top 20% risk score output from the 2021 Wildfire Distribution Risk Model ii. PSPS Impacted Locations iii. Locations where risk has materialized iv. PSPS Impacted Locations In response to OEIS-PG&E-22-007 Question 16, PG&E states that it "utilized the decision tree presented in 2021 for the 2022 scope of work." a. Is this in reference to the decision-tree provided in response to PG&E-Remedies-21-14 as part of the 2021 WMP Progress Report? b. How and where does PG&E's risk modeling output inform decision-making in relation to the decision-tree discussed in part (a)? c. When was this decision-making process first implemented? d. How does this align and/or differ with the system hardening decision-making methodology presented on May 21, 2021, to the Wildfire Safety Division (titled PG&E's System Hardening Program)? e. What changes to PG&E's decision-making have been made since the May 21, 2021 presentation to the Wildfire Safety Division? In Table 3.3-1(A) of PG&E's 2022 WMP Update, PG&E shows a decrease in targets for implementing sectionalization devices both at the distribution and transmission levels. For distribution, PG&E's targets decreased from 250 in 2021 to 100 in 2022. For transmission, PG&E's targets decreased from 29 in 2021 to 15 in 2022.	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	0	4.6	Grid Design and System Hardening	System Hardening
233	OEIS	Set 10	OEIS-PG&E-22-010	3	OEIS-PG&E-22-010_3	In response to OEIS-PG&E-22-007 Question 16, PG&E states that it "utilized the decision tree presented in 2021 for the 2022 scope of work." a. Is this in reference to the decision-tree provided in response to PG&E-Remedies-21-14 as part of the 2021 WMP Progress Report? b. How and where does PG&E's risk modeling output inform decision-making in relation to the decision-tree discussed in part (a)? c. When was this decision-making process first implemented? d. How does this align and/or differ with the system hardening decision-making methodology presented on May 21, 2021, to the Wildfire Safety Division (titled PG&E's System Hardening Program)? e. What changes to PG&E's decision-making have been made since the May 21, 2021 presentation to the Wildfire Safety Division? In Table 3.3-1(A) of PG&E's 2022 WMP Update, PG&E shows a decrease in targets for implementing sectionalization devices both at the distribution and transmission levels. For distribution, PG&E's targets decreased from 250 in 2021 to 100 in 2022. For transmission, PG&E's targets decreased from 29 in 2021 to 15 in 2022.	Kevin Miller	4/15/2022	4/20/2022	4/20/2022	1	8.1.4	PSPS	Future Plans
234	OEIS	Set 11	OEIS-PG&E-22-011	1	OEIS-PG&E-22-011_1	In response to OEIS-PG&E-22-007 Question 16, PG&E states that it "utilized the decision tree presented in 2021 for the 2022 scope of work." a. Is this in reference to the decision-tree provided in response to PG&E-Remedies-21-14 as part of the 2021 WMP Progress Report? b. How and where does PG&E's risk modeling output inform decision-making in relation to the decision-tree discussed in part (a)? c. When was this decision-making process first implemented? d. How does this align and/or differ with the system hardening decision-making methodology presented on May 21, 2021, to the Wildfire Safety Division (titled PG&E's System Hardening Program)? e. What changes to PG&E's decision-making have been made since the May 21, 2021 presentation to the Wildfire Safety Division? In Table 3.3-1(A) of PG&E's 2022 WMP Update, PG&E shows a decrease in targets for implementing sectionalization devices both at the distribution and transmission levels. For distribution, PG&E's targets decreased from 250 in 2021 to 100 in 2022. For transmission, PG&E's targets decreased from 29 in 2021 to 15 in 2022.	Kevin Miller	4/22/2022	4/27/2022	4/27/2022	1	7.3.3	Grid Design and System Hardening	Additional Detail
235	OEIS	Set 11	OEIS-PG&E-22-011	2	OEIS-PG&E-22-011_2	a. Explain why PG&E has decreased its targets from 2021 to 2022 for sectionalization devices for both distribution and transmission. b. Provide any risk/benefit analysis completed for implementing more sectionalization devices for determination of targets. c. Explain how PG&E intends to decrease the number of customers impacted by de-energization (both for EPSS and PSPS) through future sectionalization, including how such analysis is used for determination of targets.	Kevin Miller	4/22/2022	4/27/2022	4/27/2022	0	7.3.3.8.1 7.3.3.8.2	Grid Design and System Hardening	Distribution & Transmission Line Sectionalizing

236	OEIS	Set 11	OEIS-PG&E-22-011	3	OEIS-PG&E-22-011_3	Regarding section 7.3.2.1.3 weather stations: a. Please explain how PG&E has determined 1300 weather stations as its long-term goal for weather stations density. i. Include any weather station to circuit mapping findings PG&E has used to identify any spatial gaps in network. Regarding information in PG&E's Third Errata to its 2022 WMP Update, provided April 25, 2022: a. PG&E has modified its pole clearing program target to inspect and clear (where clearance is needed) all poles identified in PG&E's VM Database, as of October 1, 2021, in HTFD areas or HFRA, not required by PRC 4292. How many poles meet these criteria? b. How many assets have been discovered since October 1, 2021? c. Does PG&E have an estimate for the number of assets it will discover from now to August 31, 2022? i. If so, provide the estimate and an explanation of how that estimate was calculated. d. Why is PG&E extending its target date from April 30, 2022, to October 1, 2022? e. How does a "target due date" differ from the 45-day timeline? f. How many assets discovered since October 1, 2021, have exceeded the 45-day timeline for inspection and clearance? g. How often (percentagewise) has PG&E missed the 45-day deadline due to "External Factors"? h. What is PG&E's plan for discovering assets for inspection and clearance?	Kevin Miller	4/22/2022	4/29/2022	4/29/2022	1		7.3.2.1.3	Situational Awareness and Forecasting	Weather monitoring
237	OEIS	Set 12	OEIS-PG&E-22-012	1	OEIS-PG&E-22-012_1	Regarding information in PG&E's Third Errata to its 2022 WMP Update, provided April 25, 2022: a. PG&E has modified its pole clearing program target to inspect and clear (where clearance is needed) all poles identified in PG&E's VM Database, as of October 1, 2021, in HTFD areas or HFRA, not required by PRC 4292. How many poles meet these criteria? b. How many assets have been discovered since October 1, 2021? c. Does PG&E have an estimate for the number of assets it will discover from now to August 31, 2022? i. If so, provide the estimate and an explanation of how that estimate was calculated. d. Why is PG&E extending its target date from April 30, 2022, to October 1, 2022? e. How does a "target due date" differ from the 45-day timeline? f. How many assets discovered since October 1, 2021, have exceeded the 45-day timeline for inspection and clearance? g. How often (percentagewise) has PG&E missed the 45-day deadline due to "External Factors"? h. What is PG&E's plan for discovering assets for inspection and clearance?	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0		7.3.5.2	Detailed Inspections and Management Practices for Vegetation Clearances	Pole Clearing
238	OEIS	Set 12	OEIS-PG&E-22-012	2	OEIS-PG&E-22-012_2	Regarding PG&E's implementation of EPSS? a. How many customer complaints has PG&E received regarding EPSS since implementation in June 2021? Provide a breakdown of number by month. b. What lessons learned has PG&E implemented as a result of EPSS-related customer complaints?	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0		7.3.6.8	Grid Operations and Protocols	EPSS
239	OEIS	Set 12	OEIS-PG&E-22-012	3	OEIS-PG&E-22-012_3	Regarding Table 7.2 from PG&E's 2022 WMP Update: a. Why does PG&E project an overall increase in ignitions from 2022 to 2023? b. Why does PG&E project a slight increase in overall ignitions for Tier 2 from 2022 to 2023? c. Why does PG&E project a sustained (no change) number of ignitions for Tier 3 from 2022 to 2023? d. Why does PG&E project a system-wide increase in ignitions from 2022 to 2023 for the following? i. Vegetation contact ii. Capacitor bank damage or failure iii. Conductor damage or failure iv. Fuse damage or failure v. Lightning arrester damage or failure vi. Switch damage or failure vii. Crossarm damage or failure viii. Recloser damage or failure ix. Connection device damage or failure x. Transformer damage or failure xi. Other equipment damage or failure xii. Wire-to-wire contact e. Why does PG&E project an increase in the number of ignitions at the transmission level within Tier 3 for other equipment damage or failure? f. Why does PG&E project a sustained (no change) number of ignitions at the distribution level within the HTFD from 2022 to 2023 for the following? i. Vegetation contact ii. Conductor damage or failure iii. Pole damage or failure iv. Crossarm damage or failure v. Connection device damage or failure	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0		6.7	Performance Metrics and Underlying Data	Recent and Projected Drivers of Ignition Probability
240	OEIS	Set 12	OEIS-PG&E-22-012	4	OEIS-PG&E-22-012_4	On page 915 under "Preparation for Re-Energization" PG&E lists the vegetation management programs which will use the One VM Tool. Energy Safety acknowledges it defined "Future improvements to initiative" as "the next 5 years," i.e., 2022-2028 (2022 Guidelines, Attachment 2, page 74). Energy Safety needs to understand whether "Short-term improvements (2023-2028)" is a standard heading (as it is repeated throughout the WMP) or whether "2023-2028" in this case represents a timeline for deployment of the One VM Tool. a. Confirm that the schedule for deploying the VM One Tool to the listed programs is 2023-2028. i. If yes, does PG&E have a more detailed schedule for deployment? If so, share this schedule. ii. If no, clarify the schedule of the VM One Tool's deployment to the listed programs.	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0		7.3.5.19	Vegetation Management (VM) and Inspections	Vegetation Management Enterprise System
241	OEIS	Set 12	OEIS-PG&E-22-012	5	OEIS-PG&E-22-012_5	On page 915 under "Preparation for Re-Energization" PG&E lists the restoration team's activities leading up to re-energization, including "Determine if any Customer Owned Lines identified as being at risk are within the event footprint (both transmission and distribution) as detailed in Section 7.3.6.4. These are then isolated either during segmenting activities or during patrols, but in either case, prior to re-energization." a. Please explain what criteria is used to determine whether Customer Owned Lines are at risk. b. How does this new initiative further reduce wildfire ignition risk during the EPSS restoration process?	Kevin Miller	4/29/2022	5/4/2022	5/4/2022	0		8.2.4	Protocols on PSPS	Re-Energization Strategy
242	OEIS	Set 13	OEIS-PG&E-22-013	1	OEIS-PG&E-22-013_1	Regarding information in its Fourth Errata to its 2022 WMP Update, provided April 29, 2022, PG&E has modified the number of circuits from 988 to 1,018 and introduced language to indicate that the May 1st and August 1st target dates measure the number of line devices loaded with engineered settings and deleted reference to circuits. a. What is the reason for the increase in circuits identified for EPSS enablement? b. What is the reason for the change of target reframing measurement from circuit to device? i. How has this specifically changed the calculation of percent of target addressing percent of risk? c. Given that focus on devices may overstate or understate the scope of EPSS in terms of miles: i. How many circuit miles will be enabled by EPSS? ii. How is PG&E determining this? iii. How many miles are covered per device when averaged? d. In terms of decision-making to determine the number of devices, how is PG&E quantifying coverage? e. In terms of risk addressed, how is PG&E determining what coverage	Kevin Miller	5/6/2022	5/11/2022	5/11/2022	0		7.3.6.8	Grid Operations and Protocols	Protective Equipment and Device Settings
243	OEIS	Set 14	OEIS-PG&E-22-014	1	OEIS-PG&E-22-014_1	The Wildfire Distribution Risk Model (WDRM) is undergoing third-party review to check for validation. PG&E previously conveyed that the WDRM V3 Validation Report would be published April 29, 2022. Energy Safety requests a copy of this report as soon as it is available. a. In the interim, please provide the planned publication date. Energy Safety would like to know whether there were changes in personnel costs related to WMP between 2021 and 2022. a. If so, please provide this cost differential information. i. Overall ii. By Mitigation Initiative Category of spend: (1) Risk Assessment and Mapping (2) Situational Awareness and Forecasting (3) Grid Design and System Hardening (4) Asset Management and Inspections (5) Vegetation Management and Inspections (6) Grid Operations and Protocols (7) Data Governance (8) Resource Allocation Methodology (9) Emergency Planning and Preparedness (10) Stakeholder Cooperation and Community Engagement b. Which mitigation initiatives have experienced increases in spend?	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0		4.5	Model and Metric Calculation Methodologies	Wildfire Distribution Risk Model
244	OEIS	Set 14	OEIS-PG&E-22-014	2	OEIS-PG&E-22-014_2	Regarding further breakdown of personnel changes: a. Does PG&E have a plan and resources to hire 100 employees for North Counties and another 100 for Sonoma County for WMP implementation? b. To which departments or programs would these positions be allocated? c. Would these positions be full time employees or contractors? d. What is the ratio of employees to contractors for North Counties and Sonoma County?	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0		3.1	Actuals and Planned Spending for Mitigation Plan	Summary of WMP initiative expenditures
245	OEIS	Set 14	OEIS-PG&E-22-014	3	OEIS-PG&E-22-014_3	Regarding further breakdown of personnel changes: a. Does PG&E have a plan and resources to hire 100 employees for North Counties and another 100 for Sonoma County for WMP implementation? b. To which departments or programs would these positions be allocated? c. Would these positions be full time employees or contractors? d. What is the ratio of employees to contractors for North Counties and Sonoma County?	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	0		N/A	N/A	N/A
246	OEIS	Set 14	OEIS-PG&E-22-014	4	OEIS-PG&E-22-014_4	Regarding PG&E's Public Safety Specialist (PSS) Program a. Provide how many total Public Safety Specialist positions have been filled for the following years and the counties they were assigned to. i. 2020 ii. 2021 iii. 2022	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	4		7.3.9	Emergency Planning and Preparedness	Additional Detail
247	OEIS	Set 14	OEIS-PG&E-22-014	5	OEIS-PG&E-22-014_5	In its discussion of its EPSS Initiative 7.3.6.8 Protective Equipment and Device Settings (pp. 730-739) SCADA is not mentioned. a. Please discuss how SCADA is being implemented with EPSS enablement. b. How many EPSS devices are currently SCADA-enabled? c. What are PG&E's quarterly goals between now through 2024 for SCADA-enabling additional EPSS devices? d. Has a protocol been developed to centrally coordinate device/circuit assessment/restoration prioritization based upon SCADA communication? i. If so, provide a description of the protocol. ii. If not, provide a description of PG&E's plans to evaluate and implement protocols in the future.	Kevin Miller	5/13/2022	5/18/2022	5/18/2022	1		7.3.6.8	Grid Operations and Protocols	Protective equipment and device settings

248	OEIS	Set 14	OEIS-PG&E-22-014	6	OEIS-PG&E-22-014_6	Regarding PG&E's work orders: a. How many work orders within the HFTD in the past three years have decreased in priority levels? What percentage of total work orders within the HFTD in the past three years does this account for? b. How many work orders within the HFTD in the past three years have increased in priority levels? What percentage of total work orders within the HFTD in the past three years does this account for? c. Provide a spreadsheet of all work orders discussed in parts a and b above, including columns for the following: i. Work order number ii. Work order equipment iii. Work order description iv. HFTD level v. Original priority level vi. New priority level vii. Date for when the work order was created viii. Original due date ix. Date for when the work order changed priority level x. New due date (if changed) xi. Original priority level xii. Cause for change in priority level (i.e. reinspection, etc.) xiii. Associated wildfire risk ranking from modeling output for circuit location	Kevin Miller	5/13/2022	5/18/2022	5/19/2022	1	7.3.4	Asset Management and Inspections	Additional Detail
249	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	1	CalAdvocates-PGE-2022WMP-21_1	With regard to PG&E's undergrounding efforts in the HFTD for wildfire mitigation purposes: a) Describe PG&E's current policy regarding undergrounding of existing service connections when the main lines are moved underground. b) Describe PG&E's current policy regarding the installation of new service connections underground when new main lines are installed underground (e.g. in a fire rebuild project or in new construction). c) Please provide a list of situations in which PG&E would underground the main line, but install or leave the service connection aboveground. d) For each situation in part (c), please explain the factors that would contribute to PG&E's decision not to underground the service connections.	Holly Wherman Carolyn Chen	5/31/2022	6/17/2022	6/15/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail
250	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	2	CalAdvocates-PGE-2022WMP-21_2	What is the average actual cost of installing service connections underground? Please provide this as a cost per foot (or a range of costs per foot, if variable) and state the time period from which this data is drawn.	Holly Wherman Carolyn Chen	5/31/2022	6/14/2022	6/14/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail
251	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	3	CalAdvocates-PGE-2022WMP-21_3	Section 7.3.3.16 of PG&E's 2022 WMP discusses PG&E's plan to underground approximately 10,000 distribution circuit miles in HFTDs. a) When PG&E undergrounds a segment of distribution circuit as part of its 10,000 mile undergrounding plan, does it plan to also underground that circuit's associated service connections? b) When PG&E places or plans to place a circuit's associated service connections underground, does PG&E include the length of those service connections in the 10,000 circuit mile forecast? c) Does the forecasted cost of undergrounding the 10,000 circuit miles discussed in your 2022 WMP include costs of undergrounding associated service connections? d) If the answer to part (c) is yes, please provide a cost estimate for the undergrounding of all service connections included as part of the 10,000 circuit mile forecast.	Holly Wherman Carolyn Chen	5/31/2022	6/17/2022	6/15/2022	0	7.3.3.16	Undergrounding of Electric Lines and/or Equipment	Additional Detail
252	CalPA	Set WMP-21	CalAdvocates-PGE-2022WMP-21	4	CalAdvocates-PGE-2022WMP-21_4	Section 7.3.3.16 of PG&E's 2022 WMP discusses PG&E's Butte County Rebuild Program, which involves undergrounding the distribution within the town of Paradise and lower Magalia. a) Does PG&E install service connections underground as part of the Butte County Rebuild Program? b) If the answer to part (a) is yes, please provide the actual to-date costs of undergrounding service connections as part of the Butte County Rebuild Program. c) If the answer to part (a) is yes, please provide the actual to-date linear feet of service connections that have been undergrounded as part of the Butte County Rebuild Program. d) Please provide the approximate percentage of service connections that have been (to date) installed above ground or left above ground as part of the Butte County Rebuild Program. e) If the answer to part (a) is no, explain all factors that contributed to PG&E's decision not to underground service connections as part of the Butte County Rebuild Program.	Holly Wherman Carolyn Chen	5/31/2022	6/14/2022	6/14/2022	0	7.3.3.17.6	Butte County Rebuild Program	Additional Detail
253	OEIS	Set 15	OEIS-P&GE-22-015	1	OEIS-P&GE-22-015_1	Section 7.3.3.16 of PG&E's 2022 WMP discusses PG&E's Butte County Rebuild Program, which involves undergrounding the distribution within the town of Paradise and lower Magalia. a) Please provide an Excel table with the following information in new columns added to the Excel table PG&E submitted in response to CalAdvocates-PGE-2022WMP-09's Questions 1, 2, and 3: i. Reason for reinspection (if applicable) ii. New due date post-reinspection (if applicable) iii. New prioritization of work order (if it changed) iv. Equipment type b) Also provide a process flow chart illustrating the inspection process or a description of the inspection process from identification of an issue through to resolving it, including the typical timescale. i. Include the length of time between identification to initiation of repair and what triggers initiation of the repair. c) Additionally, identify any interactions with external agencies, including for permitting, including the following for each agency: i. Any barriers to completing work orders due to permitting. ii. A list of all work orders that have been initiated but have been delayed due to permitting. iii. A list of all work orders for which repair has not been initiated due to permitting concerns. iv. A list of all work orders dated in the past year that have been marked as urgent for which a permit was required. (1) Provide the amount of time that elapsed from the identification of the issue to when it became urgent. (2) Note whether the repair was initiated prior to it being marked as urgent.	Kevin Miller	6/3/2022	6/15/2022	6/15/2022	6	7.3.4	Asset Management and Inspections	Additional Detail
254	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	1	CalAdvocates-PGE-2022WMP-22_1	a) On December 9, 2021, was PG&E using the Heli-Saw for wildfire mitigation purposes? b) If the answer to part (a) is yes, please identify the WMP initiative that this activity was part of.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
255	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	2	CalAdvocates-PGE-2022WMP-22_2	When did PG&E first become aware that the Heli-Saw had operated within Wunderlich County Park on December 9, 2021?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
256	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	3	CalAdvocates-PGE-2022WMP-22_3	a) Which public agencies (e.g., CPUC, OEIS, Cal Fire, San Mateo County) did PG&E notify (prior to December 9, 2021) that it planned to operate a Heli-Saw in Wunderlich County Park? b) For each agency in response to part (a), list the date PG&E gave notice to that agency.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
257	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	4	CalAdvocates-PGE-2022WMP-22_4	a) To which public agencies (e.g., CPUC, OEIS, Cal Fire, San Mateo County) did PG&E report that it had operated a Heli-Saw in Wunderlich County Park on December 9, 2021? b) For each agency in response to part (a), list the date PG&E made its report to that agency. c) Please provide copies of all reports to the agencies in response to part (a).	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
258	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	5	CalAdvocates-PGE-2022WMP-22_5	The article states that "PG&E said its Heli-Saw contractor mistakenly strayed several hundred feet into parkland after doing permitted work on nearby private land." a) Who is the Heli-Saw contractor referenced above? b) Please list all Heli-Saw contractors PG&E currently employs. c) Please describe why the Heli-Saw pilot was not aware that the Heli-Saw had passed into county parkland until the Heli-Saw had traveled "several hundred feet into parkland." d) Please describe the specific sequence of events that led to the contractor "mistakenly" straying into Wunderlich County Park. e) Please describe any and all operational failures (including but not limited to violations of Company policies and standards) that PG&E has identified that led to the use of the Heli-Saw in Wunderlich County Park on December 9, 2021.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
259	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	6	CalAdvocates-PGE-2022WMP-22_6	Please provide copies of the results of any internal audits or investigations that PG&E has performed in relation to the operation of the Heli-Saw in Wunderlich County Park on December 9, 2021.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	2	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
260	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	7	CalAdvocates-PGE-2022WMP-22_7	a) Describe PG&E's current protocol for keeping members of the public out of an area where the Heli-Saw is operating. b) Describe all precautions that PG&E takes to protect public safety while the Heli-Saw is operating. c) Describe all precautions the Heli-Saw contractor takes to protect public safety while the Heli-Saw is operating. d) Has PG&E changed its procedures or protocols related to Heli-Saw operation since receiving the Cal Fire notice of violation described in the news story? e) If the answer to part (d) is yes, please list all changes made to the procedures or protocols related to Heli-Saw operation since receiving the Cal Fire notice of violation described in the news story. f) Please provide a copy of all PG&E procedures, job aids, or other guidance documentation related to operation of the Heli-Saw.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
261	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	8	CalAdvocates-PGE-2022WMP-22_8	a) Does PG&E utilize the Heli-Saw in HFTD areas for the purposes of wildfire mitigation? b) If the answer to part (a) is yes, please list all initiatives from PG&E's 2022 WMP Update in which the Heli-Saw has been utilized to date. c) If the answer to part (a) is yes, please list all initiatives from PG&E's 2022 WMP Update in which it expects to utilize the Heli-Saw in the future. d) If the answer to part (a) is yes, why didn't PG&E mention the Heli-Saw in its 2022 WMP Update?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment

262	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	9	CalAdvocates-PGE-2022WMP-22_9	Pages 825-826 of PG&E's 2022 WMP Update discuss community outreach about wildfire mitigation activities, including helicopter operations: To set expectations with customers and with the goal of limiting work refusals or access issues, PG&E uses various communication methods, such as letters, postcards, text messages, e-mails, and automated calls through Interactive Voice Recordings. a) For normal Heli-Saw operations, which of these communication methods does PG&E use? b) For normal Heli-Saw operations, how does PG&E determine which customers should be notified? c) For the Heli-Saw operation on December 9, 2021, which of these communication methods did PG&E use? d) For the Heli-Saw operation on December 9, 2021, how did PG&E determine which customers should be notified?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
263	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	10	CalAdvocates-PGE-2022WMP-22_10	The news story states, "Sampson estimated that branches of up to eight inches in diameter fell as much as 150 feet to the ground in the park." a) In normal operation of the Heli-Saw, how does PG&E protect the public from heavy branches falling, as described above? b) In normal operation of the Heli-Saw, how does PG&E protect employees and contractors working with the Heli-Saw from heavy branches falling, as described above?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
264	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	11	CalAdvocates-PGE-2022WMP-22_11	The news story states, "The operation, according to Sampson, created hundreds of 2-foot to 6-foot-long stubbed limbs that littered the forest floor, that will likely die and create a fire hazard." a) Does PG&E dispute Sampson's statement about the fallen branches from the Heli-Saw operation creating a fire hazard, quoted above? Please explain if yes. b) Has PG&E taken any action to remove the limbs described above from Wunderlich County Park? Please describe all such actions if yes. c) Does PG&E plan to take any action in the future to remove the limbs described above from Wunderlich County Park? Please describe all such actions if yes. d) Describe PG&E's current practices regarding how it deals with fallen limbs.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
265	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	12	CalAdvocates-PGE-2022WMP-22_12	The news story states, "Safety crews were on hand before and after the operation at the park, the utility said, there were 'no safety issues...nor was the public in danger at any time.'" a) In normal Heli-Saw operations, what are the duties of the ground crews mentioned above? b) How many ground crews are involved in a typical Heli-Saw operation? c) How many people, on average, are in each ground crew for a typical Heli-Saw operation? d) How do Heli-Saw ground crews determine the location of the Heli-Saw relative to the planned flight path? e) How does the Heli-Saw pilot ensure that they follow the planned flight path? f) Please describe why the ground crews on December 9, 2021 were not aware that the Heli-Saw had passed into Wunderlich County Park until the Heli-Saw had traveled several hundred feet into parkland.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
266	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	13	CalAdvocates-PGE-2022WMP-22_13	The news story states that Cal Fire released a notice of violation in February 2022. a) Provide a copy of the notice of violation described above. b) Provide a copy of PG&E's response to the Cal Fire notice of violation described above. c) Provide a copy of any other notices of violation from any government agency related to the usage of the Heli-Saw on December 9, 2021. d) Provide a copy of all of PG&E's response to any notifications of violation from part (c).	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	3	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
267	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	14	CalAdvocates-PGE-2022WMP-22_14	The news story states, "PG&E says it is conferring with Cal Fire over the Heli-Saw related violation notice as well as the permit dispute." a) What is the current status of discussions between Cal Fire and PG&E, related to the violation, noted above? b) What is the current status of the permit dispute, noted above?	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
268	CalPA	Set WMP-22	CalAdvocates-PGE-2022WMP-22	15	CalAdvocates-PGE-2022WMP-22_15	a) Is PG&E engaged in any legal or administrative proceedings related to its use of the Heli-Saw in Wunderlich County Park on December 9, 2021? b) If the answer to part (a) is yes, please list all such proceedings and the venue.	Holly Wehrman	6/7/2022	7/5/2022	7/5/2022	0	7.3.5.20	Vegetation Management (VM) and Inspections	Vegetation Management to Achieve Clearances Around Electric Lines and Equipment
270	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	1Supp	CalAdvocates-PGE-2022WMP-03_1Supp	Please note that the geographical regions are mutually exclusive (i.e., "Other HFTD" excludes areas that are in either Tier 2 or Tier 3). Therefore, for any given circuit, the following relationships should hold: Tier 2 miles + Tier 3 miles + Other HFTD miles = total HFTD miles. Tier 2 miles + Tier 3 miles + Other HFTD miles + non-HFTD miles = total circuit miles. Provide an Excel table of all distribution circuits existing as of January 1, 2022 (as rows) that includes the following information in separate columns: bbbbb.Miles of LiDAR inspection in Non-HFTD in 2020cccc.Miles of LiDAR inspection in Non-HFTD in 2021ddd.Miles of LiDAR inspection Other HFTD in 2020eeee.Miles of LiDAR inspection Other HFTD in 2021fff.Miles of LiDAR inspection HFTD Tier 2 in 2020gggg.Miles of LiDAR inspection HFTD Tier 2 in 2021hhhh.Miles of LiDAR inspection HFTD Tier 3 in 2020iiii.Miles of LiDAR inspection HFTD Tier 3 in 2021	Alan Wehrman	1/25/2022	8/3/2022	8/3/2022	1	N/A	Miscellaneous	Additional Detail
271	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	1	CalAdvocates-PGE-2022WMP-23_1	State how many customer accounts PG&E has as of June 29, 2022, and disaggregate the total by HFTD tier (as defined above).	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	8	PSPS	Additional Detail
272	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	2	CalAdvocates-PGE-2022WMP-23_2	Please provide the protective device settings that PG&E plans on using in HFTD areas during high fire-risk weather in 2022, including the following parameters: a) The minimum to trip current; b) Definite time delay; c) Time curve; and d) Coordination parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	7.3.6.8	EPSS	Device settings
273	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	3	CalAdvocates-PGE-2022WMP-23_3	If any of the parameters identified in question 2 depend on the normal operating parameters for its protective devices (i.e., device settings such as the minimum to trip during ordinary weather), please describe how PG&E determines those normal operating parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	7.3.6.8	EPSS	Device settings
274	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	4	CalAdvocates-PGE-2022WMP-23_4	a) Please state whether PG&E plans (in 2022) to coordinate protective devices with fuses' time overcurrent curves, or plans on operating protective devices in a fuse-saving mode (i.e. the recloser/circuit breaker trips before the fuse operates) while fast curve settings are in effect. b) Please explain the reasoning for PG&E's choice(s) in part (a) of this question.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	7.3.6.8	EPSS	Device settings
275	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	5	CalAdvocates-PGE-2022WMP-23_5	Please provide: a) Any studies that show how PG&E determined that the protective device settings identified in question 2 are the best settings to use during high fire-risk weather; and b) Any studies of the expected impact to reliability due to the settings identified in question 2.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	6	7.3.6.8	EPSS	Device settings
276	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	6	CalAdvocates-PGE-2022WMP-23_6	Please provide the protective device settings that PG&E normally uses (i.e., outside of HFTD or outside of high fire risk weather) in 2022, including the following parameters: a) The minimum to trip current; b) Definite time delay; c) Time curve; and d) Coordination parameters.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	7.3.6.8	EPSS	Device settings
277	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	7	CalAdvocates-PGE-2022WMP-23_7	Please provide the following details regarding fast curve settings that PG&E used in 2021 during high fire-risk weather: a) How PG&E calculates the fault duty of the next downstream recloser, including what type of faults PG&E calculates (e.g. line-to-ground, line-to-line, triple-line-to-ground); b) How PG&E coordinated circuit breakers and main line reclosers with fuses; and c) What the instantaneous tripping currents in 2021 were for the hot-line tan (HLTI) settings mode.	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	0	7.3.6.8	EPSS	Device settings
278	CalPA	Set WMP-23	CalAdvocates-PGE-2022WMP-23	8	CalAdvocates-PGE-2022WMP-23_8	Please provide an unredacted version of the spreadsheet "WMP-Discovery2022_DR_OEIS_005-Q10A1ch01_CONF.xlsx".	Tyler Holzschuh	6/29/2022	7/14/2022	7/14/2022	1	7.3.6.8	EPSS	EPSS
279	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	1	CalAdvocates-PGE-2022WMP-24_1	Regarding transmission structures and transmission connecting hardware ("these facilities"): a) How does PG&E detect defects in these facilities that may be difficult or impossible to detect using the unaided eye (such as a broken jumper within a steel shoe)? b) Does the answer to part (a) of this question differ in HFTD areas, compared to non-HFTD areas? c) If the answer to part (b) is yes, please explain the differences.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0	7.3.4	Asset Management and Inspections	Additional Detail
280	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	2	CalAdvocates-PGE-2022WMP-24_2	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Does PG&E use x-ray to examine these facilities while in operation? b) If the answer to part (a) is yes, please describe how and where PG&E does this. c) Does PG&E use gamma rays to examine these facilities while in operation? d) If the answer to part (c) is yes, please describe how and where PG&E does this. e) Does PG&E use ultrasonic inspection to examine these facilities while in operation? f) If the answer to part (e) is yes, please describe how and where PG&E does this.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0	7.3.4	Asset Management and Inspections	Additional Detail
281	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	3	CalAdvocates-PGE-2022WMP-24_3	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Please provide all current PG&E procedures for using x-rays or gamma rays to examine these facilities. b) Please provide all available studies documenting the feasibility and effectiveness of using x-rays and gamma rays to nondestructively examine these facilities. c) If there are any studies documenting the feasibility and effectiveness of using x-rays and gamma rays to nondestructively examine these facilities that you are aware of but do not possess, please identify each such document.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	1	7.3.4	Asset Management and Inspections	Additional Detail
282	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	4	CalAdvocates-PGE-2022WMP-24_4	Regarding transmission structures and transmission connecting hardware in HFTD areas ("these facilities"): a) Please provide all current PG&E procedures for nondestructive examination of these facilities, other than using the visible spectrum and any procedures covered in question 3(a). b) Please provide all current PG&E procedures for destructive examination of these facilities.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	7	7.3.4	Asset Management and Inspections	Additional Detail

283	CalPA	Set WMP-24	CalAdvocates-PGE-2022WMP-24	5	CalAdvocate s-PGE-2022WMP-24_5	Regarding distribution structures and hardware in HFTD areas ("these facilities"): a. Please provide all current PG&E procedures for nondestructive examination of these facilities, other than using the visible spectrum. b. Please provide all current PG&E procedures for destructive examination of these facilities.	Tyler Holzschuh	7/8/2022	7/22/2022	7/22/2022	0		7.3.4	Asset Management and Inspections	Additional Detail
284	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	1	CalAdvocate s-PGE-2022WMP-25_1	Page 7 of PG&E's response states regarding the 2017 Railroad Fire, "PG&E tree contractor inadvertently dropped dead Cedar tree that the contractor was working on into a PG&E distribution line," and, "PG&E did not perform a specific lessons learned analysis for the Railroad Fire." a) Why did PG&E not perform a specific lessons learned analysis for the Railroad Fire? b) Following the Railroad Fire on August 29, 2017, through July 1, 2022, has PG&E experienced any other ignitions in its HFTD where an individual performing tree work for PG&E inadvertently dropped a tree into the distribution line? c) If the answer to part (b) is yes, please list the ignitions, including the date of the ignition, geographic latitude of the ignition, geographic longitude of the ignition, and the final size of the fire.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
285	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	2	CalAdvocate s-PGE-2022WMP-25_2	Page 5 of PG&E's response states regarding the 2018 Airline Fire, "We are currently in the process of reviewing our existing maintenance tags for tags that identify missing vibration dampers and are also reviewing our guidance to inspectors so that they properly identify missing vibration dampers during inspections." a) When did PG&E initiate the review of existing maintenance tags referenced above? b) Does the review of existing maintenance tags encompass all open maintenance tags on the electric system or some subset? If the scope is limited to a subset, please describe the scope. c) When does PG&E expect to complete the review of existing maintenance tags referenced above? d) When did PG&E initiate the review of its guidance to inspectors referenced above? e) When does PG&E expect to complete the review of its guidance to inspectors referenced above? f) Has PG&E initiated any review of design standards, engineering practices, or construction practices to ensure that vibration dampers are installed appropriately? g) If the answer to part (f) is yes, please describe the scope and timeline for this review. h) Does PG&E have equipment in service that predates the practice of utilizing vibration dampers? i) If the answer to part (h) is yes, please list all actions PG&E has taken to assess such legacy equipment and mitigate the issue of missing vibration dampers. j) Does PG&E's response regarding the 2018 Airline Fire identify several actions PG&E is undertaking to ensure that the issue of missing vibration dampers is found and remediated. Please list all actions PG&E has undertaken since the Airline Fire ignited on June 4, 2018 to ensure that the issue of missing vibration dampers does not occur in the first place.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
286	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	3	CalAdvocate s-PGE-2022WMP-25_3	Page 6 of PG&E's response regarding the 2019 Lone Oak Fire, "Corrective Action Program (CAP) event assigned to determine ongoing risk from vibration dampers in the field and deployed on #2 ACSR and #4 ACSR conductor wires. Specifically, the team evaluated extent of risk between 2 ACSR and Alcoa Stockbridge dampers." a) Please briefly describe the findings from PG&E's evaluation of the extent of the risk between ACSR and Alcoa Stockbridge dampers, described above. b) Has PG&E determined that utilizing Alcoa Stockbridge dampers presents a wildfire risk? c) If the answer to part (b) is yes, has PG&E initiated an effort to proactively identify and remove or replace Alcoa Stockbridge dampers?	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	1		4.1	Lessons Learned and Risk Trends	Additional Details
287	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	4	CalAdvocate s-PGE-2022WMP-25_4	Page 12 of PG&E's response regarding the 2021 Dixie Fire, "We have revised our response time standard to respond to outages in HFTD areas, where we can safely do so, within 60 minutes as compared to the prior standard which required a response within 24 hours to a low level outage such as the one experienced on the circuit associated with the Dixie Fire." a) Please define "respond" as used in this context. b) In the event that an outage occurs and a PG&E troubleperson cannot physically reach the site within 60 minutes due to factors beyond their control, please describe how PG&E would meet its standard to respond to the outage within 60 minutes.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
288	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	5	CalAdvocate s-PGE-2022WMP-25_5	Page 14 of PG&E's response states, "For clarification, the revision notice reference to increases in equipment-related ignitions from 2020 to 2021 refers to system-wide ignitions. However, in 2021, PG&E observed a 12.9% decrease in California Public Utilities Commission (CPUC)-reportable ignitions in HFTD areas where the suspected cause was PG&E equipment failure." Page 16 of Energy Safety's Revision Notice includes the following chart, which shows a steady increase in non-HFTD ignitions from 2018 through 2021: [GRAPHIC TABLE] a) Please list all causal factors to which PG&E attributes the increase in equipment-related ignitions from 2018 to 2021 in non-HFTD. b) Please list and briefly describe all actions PG&E is taking in 2022 to reduce the number of equipment-related ignitions in non-HFTD.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
289	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	6	CalAdvocate s-PGE-2022WMP-25_6	Page 20 of PG&E's response describes its Enhanced Ignition Analysis (EIA) program. a) Does the EIA process apply to non-HFTD ignitions? b) If the answer to part (a) is no, please explain why not.	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
290	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	7	CalAdvocate s-PGE-2022WMP-25_7	Pages 33-38 of PG&E's response include Table RN-PG&E-22-08-01: Timeline and Update on Actions To Increase Asset Inspection Quality. Please provide an updated copy of this Table with the following additional information in the "Timeline for Implementation" column: a) Date the action was initiated. b) Date the action was completed (if applicable).	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		4.1	Lessons Learned and Risk Trends	Additional Details
291	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	8	CalAdvocate s-PGE-2022WMP-25_8	Pages 37 of PG&E's response states, "Confirmed incidents of fraudulent activity (timecards, inspections) will result in discipline and up to termination." a) From January 1, 2021, through July 1, 2022, how many incidents of fraudulent activity has PG&E recorded? b) Of the incidents in part (a), how many involved fraud in relation to asset inspections? c) Of the incidents in part (b), how many inspectors have been terminated as of July 1, 2022?	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		7.3.4.19	Asset Management and Inspections	Response to RN-PGE-22-08
291	CalPA	Set WMP-25	CalAdvocates-PGE-2022WMP-25	9	CalAdvocate s-PGE-2022WMP-25_9	Pages 37 of PG&E's response states, "Confirmed incidents of fraudulent activity (timecards, inspections) will result in discipline and up to termination." a) From January 1, 2021, through July 1, 2022, how many incidents of fraudulent activity has PG&E recorded? b) Of the incidents in part (a), how many involved fraud in relation to asset inspections? c) Of the incidents in part (b), how many inspectors have been terminated as of July 1, 2022?	Holly Wehrman	7/8/2022	7/13/2022	7/13/2022	0		7.3.4	Asset Management and Inspections	Response to RN-PGE-22-08
292	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	1	CalAdvocate s-PGE-2022WMP-26_1	a) Has PG&E studied the possibility of coordinating distribution protection in a manner where the substation feeder circuit breaker trips first and then the unfaulted line segments are re-energized to increase coordination and decrease protection delay? b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the distribution protection scheme described in part (a), please identify each such document. e) Does PG&E plan to implement the distribution protection scheme described in part (a) on any portion of its electric distribution system?	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0		7.3.3	Grid Design and System Hardening	Additional Detail
293	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	2	CalAdvocate s-PGE-2022WMP-26_2	a) Has PG&E studied the use of cumulative distribution functions for high-impedance fault detection to achieve the desired tradeoff between risk mitigation and reliability? This would entail measuring the frequencies of various trip thresholds (i.e., if the threshold is surpassed every month, three months, year, etc.) to control the number of nuisance trips for high-impedance relay functions. b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the distribution protection scheme described in part (a), please identify each such document. e) Does PG&E plan to implement the distribution protection scheme described in part (a) on any portion of its electric distribution system?	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0		7.3.3	Grid Design and System Hardening	Additional Detail
294	CalPA	Set WMP-26	CalAdvocates-PGE-2022WMP-26	3	CalAdvocate s-PGE-2022WMP-26_3	a) Has PG&E studied the use of fast earthing switches (e.g., utility equipment manufacturer ABB's ultra-fast earthing switch) to extinguish a fault faster than using traditional circuit breakers to prevent wildfires? b) If the answer to part (a) is yes, when did PG&E conduct this analysis? c) If the answer to part (a) is yes, please provide all such studies or analyses that PG&E has produced or performed. d) If PG&E has reviewed any external (i.e., not created by PG&E) reports, studies or analyses related to the distribution protection scheme described in part (a), please identify each such document. e) Does PG&E plan to implement the distribution protection scheme described in part (a) on any portion of its electric distribution system?	Tyler Holzschuh	7/15/2022	7/29/2022	7/28/2022	0		7.3.3	Grid Design and System Hardening	Additional Detail
295	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	1	CalAdvocate s-PGE-2022WMP-27_1	Question 1 relates to PG&E's response to Critical Issue RN-PG&E-22-02 (hereinafter PG&E's response). Regarding Figure RN-PG&E-22-02-01 on p. 32 of PG&E's response, a) Please state the source(s) of data for the left-hand map, "PSPS Frequency of Circuit Segment." For example, are the frequencies based on actual PSPS events, PG&E's PSPS lookback analysis, or something else? In your answer, please include the date range for the data. b) Please state the source(s) of data for the right-hand map, "Wildfire Risk by Circuit Segment." For example, are these values derived from version 2 of PG&E's wildfire distribution risk model? Are these values based on equipment risk scores, vegetation risk scores, or something else?	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0		8	PSPS	Additional Detail

296	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	2	CalAdvocate s-PGE-2022WMP-27_2 Q2 related to PG&E's response to Critical Issue RN-PG&E-22-03 (hereinafter PG&E's July 11, 2022 response). Table RN-PG&E-22-03-02 on page 38 of PG&E's July 11, 2022 response states that 59 miles of undergrounding work will be performed in the top 20% risk-ranked circuit segments in 2022. Cal Advocates reviewed attachment "2022-02-25_PGE_2022_WMP-Update_RO_Section 4.6_Remedies 21-14_Atch01_CONF_R1.xlsx" to PG&E's 2022 WMP Update to estimate the percentage of undergrounding work that was planned in the top 20% risk-ranked circuit segments. To determine this, Cal Advocates filtered Column W (2021 Risk Rank) to show only circuit segments ranked from 1-727.2 and filtered column G (Planned UG Miles) to include only projects with planned underground miles. To estimate a lower bound of planned 2022 underground work, Cal Advocates subtracted the sum of filtered column H (Planned OH Miles) from the sum of filtered column M (2022 Forecast Miles), resulting in approximately 90.6 miles of planned 2022 undergrounding work. 2 Per PG&E's response to data request CalAdvocates-PGE-2022WMP-19, question 1. a) Please explain why the planned 2022 undergrounding mileage in the top 20% risk-ranked circuit segments in Table RN-PG&E-22-03-02 of PG&E's July 11, 2022 response is substantially lower than the planned undergrounding mileage in the top 20% risk-ranked circuit segments in attachment "2022-02-25_PGE_2022_WMP-Update_RO_Section 4.6_Remedies 21-14_Atch01_CONF_R1.xlsx" to PG&E's 2022 WMP Update. b) Please correct any errors in Cal Advocates' analysis, described above. c) Did PG&E reduce its planned 2022 undergrounding mileage in the top 20% risk-ranked circuit segments between filing its 2022 WMP Update on February 25, 2022, and filing its July 11, 2022 response to Energy Safety? d) If the answer to part (c) is yes, please state the basis for PG&E's decision to reduce its planned 2022 undergrounding mileage in the top 20% risk-ranked circuit segments between filing its 2022 WMP Update and its July 11, 2022 response.	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	4.6	Grid Design and System Hardening	System Hardening
297	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	3	CalAdvocate s-PGE-2022WMP-27_3 Page 39 of PG&E's July 11, 2022 response states, "In order to focus undergrounding projects in locations to both address wildfire risk over the entire year and locations where wind driven events pose high wildfire risk, both the WDRM and PSPS models are referenced in identifying candidate miles for undergrounding." Page 39 additionally states, "Other models, which are categorized as "Operational," such as PG&E's FPI and IPW Models, focus on informing day-to-day risk mitigation operations based on hourly weather forecasts, but only for a few days into the future." Cal Advocates understands the phrase "PSPS models" to refer to these operational models, such as the FPI and IPW models. a) Is the understanding stated above correct? If not, please correct any errors in this understanding. b) If the understanding stated above is correct, please explain how these operational models, which inform day-to-day mitigation operations, are able to inform candidate miles for undergrounding. c) Please explain how PG&E used its PSPS models to identify its 2022 candidate miles for undergrounding. d) Please explain how PG&E used its PSPS models to identify its 2023 candidate miles for undergrounding.	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	8	PSPS	Additional Detail
298	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	4	CalAdvocate s-PGE-2022WMP-27_4 Question 7 relates to PG&E's response to Critical Issue RN-PG&E-22-05 (hereinafter PG&E's response). Table RN-PG&E-22-05-03 on pages 55 and 56 of PG&E's response outlines PG&E's planned timeline for addressing Ignition Risk tags. PG&E plans to close out 8,300 tags in Q1 of 2023, 26,700 tags in Q2, 40,000 tags in Q3, and 8,300 tags in Q4. a) Please explain the resources and plans PG&E will have in place in order to ramp up from addressing 8,300 tags in Q1 to 26,700 tags in Q2. b) Q3 is historically amid active wildfire season. Does PG&E anticipate any issues with closing out 40,000 tags in Q3 while simultaneously addressing active wildfire issues? c) If the answer to part (b) is yes, please explain the potential issues and PG&E's plan to mitigate such issues. d) If the answer to part (b) is no, please explain why PG&E did not perform any reinspections described in part (a).	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	0	7.3.4.17	Asset Management and Inspections	Response to Critical Issue RN-PG&E-22-05
299	CalPA	Set WMP-27	CalAdvocates-PGE-2022WMP-27	5	CalAdvocate s-PGE-2022WMP-27_5 In response to data request CalAdvocates-PGE-2022WMP-25, Question 9, PG&E stated that seven inspectors had committed fraudulent activity related to asset inspections between January 1, 2021 and July 1, 2022. a) Did PG&E perform any reinspections of the assets inspected by the seven inspectors referenced above? b) If the answer to part (a) of this question is yes, please describe the scope of the reinspections described in part (a). For example, did PG&E reinspect a random sample of assets, all assets inspected by these inspectors in the past three months, or some other subset of assets inspected by these inspectors? If the answer varies between the seven inspectors, please provide separate responses for each of the seven inspectors. c) Please state the basis for PG&E's choice of scope in part (b) of this question. If PG&E did not perform any reinspections described in part (a) of this question, please explain why.	Holly Wehrman	7/20/2022	7/25/2022	7/25/2022	1	7.3.4	Asset Management and Inspections	Additional Detail
300	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	1	CalAdvocate s-PGE-2022WMP-28_1 a) How many total ignitions has PG&E experienced related to underground distribution lines from January 1, 2015 through June 30, 2022? b) How many total ignitions has PG&E experienced related to overhead distribution lines from January 1, 2015 through June 30, 2022?	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	4.1	Lessons Learned and Risk Trends	Lessons Learned
301	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	2	CalAdvocate s-PGE-2022WMP-28_2 For questions 2 and 3, please refer to the definitions of HFTD areas above. If you have any questions about these definitions, contact the originators of this data request. Note that the HFTD areas are defined to be both mutually exclusive and exhaustive. Therefore, in the tables below, the systemwide total for each time period should equal the sum of the cells in that column. a) Please complete Table 2a below, including only ignitions related to underground distribution lines. [see PDF for table] b) Please complete Table 2b below, including only ignitions related to overhead distribution lines. [see PDF for table]	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.4.18	Asset Management and Inspections	Response to RN-PGE-22-06
302	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	3	CalAdvocate s-PGE-2022WMP-28_3 Please complete Table 3a below, stating the total circuit-miles of underground distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column). [see PDF for table] Please complete Table 3b below, stating that total circuit-miles of overhead distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column). [see PDF for table]	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.4.18	Asset Management and Inspections	Response to RN-PGE-22-06
303	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	4	CalAdvocate s-PGE-2022WMP-28_4 Page 2 of PG&E's response to the revision notice states, "PG&E's subject matter experts estimate that placing overhead lines underground reduces ignition risk by approximately 99% in that location." a) Please describe PG&E's validation process for your estimate of 99% ignition risk reduction, referenced in the quote above. b) Has PG&E compared the number of ignitions on a given circuit segment both prior to and after undergrounding the segment? c) If the answer to part (b) of this question is yes, please explain how PG&E performed this comparison. d) If the answer to part (b) is no, please explain why PG&E did not perform such a comparison.	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
304	CalPA	Set WMP-28	CalAdvocates-PGE-2022WMP-28	5	CalAdvocate s-PGE-2022WMP-28_5 On July 11, 2022, in response to Critical Issue RN-PG&E-22-03, PG&E provided Table RN-PG&E-22-03-02. This table states that, in 2023, PG&E's 2023 undergrounding workplan includes 662 miles, of which 419 miles are in the top 20% risk-ranked circuit segments. On July 26, 2022, in response to Critical Issue RN-PG&E-22-04, PG&E provided attachment 2022-07-26_PGE_22-04_RNR_R3_Atch01CONF.xlsx.2 Cal Advocates filtered Column J (2023 Forecast Miles) to include only non-zero values. The resulting lines contain about 569 miles of Planned UG Miles in Column F. Cal Advocates further filters Column S (2021-2023 Risk Rank (V2)) to show only circuit segments ranked from 1-727.3. The resulting lines contain about 383 Planned UG Miles in Column F. a) Please explain why PG&E's response to Critical Issue RN-PG&E-22-03 indicates that PG&E's 2023 system hardening workplan includes 662 miles of undergrounding, while PG&E's response to response to Critical Issue RN-PG&E-22-04 indicates that PG&E's 2023 system hardening workplan includes 569 miles of undergrounding. b) Please explain why PG&E's response to Critical Issue RN-PG&E-22-03 indicates that PG&E's 2023 system hardening workplan includes 419 miles of undergrounding in the top 20% of risk-ranked circuit segments, while PG&E's response to response to Critical Issue RN-PG&E-22-04 indicates that PG&E's 2023 system hardening workplan includes 383 miles of undergrounding in the top 20% of risk-ranked circuit segments. c) If attachment 2022-07-26_PGE_22-04_RNR_R3_Atch01CONF.xlsx contains any errors, inaccuracies, or omissions, please provide a corrected version. Provide a flowchart demonstrating PG&E's decision-making process for choosing undergrounding for a particular location, if such differs from the one described in the 2022 WMP Update.	Holly Wehrman	7/27/2022	8/1/2022	8/1/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
305	OEIS	Set 16	OEIS-PG&E-22-016	1	OEIS-PG&E-22-016_1 During a call with Energy Safety on August 3, 2022, PG&E discussed using pre-fire vegetation levels for fire burn scars. a. Describe why PG&E made these choices for determining ground fuels layers as inputs in its wildfire risk modeling. b. Provide a list of the associated CPZs that fall under these areas within Attachment 2022-07-26_PGE_22-04_RNR_R3_Atch01CONF.xlsx. Provide a flowchart demonstrating PG&E's decision-making process for choosing undergrounding for a particular location, if such differs from the one described in the 2022 WMP Update.	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	4.5	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
306	OEIS	Set 16	OEIS-PG&E-22-016	2	OEIS-PG&E-22-016_2 a. Describe why PG&E made these choices for determining ground fuels layers as inputs in its wildfire risk modeling. b. Provide a list of the associated CPZs that fall under these areas within Attachment 2022-07-26_PGE_22-04_RNR_R3_Atch01CONF.xlsx. Provide a flowchart demonstrating PG&E's decision-making process for choosing undergrounding for a particular location, if such differs from the one described in the 2022 WMP Update.	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	4.5	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
307	OEIS	Set 16	OEIS-PG&E-22-016	3	OEIS-PG&E-22-016_3 What qualifications are required for inspectors completing asset inspections?	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding
308	OEIS	Set 16	OEIS-PG&E-22-016	4	OEIS-PG&E-22-016_4 How has PG&E worked to retain and keep inspectors for asset inspections?	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	5.4.3	Planning for Workforce and Other Limited Resources	Target Role - Asset Inspections
309	OEIS	Set 16	OEIS-PG&E-22-016	5	OEIS-PG&E-22-016_5 What are PG&E's plans for increasing internal employment of inspectors for asset inspections (as opposed to relying on contractors)?	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	5.4	Planning for Workforce and Other Limited Resources	Additional Detail
310	OEIS	Set 16	OEIS-PG&E-22-016	6	OEIS-PG&E-22-016_6 What are PG&E's plans for increasing internal employment of inspectors for asset inspections (as opposed to relying on contractors)?	Kevin Miller	8/9/2022	8/12/2022	8/12/2022	0	5.4	Planning for Workforce and Other Limited Resources	Additional Detail

311	CalPA	Set WMP-29	CalAdvocates-PGE-2022WMP-29	1	<p>Page 5 of PG&E's quarterly notification states, with regard to initiative D.01 "Distribution HFD Inspections (Poles)," "Additional resources have been shifted to support Distribution overhead inspections to help close this gap. The recovery plan date to be back on track with the WMP Target is July 30, 2022."</p> <p>a) As of July 31, 2022, was PG&E on track with its WMP target with regard to this initiative?</p> <p>b) If the answer to part (a) is no, state the reason(s) for the delay and PG&E's expected date to be back on track with its WMP target.</p> <p>c) State PG&E's target for this type of distribution inspection by the end of July 2022, as of the time that PG&E submitted its original 2022 WMP on February 25, 2022.</p> <p>d) As of July 31, 2022, how many inspections had PG&E completed under initiative D.01 as of July 31, 2022?</p>	Holly Wehrman	8/10/2022	8/24/2022	8/24/2022	0	7.3.4.1	Asset Management and Inspections	Detailed Inspections of Distribution Electric Lines and Equipment
312	CalPA	Set WMP-29	CalAdvocates-PGE-2022WMP-29	2	<p>Table 7.1 of PG&E's second quarter Quarterly Data Report, PG&E reported one fatality of a member of the public due to wildfire mitigation initiatives in Q1 2022.</p> <p>a) Please identify the date, time, and location of the fatal incident.</p> <p>b) Please state the circumstances that led to this fatality.</p> <p>c) Please list the wildfire mitigation initiative(s) that were associated with this fatality.</p> <p>d) Please provide copies of any reports related to this fatality that PG&E provided to SED, OSHA, or other regulatory agencies.</p> <p>e) Please describe the root cause(s) of this fatality.</p> <p>f) Please describe what measures, if any, PG&E has put in place to mitigate the risk of future fatalities related to the root cause(s) in part (e).</p> <p>g) Please describe any measures that PG&E plans to put in place to mitigate the risk of future injuries related to the root cause(s) in part (e).</p>	Holly Wehrman	8/10/2022	8/24/2022	8/24/2022	0	6.4	Performance Metrics and Underlying Data	Detailed Information Supporting Outcome Metrics
313	CalPA	Set WMP-29	CalAdvocates-PGE-2022WMP-29	3	<p>Table 7.1 of PG&E's second quarter Quarterly Data Report, PG&E reported one OSHA-reportable injury to a member of the public due to wildfire mitigation initiatives in Q1 2022.</p> <p>a) Please identify the date, time, and location of the injury.</p> <p>b) Please state the circumstances that led to this injury.</p> <p>c) Please list the wildfire mitigation initiative(s) that were associated with this injury.</p> <p>d) Please provide copies of any reports related to this injury that PG&E provided to SED, OSHA, or other regulatory agencies.</p> <p>e) Please describe the root cause(s) of this injury.</p> <p>f) Please describe what measures, if any, PG&E has put in place to mitigate the risk of future injuries related to the root cause(s) in part (e).</p> <p>g) Please describe any measures that PG&E plans to put in place to mitigate the risk of future injuries related to the root cause(s) in part (e).</p>	Holly Wehrman	8/10/2022	8/24/2022	8/24/2022	0	6.4	Performance Metrics and Underlying Data	Detailed Information Supporting Outcome Metrics
314	CalPA	Set WMP-29	CalAdvocates-PGE-2022WMP-29	4	<p>a) Does Table 7.1 include all EPSS-related outages?</p> <p>b) If Table 7.1 includes EPSS-related outages, which line(s) reflect EPSS outages?</p> <p>c) If some or all EPSS-related outages are not included in this table, please explain why not.</p> <p>d) If some or all EPSS-related outages are not included in this table, please explain where information on these outages can be found.</p>	Holly Wehrman	8/10/2022	8/24/2022	8/24/2022	0	6.7	Performance Metrics and Underlying Data	Recent and Projected Drivers of Ignition Probability
315	CalPA	Set WMP-30	CalAdvocates-PGE-2022WMP-30	1	<p>a) How many total ignitions has PG&E experienced related to overhead covered conductor distribution lines from January 1, 2015 through July 31, 2022?</p> <p>b) How many total ignitions has PG&E experienced related to overhead bare conductor distribution lines from January 1, 2015 through July 31, 2022?</p>	Holly Wehrman	8/12/2022	8/26/2022	8/26/2022	0	4.1	Lessons Learned and Risk Trends	Additional Details
316	CalPA	Set WMP-30	CalAdvocates-PGE-2022WMP-30	2	<p>a) Please complete Table 2a below, including only ignitions related to overhead covered conductor distribution lines on your system.</p> <p>b) Please complete Table 2b below, including only ignitions related to overhead bare conductor distribution lines on your system.</p>	Holly Wehrman	8/12/2022	8/26/2022	8/26/2022	0	4.1	Lessons Learned and Risk Trends	Additional Details
317	CalPA	Set WMP-30	CalAdvocates-PGE-2022WMP-30	3	<p>a) Please complete Table 3a below, stating the total circuit-miles of overhead covered conductor distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column).</p> <p>b) Please complete Table 3b below, stating the total circuit-miles of overhead bare conductor distribution lines that existed on your system on the first day of each time period (e.g., January 1, 2015 for the 2015 column).</p>	Holly Wehrman	8/12/2022	8/26/2022	8/26/2022	0	7.3.3.3	Grid Design and System Hardening	Covered Conductor Installation
318	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	1	<p>a) Please list all distinct risk scores generated by PG&E's WDRM v3 (for example, version 2 of PG&E's WDRM generated two different risk scores for distribution lines: a conductor risk score, and a vegetation risk score).</p> <p>b) For each risk score in part (a), please provide a category or brief description of the type of risk the score represents.</p> <p>c) For each risk score in part (a), please provide a brief explanation of how PG&E intends to use that risk score.</p> <p>d) For each risk score in part (a), please list all PG&E wildfire mitigation initiatives that are informed by that risk score.</p> <p>e) For each risk score in part (a), please state the most granular level available for that risk score. For example, in WDRM v2, the most granular level available would be the risk scores associated with individual 100m x 100m pixels.</p> <p>f) For each risk score in part (a), please state the granularity at which the risk score is used to inform wildfire mitigation initiatives (e.g. circuit segment, circuit, individual asset, etc.).</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	0	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
319	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	2	<p>Page 28 of the E3 report states, "A 'composite model' sums the probability of ignition across all relevant subsets pertaining to a particular business unit. The probability of ignition is multiplied by the consequence score to calculate a risk score. Risk scores can then be aggregated across assets and geographies for various work planning purposes (e.g. aggregated over a circuit segment to compare the risk across different segments)."</p> <p>a) Please list all composite (or aggregate) risk scores, as discussed in the E3 report, generated by PG&E's WDRM v3.</p> <p>b) For each risk score in part (a), please provide a category or brief description of the type of risk the score represents.</p> <p>c) For each risk score in part (a), please provide a brief explanation of how PG&E intends to use that risk score.</p> <p>d) For each risk score in part (a), please list all PG&E wildfire mitigation initiatives that are informed by that risk score.</p> <p>e) For each risk score in part (a), please state the most granular level available for that risk score. For example, in WDRM v2, the most granular level available would be the risk scores associated with individual 100m x 100m pixels.</p> <p>f) For each risk score in part (a), please state the granularity at which the risk score is used to inform wildfire mitigation initiatives (e.g. circuit segment, circuit, individual asset, etc.).</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	0	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
320	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	3	<p>The following questions refer to the risk scores generated from WDRM v3. This should be understood to refer to PG&E's responses to questions 1 and 2 above.</p> <p>Question 3</p> <p>Please provide a separate GIS file for each risk score identified in question 1(a) that details the most granular level available for that risk score (as discussed in question 1(e)).</p> <p>These GIS files should contain, at a minimum, the following:</p> <p>a) Geometric features detailing the most granular level available for each risk score. This may be points, polygons, lines, or whichever geometry best suits the relevant features.</p> <p>b) The risk score associated with each feature from part (a) of this question.</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
321	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	4	<p>Please provide a separate GIS file for each composite risk score identified in question 2(a) that details the most granular level available for that risk score (as discussed in question 2(e)).</p> <p>These GIS files should contain, at a minimum, the following:</p> <p>a) Geometric features detailing the most granular level available for each risk score. This may be points, polygons, lines, or whichever geometry best suits the relevant features.</p> <p>b) The risk score associated with each feature from part (a) of this question.</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
322	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	5	<p>Please provide a separate GIS file for each risk score identified in question 1(a), which shows the risk score at the same granularity that it is currently used to inform wildfire mitigation measures (as discussed in question 1(f)).</p> <p>These GIS files should contain, at a minimum, the following:</p> <p>a) Geometric features detailing the most granular level available for each risk score. This may be points, polygons, lines, or whichever geometry best suits the relevant features.</p> <p>b) The risk score associated with each feature from part (a).</p> <p>c) Circuit identification number associated with each feature from part (a).</p> <p>d) Circuit name associated with each feature from part (a).</p> <p>e) Unique identification for each geometric feature (e.g. circuit segment name, asset ID, etc.)</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
323	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	6	<p>Please provide a separate GIS file for each composite risk score identified in question 2(a), which shows the risk score at the same granularity that it is currently used to inform wildfire mitigation measures (as discussed in question 2(f)).</p> <p>These GIS files should contain, at a minimum, the following:</p> <p>a) Geometric features detailing the most granular level available for each risk score. This may be points, polygons, lines, or whichever geometry best suits the relevant features.</p> <p>b) The risk score associated with each feature from part (a).</p> <p>c) Circuit identification number associated with each feature from part (a).</p> <p>d) Circuit name associated with each feature from part (a).</p> <p>e) Unique identification for each geometric feature (e.g. circuit segment name, asset ID, etc.)</p>	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk

324	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	7	CalAdvocates-PGE-2022WMP-31_7	<p>Please provide a spreadsheet that lists (as rows) each circuit-segment that is included in the Wildfire Distribution Risk Model v3. This spreadsheet should include, at minimum, the following columns:</p> <ol style="list-style-type: none"> Name or ID number of each circuit segment. Circuit name for the circuit that each segment is part of. Circuit ID for the circuit that each segment is part of. Nominal voltage. The pixel count of the circuit segment. (Cal Advocates understands this to be the number of 100m x 100m pixels analyzed by the WDRM v3 along the length of the circuit segment). The mean MAVF core risk value(s). (Cal Advocates understands this to be the average risk associated with each pixel along the circuit segment; please provide correction if this understanding is inaccurate or incomplete). The total MAVF core risk value(s). (Cal Advocates understands this to be the mean MAVF core risk multiplied by the pixel count; please provide correction if this understanding is inaccurate or incomplete). Total circuit-miles on the circuit-segment. Total overhead circuit-miles on the circuit-segment. Total non-HFTD overhead circuit-miles on the circuit-segment. Total Tier 2 overhead circuit-miles on the circuit-segment. Total Tier 3 overhead circuit-miles on the circuit-segment. Total underground circuit-miles on the circuit-segment. Each risk score (each in a separate and labeled column) identified in question 1(a) that is used at the circuit-segment level to inform wildfire mitigation initiatives. (May require multiple columns.) Each composite risk score (each in a separate and labeled column) identified in question 2(a) that is used at the circuit-segment level to inform wildfire mitigation initiatives. (May require multiple columns.) 	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
325	CalPA	Set WMP-31	CalAdvocates-PGE-2022WMP-31	8	CalAdvocates-PGE-2022WMP-31_8	<p>On page 82 of PG&E's 2022 WMP Update, Section 4.6, Attachment 1, PG&E says it is currently in the process of developing a VM Wildfire Inspection Guide and intends to finalize this Inspection Guide by the third quarter of 2022.</p> <ol style="list-style-type: none"> Is PG&E on track to finalize the VM Wildfire Inspection Guide by the end of Q3 2022? If no, what is the status of the VM Wildfire Inspection Guide and when does PG&E expect to finalize it? <p>In response to question 2 of DR 29, PG&E stated, "After further review, we determined that this fatality was not the result of wildfire mitigation work associated with our WMP. As a result, the WMP tables will be revised to reflect this update."</p> <ol style="list-style-type: none"> Please identify the date, time, and location of the fatal incident. Did the fatal incident occur on property owned, operated, or maintained by PG&E? Please state to the best of PG&E's knowledge the circumstances that led to this fatality. Was the fatality described in DR 29 the result of activity performed by PG&E? Was the fatality described in DR 29 the result of activity performed by contractors or agents at PG&E's discretion? If the answer to part (e) is yes, was the work that resulted in the fatality approved by PG&E? Please state how the fatality described in DR 29 was previously misidentified as resulting from wildfire mitigation work. How did PG&E determine that the fatality described in DR 29 was not related to wildfire mitigation work? Please provide copies of any reports related to this fatality that PG&E provided to SED, OSHA, or other regulatory agencies. 	Holly Wehrman	8/18/2022	9/8/2022	9/8/2022	1	4.5.1	Model and Metric Calculation Methodologies	Additional Models for Ignition Probability, Wildfire and PSPS Risk
326	OEIS	Set 17	OEIS-PG&E-22-017	1	OEIS-PG&E-22-017_1	<p>In response to data request OEIS-PGE-22-012, question 4, PG&E provided a proposed accelerated timeline for integrating vegetation management programs in the "One VM Tool."</p> <ol style="list-style-type: none"> Has PG&E adopted the proposed timeline? If not, what is the current timeline for integrating vegetation management programs in the "One VM Tool?" 	Kevin Miller	8/19/2022	8/24/2022	8/24/2022	1	7.3.5.19	Vegetation Management (VM) and Inspections	Vegetation Management Enterprise System
327	OEIS	Set 17	OEIS-PG&E-22-017	2	OEIS-PG&E-22-017_1	<p>On page 82 of PG&E's 2022 WMP Update, Section 4.6, Attachment 1, PG&E says it is currently in the process of developing a VM Wildfire Inspection Guide and intends to finalize this Inspection Guide by the third quarter of 2022.</p> <ol style="list-style-type: none"> Is PG&E on track to finalize the VM Wildfire Inspection Guide by the end of Q3 2022? If no, what is the status of the VM Wildfire Inspection Guide and when does PG&E expect to finalize it? 	Kevin Miller	8/19/2022	8/24/2022	8/24/2022	1	7.3.5.21	Vegetation Management (VM) and Inspections	Additional Vegetation Management Practices Beyond Regulatory Requirements and Recommendations
328	CalPA	Set WMP-32	CalAdvocates-PGE-2022WMP-32	1	CalAdvocates-PGE-2022WMP-32_1	<p>In response to question 3 of DR 29, PG&E stated, "After further review, we determined that this serious injury was not the result of wildfire mitigation work associated with our WMP. As a result, the WMP tables will be revised to reflect this update."</p> <ol style="list-style-type: none"> Please identify the date, time, and location of the fatal incident. Did the fatal incident occur on property owned, operated, or maintained by PG&E? Please state to the best of PG&E's knowledge the circumstances that led to this fatality. Was the fatality described in DR 29 the result of activity performed by PG&E? Was the fatality described in DR 29 the result of activity performed by contractors or agents at PG&E's discretion? If the answer to part (e) is yes, was the work that resulted in the fatality approved by PG&E? Please state how the fatality described in DR 29 was previously misidentified as resulting from wildfire mitigation work. How did PG&E determine that the fatality described in DR 29 was not related to wildfire mitigation work? Please provide copies of any reports related to this fatality that PG&E provided to SED, OSHA, or other regulatory agencies. 	Holly Wehrman	8/29/2022	9/13/2022	9/13/2022	0	6.4	Performance Metrics and Underlying Data	Detailed Information Supporting Outcome Metrics
329	CalPA	Set WMP-32	CalAdvocates-PGE-2022WMP-32	2	CalAdvocates-PGE-2022WMP-32_2	<p>Page 5 of PG&E's second quarterly notification states, with respect to initiative C.02 Distribution Sectionalizing Devices - Install and SCADA commissioning:</p> <p>The program was re-baselined to adjust the interim completion targets while still delivering on the WMP commitment of 100 new PSPS devices by September 1st. A recovery plan is in place to get all jobs pre-commissioned, constructed, and commissioned on time with over 100 projects in flight (22 commissioned, 7 constructed, 59 construction-ready, and 35 being pre-commissioned) to provide buffer to ensure the 100-unit target is met by September 1, 2022 or earlier.</p> <ol style="list-style-type: none"> As of September 1, 2022, how many distribution sectionalizing devices were installed and SCADA commissioned in 2022 as part of this initiative? Please identify the status - as of September 1, 2022 - for all jobs that are part of this initiative in 2022, using the same status categories used in the quote above (commissioned, constructed, construction-ready, in pre-commissioning, or other). If the answer to part (a) is below 100, please state the reasons for the continued delays. If the answer to part (a) is below 100, please state PG&E's recovery plan for this initiative, including the date by which PG&E expects to have 100 units installed and SCADA commissioned. 	Holly Wehrman	8/29/2022	9/13/2022	9/13/2022	0	6.4	Performance Metrics and Underlying Data	Detailed Information Supporting Outcome Metrics
330	CalPA	Set WMP-33	CalAdvocates-PGE-2022WMP-33	1	CalAdvocates-PGE-2022WMP-33_1	<p>Page 5 of PG&E's second quarterly notification states, with respect to initiative C.02 Distribution Sectionalizing Devices - Install and SCADA commissioning:</p> <p>The program was re-baselined to adjust the interim completion targets while still delivering on the WMP commitment of 100 new PSPS devices by September 1st. A recovery plan is in place to get all jobs pre-commissioned, constructed, and commissioned on time with over 100 projects in flight (22 commissioned, 7 constructed, 59 construction-ready, and 35 being pre-commissioned) to provide buffer to ensure the 100-unit target is met by September 1, 2022 or earlier.</p> <ol style="list-style-type: none"> As of September 1, 2022, how many distribution sectionalizing devices were installed and SCADA commissioned in 2022 as part of this initiative? Please identify the status - as of September 1, 2022 - for all jobs that are part of this initiative in 2022, using the same status categories used in the quote above (commissioned, constructed, construction-ready, in pre-commissioning, or other). If the answer to part (a) is below 100, please state the reasons for the continued delays. If the answer to part (a) is below 100, please state PG&E's recovery plan for this initiative, including the date by which PG&E expects to have 100 units installed and SCADA commissioned. 	Holly Wehrman	9/6/2022	9/20/2022	9/14/2022	0	7.3.3.8.1	Grid Design and System Hardening	Distribution Line Sectionalizing
331	OEIS	Set 18	OEIS-PG&E-22-018	1	OEIS-PG&E-22-018_1	<ol style="list-style-type: none"> Provide a list of each data field (manufacturer, installation date, asset age, etc.) collected within PG&E's inventory for distribution and transmission equipment. Provide the percentage of missing data for each data field broken down by equipment type (transformer, circuit breaker, etc.). Explain how PG&E is determining the "expected life cycle" as well as "status of wear" for equipment, as described in OEIS Data Request 2, Question 9. In OEIS Data Request 2, Question 9, PG&E states that "Parameters such as age and status of wear of assets for Distribution equipment is still being verified and refined." What is PG&E's timeline for completion for this data? 	Kevin Miller	9/26/2022	9/29/2022	9/29/2022	1	7.3.4	Asset Management and Inspections	Asset Data Inventory
332	OEIS	Set 18	OEIS-PG&E-22-018	2	OEIS-PG&E-22-018_2	<p>Q02 Regarding PG&E's Response to Critical Issue RN-PG&E-22-05:</p> <ol style="list-style-type: none"> Provide the breakdown by calendar year quarter of Figure RN-PG&E-22-05-01 for tags opened and closed, including the number of tags closed that were backlogged. <p>PG&E's Quarterly Initiative Update states the following "Corrective Actions if Delayed" with respect to initiative C.10 10K Undergrounding:</p> <p>The scoping of the 2022 Undergrounding miles was not completed in a timely manner, which resulted in delays in August in getting work to estimating and into construction.</p> <ol style="list-style-type: none"> What was the approximate time period during which PG&E planned to complete the scoping of the 2022 undergrounding miles? Please provide a specific deadline or range, for example, "by the end of May 2022" or "between April 1 and July 15, 2022." What was the actual time period during which PG&E completed the scoping of the 2022 undergrounding miles? Please list all factors that contributed to the scoping of the 2022 undergrounding miles not being completed in a timely manner. Please list all measures PG&E plans to have in place in 2023 to mitigate the factors identified in part (c) from affecting the scoping of 2023 undergrounding miles. When does PG&E plan to complete the scoping of 2023 undergrounding miles? Please provide a beginning date and a target 	Kevin Miller	9/26/2022	9/29/2022	9/29/2022	1	7.3.4	Asset Management and Inspections	Tags/RN PG&E 22-05
333	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	1	CalAdvocates-PGE-2022WMP-34_1	<p>PG&E's Quarterly Initiative Update states the following "Corrective Actions if Delayed" with respect to initiative C.10 10K Undergrounding:</p> <p>The scoping of the 2022 Undergrounding miles was not completed in a timely manner, which resulted in delays in August in getting work to estimating and into construction.</p> <ol style="list-style-type: none"> What was the approximate time period during which PG&E planned to complete the scoping of the 2022 undergrounding miles? Please provide a specific deadline or range, for example, "by the end of May 2022" or "between April 1 and July 15, 2022." What was the actual time period during which PG&E completed the scoping of the 2022 undergrounding miles? Please list all factors that contributed to the scoping of the 2022 undergrounding miles not being completed in a timely manner. Please list all measures PG&E plans to have in place in 2023 to mitigate the factors identified in part (c) from affecting the scoping of 2023 undergrounding miles. When does PG&E plan to complete the scoping of 2023 undergrounding miles? Please provide a beginning date and a target 	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	C.10 - 10K Undergrounding	Quarterly Initiative Update

334	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	2	CalAdvocates-PGE-2022WMP-34_2	PG&E's Quarterly Initiative Update states the following "Corrective Actions If Delayed" with respect to initiative C.07 Temporary Distribution Microgrids: "The root cause of this delay was resource constraints and competing priorities." a) List the resources that were constrained with regard to initiative C.07, and what constraints existed for each. b) List the competing priorities and how each competing priority affected initiative C.07. c) At the time that PG&E set its targets for initiative C.07, did PG&E anticipate the resource constraints identified in part (a)? d) Why have the resource constraints identified in part (a) been more serious in 2022 than PG&E anticipated when it set its targets for initiative C.07? e) If the answer to part (c) is no, please explain how and when these resource constraints materialized. f) If the answer to part (c) is yes, please explain how PG&E planned to manage these resource constraints to meet its quarterly targets. g) At the time that PG&E set its targets for initiative C.07, did the competing priorities identified in part (b) exist? h) Why have the competing priorities identified in part (b) been more serious in 2022 than PG&E anticipated when it set its targets for initiative C.07? i) If the answer to part (g) is no, please explain how and when these competing priorities materialized. j) If the answer to part (g) is yes, please explain how PG&E planned to manage these resource constraints to meet its quarterly targets.	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	C.07 – Microgrid	Quarterly Initiative Update
335	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	3	CalAdvocates-PGE-2022WMP-34_3	PG&E's Quarterly Initiative Update states the following "Corrective Actions If Delayed" with respect to initiative C.06 Fuse Savers (Single Phase Reclosers) - Installations: The delay is driven by skilled resource and material priority being given to the new PSPS sectionalizing devices target, which was due by September 1, 2022, and to devices in support of EPSS. Additionally, due to process changes, IT/Electrical Business Systems has been unable to support SCADA screen builds, which caused delays in commissioning. a) Please state the reasons why skilled resource and material priority was shifted from initiative C.06 to the new PSPS sectionalizing devices target and EPSS. b) Please identify the skilled resources referenced in the quote above. c) Please describe any delays associated with the PSPS sectionalizing devices target or EPSS that led to priorities being shifted from initiative C.06. d) Please describe the process changes mentioned above that led IT/Electrical Business Systems to be unable to support SCADA screen builds. e) At the time that PG&E set its targets for initiative C.06, did PG&E expect to need to shift skilled resource and material priority to the PSPS sectionalizing devices target and EPSS? f) If the answer to part (e) is no, please explain how and when PG&E determined that it needed to shift skilled resource and material priority to the PSPS sectionalizing devices target and EPSS. g) If the answer to part (e) is yes, please explain how PG&E planned to manage skilled resource and material priority to meet its quarterly targets.	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	C.06 – Fuse Savers	Quarterly Initiative Update
336	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	4	CalAdvocates-PGE-2022WMP-34_4	PG&E's Quarterly Initiative Update states the following "Corrective Actions If Delayed" with respect to initiative C.05 SCADA Recloser Equipment - Installations: The delay was the result of material and resource priority being given to the new PSPS sectionalizing devices target, which was due by September 1, 2022, and to devices in support of EPSS. a) Please state the reasons why resource and material priority was shifted from initiative C.05 to the new PSPS sectionalizing devices target and EPSS. b) Please identify the resources referenced in the quote above. c) Please describe any delays associated with the PSPS sectionalizing devices target or EPSS that led to priorities being shifted from initiative C.05. d) At the time that PG&E set its targets for initiative C.05, did PG&E expect to need to shift resource and material priority to the PSPS sectionalizing devices target and EPSS? e) If the answer to part (d) is no, please explain how and when PG&E determined that it needed to shift resource and material priority to the PSPS sectionalizing devices target and EPSS. f) If the answer to part (d) is yes, please explain how PG&E planned to manage skilled resource and material priority to meet its quarterly targets.	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	C.05 – SCADA Reclosers	Quarterly Initiative Update
337	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	5	CalAdvocates-PGE-2022WMP-34_5	Table 1 of PG&E's Quarterly Data Report shows the following: Progress metric name 2022 Q2 2022 Q3 Level 1 findings in HFTD for detailed inspections - Distribution lines Level 2 findings in HFTD for detailed inspections - Distribution lines Level 3 findings in HFTD for detailed inspections - Distribution lines These numbers are substantially lower than equivalent numbers of inspection findings in 2019 through 2021. a) Please verify that the numbers listed above are accurate counts of the findings from 2022 detailed distribution inspections. If the numbers are inaccurate, provide corrected counts. b) If PG&E's detailed distribution inspections in either quarters 2 or 3 of 2022 have yielded significantly fewer findings (e.g. less than 5% of the average across the prior four quarters) compared to past quarters, please explain why. c) If PG&E's detailed distribution inspections in either quarters 2 or 3 of 2022 have yielded significantly fewer findings (e.g. less than 5% of the average across the prior four quarters) compared to past quarters, has PG&E initiated an internal investigation or audit to assess why? d) If the answer to part (c) is yes, please provide the results or preliminary findings from any such investigation or audit. e) If the answer to part (c) is no, please explain why PG&E has not felt it necessary to investigate these numbers. f) For each of the 7 ignitions described above, please list the following information: i. date, ii. time, iii. latitude, iv. longitude, v. HFTD tier at ignition location, vi. Size of the fire, vii. cause of the fire, and viii. a description of the utility work or operation that contributed to the ignition.	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	N/A	Quarterly Initiative Update
338	CalPA	Set WMP-34	CalAdvocates-PGE-2022WMP-34	6	CalAdvocates-PGE-2022WMP-34_6	Table 7.2 of PG&E's Quarterly Data Report shows that, in 2022, PG&E has recorded a total of 7 distribution ignitions in HFTD tiers 2 and 3 combined attributed to "Utility work / Operation." In all prior years, this value was either 0 or 1. a) Please verify that the number of distribution ignitions in HFTD attributed to "Utility work / Operation" is correct as stated above. If the numbers are inaccurate, provide corrected counts. b) Please explain why PG&E has recorded more distribution ignitions in 2022 in the HFTD associated with "Utility work / Operation" compared to past years. c) If PG&E has experienced more distribution ignitions in the HFTD associated with "Utility work / Operation" compared to past years, has PG&E initiated an internal investigation or audit to assess why? d) If the answer to part (c) is yes, please provide the results or preliminary findings from any such investigation or audit. e) If the answer to part (c) is no, please explain why PG&E has not felt it necessary to investigate these numbers. f) For each of the 7 ignitions described above, please list the following information: i. date, ii. time, iii. latitude, iv. longitude, v. HFTD tier at ignition location, vi. Size of the fire, vii. cause of the fire, and viii. a description of the utility work or operation that contributed to the ignition.	Holly Wehrman	11/17/2022	12/5/2022	12/5/2022	0	N/A	N/A	Quarterly Initiative Update
339	CalPA	Set WMP-35-CONF	CalAdvocates-PGE-2022WMP-35-CONF	1	CalAdvocates-PGE-2022WMP-35-CONF_1	On July 26, 2022, PG&E provided the RNR 04 and 09 and the Confidential Spreadsheet for RNR 04. The spreadsheet contains the circuit segments planned for its updated undergrounding projects for 2023 as well as undergrounding work which PG&E anticipate completing from 2024-2026. In total, PG&E has planned for 3,123 circuit miles for undergrounding from 2023 to 2026. PG&E noted that the data provided "is accurate as of June 13, 2022..." On December 9, 2022, PG&E served its Reply Briefs to the service list of the CPUC's Test Year 2023 General Rate Case Application 21-06-021. The Reply Brief states that "PG&E has since continued to evaluate its undergrounding plans and is adjusting the mileage pace in the 2023-2026 period as follows: 350 miles in 2023; 450 miles in 2024, 550 miles in 2025, and 750 miles in 2026, for a total of 2,100 miles during the 2023 GRC period [from 2023 to 2026]." Please provide the following of the updated, clean version of the Confidential Spreadsheet for RNR 04 reflecting the adjusted total of 2,100 miles of undergrounding planned from 2023 to 2026: a) Confidential version, and b) Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by internal entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update.	Matt Taul	12/16/2022	1/3/2023			Revision Notice	RN-04, RN-09	N/A
Pre-Discovery 01	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	1	CalAdvocates-PGE-2022WMP-02_1	Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by internal entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update.	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	17	7.3.4	Asset Management and Inspections	QA/QC Reports
Pre-Discovery 02	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	2	CalAdvocates-PGE-2022WMP-02_2	Please identify and provide a copy of all quality assurance or quality control (QA/QC) reports conducted by external entities that were completed since January 1, 2021 and that examined any programs, initiatives, or strategies described in your 2021 WMP Update. External entities include, but are not limited to, contractors, auditors, the Federal Monitor, and Independent Evaluators.	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	27	7.3.4	Asset Management and Inspections	QA/QC Reports
Pre-Discovery 03	CalPA	Set WMP-02	CalAdvocates-PGE-2022WMP-02	3	CalAdvocates-PGE-2022WMP-02_3	Provide an Excel table of all defects in the year 2021 found by Energy Safety's Compliance Branch (or, previously, the CPUC's Wildfire Safety Division) (as rows) that includes the following information in separate columns. a) Associated circuit name b) Defect type c) Description of defect d) WMP initiative associated with defect e) Date that the defect was identified f) Date that the defect was corrected g) Priority level of corresponding corrective tag h) Location of defect (latitude/longitude)	Alan Wehrman	12/17/2021	1/18/2022	1/18/2022	1	N/A	Miscellaneous	Additional Detail

Pre-Discovery 04	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	1	CalAdvocate s-PGE-2022WMP-03_1	Please note that the geographical regions are mutually exclusive (i.e., "Other HFTD" excludes areas that are in either Tier 2 or Tier 3). Therefore, for any given circuit-segment, the following relationships should hold: Tier 2 miles + Tier 3 miles + Other HFTD miles = total HFTD miles. Tier 2 miles + Tier 3 miles + Other HFTD miles + non-HFTD miles = total circuit-segment miles. Provide an Excel table of all distribution circuit-segments existing as of January 1, 2022 (as rows) that includes the following information in separate columns. For items (j) and (k), please include all relevant risk scores. For example, include vegetation risk score, conductor risk score, and any other driver-specific risk scores PG&E has developed. Please insert additional columns as needed to accommodate this. 6 a. Circuit name b. Circuit ID number c. Circuit-segment ID number d. Total circuit-segment miles e. Circuit-segment miles in Non-HFTD Areas f. Circuit-segment miles in Other HFTD g. Circuit-segment miles in HFTD Tier 2 h. Circuit-segment miles in HFTD Tier 3 i. Circuit-segment voltage j. Wildfire Risk Score(s) according to the wildfire risk model used for your 2021 WMP Update submission (may require multiple columns) k. Wildfire Risk Score(s) according to the wildfire risk model used for your 2022 WMP Update submission (may require multiple columns) l. Circuit SAIDI (System Average Interruption Duration Index) for 2021 m. Circuit SAIFI (System Average Interruption Frequency Index) for 2021 n. Circuit MAIFI (Momentary Average Interruption Frequency Index) for 2021 o. Number of times the circuit-segment was de-energized in a PSPS event in 2020. p. Number of times the circuit-segment was de-energized in a PPS event in 2021. q. Total minutes that the circuit-segment was de-energized due to PPS events in 2020 (sum of minutes across all PPS events). r. Total minutes that the circuit-segment was de-energized due to PPS events in 2021 (sum of minutes across all PPS events). s. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2020 (sum of customer-minutes across all PPS events). t. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2021 (sum of customer-minutes across all PPS events). Supplemental for Q2	Alan Wehrman	12/17/2021	2/8/2022	2/10/2022	1		N/A	Miscellaneous	Additional Detail
Pre-Discovery 05	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	2SUPP	CalAdvocate s-PGE-2022WMP-03_2SUPP	Provide an Excel table of all transmission circuit-segments existing as of January 1, 2022 (as rows) that includes the same information listed above in Question 1.	Alan Wehrman	12/17/2021	2/15/2022	2/15/2022	1		N/A	Miscellaneous	Additional Detail
Pre-Discovery 05	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	2	CalAdvocate s-PGE-2022WMP-03_2	Provide an Excel table of all transmission circuit-segments existing as of January 1, 2022 (as rows) that includes the same information listed above in Question 1.	Alan Wehrman	12/17/2021	2/8/2022	2/10/2022	1		N/A	Miscellaneous	Additional Detail
Pre-Discovery 06	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	3	CalAdvocate s-PGE-2022WMP-03_3	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) Provide the median amount of person-hours to perform a single climbing inspection of a transmission tower in 2021. b) Provide the total number of transmission towers that PG&E performed climbing inspections on in 2021.	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 07	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	4	CalAdvocate s-PGE-2022WMP-03_4	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) Provide the median amount of person-hours to perform a single drone inspection of a transmission tower in 2021. b) Provide the total number of transmission towers that PG&E performed drone inspections on in 2021.	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 08	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	5	CalAdvocate s-PGE-2022WMP-03_5	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) Provide the median amount of person-hours to perform a single detailed ground inspection of a transmission tower in 2021. b) Provide the total number of transmission towers that PG&E performed detailed ground inspections on in 2021.	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 09	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	6	CalAdvocate s-PGE-2022WMP-03_6	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) How many Priority A corrective tags were issued as a result of transmission tower climbing inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of transmission tower climbing inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 10	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	7	CalAdvocate s-PGE-2022WMP-03_7	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) How many Priority A corrective tags were issued as a result of transmission tower drone inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of transmission tower drone inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 11	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	8	CalAdvocate s-PGE-2022WMP-03_8	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. 10 a) How many Priority A corrective tags were issued as a result of transmission tower detailed ground inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of transmission tower detailed ground inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 12	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	9	CalAdvocate s-PGE-2022WMP-03_9	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) How many Priority A corrective tags were issued as a result of work verification or quality control of transmission tower climbing inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of work verification or quality control of transmission tower climbing inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 13	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	10	CalAdvocate s-PGE-2022WMP-03_10	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) How many Priority A corrective tags were issued as a result of work verification or quality control of transmission tower drone inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of work verification or quality control of transmission tower drone inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 14	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	11	CalAdvocate s-PGE-2022WMP-03_11	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) How many Priority A corrective tags were issued as a result of work verification or quality control of transmission tower detailed ground inspections performed in 2021? b) How many Priority B corrective tags were issued as a result of work verification or quality control of transmission tower detailed ground inspections performed in 2021?	Alan Wehrman	12/17/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discovery 15	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	12	CalAdvocate s-PGE-2022WMP-03_12	Please note that the geographical regions are mutually exclusive (i.e., "Other HFTD" excludes areas that are in either Tier 2 or Tier 3). Therefore, for any given circuit-segment, the following relationships should hold: Tier 2 miles + Tier 3 miles + Other HFTD miles = total HFTD miles. Tier 2 miles + Tier 3 miles + Other HFTD miles + non-HFTD miles = total circuit-segment miles. Provide an Excel table of all distribution circuit-segments that traverse HFTD areas (i.e., the segment has greater than 0 circuit-miles in HFTD) existing as of January 1, 2022 (as rows) that includes the following information in separate columns. For items (j) and (k), please include all relevant risk scores. For example, include vegetation risk score, conductor risk score, and any other driver-specific risk scores PG&E has developed. Please insert additional columns as needed to accommodate this. a. Circuit name b. Circuit ID number c. Circuit-segment ID number d. Total circuit-segment miles e. Circuit-segment miles in Non-HFTD Areas f. Circuit-segment miles in Other HFTD g. Circuit-segment miles in HFTD Tier 2 h. Circuit-segment miles in HFTD Tier 3 i. Circuit-segment voltage j. Wildfire Risk Score(s) according to the wildfire risk model used for your 2021 WMP Update submission (may require multiple columns) k. Wildfire Risk Score(s) according to the wildfire risk model used for your 2022 WMP Update submission (may require multiple columns) l. Number of times the circuit-segment was de-energized in a PPS event in 2020. m. Number of times the circuit-segment was de-energized in a PPS event in 2021. n. Total minutes that the circuit-segment was de-energized due to PPS events in 2020 (sum of minutes across all PPS events). o. Total minutes that the circuit-segment was de-energized due to PPS events in 2021 (sum of minutes across all PPS events). p. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2020 (sum of customer-minutes across all PPS events). q. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2021 (sum of customer-minutes across all PPS events).	Alan Wehrman	12/17/2021	2/8/2022	2/10/2022	0		N/A	Miscellaneous	Additional Detail
Pre-Discovery 15	CalPA	Set WMP-03	CalAdvocates-PGE-2022WMP-03	12 REV	CalAdvocate s-PGE-2022WMP-03_12 REV	Please note that the geographical regions are mutually exclusive (i.e., "Other HFTD" excludes areas that are in either Tier 2 or Tier 3). Therefore, for any given circuit-segment, the following relationships should hold: Tier 2 miles + Tier 3 miles + Other HFTD miles = total HFTD miles. Tier 2 miles + Tier 3 miles + Other HFTD miles + non-HFTD miles = total circuit-segment miles. Provide an Excel table of all distribution circuit-segments that traverse HFTD areas (i.e., the segment has greater than 0 circuit-miles in HFTD) existing as of January 1, 2022 (as rows) that includes the following information in separate columns. For items (j) and (k), please include all relevant risk scores. For example, include vegetation risk score, conductor risk score, and any other driver-specific risk scores PG&E has developed. Please insert additional columns as needed to accommodate this. a. Circuit name b. Circuit ID number c. Circuit-segment ID number d. Total circuit-segment miles e. Circuit-segment miles in Non-HFTD Areas f. Circuit-segment miles in Other HFTD g. Circuit-segment miles in HFTD Tier 2 h. Circuit-segment miles in HFTD Tier 3 i. Circuit-segment voltage j. Wildfire Risk Score(s) according to the wildfire risk model used for your 2021 WMP Update submission (may require multiple columns) k. Wildfire Risk Score(s) according to the wildfire risk model used for your 2022 WMP Update submission (may require multiple columns) l. Number of times the circuit-segment was de-energized in a PPS event in 2020. m. Number of times the circuit-segment was de-energized in a PPS event in 2021. n. Total minutes that the circuit-segment was de-energized due to PPS events in 2020 (sum of minutes across all PPS events). o. Total minutes that the circuit-segment was de-energized due to PPS events in 2021 (sum of minutes across all PPS events). p. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2020 (sum of customer-minutes across all PPS events). q. Total customer-minutes of de-energization on the circuit-segment due to PPS events in 2021 (sum of customer-minutes across all PPS events).	Alan Wehrman	12/17/2021	4/1/2022	4/1/2022	0		N/A	Miscellaneous	Additional Detail
Pre-Discovery 16	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	1	CalAdvocate s-PGE-2022WMP-04_1	For each POU to which you supply power, please respond to the following: Describe what coordination, planning, or other activities took place in 2021 between you and the POU to mitigate the effect of a potential PG&E-initiated PPS event on the POU and its customers.	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	0		8	PSPS	Communication with Publicly-Owned Utilities

Pre-Discove ry 17	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	2	CalAdvocate s-PGE- 2022WMP- 04_2	Provide a shapelle containing, as line features, the most recent spatial data for all circuit segments for which PG&E has used its Wildfire Distribution Risk Model to calculate circuit-segment-level expected risk. Include the following fields for each circuit-segment. For item (d), please include all relevant risk scores as separate attributes. For example, include vegetation risk score, conductor risk score, and all other driver-specific risk scores PG&E has developed. a) Circuit identification number b) Circuit name c) Circuit-segment identification number d) Circuit-segment Wildfire Risk Score (may require multiple columns)	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	1	7.1.F	Wildfire Mitigation Strategy	Wildfire Risk Data
Pre-Discove ry 18	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	3	CalAdvocate s-PGE- 2022WMP- 04_3	Regarding your PPS circuit modeling capabilities: a) Please describe your present circuit modeling capabilities with regard to PPS decision-making ("PPS circuit modeling capabilities"), including with what level of granularity they are able to determine how circuit hardening efforts or other changes to a line segment will affect PPS thresholds. b) Please describe any improvements to the present PPS circuit modeling capabilities that you expect to implement in 2022. c) Please describe the expected state of your PPS circuit modeling capabilities at the conclusion of the 2020-2022 WMP cycle.	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	0	8.1 and 8.2	PPSP	Additional Detail
Pre-Discove ry 19	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	4	CalAdvocate s-PGE- 2022WMP- 04_4	Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers. a) Provide the total number of transmission towers that PG&E forecasts performing climbing inspections on in 2022. b) Provide the total number of transmission towers that PG&E forecasts performing drone inspections on in 2022. c) Provide the total number of transmission towers that PG&E forecasts performing detailed ground inspections on in 2022.	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	0	7.3.4.2	Asset Management and Inspections	Detailed Inspections - Transmission
Pre-Discove ry 20	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	5 (a,b)	CalAdvocate s-PGE- 2022WMP- 04_5 (a,b)	For any program for which you forecast capital expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/4/2022	3/4/2022	1	3.1	Summary of Wildfire Mitigation Plan Initiative Expenditures	Additional detail on expenditures
Pre-Discove ry 20	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	5 (c-d)	CalAdvocate s-PGE- 2022WMP- 04_5 (c-d)	For any program for which you forecast capital expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/11/2022	3/4/2022	1	N/A	Miscellaneous	Additional Detail
Pre-Discove ry 20	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	5 (e)	CalAdvocate s-PGE- 2022WMP- 04_5 (e)	For any program for which you forecast capital expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/14/2022 (Noon)	3/14/2022	1	N/A	Miscellaneous	Additional Detail
Pre-Discove ry 21	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	6 (a,b)	CalAdvocate s-PGE- 2022WMP- 04_6 (a,b)	For any program for which you forecast operating expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: 7 a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/4/2022	3/4/2022	1	3.1	Summary of Wildfire Mitigation Plan Initiative Expenditures	Additional detail on expenditures
Pre-Discove ry 21	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	6 (c-d)	CalAdvocate s-PGE- 2022WMP- 04_6 (c-d)	For any program for which you forecast operating expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: 7 a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/11/2022	3/4/2022	1	N/A	Miscellaneous	Additional Detail
Pre-Discove ry 21	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	6 (e)	CalAdvocate s-PGE- 2022WMP- 04_6 (e)	For any program for which you forecast operating expenditures in 2022 to be at least two times actual expenditure in 2021, please provide: 7 a) The name of the program as it is identified in your 2022 WMP Update b) The WMP Initiative number in Table 12 of your 2022 WMP Update c) The name of the program as it is identified in your 2021 WMP Update d) The WMP Initiative number in Table 12 of your 2021 WMP Update e) An explanation for the projected increase.	Alan Wehrman	12/17/2021	3/14/2022 (Noon)	3/14/2022	0	N/A	Miscellaneous	Additional Detail
Pre-Discove ry 22	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	7	CalAdvocate s-PGE- 2022WMP- 04_7	Provide PG&E's workplan that describes where PG&E will undertake EVM projects in 2022. This workplan should be in an Excel format, with circuit-segments as rows. Please include the same information as in PG&E's Enhanced Oversight And Enforcement Process Corrective Action Plan 90-Day Report Pursuant To Resolution M-4852, November 4, 2021, Attachment E, columns 1-8. Please additionally include circuit-segment ID numbers that match those provided in response to Question 1 of Data Request CalAdvocates-PGE-2022WMP-03.	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	1	7.3.5.2	Vegetation Management (VM) and Inspections	Enhanced Vegetation Management
Pre-Discove ry 23	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	8	CalAdvocate s-PGE- 2022WMP- 04_8	Provide PG&E's workplan that describes where and when you will perform system hardening on distribution circuits in 2022. For projects that you expect to partially complete in 2022 (i.e. projects that started before 2022 and are expected to continue in 2022, or projects that are expected to be completed after 2022), please include the project and report the work that you forecast will actually be performed in calendar year 2022. This workplan should be in an Excel format, with circuit-segments as rows. For each project, include the following information, at a minimum: a) Circuit-segment ID number (corresponding to those provided in response to Questions 1 and 2 of Data Request CalAdvocates-PGE-2022WMP-03) associated with the project. b) Circuit-segment name c) Relevant wildfire risk score(s) d) The start date of the project. e) The expected completion date of the project. f) Length of covered conductor to be installed in 2022 in miles. g) Length of underground conductor to be installed in 2022 in miles. h) Length in miles of any other type of system hardening project to be installed in 2022 (if this is greater than zero, please describe the type of system hardening project).	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	1	7.3.3.17.1	Grid Design and System Hardening	System Hardening - Distribution
Pre-Discove ry 24	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	9	CalAdvocate s-PGE- 2022WMP- 04_9	Provide PG&E's workplan that describes where and when you will perform system hardening on transmission circuits in 2022. Include the same information detailed in the preceding question.	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	1	7.3.3.17.2	Grid Design and System Hardening	System Hardening - Transmission
Pre-Discove ry 25	CalPA	Set WMP-04	CalAdvocates-PGE-2022WMP-04	10	CalAdvocate s-PGE- 2022WMP- 04_10	Please provide or aggregate information related to system hardening in the tables below. Note: in PG&E's 2021 WMP Update, this information was aggregated into Section 7.3.3.17.1 "Updates to grid topology to minimize risk of ignition in HFTDs, System Hardening, Distribution" in Table 12. a. Please fill out the table below, disaggregating the actual and projected spending amounts as shown. Add extra columns as needed. Total Line Removal Relocation of Overhead to Underground Covered Conductor Other (please explain) 2021 expenditures (actual) 2022 expenditures (projected) b. Please fill out the table below, providing the actual or projected number of miles treated by that method per year. Add extra columns as needed. Total Miles Treated Line Removal Relocation of Overhead to Underground Covered Conductor Other (please explain) 2021 (actual) 2022 (projected)	Alan Wehrman	12/17/2021	2/25/2022	2/25/2022	0	7.3.3.17.1	Grid Design and System Hardening	System Hardening - Distribution
Pre-Discove ry 26	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	1	CalAdvocate s-PGE- 2022WMP- 05_1	Questions 1-3 relate to the article Humboldt County issues Stop Work Order, PG&E Removes Contractor on EVM in Sohum After Complaints/Video by Residents, published in Redheaded Blackbelt on December 16, 2021 (the article).2 This article describes activities performed by a contractor allegedly performing EVM work for PG&E in Humboldt County. Question 1 The article alleges that a contractor, KDF, was performing EVM work for PG&E in Humboldt County, on Thomas Road in the Salmon Creek watershed, on or around December 16, 2021. a) Is it accurate that KDF was in this area performing EVM work at this time for PG&E? b) Please provide GIS files that show where KDF has performed EVM work for PG&E in Humboldt County in 2021.	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	1	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 27	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	2	CalAdvocate s-PGE- 2022WMP- 05_2	Question 2 a) Is KDF still engaged with PG&E to perform EVM work? b) Is KDF currently engaged with PG&E as a contractor for any work other than EVM?	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 28	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	3	CalAdvocate s-PGE- 2022WMP- 05_3	Question 3 The article alleges that the contractor, KDF, did not have an encroachment permit to do road work on Thomas Road in the Salmon Creek watershed. a) Is it accurate that KDF did not have an encroachment permit to do road work in the area described, as alleged in the article? b) If the answer to part (a) is yes, please explain why KDF did not secure the proper permits prior to performing the work.	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 29	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	4	CalAdvocate s-PGE- 2022WMP- 05_4	Question 4 The article alleges that KDF had left logs and chips in the ditch, plugged culverts, and damaged the shoulders of a road. Are these allegations accurate with respect to KDF's work in this area? If not, please describe the inaccuracies or omissions in the article.	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 30	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	5	CalAdvocate s-PGE- 2022WMP- 05_5	Question 5 The article states that a PG&E spokesperson confirmed that KDF "did not complete the work to [PG&E's] satisfaction." a) Is PG&E aware of other instances during 2021 in which KDF did not complete EVM work to PG&E's satisfaction? b) If the answer to part (a) is yes, please list all such instances, including i. the location of the work, ii. the date(s) of the work, and iii. the reasons that the work was unsatisfactory.	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 31	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	6	CalAdvocate s-PGE- 2022WMP- 05_6	Question 6 Following the August CZU Lightning Complex Fire in the Santa Cruz Mountains in 2020, PG&E received several complaints from local governments regarding contractors failing to secure appropriate permits and causing erosion on narrow roads.3 a) Following these complaints, what specific actions did PG&E take to improve contractor performance? b) Following these complaints, what specific actions did PG&E take to reduce similar problems in the future?	Alan Wehrman	12/23/2021	1/24/2022	1/10/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discove ry 32	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	7	CalAdvocate s-PGE- 2022WMP- 05_7	Question 7 List all instances in 2020 and 2021 that PG&E is aware of in which a local government has complained to or about PG&E regarding vegetation management work performed by PG&E or a contractor of PG&E. For each such instance, please state: a) The name of the local government making the complaint b) The date range of the work in question c) What program was concerned (e.g., EVM, routine VM, or CEMA patrols) d) Whether the work was performed by PG&E employees or contractors e) If the work was performed by contractors, the name of the contractor firm.	Alan Wehrman	12/23/2021	1/24/2022	1/24/2022	1	7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous

Pre-Discovery 32	CalPA	Set WMP-05	CalAdvocates-PGE-2022WMP-05	7 SUPP	CalAdvocates-PGE-2022WMP-05_7 SUPP	Supplemental for Q7 List all instances in 2020 and 2021 that PG&E is aware of in which a local government has complained to or about PG&E regarding vegetation management work performed by PG&E or a contractor of PG&E. For each such instance, please state: a) The name of the local government making the complaint b) The date range of the work in question c) What program was concerned (e.g., EVM, routine VM, or CEMA patrols) d) Whether the work was performed by PG&E employees or contractors e) If the work was performed by contractors, the name of the contracting firm	Alan Wehrman	12/23/2021	1/24/2022	1/24/2022	1		7.3.5.2	Vegetation Management (VM) and Inspections	Miscellaneous
Pre-Discovery 33	CalPA	Set WMP-06	CalAdvocates-PGE-2022WMP-06	1	CalAdvocates-PGE-2022WMP-06_1	The following questions relate to the PG&E Independent Monitor Report of November 19, 2021, Kirkland & Ellis LLP, filed on November 23, 2021 (the Monitor's 2021 report). 1 The Monitor's 2021 report describes an ignition that occurred on June 16, 2021. The report states that PG&E's Preliminary Ignition Investigation Report (PIIR) attributed the ignition to "a rotten and decayed secondary, wooden cross arm failing and igniting the light, flash fuels below the pole." 3 a) Please provide a copy of the Preliminary Ignition Investigation Report mentioned above. b) Please provide copies of any additional PG&E investigation reports associated with the ignition mentioned above. c) Was the cross arm described above located in an HFTD? If so, which tier? d) Please provide the latitude and longitude of the cross arm. 2 The monitor's 2021 report states: "The cross arm was first identified in connection with an August 19, 2019 patrol. The tag had a due date of February 19, 2020 (a 6-month Priority E tag). The repair was permitted and ready for construction in April 2020 (which was already late), but was never completed. On September 10, 2020, the notification was reassessed and the crew lead requested that the work be expedited before the 2021 fire season (that is, August 30, 2021)." 4 a) In reference to the above, why was the expedited work for April 2020 not completed? b) Please explain what is meant above by "the crew lead requested that the work be expedited before the 2021 fire season." For example, did the crew open a new tag, or increase the priority of the existing tag? c) In reference to the above, why was the expedited work that was requested on September 10, 2020 not completed? d) As of June 16, 2021, what was the priority of the tag on this program discussed above?	Alan Wehrman	12/23/2021	1/10/2022	1/10/2022	2		7.3.3.5	Crossarm Maintenance	Miscellaneous
Pre-Discovery 34	CalPA	Set WMP-06	CalAdvocates-PGE-2022WMP-06	2	CalAdvocates-PGE-2022WMP-06_2	Question 3 P. 37 of the Monitor's 2021 report describes PG&E's Field Safety Reassessments (FSR) process, in which unresolved tags are periodically reviewed. a) Was the September 10, 2020 reassessment described in Question 2 part of PG&E's FSR process? b) Please provide copies of all inspection reports related to the tag on the crossarm described in Question 2, including FSR inspections, that occurred between the date the tag was originally opened and June 16, 2021. Question 4 The Monitor's 2021 report states: "As of the date of the PIIR, there were 1290 open notifications on the same circuit associated with common ignition drivers, of which 886 were past due and 256 were due within six months. Of these, 66 open notifications were associated with cross arms, of which 55 were past due and 11 were due within six months." 5 a) Following the ignition on June 16, 2021, did PG&E reinspect or otherwise assess the 886 past due tags described above? b) Describe all actions that PG&E has taken since the ignition on June 16, 2021, to mitigate the risk of another ignition associated with a past-due tag on its system.	Alan Wehrman	12/23/2021	1/14/2022	1/14/2022	0		7.3.3.5	Crossarm Maintenance	Miscellaneous
Pre-Discovery 35	CalPA	Set WMP-06	CalAdvocates-PGE-2022WMP-06	3	CalAdvocates-PGE-2022WMP-06_3	Question 5 a) Does PG&E have a plan to address the late tags that exist on its system in HFTD? b) If the answer to part (a) is yes, will this plan be described in PG&E's 2022 WMP? c) If the answer to part (a) is no, please explain why not.	Alan Wehrman	12/23/2021	1/14/2022	1/14/2022	4		7.3.3.5	Crossarm Maintenance	Miscellaneous
Pre-Discovery 36	CalPA	Set WMP-06	CalAdvocates-PGE-2022WMP-06	4	CalAdvocates-PGE-2022WMP-06_4	Question 5 a) Does PG&E have a plan to address the late tags that exist on its system in HFTD? b) If the answer to part (a) is yes, will this plan be described in PG&E's 2022 WMP? c) If the answer to part (a) is no, please explain why not.	Alan Wehrman	12/23/2021	1/14/2022	1/14/2022	0		7.3.3.5	Crossarm Maintenance	Miscellaneous
Pre-Discovery 37	CalPA	Set WMP-06	CalAdvocates-PGE-2022WMP-06	5	CalAdvocates-PGE-2022WMP-06_5	Question 5 a) Does PG&E have a plan to address the late tags that exist on its system in HFTD? b) If the answer to part (a) is yes, will this plan be described in PG&E's 2022 WMP? c) If the answer to part (a) is no, please explain why not.	Alan Wehrman	12/23/2021	1/14/2022	1/14/2022	0		7.3.4	Asset Management and Inspections	Additional Detail
Pre-Discovery 38	CalPA	Set WMP-07	CalAdvocates-PGE-2022WMP-07	1	CalAdvocates-PGE-2022WMP-07_1	Question 5 a) Does PG&E have a plan to address the late tags that exist on its system in HFTD? b) If the answer to part (a) is yes, will this plan be described in PG&E's 2022 WMP? c) If the answer to part (a) is no, please explain why not.	Alan Wehrman	12/23/2021	2/1/2022	2/1/2022	0		7.3.3.17.1	Grid Design and System Hardening	System Hardening
Pre-Discovery 39	CalPA	Set WMP-07	CalAdvocates-PGE-2022WMP-07	2	CalAdvocates-PGE-2022WMP-07_2	Please provide a GIS file showing where PG&E completed distribution system hardening work in 2021, in accordance with section 7.3.3.17.1 its 2021 Revised WMP.	Alan Wehrman	12/23/2021	2/1/2022	2/1/2022	1		7.3.3.17.1	Grid Design and System Hardening	System Hardening
Pre-Discovery 40	CalPA	Set WMP-07	CalAdvocates-PGE-2022WMP-07	3	CalAdvocates-PGE-2022WMP-07_3	The November 23, 2021 Federal Monitor's report states: In 2021, the Monitor team conducted an in-field review of 1,628 distribution structures in HFTDs that had been inspected by PG&E. Approximately 27% of the structures had potential exceptions related to field conditions, for a total of 583 missed field issues by PG&E inspectors across 435 structures. Approximately 31% of the structures had potential exceptions related to recordkeeping, for a total of 642 potential exceptions by PG&E inspectors across 507 structures. 4 a) Please describe all actions that PG&E has taken in 2021 to improve the quality of its distribution inspections to reduce the number of potential exceptions in the future. b) Has PG&E performed any re-inspections or inspection validation efforts following the findings of the Federal Monitor, described above? c) If the answer to part (b) is yes, please describe those efforts. d) If the answer to part (b) is no, please explain why not.	Alan Wehrman	12/23/2021	2/1/2022	2/1/2022	0		7.3.4.1	Asset Management and Inspections	Inspections - Distribution
Pre-Discovery 41	CalPA	Set WMP-07	CalAdvocates-PGE-2022WMP-07	4	CalAdvocates-PGE-2022WMP-07_4	In 2021, the Monitor team inspected 304 electric transmission structures via PG&E aerial photography records. Approximately 47% of the steel structures inspected had potential exceptions, for a total of 160 missed issues across 88 structures. Approximately 53% of the wood structures also had potential exceptions, for a total of 136 missed issues across 76 structures. 6 a) Please describe all actions that PG&E has taken in 2021 to improve the quality of its aerial transmission inspections to reduce the number of potential exceptions in the future. b) Has PG&E performed any re-inspections or inspection validation efforts following the findings of the Federal Monitor, described above? c) If the answer to part (b) is yes, please describe those efforts. d) If the answer to part (b) is no, please explain why not.	Alan Wehrman	12/23/2021	2/1/2022	2/1/2022	0		7.3.4.2	Asset Management and Inspections	Inspections - Transmission
Pre-Discovery 42	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	1	CalAdvocates-PGE-2022WMP-08_1	The following questions relate to the PG&E Independent Monitor Report of November 19, 2021, Kirkland & Ellis LLP, filed on November 23, 2021 (the Monitor's 2021 report). 3 and PG&E's responses to Data Request CalAdvocates-PGE-2022WMP-06, dated January 10 and 14, 2022. PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06 states that the ignition occurring on June 21, 2021 was CPUC reportable. 4 a) Please provide a copy of each ignition report (for the ignition referenced above) that PG&E submitted to the CPUC. b) If PG&E did not submit any ignition reports for the ignition referenced above, please explain why not. 3 Kirkland & Ellis LLP, PG&E Independent Monitor Report of November 19, 2021 (Case No. 14-CR-00175-WHA Doc. No. 1524-1), November 23, 2021, p. 31. 4 PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06, Question 1, Attachment 1, p. 1.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0		N/A	Miscellaneous	Additional Detail
Pre-Discovery 43	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	2	CalAdvocates-PGE-2022WMP-08_2	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06 includes an inspection report from June 13, 2021 with the finding "Open Wire Service (to weatherhead) or Open Wire Secondary at this location." 5 a) Please explain what is meant by this finding. b) Please define "Open Wire Service (to weatherhead)." c) Please define "Open Wire Secondary." 5 PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06, Question 3, Attachment 4, p. 2.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0		7.3.4	Asset Management and Inspections	Additional Details

Pre-Discovery 44	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	3	CalAdvocates-PGE-2022WMP-08_3	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06 includes an inspection report from June 13, 2021 which lists no "damage or compelling abnormal conditions" in all categories except "Other Required Data." 6 Regarding this inspection: a) It is Cal Advocates' understanding that, as of June 13, 2021, the crossarm that failed on June 16 still had open electric corrective notifications because the maintenance issues previously flagged in 2019 and 2020 had not been remediated. Is this correct? b) Please explain why the inspector did not note any damage to the crossarm during this inspection. c) State what PG&E inspection protocol(s) the inspector used on June 13, 2021 for this inspection. d) List the regulations and internal standards against which the inspector was supposed to verify compliance in this inspection on June 13, 2021. e) Has PG&E's management identified any flaws or shortcomings in the performance of this particular inspection? f) If the answer to part (e) is yes, please describe what action(s) PG&E has taken to address the identified flaws or shortcomings in the performance of this particular inspection. 6 PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0	7.3.3.5	Crossarm Maintenance	Miscellaneous
Pre-Discovery 45	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	4	CalAdvocates-PGE-2022WMP-08_4	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06 includes an inspection report from June 13, 2021. Regarding this inspection: a) Since June 16, 2021, has PG&E performed any quality control or reinspection activities to validate the completeness and accuracy of other inspections performed by the individual who performed the inspection on June 13, 2021? b) If the answer to part (a) is yes, please list and describe the specific actions PG&E has taken. c) If the answer to part (a) is no, please explain why not.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0	7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections
Pre-Discovery 46	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	5 SUPP	CalAdvocates-PGE-2022WMP-08_5 SUPP	Final ACE reports for 11 ignitions in 2021	Holly Wehrman	1/28/2022	4/8/2022	4/29/2022	2	7.3.7	Data Governance	Asset Failure Analysis
Pre-Discovery 46	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	5 (a,b)	CalAdvocates-PGE-2022WMP-08_5 (a,b)	The January 2021 report states, "For example, PG&E recently established Asset Failure Analysis Team causally connected a June 2021 ignition to a broken cross arm." 7 a) When was PG&E's Asset Failure Analysis Team established? b) Please provide a brief description of the purpose and activities of the Asset Failure Analysis Team. c) Please describe what, if any, work product is produced by the Asset Failure Analysis Team (for example, written reports or presentations). d) Please describe any changes or improvements to WMP initiatives that have resulted from activities performed by the Asset Failure Analysis Team. e) Is the Asset Failure Analysis Team discussed in PG&E's 2022 WMP Update? Please provide a reference to the appropriate section, if yes. f) Please describe how the Asset Failure Analysis Team causally connected the June 2021 ignition to the broken crossarm. g) Has the Asset Failure Analysis Team causally connected other ignitions that occurred in 2021 to failed assets with existing corrective notifications? h) If the answer to part (g) is yes, please list such ignitions, their cause, and provide copies of associated reports or investigations performed by the Asset Failure Analysis Team. 7 a) When was PG&E's Asset Failure Analysis Team established? b) Please provide a brief description of the purpose and activities of the Asset Failure Analysis Team. c) Please describe what, if any, work product is produced by the Asset Failure Analysis Team (for example, written reports or presentations). d) Please describe any changes or improvements to WMP initiatives that have resulted from activities performed by the Asset Failure Analysis Team. e) Is the Asset Failure Analysis Team discussed in PG&E's 2022 WMP Update? Please provide a reference to the appropriate section, if yes. f) Please describe how the Asset Failure Analysis Team causally connected the June 2021 ignition to the broken crossarm. g) Has the Asset Failure Analysis Team causally connected other ignitions that occurred in 2021 to failed assets with existing corrective notifications? h) If the answer to part (g) is yes, please list such ignitions, their cause, and provide copies of associated reports or investigations performed by the Asset Failure Analysis Team.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0	7.3.7	Data Governance	Asset Failure Analysis
Pre-Discovery 46	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	5 (c-h)	CalAdvocates-PGE-2022WMP-08_5 (c-h)	The January 2021 report states, "For example, PG&E recently established Asset Failure Analysis Team causally connected a June 2021 ignition to a broken cross arm." 7 a) When was PG&E's Asset Failure Analysis Team established? b) Please provide a brief description of the purpose and activities of the Asset Failure Analysis Team. c) Please describe what, if any, work product is produced by the Asset Failure Analysis Team (for example, written reports or presentations). d) Please describe any changes or improvements to WMP initiatives that have resulted from activities performed by the Asset Failure Analysis Team. e) Is the Asset Failure Analysis Team discussed in PG&E's 2022 WMP Update? Please provide a reference to the appropriate section, if yes. f) Please describe how the Asset Failure Analysis Team causally connected the June 2021 ignition to the broken crossarm. g) Has the Asset Failure Analysis Team causally connected other ignitions that occurred in 2021 to failed assets with existing corrective notifications? h) If the answer to part (g) is yes, please list such ignitions, their cause, and provide copies of associated reports or investigations performed by the Asset Failure Analysis Team.	Alan Wehrman	1/28/2022	3/4/2022	3/8/2022	0	7.3.7	Data Governance	Asset Failure Analysis
Pre-Discovery 47	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	6	CalAdvocates-PGE-2022WMP-08_6	What date does PG&E define as the start of the 2021 fire season? 8 PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06, Question 2.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0	N/A	Miscellaneous	Additional Detail
Pre-Discovery 48	CalPA	Set WMP-08	CalAdvocates-PGE-2022WMP-08	7	CalAdvocates-PGE-2022WMP-08_7	PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06 states that, as of June 16, 2021, the priority of the corrective notification associated with the failed crossarm was priority E. 9 Why was the corrective notification never re-prioritized above priority E during the period of February 19, 2020 to June 16, 2021? 9 PG&E's response to Data Request CalAdvocates-PGE-2022WMP-06, Question 2.	Alan Wehrman	1/28/2022	2/25/2022	2/25/2022	0	7.3.4	Asset Management and Inspections	Additional Detail
Pre-Discovery 49	CalPA	Set WMP-09	CalAdvocates-PGE-2022WMP-09	1	CalAdvocates-PGE-2022WMP-09_1	Provide an Excel table listing (as rows) all corrective notifications on electric distribution circuits that were open as of February 1, 2022, and located in HFTD areas. The table should include the following information in separate columns: a. Notification identification (ID) number b. Name of the associated circuit c. ID number of the associated circuit d. HFTD tier e. Functional location f. Geographic latitude in decimal degrees, truncated to seven decimal places g. Geographic longitude in decimal degrees, truncated to seven decimal places h. Date the notification was originally opened i. Priority of the original notification (please use PG&E's internal system of A, B, E, etc.) j. Due date of the original notification k. Object/damage code (see definitions) l. Date(s) the notification was reinspected or modified, if any m. Priority of the notification after it was reinspected or modified, if applicable n. Due date of the notification after it was reinspected or modified, if applicable	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	1	7.3.4	Asset Management and Inspections	Additional Detail - Distribution
Pre-Discovery 50	CalPA	Set WMP-09	CalAdvocates-PGE-2022WMP-09	2	CalAdvocates-PGE-2022WMP-09_2	Provide an Excel table listing (as rows) all corrective notifications on electric transmission circuits that were open as of February 1, 2022, and located in HFTD areas. The table should include the same information requested in Question 1.	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	1	7.3.4	Asset Management and Inspections	Additional Detail - Transmission
Pre-Discovery 51	CalPA	Set WMP-09	CalAdvocates-PGE-2022WMP-09	3	CalAdvocates-PGE-2022WMP-09_3	Provide an Excel table listing (as rows) all corrective notifications on electric substations that were open as of February 1, 2022, and located in HFTD areas. The table should include the information requested in Question 1.	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	1	7.3.4	Asset Management and Inspections	Additional Detail - Substations
Pre-Discovery 52	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	1	CalAdvocates-PGE-2022WMP-10_1	Provide the number of tree attachments existing in PG&E's system as of February 1, 2022 in each of the following categories: a) Total b) HFTD Tier 3 c) HFTD Tier 2 d) Other HFTD e) Non-HFTD	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0	7.3.3	Grid Design and System Hardening	Tree Attachments
Pre-Discovery 53	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	2	CalAdvocates-PGE-2022WMP-10_2	How many tree attachments did PG&E remediate in calendar year 2021 in each of the following categories: a) Total b) HFTD Tier 3 c) HFTD Tier 2 d) Other HFTD e) Non-HFTD	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0	7.3.3	Grid Design and System Hardening	Tree Attachments
Pre-Discovery 54	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	3	CalAdvocates-PGE-2022WMP-10_3	How many tree attachments does PG&E plan to remediate in calendar year 2022 in each of the following categories: a) Total b) HFTD Tier 3 c) HFTD Tier 2 d) Other HFTD e) Non-HFTD	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0	7.3.3	Grid Design and System Hardening	Tree Attachments
Pre-Discovery 55	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	4	CalAdvocates-PGE-2022WMP-10_4	When PG&E performs undergrounding in the HFTD for wildfire mitigation purposes, in places where other utilities (such as telecommunications providers) share PG&E's poles: a) Please describe PG&E's current policy regarding undergrounding the other utilities' equipment. b) Please describe PG&E's current policy regarding removal of the shared poles. c) Please describe PG&E's current policy regarding ownership of the shared poles after electric conductors have been placed underground. d) Please describe PG&E's approach to co-trenching with utilities that share PG&E's poles, if any. e) What is PG&E's current regarding undergrounding other utilities' equipment in locations with limited ingress and egress, such as evacuation corridors from rural communities? f) What is PG&E's current policy regarding removal of shared poles in locations with limited ingress and egress, such as evacuation corridors from rural communities?	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 56	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	5	CalAdvocates-PGE-2022WMP-10_5	During the field visit to PG&E facilities on November 2, 2021, Cal Advocates visited an undergrounding project in El Dorado County, which was referred to as "Undergrounding Project El Dorado 2101 Phase 4." During the visit PG&E representatives represented that, after the powerline was moved underground, the poles would be "topped," which would remove a portion of the pole but leave the remainder of the pole intact to support telecommunications utility infrastructure. a) Is the above representation accurate with respect to the Undergrounding Project El Dorado 2101 Phase 4? b) If the answer to part (a) is no, please correct any misrepresentations.	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 57	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	6	CalAdvocates-PGE-2022WMP-10_6	During the field visit to PG&E facilities on November 2, 2021, Cal Advocates visited an undergrounding project in El Dorado County, which was referred to as "Undergrounding Project El Dorado 2101 Phase 4." During the visit PG&E representatives represented that, after the powerline was moved underground, the poles would be "topped," which would remove a portion of the pole but leave the remainder of the pole intact to support telecommunications utility infrastructure. a) Is this representative of PG&E's practice when undergrounding powerlines that share poles with other utilities? b) If not, please describe PG&E's typical practice in such circumstances.	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 58	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	7	CalAdvocates-PGE-2022WMP-10_7	Per PG&E's response to Data Request CalAdvocates-PGE-2022WMP-03, Question 1, PG&E installed approximately 109 circuit-miles of underground conductor in HFTDs in 2021. a) Please verify that the above number of circuit-miles is accurate. b) Noting that multiple circuits may sometimes run in parallel through the same right-of-way, how many miles of right-of-way did PG&E's 2021 undergrounding work affect in HFTDs? c) Among the miles of right-of-way undergrounded in HFTDs in 2021, how many miles of telecommunications did PG&E co-trench? d) Of the miles undergrounded in HFTDs in 2021, on how many miles of right-of-way did PG&E remove the poles? e) Of the miles undergrounded in HFTDs in 2021, on how many miles of right-of-way did PG&E top the poles?	Holly Wehrman	2/15/2022	3/7/2022	3/7/2022	0	7.3.3.16	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 59	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	8	CalAdvocates-PGE-2022WMP-10_8	a) Has PG&E identified transportation corridors within its service territory where falling or failing lines or poles could currently limit egress and/or ingress during an emergency? b) If the answer to part (a) is yes, please describe how PG&E identifies such transportation corridors. c) If available, please provide a geospatial data file that contains all current identified transportation corridors with ingress and egress hazards.	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	0	7.3.9	Emergency Planning and Preparedness	Additional Detail
Pre-Discovery 60	CalPA	Set WMP-10	CalAdvocates-PGE-2022WMP-10	9	CalAdvocates-PGE-2022WMP-10_9	In its responses to Data Request CalAdvocates-PGE-2022WMP-07, Questions 3 and 4, PG&E stated that it is performing Quality Reviews of past inspections, both of which were expected to be complete by February 28, 2022. Please provide copies of these Quality Reviews, if available. If the Quality Reviews have not been completed as of the date of your response to this Data Request, provide copies as soon as they are complete.	Holly Wehrman	2/15/2022	3/2/2022	3/2/2022	2	7.3.4.14	Asset Management and Inspections	Quality Assurance/Quality Control of Inspections

Pre-Discovery 61	OEIS	Set 002	OEIS-PG&E-22-002	1	OEIS-PG&E-22-002_1	Q01. As a follow up to the answer received from DR-001, which asked: "In PG&E's cover letter to its Submission of 2022 Wildfire Mitigation Plan Maturity Model Assessment submitted February 4, 2022, PG&E states: "in addition to our internal review of the questions and the scores, this year we were also able to benchmark with Southern California Edison Company (SCE) and San Diego Gas & Electric Company (SDG&E) regarding the Survey. These benchmarking discussions were very helpful, especially to understand how the other utilities were interpreting certain questions and approaching the response to those questions. This benchmarking resulting in a re-evaluation of some of our scores based on feedback from the other utilities." Energy Safety would like to know the following: To which questions of the 2022 Wildfire Mitigation Plan Maturity Model Assessment answered by PG&E does this above notice apply?," please answer the below questions: Energy Safety requires like data for comparison across a three-year Maturity Survey for the years 2020, 2021, and 2022 to determine whether the utility has truly progressed or regressed. To help ensure accuracy in comparison of re-interpreted responses to the same questions from the 2020 and 2021 surveys, for each of the 41 questions re-interpreted in answering the 2022 Maturity Survey, please provide the following: a. How was this specific question re-interpreted? b. What would PG&E's answer to the question have been had it been answered in the same way it was interpreted in the 2020 and 2021 Maturity Surveys submitted by PG&E?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0		N/A	Miscellaneous	Maturity Survey
Pre-Discovery 62	OEIS	Set 002	OEIS-PG&E-22-002	2	OEIS-PG&E-22-002_2	A. Risk mapping and simulation Q02. Regarding PG&E's response to Maturity Survey question A.V.b (How automated is the mechanism to determine whether to update algorithms based on deviations?): a. How is PG&E planning to increase automation for algorithm updates based on deviations? b. How does PG&E currently perform partial (<50%) automation for this task?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.1	Risk Assessment and Mapping	Survey Responses	
Pre-Discovery 63	OEIS	Set 002	OEIS-PG&E-22-002	3	OEIS-PG&E-22-002_3	Q03. Regarding PG&E's response to Maturity Survey question A.V.c (How are deviations from risk model to ignitions and propagation detected?): a. Describe how PG&E "manually" checks deviations between the risk model to ignitions and propagation detection. b. Provide PG&E's plan to progress to a semi-automated for this check by January 1, 2023.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.1	Risk Assessment and Mapping	Survey Responses	
Pre-Discovery 64	OEIS	Set 002	OEIS-PG&E-22-002	4	OEIS-PG&E-22-002_4	C. Grid design and system hardening Q04. Regarding PG&E's response to Maturity Survey question C.II.a (Does grid design meet minimum G095 requirements and loading standards in HFTD areas?): a. Describe how PG&E plans to exceed GO 95 requirements by January 1, 2023.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 65	OEIS	Set 002	OEIS-PG&E-22-002	5	OEIS-PG&E-22-002_5	Q05. Regarding PG&E's response to Maturity Survey question C.III.a (What level of redundancy does the utility's transmission architecture have?): a. Provide the percentage of circuits that have n-1 redundancy. b. Provide PG&E's plan to increase level of redundancy for transmission circuits.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 66	OEIS	Set 002	OEIS-PG&E-22-002	6	OEIS-PG&E-22-002_6	Q06. Regarding PG&E's response to Maturity Survey question C.III.c (What level of sectionalization does the utility's distribution architecture have?): a. Provide the percentage of circuits that have more than 2000 customers within one switch. b. Describe PG&E's plan to isolate circuits to reduce the number of customers within one switch.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 67	OEIS	Set 002	OEIS-PG&E-22-002	7	OEIS-PG&E-22-002_7	Q07. Regarding PG&E's response to Maturity Survey question C.III.d (How does the utility consider egress points in its grid topology?): a. Given PG&E "does not consider" egress as part of its grid topology design, how does PG&E currently factor and account for egress into wildfire and safety risks? b. How is PG&E planning to input egress into grid topology design moving forward?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 68	OEIS	Set 002	OEIS-PG&E-22-002	8	OEIS-PG&E-22-002_8	Q08. Regarding PG&E's response to Maturity Survey question C.IV.d (What grid hardening initiatives does the utility include within its evaluation?): a. Define PG&E's understanding of what "Some" and "Most" include when considering grid hardening initiatives. b. How does PG&E plan to move from considering some hardening initiatives to most by January 1, 2023?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 69	OEIS	Set 002	OEIS-PG&E-22-002	9	OEIS-PG&E-22-002_9	D. Asset management and inspections Q09. Regarding PG&E's response to Maturity Survey question D.I.a (What information is captured in the equipment inventory database?): a. Describe why PG&E moved from having an "accurate inventory of equipment" to "no service territory-wide inventory" from 2021 to 2022. Include any lessons learned from benchmarking with other utilities. b. Provide an estimated percentage of the equipment currently within PG&E's inventory. c. Provide PG&E's plan to move towards an accurate inventory service territory-wide, including integration of inspections and repairs, by January 1, 2023.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.4	Asset Management and Inspections	Survey Responses	
Pre-Discovery 70	OEIS	Set 002	OEIS-PG&E-22-002	10	OEIS-PG&E-22-002_10	Q10. Regarding PG&E's response to Maturity Survey question D.I.c (Does all equipment in HFTD areas have the ability to detect and respond to malfunctions?): a. Why does PG&E only update asset condition annually? b. Provide all existing bottlenecks that prevent PG&E from updating its asset conditions more frequently, including any plans to alleviate such bottlenecks.	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.4	Asset Management and Inspections	Survey Responses	
Pre-Discovery 71	OEIS	Set 002	OEIS-PG&E-22-002	11	OEIS-PG&E-22-002_11	Q11. Regarding PG&E's response to Maturity Survey question D.IV.a (What level are electrical lines and equipment maintained at?): a. Why is PG&E not currently meeting consistent maintenance, as required? b. What percentage of circuits are not meeting required regulation? c. How did benchmarking with other utilities change PG&E's response and understanding?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	1	7.3.3	Grid Design and System Hardening	Survey Responses	
Pre-Discovery 72	OEIS	Set 002	OEIS-PG&E-22-002	12	OEIS-PG&E-22-002_12	F. Grid operations and protocols Q12. Regarding PG&E's response to Maturity Survey question F.III.d (During PSPS events does the utility's website go down?): a. How many times did PG&E's website go down during PSPS events in 2021? Include associated timeframes for when the website was down, as well as a percentage of time that the website was down during PSPS events. b. What is PG&E's plan to decrease the likelihood that the website will go down during PSPS events moving forward?	Kevin Miller	2/22/2022	3/4/2022	3/4/2022	0	7.3.6	Grid Operations and Protocols	Survey Responses	
Pre-Discovery 73	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	1	CalAdvocates-PGE-2022WMP-11_1	On February 4, 2022, PG&E filed its third 90-day report in response to the Enhanced Oversight and Enforcement Process. Please provide Excel versions of the following attachments to this report: a) Attachment A: 2021 EVM Scope of Work – Year End Summary b) Attachment B: 2021 EVM Work Performed Outside the 2021 EVM Scope of Work – Year-End Summary c) Attachment C: 2022 EVM Scope of Work	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	3	N/A	Miscellaneous	Additional Detail	
Pre-Discovery 74	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	2	CalAdvocates-PGE-2022WMP-11_2	In response to Data Request CalAdvocates-PGE-2021WMP-10, Question 5, March 3, 2021, PG&E provided its 2021 EVM workplan. Please provide an updated version of this workplan that lists the actual EVM mileage performed in each circuit-segment in 2021 as a new column. Rows should be added as needed to cover all circuit-segments where PG&E performed EVM work in 2021. Note: If the response to this question is entirely covered by Question 1, please explain how so. No additional files will be required in this case.	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	0	7.3.5.2	Vegetation Management (VM) and Inspections	Enhanced Vegetation Management	
Pre-Discovery 75	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	3	CalAdvocates-PGE-2022WMP-11_3	In response to Data Request CalAdvocates-PGE-2021WMP-10, Question 6, March 3, 2021, PG&E provided its 2021 system hardening workplan for the categories referred to in parts (a)-(d) below. Please provide an updated version of this workplan with additional columns to show the actual system hardening work performed in each circuit-segment in 2021 for each of these categories. 7 Rows should be added as needed to cover all circuit-segments where PG&E performed system hardening work in 2021. a) Installation of covered conductor b) Installation of underground conductor c) Removal of overhead conductor	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	1	7.3.3.17	Grid Design and System Hardening	System Hardening	
Pre-Discovery 76	CalPA	Set WMP-11	CalAdvocates-PGE-2022WMP-11	4	CalAdvocates-PGE-2022WMP-11_4	In response to Data Request CalAdvocates-PGE-2021WMP-10, Question 7, PG&E provided its 2021 system hardening workplan for the categories referred to in parts (a)-(d) below. Please provide an updated version of this workplan with additional columns to show the actual system hardening work performed in each circuit-segment in 2021 for each of these categories. 8 Rows should be added as needed to cover all circuit-segments where PG&E performed system hardening work in 2021. PG&E had hardened 210.5 distribution line miles under initiative "C.13 – System Hardening (Distribution)." As stated in PG&E's response to Data Request CalAdvocates-PGE-2022WMP-03, February 15, 2022, attachment "WMP-Discovery2022_DR_CalAdvocates_003-Q02Supp01Atch01CONF.xlsx," PG&E installed 153.1 miles of covered conductor in HFTD in 2021, and 108.8 miles of underground conductor in HFTD in 2021, which totals 261.9 miles. Please explain the apparent discrepancy in number of miles between the above documents.	Holly Wehrman Carolyn Chen Layla Labagh	2/24/2022	3/2/2022	3/3/2022	0	7.3.3.17	Grid Design and System Hardening	System Hardening	