



Liberty Utilities (CalPeco Electric) LLC  
933 Eloise Avenue  
South Lake Tahoe, CA 96150  
Tel: 800-782-2506  
Fax: 530-544-4811

January 31, 2023

California Public Utilities Commission  
California Office of Energy Infrastructure Safety

**Subject: Liberty Notification of Vegetation Management Substantial Completion in 2022**

Pursuant to Public Utilities Code Section 8386.3(5)(A), Liberty Utilities (CalPeco Electric) LLC (“Liberty”) hereby submits its notification of completion of a substantial portion of the vegetation management initiatives described in its 2022 Wildfire Mitigation Plan (“WMP”) Update. The following notice provides information on the status of vegetation management activities by WMP Initiative Activity for Section 7.3.5 Vegetation Management and Inspections.

Additional efforts to manage community and environmental impacts

- Treated 6.3 circuit miles
  - Plan target quantity of 6.0 circuit miles

Detailed inspections of vegetation around distribution electric lines and equipment

- Inspected vegetation along 210.6 circuit miles
  - Plan target quantity of 222.0 circuit miles

Fuel management and reduction of “slash” from vegetation management activities

- Treated 515.0 acres
  - Plan target quantity of 280.0 acres treated

LiDAR inspections of vegetation around distribution electric lines and equipment

- Inspected 701.0 circuit miles
  - Plan target quantity of 701.0 circuit miles

Patrol inspections of vegetation around distribution electric lines and equipment

- Inspected 235.0 circuit miles
  - Plan target quantity of 171.0 circuit miles

Quality assurance / quality control of vegetation inspections

- Inspected 271.7 circuit miles
  - Plan target quantity of 221.0 circuit miles

Remediation of at-risk species

- Treated 223.0 circuit miles
  - Plan target quantity of 238.0 circuit miles

Removal and remediation of trees with strike potential to electric lines and equipment

- Treated 203.0 circuit miles
  - Plan target quantity of 171.0 circuit miles

Vegetation management to achieve clearances around electric lines and equipment

- Treated 701.0 circuit miles
  - Plan target quantity of 701.0 circuit miles

If additional information is required, please do not hesitate to contact me.

Respectfully submitted,

LIBERTY UTILITIES (CALPECO ELECTRIC) LLC

/s/ Jordan Parrillo

Jordan Parrillo  
Manager of Regulatory Affairs  
Liberty Utilities (CalPeco Electric) LLC  
701 National Ave,  
Tahoe Vista, CA 96148  
Telephone: 530-721-7818  
[jordan.parrillo@libertyutilities.com](mailto:jordan.parrillo@libertyutilities.com)