

Count	Party Name	Data Set	Data Request	Question No.	Question ID	Question Text	Response	Requestor	Date Rec'd	Final Due Date	Date Sent	Links	Number of Acks	NDA Required	WMP Section	Category	Subcategory
1	CaPA	Set WMP-07	CaPA_Set WMP-07	1	CaPA_Set WMP-07_01	In the review of PG&E's WDRM v3 by Energy & Environmental Economics, Inc. ("E3 Review"), the authors note: "There were also several references to PG&E asset data, now current to 2022 (01, 01, and inclusion of updated internally sourced meteorology datasets." a) Please confirm that no asset data collected after January 1, 2022 was used in the WDRM v3. b) If asset data collected after January 1, 2022 was used in PG&E's WDRM v3, please specify the date(s) on which any such data was collected. c) Please confirm that "asset data" in parts a) and b) is geospatial (GIS) data from the operational system of record. If not, please state the origin of the asset data. Page 15 of the E3 Review includes a list of components included in the WDRM v3. 4. a) Please confirm the date that the WDRM v3 was finalized. b) In the final list of components is different than what is listed in the E3 review, please provide an updated and accurate list of components that are used as inputs in PG&E's WDRM v3. c) For any inputs included in your response to Question 2(b) that do not appear on Page 15 of the E3 review, please provide the latest date on which each input was updated. d) If any dates given in response to Question 2(c) are different from those given in question 1(b), please explain why they are different.	a) All distribution asset data utilized in the Wildfire Distribution Risk Model (WDRM) v3 were extracted from PG&E's EGIS system on January 1, 2022 with the retention of the transformer data which was extracted from EDGIS on February 2, 2022. b) See answer to part a. c) See answer to part a.	Joshua Borkowski	3/27/2023	3/30/2023	3/30/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAbocover_007.zip	0	N/A	6.2	Risk Methodology and Assessment	Risk Analysis Framework
2	CaPA	Set WMP-07	CaPA_Set WMP-07	2	CaPA_Set WMP-07_Q2	a) Please confirm the date that the WDRM v4 was finalized. If it has not been finalized, please provide an estimate of when it will be finalized. b) Please provide a current list of components that are used as inputs in v4 of the WDRM model. c) Please state the date of PG&E asset data used in v4 of the WDRM model. If there are multiple dates, include the most recent date for any asset data used in the model, and any date(s) on which the data used in the model was collected. d) Please confirm that "asset data" in part c) is geospatial (GIS) data from the operational system of record. If not, please state the origin(s) of the asset data.	a) The Wildfire Distribution Risk Model (WDRM) v4 has not been finalized. Model review and approval is scheduled for Q2 2023. b) The list of equipment components in the WDRM v4 has not been finalized at this time. c) The asset data for the WDRM v4 was extracted from PG&E's EGIS on January 1, 2023. d) Please see the response to 3c.	Joshua Borkowski	3/27/2023	3/30/2023	3/30/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAbocover_007.zip	0	N/A	6.2	Risk Methodology and Assessment	Risk Analysis Framework
3	CaPA	Set WMP-07	CaPA_Set WMP-07	3	CaPA_Set WMP-07_Q3	Please provide for Asset Point data for Camera, Fuse, Support Structure, and Weather Station.	In response to this request, PG&E is providing Camera and Weather Station data, as delivered in the Q4 2022 OEB GIS Data Standard Submission. PG&E is also providing non-confidential data from the Support Structure feature class. PG&E is not providing data for the Fuse feature class as this data is confidential critical energy infrastructure information (CEII).	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.2	Risk Methodology and Assessment	Risk Analysis Framework
4	MGRA	Data Request No. 1	MGRA_Data Request No. 1	1 SUPP	MGRA_Data Request No. 1_Q1 SUPP	Please provide for Asset Point data for Camera, Fuse, Support Structure, and Weather Station.	In response to this request, PG&E is providing Camera and Weather Station data, as delivered in the Q4 2022 OEB GIS Data Standard Submission. PG&E is also providing non-confidential data from the Support Structure feature class. PG&E is not providing data for the Fuse feature class as this data is confidential critical energy infrastructure information (CEII).	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	4	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
5	MGRA	Data Request No. 1	MGRA_Data Request No. 1	2	MGRA_Data Request No. 1_Q2	Provide Asset Line data for Transmission Line (as permitted as non-confidential), Primary Distribution Line, and Secondary Distribution Line.	In response to this request, PG&E is providing non-confidential data for the Primary and Secondary Distribution Line Feature Classes. PG&E is not providing the Transmission Line feature class because it is confidential CEII.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
5	MGRA	Data Request No. 1	MGRA_Data Request No. 1	2 SUPP	MGRA_Data Request No. 1_Q2 SUPP	Provide Asset Line data for Transmission Line (as permitted as non-confidential), Primary Distribution Line, and Secondary Distribution Line.	In response to this request, PG&E is providing non-confidential data for the Primary and Secondary Distribution Line Feature Classes. PG&E is not providing the Transmission Line feature class because it is confidential CEII.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
6	MGRA	Data Request No. 1	MGRA_Data Request No. 1	3	MGRA_Data Request No. 1_Q3	Provide PPSPS Event data. Include Event Log, Event Line, Event Polygon data. Please exclude customer meter data. Provide all PPSPS Event Asset Damage data including photos.	In response to this request, PG&E is unable to provide PPSPS Event data, PPSPS Event Damages data, and PPSPS Damage photos since there were no PPSPS Events that took place throughout 2022.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
6	MGRA	Data Request No. 1	MGRA_Data Request No. 1	3 SUPP	MGRA_Data Request No. 1_Q3 SUPP	Provide PPSPS Event data. Include Event Log, Event Line, Event Polygon data. Please exclude customer meter data. Provide all PPSPS Event Asset Damage data including photos.	In response to this request, PG&E is unable to provide PPSPS Event data, PPSPS Event Damages data, and PPSPS Damage photos since there were no PPSPS Events that took place throughout 2022.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
7	MGRA	Data Request No. 1	MGRA_Data Request No. 1	4	MGRA_Data Request No. 1_Q4	Provide Risk Event Point data, including Wire Down, Ignition, Transmission Unplanned Outage (as classified non-confidential), Distribution Unplanned Outage data, Distribution Vegetation Caused Unplanned Outage, Risk Event Asset Log and related table.	In response to this request, PG&E is providing non-confidential data for the Wire Down, Ignition, Transmission Unplanned Outage, Distribution Unplanned Outage, Distribution Vegetation Caused Unplanned Outage, and Risk Event Asset Log feature classes and related table.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
7	MGRA	Data Request No. 1	MGRA_Data Request No. 1	4 SUPP	MGRA_Data Request No. 1_Q4 SUPP	Provide Risk Event Point data, including Wire Down, Ignition, Transmission Unplanned Outage (as classified non-confidential), Distribution Unplanned Outage data, Distribution Vegetation Caused Unplanned Outage, Risk Event Asset Log and related table.	In response to this request, PG&E is providing non-confidential data for the Wire Down, Ignition, Transmission Unplanned Outage, Distribution Unplanned Outage, Distribution Vegetation Caused Unplanned Outage, and Risk Event Asset Log feature classes and related table.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
8	MGRA	Data Request No. 1	MGRA_Data Request No. 1	5	MGRA_Data Request No. 1_Q5	Provide photo data for Risk Events.	PG&E does not have any non-confidential or non-privileged data to provide in response to this request. The photos provided in this feature class may be subject to attorney client privilege or the work product doctrine and may be subject to an ongoing investigation. Additionally, PG&E risk event photos are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
8	MGRA	Data Request No. 1	MGRA_Data Request No. 1	5 SUPP	MGRA_Data Request No. 1_Q5 SUPP	Provide photo data for Risk Events.	PG&E does not have any non-confidential or non-privileged data to provide in response to this request. The photos provided in this feature class may be subject to attorney client privilege or the work product doctrine and may be subject to an ongoing investigation. Additionally, PG&E risk event photos are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
9	MGRA	Data Request No. 1	MGRA_Data Request No. 1	6	MGRA_Data Request No. 1_Q6	Under Initiatives, please provide Grid Hardening data, including Hardening Log, Hardening Point, and Hardening Line data. Inspection data is not requested at this time.	In response to this request, PG&E is providing non-confidential data for the System Hardening, Butte County Rebuild, and 10K Underground WMP initiative programs that were included in the Grid Hardening Log, Grid Hardening Point, and Grid Hardening Line feature classes and related table. Additional initiative projects reported in these feature classes includes data on where PG&E's fuse replacements, switch replacements, surge arrester replacements, and SCADA enabled work has been performed, and where future work is planned to take place. These are confidential CEII because they reveal physical facility and critical infrastructure locations. As such, have been removed from the response.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
9	MGRA	Data Request No. 1	MGRA_Data Request No. 1	6 SUPP	MGRA_Data Request No. 1_Q6 SUPP	Under Initiatives, please provide Grid Hardening data, including Hardening Log, Hardening Point, and Hardening Line data. Inspection data is not requested at this time.	In response to this request, PG&E is providing non-confidential data for the System Hardening, Butte County Rebuild, and 10K Underground WMP initiative programs that were included in the Grid Hardening Log, Grid Hardening Point, and Grid Hardening Line feature classes and related table. Additional initiative projects reported in these feature classes includes data on where PG&E's fuse replacements, switch replacements, surge arrester replacements, and SCADA enabled work has been performed, and where future work is planned to take place. These are confidential CEII because they reveal physical facility and critical infrastructure locations. As such, have been removed from the response.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
10	MGRA	Data Request No. 1	MGRA_Data Request No. 1	7	MGRA_Data Request No. 1_Q7	Under Initiatives, please provide Other Initiative data for point, line, polygon features and the Other Initiative Log.	In response to this request, PG&E is providing WMP initiative program data for the Weather Station Installation and Optimization and Camera Installation that were included in the Other Initiative Log and Other Initiative Point related table and feature class. Additional WMP initiative projects reported in this feature class and related table includes data on where PG&E's Line Sensor Installations, Distribution Fault Anticipation, EPSS Reliability Improvements and Early Fault Detection Sensors work has been performed, and where future work is planned to take place. These items are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
10	MGRA	Data Request No. 1	MGRA_Data Request No. 1	7 SUPP	MGRA_Data Request No. 1_Q7 SUPP	Under Initiatives, please provide Other Initiative data for point, line, polygon features and the Other Initiative Log.	In response to this request, PG&E is providing WMP initiative program data for the Weather Station Installation and Optimization and Camera Installation that were included in the Other Initiative Log and Other Initiative Point related table and feature class. Additional WMP initiative projects reported in this feature class and related table includes data on where PG&E's Line Sensor Installations, Distribution Fault Anticipation, EPSS Reliability Improvements and Early Fault Detection Sensors work has been performed, and where future work is planned to take place. These items are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
11	MGRA	Data Request No. 1	MGRA_Data Request No. 1	8	MGRA_Data Request No. 1_Q8	Under Other Required Data, please provide Red Flag Warning Day polygon data.	PG&E is providing the Red Flag Warning Day polygon data, as requested by MGRA.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
11	MGRA	Data Request No. 1	MGRA_Data Request No. 1	8 SUPP	MGRA_Data Request No. 1_Q8 SUPP	Under Other Required Data, please provide Red Flag Warning Day polygon data.	PG&E is providing the Red Flag Warning Day polygon data, as requested by MGRA.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
12	MGRA	Data Request No. 1	MGRA_Data Request No. 1	9	MGRA_Data Request No. 1_Q9	Please provide a layer indicating calculated circuit-level risk using the methodology presented in the WMP. If independent probability and consequence layers exist, please provide these independently as well.	The method described in the 2023 WMP to aggregate model results is conducted to produce a circuit segment level risk value but it is not used to produce a circuit level risk value. However, the geospatial representation of circuit segments that would be provided in response to this data request involves the identification of CEII, which we are required by law to maintain as confidential and cannot produce without the requesting party agreeing to protect the information through a non-disclosure agreement.	Joseph Mitchell	3/29/2023	4/10/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/MGRA_001.zip	0	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
12	MGRA	Data Request No. 1	MGRA_Data Request No. 1	9 SUPP	MGRA_Data Request No. 1_Q9 SUPP	Please provide a layer indicating calculated circuit-level risk using the methodology presented in the WMP. If independent probability and consequence layers exist, please provide these independently as well.	The method described in the 2023 WMP to aggregate model results is conducted to produce a circuit segment level risk value but it is not used to produce a circuit level risk value. However, the geospatial representation of circuit segments that would be provided in response to this data request involves the identification of CEII, which we are required by law to maintain as confidential and cannot produce without the requesting party agreeing to protect the information through a non-disclosure agreement.	Joseph Mitchell	3/29/2023	4/13/2023	4/13/2023	https://www.pge.com/page_global/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_001.zip	1	N/A	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation

13	CaPA	Set WMP-08	CaPA_Set WMP-08	1	CaPA_Set WMP-08_01	<p>PG&E's WMP status: The EVM Program concluded at the end of 2022. PG&E will continue to strengthen our other existing VM programs. PG&E is transitioning the maintenance of enhanced clearances that were achieved in EVM to Routine VM patrols. We established routine maintenance requirements for electric distribution circuits where EVM scope clearances have been performed (in HFTD designated areas) and passed by work verification.4 a) Please describe how PG&E intends to strengthen its other existing VM programs as stated above. b) Does PG&E intend to achieve "enhanced clearances" in areas where they have not already been achieved through EVM, or is PG&E only intending to maintain existing enhanced clearances? c) If PG&E will pursue the achievement of enhanced clearances in new locations, please provide PG&E's strategy and methodology for the following: i. Deciding which circuits and/or locations need enhanced clearances ii. Deciding which trees to trim in a given project location iii. Deciding the desired clearance distances iv. Setting the schedule and sequence of enhanced clearance projects d) If PG&E only intends to maintain existing enhanced clearances, please explain why.</p>	<p>a) 1) PG&E is extending the minimum clearance recommendations of 12 feet in HFTD (per C 01 Rule 26, Appendix E) to 12 feet within HFRFA. 2) There are anticipated increases of tree removals vs trims as it is the first course of action recommended at time of listing per the Distribution Vegetation Inspection Procedure (DRIP). Funding has been provided to account for increased removals. 3) There are lighter costed through reports and monitoring of work completion timelines. b) PG&E will maintain clearances where EVM work occurred. PG&E will also be prescribing a minimum radial clearance of 12 feet throughout the system within HFTD and HFRFA. Two new programs, Vegetation Management for Operational Mitigation (VMOM) and Focused Tree Inspections, are likely to result in individual trees that warrant enhanced clearance where EVM was not implemented. These programs inform clearances based on available outage data and trends, as well as site and tree specific conditions. While not called out as a uniform scope, clearances in portions of these targeted circuit segments may have similarities to EVM. c) 1) Adopting the recommendation of 12 feet minimum clearance (in HFTD/HFRFA, at time of listing) 2) Deciding which locations need enhanced clearance through VMOM execution and FTI Pilots. i. Based on specific outage data analysis of specific and future areas when available. ii. Based on analysis of outage data and trends by AOC. Additionally, any tree which is within MDR, will be within the MDR before next work completion cycle or is showing signs of imminent failure before next work completion cycle. iii. Minimum of 12 feet of clearance or enough clearance to mitigate potential impacts to facilities if tree (whole or portion of) failure were to occur. iv. PG&E prioritizes enhanced clearance projects according to the Wildfire Distribution Risk Model (WDRM) and attempts to complete work in order of highest to lowest risk whenever possible, however, operational factors including but not limited to access issues due to snow or weather, environmental limited operating periods, and agency restrictions among others may lead to a lower ranked project being completed ahead of a higher ranked project. d) PG&E will maintain existing enhanced clearances as well as establishing new clearances starting at a minimum of 12 feet.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/page_global/common/pdfs/4/efity/emergency-response/docs/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_01	0	N/A	8.2.2.2.6	Vegetation Management and Inspections	Discontinued Programs
14	CaPA	Set WMP-08	CaPA_Set WMP-08	2	CaPA_Set WMP-08_02	<p>Regarding the new "Tree Removal Inventory Program" described in section 8.2.2.2.4 of PG&E's WMP, PG&E states: This is a new transitional program for 2023 stemming from the conclusion of the EVM program. This program is intended to help reduce outages and potential ignitions using a risk-informed, targeted plan to mitigate potential vegetation contacts based on historic vegetation outages on EPSS-enabled circuits. PG&E will initially focus on mitigating potential vegetation contacts in CPZs that have experienced vegetation caused outages. Scope of work will be developed by using EPSS and historical outage data and vegetation failure from the WDRM risk model. EPSS-enabled devices vegetation outages extent of condition inspections may generate additional tree work. a) Please explain what is meant by the term "transitional" in the first sentence. b) Please explain what is meant by the sentence "EPSS-enabled devices vegetation outages extent of condition inspections may generate additional tree work." c) When will PG&E develop initial the scope of work for this program? d) How frequently will PG&E update the scope of work for this program (e.g., annually or quarterly)? e) Please explain PG&E's methodology for developing the scope of work for this program. f) Please explain how PG&E will use EPSS data to contribute to the scope of work for this program. g) Please explain how PG&E will use historical outage data to contribute to the scope of work for this program. h) Please explain how PG&E will use "vegetation failure from the WDRM v3 risk model" to contribute to the scope of work for this program.</p>	<p>a) For this program the use of "transitional" represents the program transition from EVM to our new Tree Inventory Program, which will focus on working toward the risk associated with the remaining 383K. These units were identified under EVM guidelines and will be over a period of time based on a re-evaluation of constraints or other factors that hindered completion of work. b) Yes, but not under the Tree Removal Inventory Program, which is focused on removing risk from previously listed trees with a removal prescription as part of the EVM program. Two new programs, "Vegetation for Operational Mitigations (VMOM) and Focused Tree Inspections" will identify new trees for the start of work identified in this inventory. Additionally, if any priority trees are discovered while completing the TRI scope of work, they would be listed for work consistent with all other VM programs. c) 1) For VMOM, PG&E utilized VM EPSS-enabled outage data, historical VM outage data, and customer outage impact data. 2) For FTI, Areas of Concern (AOCs) were identified through a cross-functional effort utilizing customer-based regional reviews to create polygons which are geographic areas. Initial polygon development utilized WDRM3 consequence scores, Public Safety Specialist circuit-based evaluations, expertise, 30-year lookback of meteorology data, and analysis, identified PSPS Lookback Polygons, PSPS Vegetation Management locations, vegetation caused ignition data, and vegetation caused outage data. The process is intended to be performed annually to identify where trends, models, or emerging available data indicated higher likelihood of tree caused damage or outages. d) N/A e) N/A f) The on-going re-inspection and evaluation work will focus on the remaining 209K trees that were identified for removal at the conclusion of EVM that had a TAT result other than ABATE. The 2023 Tree Inventory Program scope of work is targeting the re-inspection of approximately 20K trees that had a TAT result other than ABATE. Once re-inspected if it is determined that a tree does not need removal the tree will be inspected annually going forward during the Routine Maintenance and Second Patrol inspections. g) The program is planned to last 5 years. h) No. All of PG&E's various Vegetation Management programs have and will continue to manage inventories of trees, however, the Tree Removal Inventory program is scoped to specifically address trees in the inventory of the discontinued EVM program within 9 years and is currently not planned to continue beyond this time frame.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/page_global/common/pdfs/4/efity/emergency-response/docs/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_02	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
15	CaPA	Set WMP-08	CaPA_Set WMP-08	3	CaPA_Set WMP-08_03	<p>Regarding the new "VM for Operational Mitigations" described in section 8.2.2.2.3 of PG&E's WMP, PG&E states: This is a new transitional program for 2023 stemming from the conclusion of the EVM program. This program is intended to help reduce outages and potential ignitions using a risk-informed, targeted plan to mitigate potential vegetation contacts based on historic vegetation outages on EPSS-enabled circuits. PG&E will initially focus on mitigating potential vegetation contacts in CPZs that have experienced vegetation caused outages. Scope of work will be developed by using EPSS and historical outage data and vegetation failure from the WDRM risk model. EPSS-enabled devices vegetation outages extent of condition inspections may generate additional tree work. a) Please explain what is meant by the term "transitional" in the first sentence. b) Please explain what is meant by the sentence "EPSS-enabled devices vegetation outages extent of condition inspections may generate additional tree work." c) When will PG&E develop initial the scope of work for this program? d) How frequently will PG&E update the scope of work for this program (e.g., annually or quarterly)? e) Please explain PG&E's methodology for developing the scope of work for this program. f) Please explain how PG&E will use EPSS data to contribute to the scope of work for this program. g) Please explain how PG&E will use historical outage data to contribute to the scope of work for this program. h) Please explain how PG&E will use "vegetation failure from the WDRM v3 risk model" to contribute to the scope of work for this program.</p>	<p>a) Our wildfire mitigation capabilities have continued to evolve and mature since 2019. With the conclusion of Enhanced Vegetation Management (EVM) at the end of 2022, we continue to evolve our Vegetation Management program. The use of "transitional" for this program represents the evolution of the Vegetation Management program through the introduction of a new program, Vegetation Management for Operational Mitigations (VMOM) program, which is intended to reduce the impacts of more frequent outages caused by the increased availability of EPSS-enabled devices. b) As part of this program an extent of condition inspection is conducted when the cause of an EPSS enabled outage is determined to be vegetation related. An extent of condition inspection evaluates the spans in all directions from the location of the outage looking for additional trees that may pose a similar risk as the tree that caused the outage. The sentence "EPSS-enabled devices vegetation outages extent of condition inspections may generate additional tree work" is related to any additional trees that can be identified under this inspection. c) The 2023 VMOM Scope of work has been developed and approved on February 23, 2023. d) PG&E will develop the scope of work on an annual or as needed basis which will be progressed for consideration, review, and approval through our Wildfire Risk Governance Steering Committee. e) PG&E utilized VM EPSS-enabled outage data, historical VM outage data, and customer outage impact data. f) PG&E will utilize EPSS Outages Extent of Condition (EOC) patrols to identify and generate additional tree work throughout the year. Additionally, EPSS outage data will be utilized in the scope of work development for the following year. g) PG&E utilized historical vegetation caused outage data as well as EPSS enabled outage data provided by the EPSS PMO team to refine our CPZ targets for the VMOM program. h) The Wildfire Data Risk Model (WDRM) v3 was utilized to prioritize 9 CPZs for the VMOM program.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/page_global/common/pdfs/4/efity/emergency-response/docs/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_03	0	N/A	8.2.2.2.3	Vegetation Management and Inspections	VM for Operational Mitigations
16	CaPA	Set WMP-08	CaPA_Set WMP-08	4	CaPA_Set WMP-08_04	<p>Regarding the new "Focused Tree Inspections" described in section 8.2.2.2.5 of PG&E's WMP, PG&E states: This is a new transitional program for 2023 stemming from the conclusion of the EVM program. PG&E is developing AOCs to better focus VM efforts to address high risk areas that have experienced higher volumes of vegetation damage during PSPS events, outages, and/or ignitions. We have conducted a county-by-county review with regional SMEs and used this information to develop polygons where focused vegetation inspections can be evaluated to determine appropriate counties to prioritize pilots. Focused Tree Inspection plans will be piloted in at least one area. The pilot will develop and implement guidelines that inform inspections. a) Please explain what is meant by the word "transitional" in the first sentence. b) Does "AOC" stand for "Area of Concern" in this instance? If not, then please define it. c) Please describe PG&E's methodology for developing the abovementioned polygons. d) How does PG&E determine where focused vegetation inspections can be evaluated? e) How does PG&E determine which counties are appropriate to prioritize for pilots? f) How will PG&E determine in which county or counties to execute a pilot or pilots? i. Scope of work ii. Budget iii. Duration iv. Goals and objectives v. Success metrics vi. Please describe the following regarding the guidelines that PG&E will develop based on the pilot(s), as mentioned above: i. The expected content of the guidelines ii. How PG&E expects the guidelines to inform inspections iii. When PG&E expects to develop such guidelines iv. Please describe the steps that PG&E expects a "focused tree inspection" to include. v. Please complete the planned "focused tree inspections" to the tree inspections previously performed as part of PG&E's EVM program. Describe the similarities and differences. vii. What metrics and criteria will PG&E use to determine whether a tree passes or fails a "focused tree inspection"?</p>	<p>a) Similar to TRI and VMOM programs, the Focus Tree Inspection (FTI) program has been developed following the conclusion of EVM in 2022. For this program "transitional" is used to recognize similar targeted efforts to reduce risk formerly associated with EVM that go beyond compliance mandated clearances. All three programs are intended to further reduce vegetation related outages and ignitions. The FTI program was built in response to RN-22-09 which compelled benchmarking the use of predictive and risk modeling in VM with SCE and SDG&E. As a result, PG&E has developed data and SME Informed "Areas of Concern" (AOC) to pilot enhanced targeted inspections where the analysis indicates increased risk of vegetation failures in high-risk areas. Similar to EVM, the piloting of this program has been prioritized using information from the Wildfire Distribution Risk Model (WDRM). Pilots will begin in Q2 2023 in four AOC. The results and learnings from the pilots will inform the development and monitoring of a broader program as a transitional measure intended to reduce VM outages. b) Yes c) AOCs were identified through a cross-functional effort utilizing county-based regional reviews to create polygons which are geographic areas. Initial polygon development utilized Public Safety Specialist circuit-based evaluations, 30-year lookback of meteorology data, PSPS Lookback Polygons, PSPS Vegetation Management locations, vegetation caused ignition data, and vegetation caused outage data. The process is intended to be performed annually to identify where trends, models, or emerging available data indicate higher likelihood of tree caused damage or outages. d) The FTI program will be piloted in four regional AOCs beginning in Q2 2023. These regional pilot areas and the resulting inspections will be evaluated and monitored to inform refinements to the program prior to larger-scale implementation. The program will rely upon ongoing evaluation to refine AOC areas and inspection scope based on these evaluations predominantly informed by outage analysis. e) Pilot AOCs are prioritized using WDRM3. The four pilot AOCs selected for 2023 incorporated additional reviews from the VM VM Execution Operational Team to select appropriate regional areas to inform the programs development. f) Please refer to response e). Butte, Calaveras, El Dorado, and Napa counties were selected for regional pilots. g) Please describe the following aspects of the pilot or pilots: i. Scope of Work: Complete a focused tree inspection pilot project of ~300 OH line miles in</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/page_global/common/pdfs/4/efity/emergency-response/docs/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_04	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections

17	CaPA	Set WMP-08	CaPA_Set WMP-08	5	CaPA_Set WMP-08_05	<p>PG&E states on p. 539 of its WMP: PG&E is restructuring its VM Program starting in 2023. Based on recent data and analysis, the risk reduction of the EVM Program is less than the risk reduction from the EPSS program that was introduced in 2021.</p> <p>a) Please describe the aforementioned "data and analysis" that shows that "the risk reduction of the EVM program is less than the risk reduction from the EPSS program".</p> <p>b) Please provide any available workpapers, reports, or other documents that support the statement quoted above.</p>	<p>a) PG&E introduced the comparison of risk reduction and Risk Spend Efficiency (RSE) of EPSS vs EVM in the 2022 WMP and 2023 GRC Supplemental Filing in February 2022. This comparison is described in the 2023 GRC, Exhibit 3 Chapter 4 page 3.2 through 3.7. The updated wildfire mitigation strategy is summarized in Table 3-4 on page 3-36 as the risk reduction relative to spend between EVM and EPSS is substantially in EPSS's favor.</p> <p>b) Please reference the following workpapers: - 2022 WMP o 2022 WMP Data Table 12 - 2022-02-25_PGE_2022_WMP_Update_R0_Section 7.3.a_Ach07_Initiative 7.3.15 and 7.3.6.8 o EVM RSE Workpaper - 2022-02-25_PGE_2022_WMP-Update_R0_Section 7.3.a_Ach06-R1 o EPSS RSE Workpaper - 2022-02-25_PGE_2022_WMP-Update_R0_Section 7.3.a_Ach07 - 2023 GRC Supplemental Filing o ED_001 - EO-WLDFR-3_RSE Input File.xlsx 8 PG&E's WMP, p. 539.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.3.4	Vegetation Management and Inspections	Fall-In Mitigation
18	CaPA	Set WMP-08	CaPA_Set WMP-08	6	CaPA_Set WMP-08_06	<p>PG&E states on p. 539 of its WMP: Additional Operational Mitigations such as PVD and DCD will also help to mitigate risk previously prescribed to EVM. As a result, PG&E concludes the EVM Program at the end of 2022.</p> <p>a) Does "PVD" stand for "Partial Voltage Detection" in this instance? Please define if not.</p> <p>b) Does "DCD" stand for "Downed Conductor Detection" in this instance? Please define if not.</p> <p>c) How has PG&E determined that PVD will help to mitigate risk that PG&E previously sought to mitigate with EVM?</p> <p>d) Which particular risks will PVD help mitigate that PG&E previously sought to mitigate with EVM?</p> <p>e) Please provide any available documentation and analysis showing that PVD will help to mitigate risks that PG&E previously sought to mitigate with EVM.</p> <p>f) How has PG&E determined that DCD will help to mitigate risk that PG&E previously sought to mitigate with EVM?</p> <p>g) Which particular risks will DCD help mitigate that PG&E previously sought to mitigate with EVM?</p> <p>h) Please provide any available documentation and analysis showing that DCD will help to mitigate risks that PG&E previously sought to mitigate with EVM.</p>	<p>a) Yes, "PVD" refers to Partial Voltage Detection.</p> <p>b) Yes, "DCD" refers to Downed Conductor Detection.</p> <p>c) Partial Voltage Detection (and subsequent force cuts of the nearest upstream SCADA capable device) are part of a "defense in depth" strategy that supplements the already highly effective baseline Enhanced Powerline Safety Settings (EPSS). In particular, Partial Voltage Force Out actions and DCD both mitigate high impedance faults, which are very difficult to detect for traditional protection schemes. In 2022, 36 Partial Voltage Detectors and Force Out actions occurred in 11 of 36 force out, hazards were identified that could have caused an ignition. These hazards included wire down and/or vegetation contact.</p> <p>d) As indicated in response c, PVD is a mitigation measure for high impedance faults, which can occur when vegetation contacts a powerline or a downed conductor. PVD is also able to provide detection for transformer backfeed high impedance faults.</p> <p>e) PVD increases the ability to mitigate high impedance fault conditions, which can occur following vegetation contact with a powerline. These benefits have the potential to add extra protection or complement EPSS. PG&E determined that EPSS mitigates risk which PG&E previously sought to mitigate with EVM and sees PVD as part of a defense in depth strategy to supplement EPSS. PG&E did not separately compare PVD to EVM.</p> <p>f) DCD is part of a "defense in depth" strategy that supplements the already highly effective component of the already highly effective EPSS. DCD mitigates high impedance ground faults, which are very difficult to detect for traditional protection schemes. DCD detects and de-energizes faults as low as 1 amp primary ground current and trips in 1 second as compared to the existing Sensitive Ground Fault detection, which trips at a minimum of 15 amps, typically in 10 seconds. PG&E has performed lab testing which has shown DCD is able to detect and de-energize downed conductors reducing ignition risk where installed.</p> <p>g) DCD is an automated protection element that is expected to mitigate high impedance ground faults.</p> <p>h) DCD also increases the ability to mitigate high impedance ground fault conditions, which can occur following vegetation contact with a powerline. These benefits have the potential to add extra protection or complement EPSS. PG&E determined that EPSS mitigates risk which PG&E previously sought to mitigate with EVM and sees DCD as part of a defense in depth strategy to supplement EPSS. PG&E did not separately compare DCD to EVM.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.3.4	Vegetation Management and Inspections	Fall-In Mitigation
19	CaPA	Set WMP-08	CaPA_Set WMP-08	7	CaPA_Set WMP-08_07	<p>On pp. 314-316 of PG&E's WMP, PG&E divides its operational mitigations into four different groups. Group 2 includes "Inspections and maintenance programs where we exceed compliance requirements until permanent mitigations are deployed and/or we implement new technologies so that we no longer need to exceed compliance requirements." For the following Group 2 mitigations, please state the criteria by which PG&E will determine that it no longer needs to exceed compliance requirements, and state the basis for such a determination:</p> <p>a) Equipment Maintenance and Repair b) Pole Clearing Program c) Utility Defensible Space Program d) Wood Management e) Substation Defensible Space f) Focused Tree Inspections g) Transmission Integrated VM h) Emergency Response VM</p>	<p>PG&E does not currently have specific criteria for the listed mitigations, though certain permanent mitigations (e.g. distribution undergrounding) may reduce risk to a point where exceeding compliance is no longer needed. Continued analysis of ignitions, inspection finds, technology implementation results, etc. will inform the level of interim mitigation needed. We will continue to implement the Group 2 mitigations based on risk or benefit information.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	7.2.3	Vegetation Management and Inspections	Interim Mitigation Initiatives
20	CaPA	Set WMP-08	CaPA_Set WMP-08	8	CaPA_Set WMP-08_08	<p>On pp. 314-316 of PG&E's WMP, PG&E divides its operational mitigations into four different groups. Group 2 includes "Inspections and maintenance programs where we exceed compliance requirements until permanent mitigations are deployed and/or we implement new technologies so that we no longer need to exceed compliance requirements." For the following Group 2 mitigations, please state whether PG&E intends to discontinue the program/initiative once permanent mitigations are deployed or new technologies are implemented:</p> <p>a) Equipment Maintenance and Repair b) Pole Clearing Program c) Utility Defensible Space Program d) Wood Management e) Substation Defensible Space f) Focused Tree Inspections g) Transmission Integrated VM h) Emergency Response VM</p>	<p>At this time PG&E does not intend to discontinue any of the programs/initiatives listed in Group 2 mitigation. The programs/initiatives are designed and implemented to ensure that PG&E maintains compliance with state and federal regulations, as well as mitigate components of the system that may be exposed to wildfire risk that cannot be managed through our control programs pending the implementation of System Resilience mitigations. In the future, for programs/initiatives that exceed compliance, PG&E may determine to stay at compliance requirements based on risk or benefit information.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	7.2.3	Vegetation Management and Inspections	Interim Mitigation Initiatives
21	CaPA	Set WMP-08	CaPA_Set WMP-08	9	CaPA_Set WMP-08_09	<p>Regarding the new "Tree Removal Inventory Program" described in section 8.2.2.2.4 of PG&E's WMP, PG&E states: "PG&E estimates that our EVM inventory included more than 300,000 trees at the end of 2022."</p> <p>Table 8-14, PG&E's VM Targets, p. 502, states that PG&E will remove approximately 60,000 trees identified from the legacy EVM program through the end of 2025. 11 PG&E's EVM inventory:</p> <p>a) Are the 60,000 trees "identified from the legacy EVM program" a subset of the trees in PG&E's EVM inventory?</p> <p>b) If the answer to part (a) is yes, how will PG&E mitigate the risk posed by the approximately 240,000 trees from the EVM inventory that will not be removed during the period from 2023-2025?</p> <p>c) If the answer to part (a) is no, please explain the difference between the 60,000 trees to be addressed through 2023, and the more than 300,000 trees in the EVM inventory.</p> <p>Per Table 8-12, Vegetation Management Implementation Objectives, PG&E's Focused Tree Inspection Program is currently under development. By the end of 2025, PG&E plans to fully implement AOC cross-functional team to implement guidelines across all AOCs. Given that PG&E's EVM program has been discontinued, and that its Focused Tree Inspection Program has not yet been fully developed, how will PG&E assess the risk of tree fall during the period from 2023-2025?</p>	<p>a) Yes, the 60K trees come from the group of approximately 385K EVM trees remaining. We plan to work down the risk associated with the 385K trees starting with 15K trees in 2023, 20K trees in 2024, and 25K trees in 2025, which results in 60K trees being worked through 2025.</p> <p>b) PG&E has operational mitigations including EPSS enablement in place. Additionally, PG&E conducts and will continue to conduct annual Routine and Second Patrol of these areas and address any Priority 1 or 2 hazardous tree conditions accordingly.</p> <p>c) N/A</p> <p>10 PG&E's WMP, p. 528. 11 15,000 trees in 2023, 20,000 trees in 2024, and 25,000 trees in 2025.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
22	CaPA	Set WMP-08	CaPA_Set WMP-08	10	CaPA_Set WMP-08_010	<p>Regarding the new "Tree Removal Inventory Program" described in section 8.2.2.2.4 of PG&E's WMP, PG&E states: "PG&E estimates that our EVM inventory included more than 300,000 trees at the end of 2022."</p> <p>Table 8-14, PG&E's VM Targets, states that PG&E will collect LiDAR data on its Transmission System (17,500 circuit miles).</p> <p>Table 5-2, Electrical Infrastructure, states that PG&E has a total of 18,111 circuit miles of overhead transmission lines.</p> <p>Table 8-14, PG&E's VM Targets, states that PG&E will collect LiDAR data on approximately 600 overhead circuit miles of transmission?</p> <p>a) If the answer to part (a) is yes, please explain why.</p> <p>b) If the answer to part (a) is no, please explain why Table 8-14 shows a LiDAR target that is smaller than the size of PG&E's overhead transmission system.</p>	<p>PG&E will continue to assess the risk of tree fall-ins during the period from 2023-2025 through the Distribution Routine and Second Patrol programs accordingly. The identification of hazardous or other emergent priority trees is embedded into all VM tree trimming and mitigation programs, as well as the resulting work verification and quality programs.</p> <p>In addition to the Focused Tree Inspection Program, PG&E has also introduced the Tree Removal Inventory (TRI) and Vegetation Management for Operational Liability programs which will also be implemented to assess the risk of tree fall-ins during the same period in targeted portions of the service territory.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
23	CaPA	Set WMP-08	CaPA_Set WMP-08	11	CaPA_Set WMP-08_011	<p>Table 8-14, PG&E's VM Targets, states that PG&E will collect LiDAR data on its Transmission System (17,500 circuit miles).</p> <p>Table 5-2, Electrical Infrastructure, states that PG&E has a total of 18,111 circuit miles of overhead transmission lines.</p> <p>Table 8-14, PG&E's VM Targets, states that PG&E will collect LiDAR data on approximately 600 overhead circuit miles of transmission?</p> <p>a) If the answer to part (a) is yes, please explain why.</p> <p>b) If the answer to part (a) is no, please explain why Table 8-14 shows a LiDAR target that is smaller than the size of PG&E's overhead transmission system.</p>	<p>a) No, PG&E will collect LiDAR data on all overhead Transmission circuit miles.</p> <p>b) N/A</p> <p>c) The difference between LiDAR Transmission inspections mapped on ETGIS and our LiDAR vendor's data is due largely to parallel circuits and some geometry differences; miles are confirmed against circuit location and length from the LiDAR data. It is common to see a difference between ETGIS and LiDAR survey data. When our LiDAR vendor indicates their completed miles on 100% of PG&E Transmission circuit miles, we use the ETGIS miles. PG&E continues to use ETGIS values as this is our core data.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.2.11	Vegetation Management and Inspections	Routine Transmission NERC and Non-NERC
24	CaPA	Set WMP-08	CaPA_Set WMP-08	12	CaPA_Set WMP-08_012	<p>Table 8-14, PG&E's VM Targets, states that "Each of the 3 programs (Routine Distribution, Routine Transmission and Pole Clearing) must achieve a 95% quality verification audit results pass rate."</p> <p>Please describe the actions PG&E will take during the 2023-2025 period if a program does not achieve a 95% pass rate on quality verification audits.</p> <p>Table 8-15, Vegetation Management QV Program, lists the following audit pass results for 2022 VM work: Transmission: 84.2% Vegetation Control Pole Clearing: 90.3%</p> <p>a) Please describe any actions PG&E has taken or plans to take to improve the Distribution VM audit results pass rate from 84.2% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p> <p>b) Please describe any actions PG&E has taken or plans to take to improve the Transmission VM audit results pass rate from 90.3% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p> <p>c) Please describe any actions PG&E has taken or plans to take to improve the Pole Clearing VM audit results pass rate from 90.3% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p>	<p>Should a program fall below a 95% pass rate, catch back plans will be developed in partnership with VM execution to mitigate for specific cause of deficient rate.</p> <p>a) Improved quality verifications have been established for 2023, allowing for greater insight into difference between ETGIS and LiDAR survey data. When our LiDAR vendor indicates their completed miles on 100% of PG&E Transmission circuit miles, we use the ETGIS miles. PG&E continues to use ETGIS values as this is our core data.</p> <p>b) Improved quality verifications have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits.</p> <p>c) Improved quality verifications have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.5	Vegetation Management and Inspections	Quality Assurance/Quality Control
25	CaPA	Set WMP-08	CaPA_Set WMP-08	13	CaPA_Set WMP-08_013	<p>Table 8-15, Vegetation Management QV Program, lists the following audit pass results for 2022 VM work: Transmission: 84.2% Vegetation Control Pole Clearing: 90.3%</p> <p>a) Please describe any actions PG&E has taken or plans to take to improve the Distribution VM audit results pass rate from 84.2% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p> <p>b) Please describe any actions PG&E has taken or plans to take to improve the Transmission VM audit results pass rate from 90.3% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p> <p>c) Please describe any actions PG&E has taken or plans to take to improve the Pole Clearing VM audit results pass rate from 90.3% in 2022 to 95% in 2023. Please include the timeline for completing those actions.</p>	<p>a) Improved quality verifications have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits.</p> <p>b) Improved quality verifications have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits.</p> <p>c) Improved quality verifications have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits.</p>	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008.zip	0	N/A	8.2.5.1	Vegetation Management and Inspections	Quality Assurance and Quality Verification

26	CaPA	Set WMP-08	CaPA_Set WMP-08	14	CaPA_Set WMP-08_014	Regarding the "Distribution Second Patrol" described in section 8.2.2.2.2 of PG&E's WMP, PG&E states: "PG&E has implemented a plan to complete the identified deadening tree work within 180 days for HFTD areas and within 365 days for non-HFTD areas." a) What specific steps, actions, or measures are included in the plan noted in the quote above - in other words, what specific steps is PG&E taking to ensure that deadening tree work will be completed within the stated timelines? b) How did PG&E determine that 180 days was an appropriate and prudent timeframe for completing deadening tree work in HFTD areas? c) Does PG&E plan to complete identified deadening tree work within 180 days in HFTD areas for its Distribution Routine Patrol (section 8.2.2.1.1)? d) If the answer to part (c) is no, please explain why not. e) What is PG&E's expected time to complete deadening tree work identified during its Distribution Routine Patrol? Regarding the "Defensible Space Inspection" described in section 8.2.3.1.1 of PG&E's WMP, PG&E states: "Landowner related issues continue to prevent PG&E from achieving 100 percent defensible space completion status at locations where substitution defensible space zones extend into privately owned property." a) Where substitution defensible space zones extend into privately owned property, what is PG&E's process for completing defensible space inspections? b) What actions does PG&E plan to take during the 2023-2025 WMP period to address landowner related issues in order to achieve the highest possible defensible space completion status?	a) To ensure that deadening tree work is completed with 180 days in HFTD and 365 days in non-HFTD, PG&E has developed a process to report out in Daily Operating Review and Weekly Operating reviews at multiple functional levels, including VM Leadership and VM execution - the status of dead and dying trees and their timelines and timeliness status. This will ensure visibility and accountability at the regional level. b) In addition to managing to complete work between Routine and Second Patrol work cycles, the timeframe to complete deadening tree work within HFTD areas was based on GO 56 Rule 18 priority level 2, for corrective actions of conditions within Tier 3 to be completed within 6 months (180 days) of identification. c) Yes, PG&E does plan to address identified deadening trees in the stated timeframes in HFTD and non-HFTD in Distribution Routine Patrol. d) N/A. See above. e) The timeframe to complete deadening tree work identified during Distribution Routine Patrol is 180 days in HFTD and 365 days in non-HFTD. a) When defensible space zones extend onto private property, outreach to such landowners is made in advance to obtain permission to enter and conduct inspection. If access is granted, the inspection is executed with fuel reduction and PRC 4201 compliance prescription identified. If access is denied and found to be without applicable easement, other land rights or valid entry agreements, the inspection record will reflect a "refusal" and documented for future reference as PG&E does not have the right to conduct defensible space inspections on property not owned by the Company. b) Annual defensible space inspections do serve as an opportunity to re-engage prior refusal landowners. Changes of ownership, changes in landowner opinion, new local agency defensible space ordinances or code often support reversal in status. c) PG&E will remove the wood chips when safe to do so. If access does not allow for chipping and wood chip removal, crews will lop and scissor debris on site in accordance with applicable regulations. d) There are multiple real-time opportunities for landowners to request wood management. PG&E field personnel attempt to engage with landowners in-person about tree work and wood management preferences at the time of inspections, tree work and post-tree work verification. Field personnel may also leave door hangers or other informational materials if landowners are unavailable. Following active emergency response efforts where landowners may not be present, we initiate regional post-event outreach. This may include letters, door hangers, interactive voice messages and/or press releases. Information is also available at pge.com. e) Our dedicated customer team is equipped to receive, record, and process all landowner opt-ins for wildlife and EVM wood management through our internal customer relationship management database. This includes opt-ins that come through field personnel. f) Yes, landowner wood management preferences are effective immediately. We work as quickly and efficiently as possible to manage and haul accessible wood without compromising public safety, access or environmental and cultural resources. As each property is different, we collaborate with the landowner to find an optimal solution. The timeline for wood management is dependent on landowner permission, ground conditions, and the ability for our crews to safely access the wood. Wood management may also be subject to permitting requirements. Landowners can opt into the Wood Management program at any time before, during or after tree work is conducted. Field personnel as well as our dedicated customer team can work directly with landowners to record their wood management preferences through our internal customer management database in person, by phone or by email. g) Landowner wood management preferences are indicated to operations personnel through our work management platform. h) Wood management preferences apply to an instance of tree work activity on a property, if new tree work is prescribed, we would coordinate with the landowner on their preferences again as preferences may vary by tree species, size or specific location. We are always looking for opportunities to continuously improve our Wood Management program, including new methods for recording landowner preferences. i) Wood management escalations are primarily received, recorded and responded to by our dedicated customer team through our internal system and case management process.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	0	N/A	8.2.2.2.2	Vegetation Management and Inspections	Distribution Second Patrol
27	CaPA	Set WMP-08	CaPA_Set WMP-08	15	CaPA_Set WMP-08_015	Regarding the "Defensible Space Inspection" described in section 8.2.3.1.1 of PG&E's WMP, PG&E states: "Landowner related issues continue to prevent PG&E from achieving 100 percent defensible space completion status at locations where substitution defensible space zones extend into privately owned property." a) Where substitution defensible space zones extend into privately owned property, what is PG&E's process for completing defensible space inspections? b) What actions does PG&E plan to take during the 2023-2025 WMP period to address landowner related issues in order to achieve the highest possible defensible space completion status?	a) When defensible space zones extend onto private property, outreach to such landowners is made in advance to obtain permission to enter and conduct inspection. If access is granted, the inspection is executed with fuel reduction and PRC 4201 compliance prescription identified. If access is denied and found to be without applicable easement, other land rights or valid entry agreements, the inspection record will reflect a "refusal" and documented for future reference as PG&E does not have the right to conduct defensible space inspections on property not owned by the Company. b) Annual defensible space inspections do serve as an opportunity to re-engage prior refusal landowners. Changes of ownership, changes in landowner opinion, new local agency defensible space ordinances or code often support reversal in status. c) PG&E will remove the wood chips when safe to do so. If access does not allow for chipping and wood chip removal, crews will lop and scissor debris on site in accordance with applicable regulations. d) There are multiple real-time opportunities for landowners to request wood management. PG&E field personnel attempt to engage with landowners in-person about tree work and wood management preferences at the time of inspections, tree work and post-tree work verification. Field personnel may also leave door hangers or other informational materials if landowners are unavailable. Following active emergency response efforts where landowners may not be present, we initiate regional post-event outreach. This may include letters, door hangers, interactive voice messages and/or press releases. Information is also available at pge.com. e) Our dedicated customer team is equipped to receive, record, and process all landowner opt-ins for wildlife and EVM wood management through our internal customer relationship management database. This includes opt-ins that come through field personnel. f) Yes, landowner wood management preferences are effective immediately. We work as quickly and efficiently as possible to manage and haul accessible wood without compromising public safety, access or environmental and cultural resources. As each property is different, we collaborate with the landowner to find an optimal solution. The timeline for wood management is dependent on landowner permission, ground conditions, and the ability for our crews to safely access the wood. Wood management may also be subject to permitting requirements. Landowners can opt into the Wood Management program at any time before, during or after tree work is conducted. Field personnel as well as our dedicated customer team can work directly with landowners to record their wood management preferences through our internal customer management database in person, by phone or by email. g) Landowner wood management preferences are indicated to operations personnel through our work management platform. h) Wood management preferences apply to an instance of tree work activity on a property, if new tree work is prescribed, we would coordinate with the landowner on their preferences again as preferences may vary by tree species, size or specific location. We are always looking for opportunities to continuously improve our Wood Management program, including new methods for recording landowner preferences. i) Wood management escalations are primarily received, recorded and responded to by our dedicated customer team through our internal system and case management process.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	0	N/A	8.2.3.1	Vegetation Management and Inspections	Defensible Space Inspection
28	CaPA	Set WMP-08	CaPA_Set WMP-08	16	CaPA_Set WMP-08_016	Regarding "Wood and Slash Management" described in section 8.2.3.2 of PG&E's WMP, PG&E states: "Chips are left on site or removed off site based on owner preferences." PG&E further states that "Wood Management is a voluntary program in which property owners must opt-in to participate." a) If PG&E is unable to contact a landowner, how does it manage wood chips? b) How does PG&E ensure that landowners are aware of the opt-in Wood Management program? c) How does PG&E record landowner opt-ins to the Wood Management program? d) Once a landowner opt-in to the Wood Management program, how quickly does the program become effective? E.g., could a landowner opt-in while VM work is being performed? e) How does PG&E inform VM contractors of the landowner's Wood Management preferences? f) Does the Wood Management opt-in remain valid indefinitely or must landowners renew their preferences on a regular basis? g) If a landowner has complaints regarding wood and slash management by PG&E VM employees or contractors, what is the process for receiving, recording, and responding to such complaints?	a) For Routine and Second Patrol, PG&E does not currently have standards specific to high-risk species. Trees identified during these inspection cycles that require mitigation per PRC4203 and GO56 Rule 35 are expected to be identified and listed for work regardless of species. A new program, Focused Tree Inspection (FTI) is being piloted starting in Q2 2023 and will incorporate regional outage analysis informed by tree caused outages within Areas of Concern (AOC) developed in Q4 2022. These pilots are expected to analyze area specific vegetation related outages within the AOC polygons in advance of FTI. When detailed outage data is available, this analysis will indicate vegetation caused outage trends that include species and failure types. The experience and findings during execution of these pilots may inform development of program specific guidance that relates to regional high-risk species. PG&E will then determine which programs are best suited to incorporate species specific guidance due to anticipated regional variation. b) Development of any standards related to high-risk species is still being determined and contingent upon completion of FTI pilots in 2023. A determination will be made specific to that program as its guidance is formalized following the pilots. c) Not applicable.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	0	N/A	8.2.3.2	Vegetation Management and Inspections	Wood and Slash Management
29	CaPA	Set WMP-08	CaPA_Set WMP-08	17	CaPA_Set WMP-08_017	Regarding "High-Risk Species" described in section 8.2.3.6 of PG&E's WMP, PG&E states: "There are no governing standards for high-risk species." a) Does PG&E plan to develop governing standards for high-risk species? b) If the answer to part (a) is yes, when does PG&E expect to complete development of such standards? c) If the answer to part (a) is no, please explain why not.	a) For Routine and Second Patrol, PG&E does not currently have standards specific to high-risk species. Trees identified during these inspection cycles that require mitigation per PRC4203 and GO56 Rule 35 are expected to be identified and listed for work regardless of species. A new program, Focused Tree Inspection (FTI) is being piloted starting in Q2 2023 and will incorporate regional outage analysis informed by tree caused outages within Areas of Concern (AOC) developed in Q4 2022. These pilots are expected to analyze area specific vegetation related outages within the AOC polygons in advance of FTI. When detailed outage data is available, this analysis will indicate vegetation caused outage trends that include species and failure types. The experience and findings during execution of these pilots may inform development of program specific guidance that relates to regional high-risk species. PG&E will then determine which programs are best suited to incorporate species specific guidance due to anticipated regional variation. b) Development of any standards related to high-risk species is still being determined and contingent upon completion of FTI pilots in 2023. A determination will be made specific to that program as its guidance is formalized following the pilots. c) Not applicable.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	0	N/A	8.2.3.6	Vegetation Management and Inspections	High-Risk Species
30	CaPA	Set WMP-08	CaPA_Set WMP-08	18	CaPA_Set WMP-08_018	The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission. Table 8-10: Priority 1/Priority 2 and Second Patrol Trees Categorized By Age: shows 296 priority 1 or 2 trees that were inspected more than 180 days prior to February 28, 2023. Please provide a table with the following additional information for these 296 trees: a) The exact number of days since the last inspection, as of February 28, 2023. b) The current priority level of the tree c) The type of the most recent inspection d) The HFTD tier where the tree is located e) PG&E's expected remediation date for the tree.	The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission. The data for the 296 P1/P2/Second Patrol trees can be found on "WMP Discovery2023_DR_CalAdvocates_008-Q019A201.xlsx" For the 3 Priority 1/Priority 2 trees out of the set of 296, please refer to tab "P2 Data". a) Please see "Age" in Column F on tab "P2 Data" for the age in days since the last inspection as of February 28, 2022. b) Please see "Priority" in Column C on tab "P2 Data" for the priority level. • If vegetation is determined to be an immediate risk to PG&E facilities, described as a Priority 1 Condition, the condition will be mitigated within 24 hours of identification as long as conditions are safe for the tree crew to proceed with work. • Vegetation identified as pending Priority 2 work within the RFW area will be reviewed and mitigated as outlined in the VM Priority Tag Procedure (TD 71029-1). c) Please see "dtInsprDate" in Column D on tab "P2 Data" for the inspection date. d) Please see "HFTDTier" in Column H on tab "P2 Data" for the HFTD tier. e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time. For the 293 trees out of the set of 296, please refer to tab "TM Data". Please note, the quantity of trees that correspond to the "TreeRecsd" can be located on Column L of the "TM Data" tab in attachment. a) Please see "Age" in Column J on tab "TM Data" for the age in days since the last inspection as of February 28, 2022. b) Please see "Priority" in Column F on tab "TM Data" for the priority level. • Routine classification is normal compliance work prioritized to be completed during the normal work cycle. • Expedited classification is work that needs to be completed as part of reliability. • Accelerated classification are trees that are out of compliance and need to be worked before the next work cycle occurs. c) Please see "dtInsprDate" in Column D on tab "TM Data" for the last inspection date as of February 28, 2022. d) Please see "HFTDTier" in Column K on tab "TM Data" for the HFTD tier. e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	0	N/A	8.2.5.2	Vegetation Management and Inspections	Quality Control
31	CaPA	Set WMP-08	CaPA_Set WMP-08	19	CaPA_Set WMP-08_019	The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission. Table 8-10: Priority 1/Priority 2 and Second Patrol Trees Categorized By Age: shows 296 priority 1 or 2 trees that were inspected more than 180 days prior to February 28, 2023. Please provide a table with the following additional information for these 296 trees: a) The exact number of days since the last inspection, as of February 28, 2023. b) The current priority level of the tree c) The type of the most recent inspection d) The HFTD tier where the tree is located e) PG&E's expected remediation date for the tree.	The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission. The data for the 296 P1/P2/Second Patrol trees can be found on "WMP Discovery2023_DR_CalAdvocates_008-Q019A201.xlsx" For the 3 Priority 1/Priority 2 trees out of the set of 296, please refer to tab "P2 Data". a) Please see "Age" in Column F on tab "P2 Data" for the age in days since the last inspection as of February 28, 2022. b) Please see "Priority" in Column C on tab "P2 Data" for the priority level. • If vegetation is determined to be an immediate risk to PG&E facilities, described as a Priority 1 Condition, the condition will be mitigated within 24 hours of identification as long as conditions are safe for the tree crew to proceed with work. • Vegetation identified as pending Priority 2 work within the RFW area will be reviewed and mitigated as outlined in the VM Priority Tag Procedure (TD 71029-1). c) Please see "dtInsprDate" in Column D on tab "P2 Data" for the inspection date. d) Please see "HFTDTier" in Column H on tab "P2 Data" for the HFTD tier. e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time. For the 293 trees out of the set of 296, please refer to tab "TM Data". Please note, the quantity of trees that correspond to the "TreeRecsd" can be located on Column L of the "TM Data" tab in attachment. a) Please see "Age" in Column J on tab "TM Data" for the age in days since the last inspection as of February 28, 2022. b) Please see "Priority" in Column F on tab "TM Data" for the priority level. • Routine classification is normal compliance work prioritized to be completed during the normal work cycle. • Expedited classification is work that needs to be completed as part of reliability. • Accelerated classification are trees that are out of compliance and need to be worked before the next work cycle occurs. c) Please see "dtInsprDate" in Column D on tab "TM Data" for the last inspection date as of February 28, 2022. d) Please see "HFTDTier" in Column K on tab "TM Data" for the HFTD tier. e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time.	Holly Wehman	3/30/2023	4/5/2023	4/5/2023	https://www.pge.com/pge_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_008_ip	1	N/A	8.2.6	Vegetation Management and Inspections	Open Work Orders

32	CaPA	Set WMP-09	CaPA_Set WMP-09	1	CaPA_Set WMP-09_01	<p>P. 10 of PG&E's WMP states, "We have completed certain programs and removed some less impactful targets from the 2023 WMP."</p> <p>a) Please list the "less impactful" targets that were removed from the 2023 WMP.</p> <p>b) For each target in part (a), please explain how PG&E determined that the target was "less impactful."</p>	<p>a) The targets that were included in the 2022 WMP but not included in the 2023 WMP are identified below. Please note that we do not necessarily consider each of these to be "less impactful" in all situations. Instead, they are more properly described as not being the best choice for our wildfire mitigation portfolio at this particular point in time.</p> <ul style="list-style-type: none"> Weather Station Installation and Optimization - PG&E did not include a target for weather station installation in the 2023-2025 WMP because our weather station network is nearing full maturity with more than 1,400 weather stations installed. We will continue to evaluate the need for additional stations. High-Definition Camera Installations - PG&E has sponsored over 600 cameras covering 90 percent of the HTD tier 2 and tier 3 areas and, given this saturation, we are not currently planning to install new cameras at this time. Early Fault Detection Installations - PG&E does not have a 2023 target for EFD installations. We plan to develop and implement processes and procedures to analyze EFD alarms, conduct field investigations and track mitigation activities to effectively use EFD technology prior to deploying additional sensors. Distribution Sectionizing Devices - PG&E has completed our transmission and distribution PSPP line sectionalizing program. Because there is limited incremental benefit to installing additional switches, we are not including these mitigation initiatives in this WMP. Temporary Distribution Microgrids - No additional temporary distribution microgrids will be built in 2023. The program will close after improvement projects on existing sites are completed. PG&E may develop other distribution microgrids supported by temporary or permanent generation through other programs such as the Community Microgrid Enablement Program and Microgrid Incentive Program. Remote Grid - PG&E is continuing to develop Remote Grids as an alternative to, or in conjunction with, system hardening or other mitigation efforts. Even though we do not have a quantitative target for remote grids installed, they will continue to be part of our wildfire mitigation portfolio. Enhanced Vegetation Management (EVM) - PG&E's EVM program concluded at the end of 2022. EPSS Reliability Improvements - This initiative was a target in PG&E's 2022 WMP. In our 2023 WMP this target becomes an objective (GM-07) through which we will update our EPSS reliability study annually. Community Engagement Meetings - In the 2023 WMP Community Engagement Meetings <p>PG&E notes that this statement is included in the 2023-2025 WMP as a general observation about the sensitivity of certain electric assets to prevailing temperatures that exceed equipment design specifications. It does not constitute a thorough evaluation of the vulnerability (meaning, the exposure of an asset to a specific climate hazard as well as an asset's sensitivity to that climate hazard) of a given asset or of the grid as a whole. PG&E will file its first Climate Vulnerability Assessment pursuant to CPUC Decision 20-08-046 in May 2024. In addition to the answers provided below, the 2022 Climate Strategy Report contains a significant amount of detail on the Company's climate mitigation and adaptation activities.</p> <p>a) PG&E has substantial existing adaptive capacity to manage the increased risk of asset failure driven by heat-related climate hazards and is taking the following steps to mitigate this risk:</p> <ol style="list-style-type: none"> 1) PG&E routinely monitors, maintains, and replaces heat-sensitive electric equipment as part of its company's core mission to deliver safe, clean, affordable, reliable energy. 2) PG&E has developed a predictive transformer failure model to better target existing transformer replacement efforts. 3) PG&E is currently reviewing electric design standards to ensure that they account for projections of future heat conditions. This will ensure that equipment at the end of its useful life will be replaced with equipment designed to be resilient to prevailing future conditions. <p>b) In addition to the above, PG&E's Climate Resilience Team provides relevant climate projection data to PG&E's Enterprise and Operational Risk Management group for incorporation into the bowtie models that are the foundation of the Risk Assessment and Mitigation Phase (RAMP) filing.</p> <p>Climate data is integrated into risk bowtie models to the extent that climate projection data can be translated into near-term frequencies while maintaining statistical validity (climate projections cannot and should not be used to "predict" weather events in a given future year). Please see PG&E's 2020 RAMP filing for more information about the treatment of the climate change cross cutting risk factor.</p> <p>b) In the 2023-2025 period, PG&E will continue to manage the risk of asset failure utilizing existing capabilities as mentioned above, including advancing the quantitative Risk Assessment and Mitigation Phase filing which is focused on quantifying the probability and consequences of asset failure and identifying cost effective mitigations.</p> <p>Climate projections provide directional guidance as to changes in the average frequency and a) PG&E ran a pilot of AI technology in 2021 to determine the efficacy of this new technology to assist with the detection and notification of new ignitions. In 2022 a project was launched under the Electric Program Investment Charge 3.45 in which multiple potential vendors participated to prove out the ability of the AI technology to continuously monitor the feeds from the wildfire cameras installed in PG&E service territory and provide alerts to both PG&E and responding agency partners in order to reduce response time to detected ignitions.</p> <p>b) For the EPIC project, PG&E's team determined that AI would enable both PG&E and First Responders to receive notifications of ignitions detected on installed wildfire cameras. The decision was made to pursue AI implementation on all PG&E sponsored cameras in 2023. It is important to note that CAL FIRE, SCE, and SDG&E are all sponsoring AI implementation on their sponsored cameras in 2023.</p> <p>The ability for the over 1,000 wildfire cameras installed across the state to be continuously monitored with rapid alerting for responding agencies is seen as a major step forward in the detection and response to wildfire ignitions.</p> <p>b) AI detection will enable more rapid notification of responding agencies to new fire ignitions. Early results have shown between 2 and 30 minutes are saved when utilizing automated detection technology (AI). The anticipated improvement across the entire state is that responding agencies will become aware of new ignitions more quickly than relying on the public notifications that have been utilized to this point (i.e., calling 9-1-1).</p> <p>c) Please refer to attachment WMP-Discovery2023_DR_CaAdvocates_009-Q003_Ach01 which contains a comparative analysis illustrating instances when the AI detection times were faster than the 9-1-1 calls (RPNV Discovery Time).</p> <p>d) As of the beginning of 2023, PG&E spent \$1,043,000 on the Electric Program Investment Charge 3.45, "Automated Fire Detection from Wildfire Alert Cameras" program.</p> <p>e) The EPIC project has ended and there will be no additional spend on this going forward. The cost to implement AI on the PG&E sponsored cameras will be carried within the Wildfire Camera program budget. This is expected to be approximately \$1,600,000 in 2023 with incremental increases going forward. CAL FIRE, SCE, and SDG&E will also be supporting AI on their sponsored cameras at the same cost per camera.</p> <p>f) PG&E expects to realize benefits from automated fire detection as early as June 2023.</p>	<p>https://www.pge.com/pge_eboba/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAdvocates_009.zip</p>	0	N/A	1	Executive Summary & Overview	N/A
33	CaPA	Set WMP-09	CaPA_Set WMP-09	2	CaPA_Set WMP-09_02	<p>P. 107 of PG&E's WMP states, "Increased temperatures can cause electric equipment to age more quickly which will increase the need for more frequent asset replacements. Higher temperatures may cause equipment to fail resulting in customer outages."</p> <p>a) What steps has PG&E taken to mitigate the increased risk of asset failure anticipated from rising temperatures?</p> <p>b) What steps does PG&E plan to take during the 2023-2025 WMP period to mitigate the increased risk of asset failure anticipated from rising temperatures?</p>	<p>PG&E notes that this statement is included in the 2023-2025 WMP as a general observation about the sensitivity of certain electric assets to prevailing temperatures that exceed equipment design specifications. It does not constitute a thorough evaluation of the vulnerability (meaning, the exposure of an asset to a specific climate hazard as well as an asset's sensitivity to that climate hazard) of a given asset or of the grid as a whole. PG&E will file its first Climate Vulnerability Assessment pursuant to CPUC Decision 20-08-046 in May 2024. In addition to the answers provided below, the 2022 Climate Strategy Report contains a significant amount of detail on the Company's climate mitigation and adaptation activities.</p> <p>a) PG&E has substantial existing adaptive capacity to manage the increased risk of asset failure driven by heat-related climate hazards and is taking the following steps to mitigate this risk:</p> <ol style="list-style-type: none"> 1) PG&E routinely monitors, maintains, and replaces heat-sensitive electric equipment as part of its company's core mission to deliver safe, clean, affordable, reliable energy. 2) PG&E has developed a predictive transformer failure model to better target existing transformer replacement efforts. 3) PG&E is currently reviewing electric design standards to ensure that they account for projections of future heat conditions. This will ensure that equipment at the end of its useful life will be replaced with equipment designed to be resilient to prevailing future conditions. <p>b) In addition to the above, PG&E's Climate Resilience Team provides relevant climate projection data to PG&E's Enterprise and Operational Risk Management group for incorporation into the bowtie models that are the foundation of the Risk Assessment and Mitigation Phase (RAMP) filing.</p> <p>Climate data is integrated into risk bowtie models to the extent that climate projection data can be translated into near-term frequencies while maintaining statistical validity (climate projections cannot and should not be used to "predict" weather events in a given future year). Please see PG&E's 2020 RAMP filing for more information about the treatment of the climate change cross cutting risk factor.</p> <p>b) In the 2023-2025 period, PG&E will continue to manage the risk of asset failure utilizing existing capabilities as mentioned above, including advancing the quantitative Risk Assessment and Mitigation Phase filing which is focused on quantifying the probability and consequences of asset failure and identifying cost effective mitigations.</p> <p>Climate projections provide directional guidance as to changes in the average frequency and a) PG&E ran a pilot of AI technology in 2021 to determine the efficacy of this new technology to assist with the detection and notification of new ignitions. In 2022 a project was launched under the Electric Program Investment Charge 3.45 in which multiple potential vendors participated to prove out the ability of the AI technology to continuously monitor the feeds from the wildfire cameras installed in PG&E service territory and provide alerts to both PG&E and responding agency partners in order to reduce response time to detected ignitions.</p> <p>b) For the EPIC project, PG&E's team determined that AI would enable both PG&E and First Responders to receive notifications of ignitions detected on installed wildfire cameras. The decision was made to pursue AI implementation on all PG&E sponsored cameras in 2023. It is important to note that CAL FIRE, SCE, and SDG&E are all sponsoring AI implementation on their sponsored cameras in 2023.</p> <p>The ability for the over 1,000 wildfire cameras installed across the state to be continuously monitored with rapid alerting for responding agencies is seen as a major step forward in the detection and response to wildfire ignitions.</p> <p>b) AI detection will enable more rapid notification of responding agencies to new fire ignitions. Early results have shown between 2 and 30 minutes are saved when utilizing automated detection technology (AI). The anticipated improvement across the entire state is that responding agencies will become aware of new ignitions more quickly than relying on the public notifications that have been utilized to this point (i.e., calling 9-1-1).</p> <p>c) Please refer to attachment WMP-Discovery2023_DR_CaAdvocates_009-Q003_Ach01 which contains a comparative analysis illustrating instances when the AI detection times were faster than the 9-1-1 calls (RPNV Discovery Time).</p> <p>d) As of the beginning of 2023, PG&E spent \$1,043,000 on the Electric Program Investment Charge 3.45, "Automated Fire Detection from Wildfire Alert Cameras" program.</p> <p>e) The EPIC project has ended and there will be no additional spend on this going forward. The cost to implement AI on the PG&E sponsored cameras will be carried within the Wildfire Camera program budget. This is expected to be approximately \$1,600,000 in 2023 with incremental increases going forward. CAL FIRE, SCE, and SDG&E will also be supporting AI on their sponsored cameras at the same cost per camera.</p> <p>f) PG&E expects to realize benefits from automated fire detection as early as June 2023.</p>	<p>https://www.pge.com/pge_eboba/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAdvocates_009.zip</p>	0	N/A	5.3.4.2	Overview of the Service Territory	Climate Change Phenomena and Trends
34	CaPA	Set WMP-09	CaPA_Set WMP-09	3	CaPA_Set WMP-09_03	<p>P. 586 of PG&E's WMP states: "In 2022 we continued our assessment through the Electric Program Investment Charge 3.45, "Automated Fire Detection from Wildfire Alert Cameras," program. Through our assessment period we determined that AI detection on cameras will improve our detection system and in 2023 we will select a vendor to install AI detection on our cameras."</p> <p>a) How did PG&E determine that AI detection would improve the detection system?</p> <p>b) Please quantify the extent to which PG&E anticipates AI detection will improve PG&E's detection system.</p> <p>c) Please provide any available studies, analyses or reports to support your statements in response to parts (a) and (b).</p> <p>d) As of the beginning of 2023, how much has PG&E spent on the Electric Program Investment Charge 3.45, "Automated Fire Detection from Wildfire Alert Cameras," program?</p> <p>e) How much does PG&E forecast spending on the Electric Program Investment Charge 3.45, "Automated Fire Detection from Wildfire Alert Cameras," program in each of the years 2023, 2024, and 2025?</p> <p>f) When is the earliest date that PG&E expects to realize benefits from automated fire detection?</p>	<p>PG&E's PPSR MAVF Risk Score includes safety, reliability, and financial components. The combination of the components results in a total MAVF Risk Score for PPSR.</p> <p>For Safety, PG&E uses the combination of 50% PG&E PPSR data and 50% US industry widespread unplanned outage data. Based on blending of the two datasets, PG&E arrives at a Serious Injury or Fatality (SIF) / million Customer Minutes Interrupted (CMI). Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach01 pptx."</p> <p>For Reliability, PG&E uses the CMI estimates from the historical back-cast for each lookback event. Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach02.xlsx."</p> <p>For Financial, PG&E uses the historical cost of executing PPSR events and estimates a fixed cost of executing a PPSR and a cost per customer through linear regression. Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach03.xlsx."</p> <p>PG&E's PPSR consequence model is based off the back-cast of potential PPSR events since 2010 at the customer level. For each customer, the model produces an expected number of CMI based on the PPSR frequency and duration. However, the CMI outputted is not directly converted to MAVF. This is because of the non-linear scaling of the MAVF (1 event with very high CMI impact is not the same as many events with small CMI impacts). As such, PG&E calibrates the PPSR Consequence Model to the Enterprise MAVF risk score by proportionally allocating the percent contribution of each customer CMI of the total times the total MAVF Risk Score. Additionally, PG&E includes a critical customer weighting, for example, a medical baseline customer has a weighting of 2, so the CMI associated with that customer would be equivalently double that of a regular customer.</p> <p>As an example:</p> <p>The Overall MAVF Risk Score is 100</p> <p>Customer 1 (medical baseline) experiences 10 CMI</p> <p>Customer 2 (regular) experiences 30 CMI</p> <p>Customer 1's equivalent CMI is 10 CMI * 2 weighting = 20 CMI</p> <p>Customer 2's equivalent CMI is 30 CMI * 1 weighting = 30 CMI</p> <p>Customer 1's MAVF = 100 * (20/(20+30)) = 40 MAVF</p> <p>Customer 2's MAVF = 100 * (30/(20+30)) = 60 MAVF</p>	<p>https://www.pge.com/pge_eboba/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAdvocates_009.zip</p>	1	N/A	8.3.4.2	Situational Awareness and Forecasting	Ignition Detection Systems
35	CaPA	Set WMP-09	CaPA_Set WMP-09	4	CaPA_Set WMP-09_04	<p>P. 174 of PG&E's WMP states, "The results of the PPSR Consequence Model are then calibrated to PG&E's Enterprise Risk Model's MAVF Risk Score for PPSR." For each component in PG&E's MAVF, explain how the results of the PPSR Consequence Model are calibrated to the MAVF.</p>	<p>PG&E's PPSR MAVF Risk Score includes safety, reliability, and financial components. The combination of the components results in a total MAVF Risk Score for PPSR.</p> <p>For Safety, PG&E uses the combination of 50% PG&E PPSR data and 50% US industry widespread unplanned outage data. Based on blending of the two datasets, PG&E arrives at a Serious Injury or Fatality (SIF) / million Customer Minutes Interrupted (CMI). Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach01 pptx."</p> <p>For Reliability, PG&E uses the CMI estimates from the historical back-cast for each lookback event. Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach02.xlsx."</p> <p>For Financial, PG&E uses the historical cost of executing PPSR events and estimates a fixed cost of executing a PPSR and a cost per customer through linear regression. Details are shown in "WMP-Discovery2023_DR_CaAdvocates_009-Q004Ach03.xlsx."</p> <p>PG&E's PPSR consequence model is based off the back-cast of potential PPSR events since 2010 at the customer level. For each customer, the model produces an expected number of CMI based on the PPSR frequency and duration. However, the CMI outputted is not directly converted to MAVF. This is because of the non-linear scaling of the MAVF (1 event with very high CMI impact is not the same as many events with small CMI impacts). As such, PG&E calibrates the PPSR Consequence Model to the Enterprise MAVF risk score by proportionally allocating the percent contribution of each customer CMI of the total times the total MAVF Risk Score. Additionally, PG&E includes a critical customer weighting, for example, a medical baseline customer has a weighting of 2, so the CMI associated with that customer would be equivalently double that of a regular customer.</p> <p>As an example:</p> <p>The Overall MAVF Risk Score is 100</p> <p>Customer 1 (medical baseline) experiences 10 CMI</p> <p>Customer 2 (regular) experiences 30 CMI</p> <p>Customer 1's equivalent CMI is 10 CMI * 2 weighting = 20 CMI</p> <p>Customer 2's equivalent CMI is 30 CMI * 1 weighting = 30 CMI</p> <p>Customer 1's MAVF = 100 * (20/(20+30)) = 40 MAVF</p> <p>Customer 2's MAVF = 100 * (30/(20+30)) = 60 MAVF</p>	<p>https://www.pge.com/pge_eboba/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CaAdvocates_009.zip</p>	3	N/A	6.2.2.3	Risk Methodology and Assessment	Risk and Risk Components Calculation

36	CaPA	Set WMP-09	CaPA_Set WMP-09	5	CaPA_Set WMP-09_05	<p>P. 161 of PG&E's WMP discusses Group G, Above-Grade Hardware, in the context of PG&E's WTRM Group G has two sub-groups. PG&E states, "Sub-Group 1 consists of components where the life cycle closely aligns with that of the structure. These include the hanger plate and bolts.</p> <p>a) Does the WTRM apply the same hazards and threats to all components within a grouping? Please explain your answer.</p> <p>b) Does PG&E's grouping within the WTRM account for any hazards that may be unique to a subset of hardware within a group? Please explain your answer.</p> <p>c) Hanger plates may be subject to wear such as "keyholing" that the main structure may not experience. How does PG&E account for this potential difference in life cycle between hanger plates and the structure?</p> <p>d) Which group within the WTRM includes C-hooks?</p> <p>e) Please explain your justification for your answer to part (d).</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	6.2.2.1	Risk Methodology and Assessment	Risk and Risk Components Calculation
37	CaPA	Set WMP-09	CaPA_Set WMP-09	6	CaPA_Set WMP-09_06	<p>P. 193 of PG&E's WMP states, "top-risk areas are defined as the areas corresponding to those 100 x 100 m pixels that intersect PG&E overhead electrical infrastructure locations and that are in the upper 20th percentile based on WDRM v3 risk scores."</p> <p>a) By "upper 20th percentile," does PG&E mean the 80th through 100th percentiles, as percentiles are conventionally defined (in other words, the highest quintile of risk scores)?</p> <p>b) In the above statement, does "upper 20th percentile" refer to all WDRM v3 risk scores (which encompass most of PG&E's service territory), or a subset (for example, the upper 20th percentile of those WDRM v3 risk scores located within HFDT)? Please explain your answer.</p> <p>c) How many circuit miles are included in the "upper 20th percentile" as this term is used in PG&E's WMP?</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	6.4.1.2	Risk Methodology and Assessment	Top Risk Areas Within the HFRA
38	CaPA	Set WMP-09	CaPA_Set WMP-09	7	CaPA_Set WMP-09_07	<p>P. 73 of PG&E's WMP states, "We created a species-specific stress index model for PG&E tree health and mortality."</p> <p>a) What is PG&E's species-specific stress index model for tree health and mortality?</p> <p>b) How does PG&E utilize its species-specific stress index model for tree health and mortality? Please describe the data inputs to this model.</p> <p>c) Please describe the outputs of this model.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	4.4	Overview of WMP	Risk-Informed Framework
39	CaPA	Set WMP-09	CaPA_Set WMP-09	8	CaPA_Set WMP-09_08	<p>P. 129 of PG&E's WMP states: PG&E employees and contractors must adhere to PG&E's Best Management Practices (BMP) where practicable. BMPs are considered practicable where physically possible and not conflicting with other regulatory obligations or safety considerations (GO 95 Rule 35 and Public Resources Codes 4292 and 4293), or emergency response situations.</p> <p>a) How do VM contractors determine when adherence to BMPs is not "physically possible."</p> <p>b) How does PG&E audit or review VM contractors to ensure they are adhering to BMPs where practicable?</p> <p>c) What actions does PG&E take if it determines that a VM contractor has not consistently adhered to BMPs where practicable?</p> <p>d) Please list all instances in 2022 where PG&E has determined that a VM contractor did not adhere to BMPs where BMPs were practicable, as defined above.</p> <p>e) Please list all instances in 2022 in which PG&E took action to reprimand or sanction a VM contractor for failing to adhere to BMPs where practicable.</p>	Holly Wetman	4/4/2023	4/12/2023	4/12/2023	1	N/A	5.4.5	Overview of the Service Territory	Environmental Compliance and Permitting
39	CaPA	Set WMP-09	CaPA_Set WMP-09	8 Rev	CaPA_Set WMP-09_08 Rev	<p>P. 129 of PG&E's WMP states: PG&E employees and contractors must adhere to PG&E's Best Management Practices (BMP) where practicable. BMPs are considered practicable where physically possible and not conflicting with other regulatory obligations or safety considerations (GO 95 Rule 35 and Public Resources Codes 4292 and 4293), or emergency response situations.</p> <p>a) How do VM contractors determine when adherence to BMPs is not "physically possible."</p> <p>b) How does PG&E audit or review VM contractors to ensure they are adhering to BMPs where practicable?</p> <p>c) What actions does PG&E take if it determines that a VM contractor has not consistently adhered to BMPs where practicable?</p> <p>d) Please list all instances in 2022 where PG&E has determined that a VM contractor did not adhere to BMPs where BMPs were practicable, as defined above.</p> <p>e) Please list all instances in 2022 in which PG&E took action to reprimand or sanction a VM contractor for failing to adhere to BMPs where practicable.</p>	Holly Wetman	4/4/2023	4/12/2023	4/12/2023	1	N/A	5.4.5	Overview of the Service Territory	Environmental Compliance and Permitting
40	CaPA	Set WMP-09	CaPA_Set WMP-09	9	CaPA_Set WMP-09_09	<p>P. 526 of PG&E's WMP states, "The primary target for secondary patrols is HFDT and HFRA but exceptions and additional areas are included to appropriately address vegetation associated risks."</p> <p>P. 267 states, "Beginning in 2023, PG&E will use the annual review of ADC that we committed to doing in RW_PG&E-22-05, to identify areas subject to Second Patrols."</p> <p>a) Is there a difference between "secondary patrols" and "Second Patrols" in the two passages quoted above? If so, please explain the difference(s).</p> <p>b) In 2022, did PG&E's secondary patrol cover the entire HFDT? Please explain your answer.</p> <p>c) In 2023, will PG&E's secondary patrol cover the entire HFDT? Please explain your answer.</p> <p>d) Is PG&E planning to cover fewer circuit miles with second patrols in 2023 than were covered in 2022? Please explain your answer.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	8.2.2.2	Vegetation Management and Inspections	Distribution Second Patrol

41	CaPA	Set WMP-09	CaPA_Set WMP-09	10	CaPA_Set WMP-09_010	<p>P. 342 of PG&E's WMP states, "In July 2021, PG&E launched a multi-year program to underground 10,000 distribution circuit miles in high wildfire risk areas."</p> <p>a) Since the July 2021 announcement of its 10,000 mile underground program, has PG&E performed any studies to determine whether the planned scope of 10,000 circuit miles should be revised?</p> <p>b) Please provide any available studies, analyses, reports, or workpapers pertinent to your answer to part (a).</p> <p>c) If the answer to part (a) is no, please explain why not.</p> <p>d) Does PG&E plan to perform any studies or analyses during the 2023-2025 WMP period to determine whether 10,000 circuit miles is still the appropriate scope to target for undergrounding?</p> <p>e) If the answer to part (d) is yes, please describe the planned scope and timing of such studies.</p> <p>f) If the answer to part (d) is no, please explain why not.</p>	<p>a) Yes, PG&E determined that undergrounding approximately 10,000 miles will reduce approximately 70 percent of risk in the HFTD. We initially used the output from our Wildfire Distribution Risk Model (WDRM) version 2 to first identify the 10,000 miles. We then subsequently validated that this was the correct number of miles after the July 2021 announcement using the output from our updated WDRM v3.</p> <p>b) Please see the attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q010ACh01.xlsx" for requested information on the WDRM v2 analysis. Based on the WDRM v2, the top 20% risk-ranked circuit segments are represented by 727 circuit segments. Shown in cell K730:M730, the cumulative overhead miles are approximately 8,762 with a cumulative risk reduction of approximately 70%.</p> <p>c) Please see attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q010ACh02.xlsx" for the requested information on the WDRM v3 analysis. Based on WDRM v3, PG&E's 10,000 underground circuit miles is represented by approximately 8,100 overhead miles, which is also equal to approximately 70% risk reduction.</p> <p>d) Not applicable, please see the response to subparts (a) and (b) above.</p> <p>e) PG&E's undergrounding plan will continue to evolve based on changing risk. We plan to update our risk model annually. We will continue to review the information in our updated models which will contribute to our thinking/understanding of the risk and the scope of the work. Additionally, we will outline our future plans in more detail in our SB884 filing which we plan to file later in 2023.</p> <p>f) Yes, please see the response to subpart (d).</p> <p>g) Not applicable, please see the responses to subparts (d) and (e).</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	2	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
42	CaPA	Set WMP-09	CaPA_Set WMP-09	11	CaPA_Set WMP-09_011	<p>P. 969 of PG&E's WMP states, "on average, it takes 1.25 UG install miles to replace 1 OH mile. However, at times, this multiplier can be 2-3 times greater."</p> <p>a) Does PG&E's target of 10,000 miles of undergrounding refer to the number of OH circuit-miles to be moved underground, or the number of underground circuit-miles to be installed?</p>	<p>The 10,000 mile target refers to the number of miles of underground circuit and aligned with the assumption of removing approximately 8,100 overhead circuit miles.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-23-34 - Review Process of Prioritizing Wildfire Mitigations
43	CaPA	Set WMP-09	CaPA_Set WMP-09	12	CaPA_Set WMP-09_012	<p>a) What is PG&E's current forecast cost per circuit-mile for undergrounding projects completed in the second half of 2023?</p> <p>b) Please provide workpapers to support your answer to part (a).</p>	<p>a) PG&E did not provide a forecast cost per circuit miles for undergrounding projects completed specifically in the second half of 2023 in its WMP. However, PG&E did provide a target unit cost (cost per circuit mile) by year for undergrounding projects through our 2023 EIC Reply Brief (A-21-06-021).</p> <p>b) PG&E's unit cost forecast is a target value based on a strategic reduce unit costs over time that is not based on a specific calculation.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
44	CaPA	Set WMP-09	CaPA_Set WMP-09	13	CaPA_Set WMP-09_013	<p>a) What is PG&E's forecast RSE for undergrounding completed in the second half of 2023?</p> <p>b) Please provide workpapers to support your answer to part (a).</p>	<p>a) PG&E does not forecast an RSE for undergrounding projects planned to be completed specifically in the second half of 2023 in its WMP. However, in the 2023 GRC, PG&E provided an RSE of 5.4 in 2023 for underground system hardening (A-21-06-021, Exhibit PG&E-4, Chapter 3, p. 3-4, Table 3-1).</p> <p>b) Please see attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q013ACh01.xlsx" for the requested information on the "RSE Results" tab, cell V12 for the 2023 Undergrounding RSE with supporting data on the other tabs. Complementarily, targets to support the RSE. Results tab are based on the following tables to compute the RSE:</p> <ul style="list-style-type: none"> - Program Exposure - Identifies miles of Overhead miles replaced worked per year across the branches of the Wildfire Risk. - Program Cost - Identifies the programmatic costs per year - EIC Programs - Identifies the programmatic effectiveness by driver and subdriver for each mitigation. 	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	1	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
45	CaPA	Set WMP-09	CaPA_Set WMP-09	14	CaPA_Set WMP-09_014	<p>a) What is PG&E's current forecast cost per circuit-mile for covered conductor projects completed in the second half of 2023?</p> <p>b) Please provide workpapers to support your answer to part (a).</p>	<p>a) PG&E does not forecast costs per circuit-mile for covered conductor projects in its WMP. However, PG&E did provide a unit cost of \$1.078 million per mile for overhead hardening in 2023 in its 2023 GRC (A-21-06-021, Exhibit PG&E-4, Workpaper 4.2B, line 16).</p> <p>b) Please see attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q014ACh01.pdf" for the requested information.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	1	N/A	8.1.2.5	Grid Design and System Hardening	Traditional Overhead Hardening - Transmission Conductor and Distribution
46	CaPA	Set WMP-09	CaPA_Set WMP-09	15	CaPA_Set WMP-09_015	<p>a) What is PG&E's forecast RSE for covered conductor system hardening completed in the second half of 2023?</p> <p>b) Please provide workpapers to support your answer to part (a).</p> <p>Question 16</p>	<p>a) PG&E does not forecast an RSE for covered conductor system hardening for the second half of 2023 in its WMP. However, in the 2023 GRC, PG&E provided an RSE of 5.4 in 2023 for overhead system hardening (A-21-06-021, Exhibit PG&E-4, Chapter 3, p. 3-4, Table 3-1).</p> <p>b) Please see attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q015ACh01.xlsx" for the requested information.</p>	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	0	N/A	8.1.2.5	Grid Design and System Hardening	Traditional Overhead Hardening - Transmission Conductor and Distribution
47	CaPA	Set WMP-09	CaPA_Set WMP-09	16	CaPA_Set WMP-09_016	<p>In response to data request CalAdvocates-PGE-2023WMP-03, question 7c, PG&E states, "The primary approach for selecting miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v2, and (2) the Wildfire Feasibility Efficiency (WFE)-ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility."</p> <p>Provide an Excel table of the WFE-ranked circuit segments based on the 2022 WDRM v3, as described above. For each circuit segment, provide the following attributes as columns:</p> <ol style="list-style-type: none"> Circuit name Circuit ID number Circuit segment name WDRM v3 risk score Feasibility factor WFE score as defined on p. 969 of PG&E's WMP WFE ranking 	<p>Please see attachment "WMP-Discovery2023_DR_CalAdvocates_009-Q016ACh01_CONF.xlsx" for the requested information from data request CalAdvocates PGE-2023WMP-03, question 7c (projects identified for possible undergrounding in the 2023-2025 timeframe).</p> <p>Please see column M that shows the applicable risk model used for scoping the project (WDRM v2, WDRM v3).</p> <ol style="list-style-type: none"> Please see column N of the attachment. Please see column O of the attachment. Please see columns P and S of the attachment. Please see column AD of the attachment. Please see column W of the attachment. Please see column AE of the attachment. Please see column AF of the attachment. 	Holly Wetman	4/4/2023	4/7/2023	4/7/2023	1	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy
48	CaPA	Set WMP-10	CaPA_Set WMP-10	1	CaPA_Set WMP-10_01	<p>Table 8-3 on p. 332 of PG&E's WMP states that PG&E will make capable for Down Conductor Detection (DCD):</p> <ul style="list-style-type: none"> • 500 devices in 2023, • 400 devices in 2024, and • 250 devices in 2025. <p>a) Please explain the reasoning for the decreasing number of devices made capable for DCD from 2023-2025.</p> <p>b) Approximately how many circuit miles in the HFTD will be protected by DCD at the end of 2023?</p>	<p>a) DCD is capable of seeing from the device to "end of line", therefore we are able to provide DCD protection on most eligible High Fire Risk Area line miles by the end of 2023, then supplementing that coverage in 2024 and 2025, including in the EPSS Buffer area. The number of devices decrease in 2024 and 2025 because the line miles covered in 2024 and 2025, including EPSS Buffer area are less than the line coverage in eligible HFRA for 2023.</p> <p>b) We anticipate approximately 21,000 circuit miles in HFRA will be protected by DCD at the end of 2025.</p>	Holly Wetman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.1.2	Grid Design, Operations, and Maintenance	Targets
49	CaPA	Set WMP-10	CaPA_Set WMP-10	2	CaPA_Set WMP-10_02	<p>Table 8-6 on p. 336 of PG&E's WMP shows a forecast reduction in the number of EPSS events of one to two percent annually from 2022 to 2025.</p> <p>a) What factors does PG&E expect to contribute to the reduction in the number of EPSS events discussed above?</p> <p>b) Why is PG&E's forecast reduction in the number of EPSS events linear across the 2023-2025 period?</p> <p>c) Please provide any available workpapers that support PG&E's forecasts regarding the number of EPSS events annually in 2023-2025.</p>	<p>a) For 2023, factors contributing to the reduction in the number of EPSS related outages are based on actions to install additional Line Reclosers (LR) and Fuse Savers on the highest impacted protective zones to reduce the reliability impact. These will be installed in locations that are within the HFRA or protect equipment within the HFRA. The planned installs will provide reliability benefits on fuse tap lines within the scope of the EPSS program. PG&E will also undertake reliability mitigations intended to reduce outage frequency on those circuit protection zones (CPZs) that experienced the greatest number of outages while EPSS was enabled in 2022. This will include proactive vegetation management work incremental to existing vegetation management scope on CPZs that experienced vegetation caused outages in 2022. Reactive vegetation management work will also be conducted in-season, as needed based on escalated vegetation caused outages. Annual mitigation work will also be performed on CPZs that experienced again or other animal contacts in 2022.</p> <p>b) With only one year of EPSS protection performance to review, we made a conservative estimate of the reliability improvement that could be realized based on the planned securitization and mitigation activities.</p> <p>c) PG&E does not have any applicable workpapers available.</p>	Holly Wetman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.13	Grid Design, Operations, and Maintenance	Performance Metrics Identified by the Electrical Corporation
50	CaPA	Set WMP-10	CaPA_Set WMP-10	3	CaPA_Set WMP-10_03	<p>a) Does PG&E forecast a change in the average duration of EPSS events during the 2023-2025 period?</p> <p>b) If the answer to part (a) is yes, provide the expected average duration of EPSS events for 2023, 2024, and 2025.</p> <p>c) If the answer to part (a) is no, explain why not.</p> <p>d) Please provide any available workpapers that support PG&E's forecasts regarding the duration of EPSS events in 2023-2025.</p>	<p>a) Not at this time.</p> <p>b) N/A</p> <p>c) We require more operating experience before being able to accurately forecast reduction in average duration for EPSS outages. We have observed the target of four hours to 210 minutes in 2023.</p> <p>d) PG&E does not have any applicable workpapers available.</p>	Holly Wetman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.13	Grid Design, Operations, and Maintenance	Performance Metrics Identified by the Electrical Corporation

51	CaPA	Set WMP-10	CaPA_Set WMP-10	4	CaPA_Set WMP-10_04	<p>P. 358 of PG&E's WMP states, with regard to DTS-FAST:</p> <p>A prototype field installation was completed on a 110kV tower in Martinez and a wood pole in Santa Cruz in 2021. The valuable lessons learned have been updated to streamline designs, increase scalability, and reduce costs. In 2022, we filed a non-provisional patent application for DTS-FAST. For 2023, we have no field installation plans but will be working through the patent examination process.</p> <p>a) These provide data on the results of the field test installation in Martinez.</p> <p>b) Other than working through the patent examination process, what steps does PG&E plan to take in 2023 to further develop DTS-FAST?</p> <p>c) When does PG&E expect to begin additional DTS-FAST installations?</p> <p>d) Through the end of 2022, how much has PG&E spent on DTS-FAST?</p> <p>e) What portion of your response to part (d) is related to the patent application and examination process?</p> <p>f) What are your forecast costs for DTS-FAST through the 2023-2025 period?</p> <p>g) What portion of your response to part (f) is related to the patent application and examination process?</p>	<p>a) DTS-FAST is an integrated system of sensors and technologies that are established and available on the market, working together to mitigate wildfire risk. Testing focused on validating sensor functionality in wildfire and utility user scenarios, encompassing functional testing, environmental testing, and long-term resilience testing. Learnings were immediately applied to optimize sensor configuration.</p> <p>Key learnings from the Martinez installation and testing include:</p> <ul style="list-style-type: none"> Sensors - we installed over 25 devices and tested their intended functionality for accuracy and reliability. These are the types of tests performed: Reproducibility testing verifies the consistency and reliability of sensor measurements by repeating measurements multiple times and checking the results for consistency. This test criterion ensures that the sensing device provides consistent and reproducible measurements. Sensitivity testing evaluates the sensor's ability to detect and respond to small changes or variations in input. This is achieved by varying the input parameters and verifying if the sensor's output changes accordingly. Range testing evaluates the sensor's operating range by evaluating its performance across its specified range of operation. This involves testing the sensor at its minimum and maximum limits, as well as at different points within its operating range. Stability tests evaluate the sensor's stability over time by monitoring its output for a prolonged period under normal operating conditions. This can help identify any drift or instability in sensor readings. Environment played a major factor in the sensor's performance under different conditions that may affect its operation such as temperature, humidity, vibration, and electromagnetic interference. This can help ensure that the sensor is robust and reliable in real-world operating conditions. Failure testing evaluates the sensor's response to failure conditions, such as sensor malfunction, signal loss, or power failure, and verify if the sensor's behavior is appropriate and safe during such scenarios. The key takeaway is to test multiple brands of similar devices to verify vendor specifications on operating range and performance. During our testing, approximately 50% tested successfully. Keep in mind, none of these devices were intentionally developed to be installed on 115kV electric towers. We think most failed due to long exposure to high sustained EMF (Electro-Magnetic Field) disturbances, or environmental conditions (i.e., temperature, humidity, dust, rain, fog, wind, vibration). Based on the exhaustive testing conducted before 	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.2.6.2	Grid Design and System Hardening	Emerging Grid Hardening Technology Installations and Pilots
52	CaPA	Set WMP-10	CaPA_Set WMP-10	5	CaPA_Set WMP-10_05	<p>P. 357 of PG&E's WMP states, "if deployed, DTS-FAST could have a significant impact on wildfire risk where deployed."</p> <p>a) Please quantify the phrase "a significant impact on wildfire risk" in the above quote.</p> <p>b) Please provide any workpapers or studies to support your answer to part (a).</p>	<p>a) Please quantify the phrase "a significant impact on wildfire risk" in the above quote. We do not have enough data to provide a precise quantification of the impact at this time. The deployed sensor system is designed to actively monitor the environment for potential wildfire risks. For instance, the sensors are capable of detecting vegetation that has fallen onto power lines or are leaning against it. When such an event is detected, the sensor will trigger an alarm at the location, allowing for operational decisions to be made such as de-energizing the line before a potential fire hazard arises. The key differentiator of this system is that it is deployed outside of the substation, directly in high fire threat areas, and could detect risks before any electrical fault has occurred.</p> <p>b) Please provide any workpapers or studies to support your answer to part (a). We do not have any workpapers or studies to provide. The sensor's detection speed is almost instantaneous or within one second and the actual delivery of the alarm message to operations is dependent on the fastest telecommunications service at the sensor site. In our lab, we detected falling vegetation against energized conductors within one second. Our field testing with good telecommunications service took approximately 4-8 seconds.</p> <p>Please see "WMP-Discovery2023_DR_CalAdvocates_010-000064ch01.xlsx."</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.2.6.1	Grid Design and System Hardening	Emerging Grid Hardening Technology Installations and Pilots
53	CaPA	Set WMP-10	CaPA_Set WMP-10	6	CaPA_Set WMP-10_06	<p>P. 464 of PG&E's WMP states, "In 2022, we reduced the Customer Average Interruption Duration Index (CAIDI) and Customers Experiencing a Sustained Outage (CESO) for customers served by EPSS-capable lines when compared to data from the 2021 program pilot."</p> <p>a) Please provide the CAIDI value for all HFTD customers for each year from 2018-2022.</p> <p>b) Please provide the CESO value for all HFTD customers for each year from 2018-2022.</p>	<p>The 42-minute figure is an average of the response time to all outages on EPSS-protected circuits in 2022 since EPSS Outage Response time tracking began. The timeframe covered is May 23, 2022 - December 31, 2022.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	1	N/A	8.1.8.1.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
54	CaPA	Set WMP-10	CaPA_Set WMP-10	7	CaPA_Set WMP-10_07	<p>P. 464 of PG&E's WMP states, "By the end of 2022, we responded to 89 percent of outages on EPSS-enabled lines within 60 minutes, responding on average within 42 minutes." The statement above refers to results achieved "by the end of 2022." What time period is this data drawn from? In other words, the 42-minute figure is an average of response times in what period of time?</p>	<p>2022 EPSS OUTAGE RESPONSE AVERAGE RESPONSE TIME: 42 MINUTES 25TH PERCENTILE RESPONSE TIME: 27 MINUTES MEDIAN (50TH PERCENTILE) RESPONSE TIME: 29 MINUTES 75TH PERCENTILE RESPONSE TIME: 32 MINUTES LONGEST RESPONSE TIME: 408 MINUTES</p> <p>Note: Table values reflect available data since EPSS Outage Response time tracking began. The timeframe for tracking in 2022 was May 23, 2022 - December 31, 2022.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
55	CaPA	Set WMP-10	CaPA_Set WMP-10	8	CaPA_Set WMP-10_08	<p>P. 464 of PG&E's WMP states, "By the end of 2022, we responded to 89 percent of outages on EPSS-enabled lines within 60 minutes, responding on average within 42 minutes." For all outages on EPSS-enabled lines in all of 2022, provide the following:</p> <p>a) Average response time</p> <p>b) 25th percentile response time</p> <p>c) Median (50th percentile) response time</p> <p>d) 75th percentile response time</p> <p>e) Longest response time</p>	<p>2022 EPSS OUTAGE RESPONSE AVERAGE RESPONSE TIME: 42 MINUTES 25TH PERCENTILE RESPONSE TIME: 27 MINUTES MEDIAN (50TH PERCENTILE) RESPONSE TIME: 29 MINUTES 75TH PERCENTILE RESPONSE TIME: 32 MINUTES LONGEST RESPONSE TIME: 408 MINUTES</p> <p>Note: Table values reflect available data since EPSS Outage Response time tracking began. The timeframe for tracking in 2022 was May 23, 2022 - December 31, 2022.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
56	CaPA	Set WMP-10	CaPA_Set WMP-10	9	CaPA_Set WMP-10_09	<p>P. 464 of PG&E's WMP states, "By the end of 2022, we responded to 89 percent of outages on EPSS-enabled lines within 60 minutes, responding on average within 42 minutes." For the 11 percent of outages (noted in this quote) on EPSS-enabled lines that PG&E did not respond to within 60 minutes, provide the following:</p> <p>a) Average response time</p> <p>b) Longest response time.</p>	<p>2022 EPSS OUTAGE RESPONSE AVERAGE RESPONSE TIME: 95 MINUTES LONGEST RESPONSE TIME: 408 MINUTES</p> <p>Note: Table values reflect available data since EPSS Outage Response time tracking began. The timeframe for tracking in 2022 was May 23, 2022 - December 31, 2022.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
57	CaPA	Set WMP-10	CaPA_Set WMP-10	10	CaPA_Set WMP-10_010	<p>P. 441 of PG&E's WMP states, "We plan to implement a QA (quality assurance) program for systems inspections."</p> <p>a) Please discuss the progress PG&E has made so far in implementing a QA program for systems inspections.</p> <p>b) When does PG&E expect to implement a QA program for systems inspections?</p> <p>c) Please describe the main features of the QA program that PG&E plans to implement.</p> <p>d) What are the probable limitations of the QA program that PG&E plans to implement?</p>	<p>a) The function that has been historically referred to as "quality verification" is in fact a component of the QA program for systems inspections and will be referred to as "QA" rather than "QV" moving forward. We have made significant progress on this work and the program has been implemented.</p> <p>b) The program has already been implemented.</p> <p>c) Main features are described in Section 8.1.8.1.f of our 2023 WMP: "A Quality Verification (QV) function will be performed in 2023 that provides analysis and program value. The function historically referred to as QV is included within the QA program referred to above."</p> <p>d) We are not presently aware of any probable limitations of the QA program. However, as the program continues, efforts will be taken to proactively identify limitations as they arise.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.6.1	Quality Assurance and Quality Control	Quality Assurance
58	CaPA	Set WMP-10	CaPA_Set WMP-10	11	CaPA_Set WMP-10_011	<p>P. 441 of PG&E's WMP states, "We plan to update existing QV (quality verification) procedures for systems inspections."</p> <p>a) Please discuss the progress PG&E has made so far in updating existing QV procedures for systems inspections.</p> <p>b) When does PG&E expect to complete its updates to existing QV procedures for systems inspections?</p> <p>c) Please describe how the planned updates will improve PG&E's existing QV procedures.</p>	<p>a) The quality team is currently undergoing a thorough review of the prior QV procedures as an initial step in the development of updated procedures.</p> <p>b) Expected completion of this work is the end of the third quarter of 2023.</p> <p>c) The planned updates improve upon PG&E's existing QV procedures by accurately reflecting the QV role in the holistic systems inspection throughout.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.6.1	Quality Assurance and Quality Control	Quality Assurance

59	CaPA	Set WMP-10	CaPA_Set WMP-10	12	CaPA_Set WMP-10_012	<p>P. 450 of PG&E's WMP states, "Along with reducing wildfire risk related to backdropping ignition risk tags in HFTD/HFRA, new (EC) notifications identified after January 1st, 2023 HFTD/HFRA ignition risk tags will be completed in compliance with GO 95 rule 18 limitations, barring external factors."</p> <p>a) What external factors does PG&E anticipate may prevent it from completing HFTD/HFRA ignition risk tags in compliance with GO 95 Rule 18 limitations?</p> <p>b) For each external factor identified in part (a), what is PG&E's plan to mitigate the effect the external factor may have?</p> <p>c) During the period from 2023-2025, will PG&E complete new ignition risk tags in compliance with GO 95 rule 18 limitations for those ignition risk tags located outside the HFTD/HFRA? Please explain your answer.</p>	<p>a) Please refer to page 831 of our 2023 WMP which defines external factors as follows: "External Factors represent reasonable circumstances which may impact execution against targets, objectives, other work, or performance metrics including, but not limited to, physical conditions, landholder refusals, environmental delays, customer refusals or non-contacts, permitting delays/restrictions, weather conditions, removed or destroyed assets, active wildfires, exceptions or exemptions to regulatory/statutory requirements, and other safety considerations." Specifically, each of the items identified in the definition could apply to our asset tag work and cause our work to be delayed. As an example, the severe and repeated storms in the first quarter of 2023 have caused delays in performing our asset tag work and fall under the category of external factors.</p> <p>b) Physical conditions: To mitigate the impacts of physical conditions, we work with our leadership and strategy teams to create solutions specifically tailored to the individual situation. However, despite these efforts, there are times where we must simply await the removal of the external physical condition in order to proceed with work as there is no other reasonable alternative.</p> <p>WMP-Discovery2023_DR_CalAdvocates_010-Q012 Page 2</p> <p>Landholder refusals: To mitigate the impacts of landholder refusals, we work our local government affairs team to help resolve the refusals in the most efficient way possible so that we can proceed with work.</p> <p>Environmental delays: To mitigate the impacts of environmental delays, we work with our leadership and strategy teams to create solutions specifically tailored to the individual situation. However, despite these efforts, there are times where we must simply await the removal of the external environmental conditions in order to proceed with work as there is no other reasonable alternative.</p> <p>Customer refusals or non-contacts: To mitigate the impacts of customer refusals or non-contacts, we work with our local government affairs team to resolve the refusals and to proceed with the work.</p> <p>Permitting delays/restrictions: To mitigate the impacts of permitting delays and restrictions, we work with our leadership and government affairs teams to have the delays or restrictions resolved as expeditiously as possible and to proceed with work.</p> <p>Weather conditions: To mitigate the impacts of weather conditions, we work with our leadership, strategy, and meteorology teams to create solutions specifically tailored to the individual situation. However, despite these efforts, there are times where we must simply await the removal of the external physical condition in order to proceed with work as there is no other reasonable alternative.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.7.2	Open Work Orders	Open Work Orders - Distribution Tags
60	CaPA	Set WMP-10	CaPA_Set WMP-10	13	CaPA_Set WMP-10_013	<p>Table PG&E-8.1.7.1 on p. 451 of PG&E's WMP states, Field Safety Reassessment (FSR) performed annually on line dependent tag (LDT) for Priority A and B.</p> <p>a) Under PG&E's current procedures and policies, can a FSR de-escalate the priority of a notification? Please explain your answer.</p> <p>b) Under PG&E's current procedures and policies, can a FSR be used to extend the due date of a notification beyond GO 95 rule 18 limitations? Please explain your answer.</p>	<p>a) The FSR program is focused on identifying conditions that have escalated to Priority A and B. Inspectors can also recommend that a notification be canceled if they believe was noted in error, is no longer required according to PG&E's guidelines, or if they find all work identified on the EC is already completed in the field. In certain instances, the FSR can lead to a downgrade in tag priorities. For example, if the tag gatekeeper disagrees with an inspector-recommended escalations or cancellations, the gatekeeper can downgrade the tag rather than cancel or extend it. PG&E uses a process to assess the practices and procedures on FSRs and evaluate what alternatives are provided to inspectors and tag gatekeepers.</p> <p>b) FSRs do not extend a notification's required end date beyond GO 95 rule 18 limitations. PG&E's current execution of EC notifications does not meet GO 95 Rule 18 compliance 100% of the time. FSRs are an internal containment activity PG&E performs to mitigate potential safety impacts.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.7.2	Open Work Orders	Open Work Orders - Distribution Tags
61	CaPA	Set WMP-10	CaPA_Set WMP-10	14	CaPA_Set WMP-10_014	<p>Table PG&E-8.1.7.3 on p. 456 of PG&E's WMP has empty cells in the HFRA row.</p> <p>a) Please explain why the HFRA row is empty in the above table.</p> <p>b) Please provide an updated version of PG&E-8.1.7.3 with the HFRA row filled in.</p>	<p>The HFRA line in Table PG&E-8.1.7.3 was blank because PG&E was unable to segregate the HFRA tags.</p> <p>Table 1 below shows the number of open distribution work orders categorized by HFTD tier from D1 2020 through Q4 2022 and is tied to the QDR data provided to Energy Safety on March 1, 2023.</p> <p>The numbers in the March 1, 2023 QDR are different from the numbers provided in Table 8.1.7.3 in PG&E's March 27, 2023 WMP submission. The numbers in the March 1, 2023 QDR are correct.</p> <p>Table 1 = Open Distribution Work Orders by HFTD Tier</p> <p>HFTD Area</p> <p>2020</p> <p>2021</p> <p>2022</p> <p>Buffer Zone</p> <p>5</p> <p>0</p> <p>Non-HFTD</p> <p>97,116</p> <p>78,547</p> <p>5,268</p> <p>Tier 2</p> <p>10,538</p> <p>25,025</p> <p>1,621</p> <p>Tier 3</p> <p>13,018</p> <p>12,976</p> <p>30,169</p> <p>Zone 1</p> <p>14</p> <p>83</p> <p>2</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.7.2	Open Work Orders	Open Work Orders - Distribution Tags
62	CaPA	Set WMP-10	CaPA_Set WMP-10	15	CaPA_Set WMP-10_015	<p>In response to data request CalAdvocates-PGE-2023WMP-05, question 3, PG&E states, "There is an inherent QC process that is part of the drone inspection, but there is no outside group that is looking at QC."</p> <p>a) Please describe the inherent QC process for drone inspections. What are the main features of this inherent QC process?</p> <p>b) What types of problems or flaws in drone inspections can the inherent QC process identify?</p> <p>c) Please identify the five most common problems or flaws in drone inspections that the inherent QC process identified in 2022.</p> <p>d) What are the limitations of this inherent QC process?</p>	<p>a) There is a 100% review of all inspections that are part of the inspection process. The inspector completes the inspection and a spot check is performed for commonly missed items.</p> <p>b) Spot checks are performed for the commonly missed items that potentially cause a fire or ignition.</p> <p>c) The five most common problems identified in the QC process are: C-hooks, insulators, cotter pins, shrouds, and structural issues.</p> <p>d) We have not identified any limitations of the QC process at this time.</p>	Holly Wehman	4/4/2023	4/10/2023	4/10/2023	0	N/A	8.1.3	Asset Inspections	N/A
63	TURN	001	TURN_001	1	TURN_001_01	<p>1. Regarding ACI PG&E-23-34, which found that "PG&E's current process of prioritizing wildfire mitigations assigns a high priority to undergrounding and does not demonstrate adequate weight to risk model outputs or RSE estimates" and which detailed the showing that PG&E must make in this WMP to show the required progress.</p> <p>a. Does PG&E's 2023-2025 WMP or supporting documentation provide a comparison of the RSEs (either at a tranche level or more aggregated level) for undergrounding compared to the RSEs of alternative mitigation techniques, such as covered conductor?</p> <p>i. If so, please provide the relevant citations, identifying the specific content that provides this information by page number and specific paragraphs, tables or figures (i.e., not just a multiple page citation).</p> <p>ii. Whether or not this information is provided in PG&E's 2023-2025 WMP, please state whether, and if so, how PG&E incorporates RSE estimates and risk model outputs that compare undergrounding with alternative mitigation techniques, such as covered conductor, at a project level early in the decision-making process. Please provide all documents showing that this comparison of RSE estimates and risk model outputs is included in PG&E's decision-making process.</p> <p>c. Please explain whether and, if so, how PG&E's quantitative analysis takes into account the PSPS risk for a particular location when deciding whether to undertake an undergrounding project or an alternative mitigation technique in that location. For example, all other things being equal, does undergrounding fare worse in the quantitative analysis for a location deemed to have no or low PSPS risk compared to a location deemed to have high PSPS risk, and, if so, how is this difference in PSPS risk reflected in the quantitative analysis? Please provide all documents showing how PSPS risk is included in PG&E's decision-making process.</p> <p>Please provide the attachment to the response to CalAdvocates-PG&E-2023WMP-06-007 which PG&E has labeled as confidential.</p>	<p>a) No. PG&E's 2023-2025 WMP does not provide a comparison of the RSEs for undergrounding compared to the RSEs of alternative mitigations. However, this information, RSEs at the tranche and aggregated level for wildfire mitigations including undergrounding, is provided in PG&E's 2023 General Rate Case - in response to Energy Division data request ED_001.</p> <p>b) Yes, the 2023 WMP explains how PG&E performs this analysis. PG&E evaluated the outputs from its Wildfire Distribution Risk Models (WDRM) to determine the highest risk miles in its service territory. The primary approach for selecting system hardening miles used two risk prioritization methodologies: (1) the top 20 percent of circuit segments based on the 2021 WDRM v2; and (2) the Wildfire Feasibility Efficiency (WFE) ranked circuit segments based on the 2022 WDRM v2.</p> <p>PG&E uses the Simplified Wildfire RSE (SWRSE) or WFE in evaluating undergrounding projects. The SWRSE includes the components of the RSE including wildfire risk and cost. In executing the system hardening program, PG&E first uses a scoring criterion that identifies the highest risk areas, and then selects the appropriate risk mitigation approach for that circuit which may include undergrounding, remote grid installation, line removal, or overhead hardening (depending on the local circumstances). Since late 2021, PG&E has prioritized undergrounding as the preferred approach to reduce the most system risk. Once a circuit is selected for undergrounding, PG&E evaluates each proposed circuit segment quantitatively and qualitatively to mitigate the maximum amount of risk and evaluate feasibility and executability.</p> <p>i. Please see Section 8.1.2.1, page 339, Overview of the Activity and Section 8.1.2.2, p. 342-343, Overview of the Activity for the requested information.</p> <p>ii. PG&E does not have documentation comparing different mitigation alternatives at the project level. PG&E uses the Simplified Wildfire RSE (SWRSE) or Wildfire Feasibility Efficiency (WFE) in evaluating undergrounding projects. The SWRSE includes the components of the RSE including wildfire risk and cost. PG&E uses the SWRSE to identify where it can most efficiently reduce risk given the terrain feasibility at a particular location.</p> <p>c) We currently do not use the PSPS risk in our quantitative decision-making when deciding whether to undertake an undergrounding project or an alternative mitigation. However, when evaluating potential undergrounding locations, PG&E considers project location and would reduce PSPS customer impacts and may adjust project scope to further address PSPS impacts.</p> <p>Please see attachment "WMP-Discovery2023_DR_TURN_002-0004h3hCONFIN.xlsx" for the requested information.</p>	Tom Long	4/4/2023	4/7/2023	4/7/2023	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-23-34 - Revise Process of Prioritizing Wildfire Mitigations
64	TURN	002	TURN_002	1	TURN_002_01	<p>Please provide the attachment to the response to CalAdvocates-PG&E-2023WMP-06-008, which PG&E has labeled as confidential.</p>	<p>Please see attachment "WMP-Discovery2023_DR_TURN_002-0004h3hCONFIN.xlsx" for the requested information.</p>	Tom Long	4/4/2023	4/7/2023	4/7/2023	1	Yes	8.2.3	Vegetation Management and Inspections	Vegetation and Fuels Management
65	TURN	002	TURN_002	2	TURN_002_02	<p>Please provide the attachment to the response to CalAdvocates-PG&E-2023WMP-06-009, which PG&E has labeled as confidential.</p>	<p>The attachment to CalAdvocates-PG&E-2023WMP-06-009 was identical to the attachment provided for CalAdvocates-PG&E-2023WMP-06-008, so please refer to the attachment sent with Answer 002 of this data request response.</p>	Tom Long	4/4/2023	4/7/2023	4/7/2023	1	Yes	8.2.3	Vegetation Management and Inspections	Vegetation and Fuels Management
66	TURN	002	TURN_002	3	TURN_002_03	<p>Please provide the attachment to the response to CalAdvocates-PG&E-2023WMP-06-009, which PG&E has labeled as confidential.</p>	<p>The attachment to CalAdvocates-PG&E-2023WMP-06-009 was identical to the attachment provided for CalAdvocates-PG&E-2023WMP-06-008, so please refer to the attachment sent with Answer 002 of this data request response.</p>	Tom Long	4/4/2023	4/7/2023	4/7/2023	0	N/A	2022 WMP Section 7.3.5.2	Vegetation Management and Inspections	Enhanced Vegetation Management

67	TURN	002	TURN_002	4	TURN_002_04	Provide the 2023-2026 Undergrounding Workplan referenced on page 911 of PG&E's WMP and in footnote 208, which indicates that PG&E has labeled the Workplan confidential.	Please see "WMP-Discovery2023_DR_TURN_002-Q004A601.COM-rlta" for the requested information.	Tom Long	4/4/2023	4/7/2023	4/7/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/TURN_002.sp	1	Yes	Appendix D	Areas for Continued Improvement	ACI PG&E-22-16 - Progress and Updates on Undergrounding and Risk Prioritization
68	CPUC - SPD (Safety Policy Division)	002	CPUC - SPD (Safety Policy Division)_002	1	CPUC - SPD (Safety Policy Division)_002_01	Provide Attachment 2023-03-27_PGE_2023_WMP_RO_Appendix D ACI PG&E-22-16_A601_CONF PG&E's 2023-2026 Undergrounding Workplan.	The CONFIDENTIAL attachment is being provided pursuant to the confidentiality declaration D0U1407-003. Confidentiality Declaration. As requested, please see attachment "2023-03-27_PGE_2023_WMP_RO_Appendix D ACI PG&E-22-16_A601_CONF" attached.	Kevin Miller	4/4/2023	4/5/2023	4/4/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/TURN_002.sp	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-16 - Progress and Updates on Undergrounding and Risk Prioritization
69	OES	001	OES_001	1	OES_001_01	Regarding PG&E's Tree Assessment Tool (TAT) Considering PG&E has discontinued its Enhanced Vegetation Management (EVM) program: a. How is PG&E using and planning to use its TAT? b. What inspection programs, if any, listed in Section 8.2.2 will use the TAT? c. If PG&E is not using its TAT, why has it discontinued its use?	a) The TAT was developed for the EVM program. The TAT will no longer be utilized as the EVM program concluded at the end of 2022. There are no current plans to utilize TAT to support other VM programs. b) No inspection programs listed in Section 8.2.2 of the 2023-2025 WMP plan will use the TAT at this time. Please see the response to part (a) of this question. c) The approach to tree inspection programs is to use the American National Standards Institute (ANSI) A-300 tree risk assessment standard per field conditions and individual tree mitigation needs.	Colin Lang	4/9/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	0	N/A	8.2.2	Vegetation Management and Inspections	Vegetation Management Inspections
70	OES	001	OES_001	2	OES_001_02	Regarding PG&E's Targeted Tree Species (TTS) Study and its Tree Assessment Tool (TAT) On page 184 of its 2022 WMP Update, PG&E states "The results of our Targeted Tree Species study in conjunction with improving the Tree Assessment Tool (TAT) will allow PG&E to more accurately identify and mitigate trees at elevated risk of failure, providing better visibility into risk." On page 579 of its 2023-2025 WMP, PG&E states "We have evaluated the recommendations in the final [Targeted Tree Species] report and continue to analyze them and consider our go-forward actions." a. Since the Target Tree Species study was completed on March 31, 2022, what actions has PG&E taken and will take to implement the nine recommendations? Respond specifically to each of the nine recommendations. b. What improvements have been and will be made to the TAT in response to these recommendations and generally (i.e., not in response to these recommendations)? c. If PG&E is not using or planning to use its TAT, did PG&E make change/improvements to the TAT before it decided to end its use? If so, what were those change/improvements?	a) Nine recommendations were provided to PG&E in the final report of the Targeted Tree Species Study that was completed in March 2022. PG&E has considered these recommendations and has taken action where we deemed appropriate. Below are the actions taken specific to each of the nine recommendations. Recommendation 1: Implement a rule set, harmonized with O&I procedures, for TAT to record at species level, with only specified genus allowed as aggregate. Adopt definitions presented in OES Geographic Information Systems Data Standard, DIRAF Version 2.2 in Section 3.4.3 Ignition (Feature Class), Page 71. Action Taken: An updated tree species list has been created that aggregates species at the genus level where appropriate. The updated tree species list is currently in process of being updated within One VM. Recommendation 2: Outage and/or ignition investigations should record accurate (dual-phase GPS) positions and be assigned to an EVM circuit segment that correlates to geo-rectified and spatially correlated PG&E EDCS digital terrain vector data. Similar to PG&E Transmission VM, where possible, associate the O&I tree with a LIDAR tree segmentation ID to further improve tree locational accuracy, and future tracking. Action Taken: Current electronic devices are able to capture accurate GPS positions due to technological improvements. Recommendation 3: TAT TAT abatement species compositions and compare to outage and ignition species distributions. Note potential over- or under-abate-ments. Action Taken: This can serve as a programmatic KPI. Recommendation 4: Harmonize Outage and Ignition (O&I) data with TAT data parameters. Action Taken: Analysis for abatement species compositions compared to outage and ignition species distributions has been completed. Recommendation 5: Increase green tree abatement rates for trees with no obvious defects. Consider scored abatements that add LIDAR metrics for overstrike distance, fall pathways to assets, tree position slope to alignment, and canopy exposure to wind. Action Taken: We have developed an updated outage and ignition investigation form that incorporates data parameters that will allow for increased data analytics. The updated form is in process of being digitized which will improve data consistency. Recommendation 6: Increase green tree abatement rates for trees with no obvious defects. Consider scored abatements that add LIDAR metrics for overstrike distance, fall pathways to assets, tree position slope to alignment, and canopy exposure to wind.	Colin Lang	4/9/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	0	N/A	8.2.3.6	Vegetation Management and Inspections	High-Risk Species
71	OES	001	OES_001	3	OES_001_03	Regarding PG&E's Focused Tree Inspections pilot a. Describe the current state of development for the pilot area, PG&E's Areas of Concern (AOC), and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots" (page 529) and the expected timeline for operationalization. b. Detail the criteria PG&E has and is using to develop the pilot area, PG&E's Areas of Concern (AOC), and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots" (page 529). c. What standards, processes, procedures, and tools are vegetation management personnel using/will use to perform tree risk assessments for this pilot? d. Will PG&E be using its One VM Tool for recordkeeping for this pilot? If not, what system will PG&E use for recording keeping for this pilot? e. Where is PG&E conducting its Focused Tree Inspections pilot? If PG&E has not yet begun its pilot, where will PG&E be conducting its Focused Tree Inspections pilot? f. How many circuit miles are in scope for the pilot? g. Was the pilot area previously in-scope for Enhanced Vegetation Management (EVM)? h. For each Circuit Protection Zone (CPZ) in the pilot area provide the: i. CPZ name. ii. Tree Weighted Risk Score from PG&E's most recent version of its EVM Tree-Weighted Prioritization List. iii. Tree Weighted Rank from PG&E's most recent version of its EVM Tree-Weighted Prioritization List. iv. Risk Tranche i. Does PG&E have a plan to continue its Focused Tree Inspections assuming the pilot is a success? If so, detail those plans, including how many circuit miles PG&E plans to inspect under this program in 2023 and 2024. j. Provide a GIS layer of the pilot area, PG&E's Areas of Concern (AOC), and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots" (page 529). As applicable, provide the following attributes for each polygon: i. Number of overhead circuit miles within the polygon ii. Overall Utility Risk iii. Ignition Risk iv. PSPS Risk	a) Four regional AOCs totaling 300 miles have been identified for the FTI Pilot, one in each of the following counties: Butte, Calaveras, El Dorado, and Napa. Pilot operationalization will begin in Q2 2023. b) AOCs were identified through a cross-functional effort utilizing county-based regional reviews to create polygons. Initial polygon development utilized Public Safety Specialist-circuit-based evaluations, 30-year lookback of meteorology data, PSPS Lookback Polygons, PSPS Vegetation Damage locations, vegetation caused ignition data, and vegetation caused outage data. The completed AOC polygons were further analyzed against WDRM3 model. This analysis supported the prioritization of AOC polygons which were selected as regional pilots. To bring value to overall future guidance and execution, the pilots need to capture regional variations and piloting only in highest risk AOC polygons would not support the significant learning/expected of the pilot. c) The approach to tree inspections pilots intends to follow the American National Standards Institute (ANSI) A-300 tree risk assessment standard per field conditions and individual tree mitigation needs. In addition, inspections will utilize ISA TRAQ Certified Arborists and supporting checklist for tree assessments. d) The pilot plans to use OneVM for execution. Business requirements to import the CPZ and/or targeted circuit segments in AOC polygons are under development as of 3-31-2023. We expect to standardize the data collection system for the pilot in April 2023. e) The FTI program will be piloted in four regional AOCs (Butte, Calaveras, El Dorado, and Napa Counties) beginning in Q2 2023. f) The FTI Pilot will consist of 300 miles within AOCs. g) Yes all circuit segments in HFTD were subject to annual EVM plans as prioritized by WDRM models. FTI program pilots are targeted in HFTD areas. Portions of FTI circuit segments have been subject to EVM mitigation in prior years and trees will be inspected consistent with the portions that were not previously mitigated with EVM. h) See attachment "WMP-Discovery2023_DR_OES_001-Q003_Arch001" for CPZ names and associated tranches. i. See response to j) for WDRM3 scores per AOCs. Development and prioritization of Areas of Concern polygons that define the pilot areas for the FTI program used WDRM v3. WDRM v3 improved upon v2 by taking individual event driver inputs into consideration separately and allowing them to be composed for the appropriate mitigation program. This was combined with effectiveness measurements to provide more h) 2023 development of Areas of Concern (AOC) used WDRM v3 to prioritize CPZs to inform the pilot areas selected. In the four AOC selected for pilots there are 31 CPZs total. 22 of these CPZs match where WDRM v3 was used in 2022 and EVM Tree Weighted Risk Scores and Rankings are available to accurately cross-reference. 9 CPZs do not have EVM Tree Weighted Risk Scores or Rankings. These omissions are due to circuit configuration and/or operating number changes that do not allow for matching with the WDRM v2 CPZ list. Where available EVM Tree Weighted Risk Score and EVM Tree Weighted Rank are provided in the table below.	Colin Lang	4/9/2023	4/19/2023	4/19/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	0	N/A	8.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections

71	OEIS	001	OEIS_001	3 SUPP_2	OEIS_001_Q3 SUPP_2	<p>Regarding PG&E's Focused Tree Inspections pilot</p> <p>a. Describe the current state of development for the pilot area, PG&E's Areas of Concern (AOC), and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots(s)" (page 529) and the expected timeline for operationalization.</p> <p>b. Detail the criteria PG&E has and is using to develop the pilot area, PG&E's Areas of Concern (AOC), and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots(s)" (page 529).</p> <p>c. What standards, processes, procedures, and tools are vegetation management personnel going to use to perform tree risk assessments for this pilot?</p> <p>d. Will PG&E be using its One VM Tool for recordkeeping for this pilot? If not, what system will PG&E use for recordkeeping for this pilot?</p> <p>e. Where is PG&E conducting its Focused Tree Inspections pilot? If PG&E has not yet begun its pilot, where will PG&E be conducting its Focused Tree Inspections pilot?</p> <p>f. How many crucial miles are in scope for the pilot?</p> <p>g. Was the pilot area previously in-scope for Enhanced Vegetation Management (EVM)?</p> <p>h. For each Circuit Protection Zone (CPZ) in the pilot area provide the:</p> <ol style="list-style-type: none"> CPZ name. Tree Weighted Risk Score from PG&E's most recent version of its EVM Tree-Weighted Prioritization List. Tree Weighted Rank from PG&E's most recent version of its EVM Tree-Weighted Prioritization List. Risk Tranche. <p>i. Does PG&E have a plan to continue its Focused Tree Inspections assuming the pilot is a success? If so, detail those plans, including how many crucial miles PG&E plans to inspect under this program in 2023 and 2024.</p> <p>j. Provide a GIS layer of the pilot area, PG&E's Areas of Concern (AOC), 1 and "polygons where focused vegetation inspection can be evaluated to determine appropriate counties to prioritize pilots(s)" (page 529). As applicable, provide the following attributes for each polygon:</p> <ol style="list-style-type: none"> Number of overhead crucial miles within the polygon Overall Utility Risk Ignition Risk PSPS Risk 	Colin Lang	4/9/2023	4/27/2023			8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections		
72	OEIS	001	OEIS_001	4	OEIS_001_Q4	<p>Regarding PG&E's Tree Removal Inventory on page 528, PG&E states that it will "remove, or re-inspect trees identified in the EVM program"</p> <p>a. How does PG&E decide whether a tree should be 1) simply abated based on the existing risk assessment or 2) re-inspected/assessed prior to abatement?</p> <p>b. What standards, processes, procedures, and tools are vegetation management personnel using/will use to perform tree risk assessments for this program?</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023		0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
73	OEIS	001	OEIS_001	5	OEIS_001_Q5	<p>Regarding Wood Management On page 536, PG&E says that its wood management program addressed large wood generated by PG&E's VM activities including post-fire work activities and wood generated by the EVM Program.</p> <p>a. Considering the EVM program has been discontinued, does the wood management program:</p> <ol style="list-style-type: none"> Address large wood generated from the EVM program that has not already addressed? Address large wood generated from PG&E's Tree Removal Inventory program, a remnant of the EVM program? How is large wood addressed when generated by other VM programs, including Distribution Routes/Second Patrol, VM for Operational Mitigations, and Focused Tree Inspections? <p>b. When debris and/or large wood generated from PG&E's VM activities are left on site, what standards, protocols, processes, and procedures does PG&E use to ensure the debris and large wood are placed in a manner that does not:</p> <ol style="list-style-type: none"> Block or hinder ingress or egress. Infringe on FRC 4291 detritus space clearance. Infringe watercourses and drainage. Conflict with property owner's interests. Otherwise create a hazard? 	Colin Lang	4/9/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	1	N/A	8.2.3.2	Vegetation Management and Inspections	Wood and Slash Management
74	OEIS	001	OEIS_001	6	OEIS_001_Q6	<p>Regarding Enhanced Clearances on page 537, PG&E says it "complies with Appendix E of GO 95. They go on to describe the recommended minimum clearances set forth in Appendix E of GO 95.</p> <p>a. In the HE TD, does PG&E obtain the recommended clearances "where practicable"?</p> <p>b. If it does not describe how PG&E implements/enforces "enhanced" clearances, clarify how PG&E operationalizes the recommended clearances set forth in Appendix E of GO 95.</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	0	N/A	8.2.3.3	Vegetation Management and Inspections	Clearance
75	OEIS	001	OEIS_001	7	OEIS_001_Q7	<p>Regarding Appendix B Items That Are Currently Optional Or "By Request" Only Provide the following, which are outlined in the 2023-2025 Wildfire Mitigation Plan Technical Guidelines, Appendix B. If the data is tabular (formulas, tables, graphs, charts) provide it in MS Excel. If the data is text-heavy, provide the information in MS Word.</p> <p>a. Detailed Model Documentation for each model and sub-model discussed in PG&E's response to Section 6.1.2 Summary of Risk Models (Technical documentation should be presented according to ASTM E 1472 - Standard Guide for Documenting Computer Software for Fire Models.)</p> <ol style="list-style-type: none"> Include a list of assumptions and known model limitations according to ASTM E 1895 - Standard Guide for Determining Uses and Limitations of Deterministic Fire Models. Present verification and validation documentation according to the SIRE's Guidelines for Substantiating a Fire Model for a Given Application or ASTM E 1355 - Standard Guide for Evaluating the Predicting Capability of Deterministic Fire Models. <p>At a minimum, the documentation must include:</p> <ol style="list-style-type: none"> Purpose of the model/problem identification. Model version. Theoretical foundation. Mathematical foundation. External dependencies. Model substantiation, and Sensitivity. <p>b. Model Substantiation-3</p> <ol style="list-style-type: none"> For each model, provide documentation of the following model substantiation studies: <ol style="list-style-type: none"> Validation data. Model verification. Model validation, and Model calibration Additional Models Supporting Risk Calculation-4 For each additional model that supports the risk calculations, provide weather analysis and fuel conditions. Calculation of Risk and Risk Components: Likelihoods More detailed information on: <ol style="list-style-type: none"> Ignition Likelihood 	Colin Lang	4/9/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	4	N/A	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definitions	Detailed Model Documentation
76	OEIS	001	OEIS_001	8	OEIS_001_Q8	<p>Regarding Comprehensive System Diagram for All Risk Models Used Provide comprehensive system diagrams in MS Visio or PPT for all risk models.</p> <ol style="list-style-type: none"> A comprehensive diagram for operational models and A comprehensive diagram for planning models. <p>Section 6.1.2, Summary of Risk Models, asks for a summary of risk models for a table form with specific fields. Section 6.2.1, Risk and Risk Component Identification, asks for a chart that demonstrates the components of overall utility risk.</p> <p>The request is comprehensive of all models that work together in the Decision-Making Framework (DMF). The requested diagram should show:</p> <ol style="list-style-type: none"> Interaction between models/presentations (e.g., inputs and outputs coming to and going from models to other models). Organization with the use of swimlanes where applicable. Starting and ending points. Decisions and process flows. Use of a legend and colors to classify inputs/outputs types and model-to-model interactions, and The full cycle of models working together and creating feedback for model adjustments and fine-tuning. 	Colin Lang	4/9/2023	4/24/2023	4/24/2023	https://www.pge.com/page_global/common/pdfs/safety/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/OEIS_001.sp	1	N/A	6.1.2	Risk Methodology and Assessment	Summary of Risk Models

77	OEIS	001	OEIS_001	9	OEIS_001_09	<p>Regarding Portfolio Level Risk Analysis and Risk Spend Efficiency</p> <p>a. Provide an example of how risks are aggregated to a portfolio, and if and how interdependencies between the risks are explicitly captured in the portfolio. Response should be provided in Excel. Also include the level of organization for the portfolio (e.g., asset, geographical or business unit)</p> <p>b. Are tail risks calculated on a portfolio of risks? If so, provide an example.</p> <p>c. Are probability distributions and interdependencies used as inputs to outputs for the bowties used in PG&E's WMP submission (see examples present in Appendix B)? If so, provide an example using the bowtie charts presented in PG&E's Appendix B submission. As appropriate, response should be provided in Excel.</p> <p>d. Provide an example of how risk spend efficiency (RSE) deals with interdependent risks, and mutually exclusive risks. As appropriate, response should be provided in Excel.</p> <p>e. Is RSE calculated for both average and tail? If so, provide an example. Response should be provided in Excel.</p>	<p>a) Based on the Wildfire Distribution Risk Model, which is based on circuit segments, circuit segments are aggregated to the enterprise wildfire risk model to evaluate mitigation program benefits at the portfolio level. The branches, in this case, are broken down by quintiles of likelihood of risk event (LORE) and consequence of risk event (CORE). Please see "WMP-Discovery2023_DR_OEIS_001-Q009A0c01.xlsx", which is PG&E's 2023-2025 wildfire bowtie used for the GRC where we aggregated our distribution risk model to the LORE and CORE branches to calculate risk at a portfolio level. This level of organization is based on the risk at the circuit protection zone level.</p> <p>b) Tail risks are captured as part of the enterprise risk assessment process and represented as probabilistic distributions of consequence.</p> <p>c) Yes, please see "WMP-Discovery2023_DR_OEIS_001-Q009A0c02.xlsx". The inputs listed in Tab-Corres are the probability distributions that feed into the bowtie analysis, and its outputs are shown in "WMP-Discovery2023_DR_OEIS_001-Q009A0c01.xlsx" referenced in response to part a).</p> <p>d) Risk Spend Efficiency for EPSS includes the risk reduction tied to the wildfire risk but is independent with the Distribution Overhead asset risk, which increases due to the reliability impacts EPSS causes. The RSE would capture both the risk reduction of wildfire and increased risk of asset failure and reliability.</p> <p>e) The RSE is calculated as a representation of average, but the consequence values are scaled in a non-linear fashion to capture the tail risk. In accordance with D.16-12-014, PG&E calculates an RSE using the expected value of the MVF, i.e., the expected value of the distribution of consequences after they have been converted to Scaled Units by the Scaling Function. PG&E does not separately calculate an RSE based on tail statistics (e.g. tail average). Instead, PG&E's non-linear Scaling Function effectively amplifies the consequences of tail events such that the expected value of the MVF will be higher compared to another risk which has the same average consequence in natural units but does not include similar tail events.</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023	2	N/A	7.1.4.1	Mitigation Strategy Devic	Identifying and Evaluating Mitigation
78	OEIS	001	OEIS_001	10	OEIS_001_10	<p>Regarding Cost-Benefit within and Overall Decision-Making Framework</p> <p>a. If projects are justified based on a multi-attribute value function/cost basis, what threshold or hurdle is used?</p> <p>b. How is the chance that a project exceeds the threshold computed?</p> <p>c. If projects are justified based on a multi-attribute value function/cost basis, what threshold or hurdle is used?</p>	<p>a) We do not have a specific threshold to justify projects.</p> <p>b) While we don't calculate a specific threshold for executing mitigations, PG&E prioritizes higher MAV/cost locations for executing projects. We also design risk buydown curves and implement projects at the higher end of the curve. The higher end of the curve represents the higher MAV/cost values.</p> <p>c) As described in response to subpart a), we do not have a specific threshold or cutoff to justify projects.</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023	0	N/A	7.1.4.2	Mitigation Strategy Devic	Mitigation Initiative Prioritization
79	OEIS	001	OEIS_001	11	OEIS_001_11	<p>Regarding PG&E's Response to ACI PG&E-22-10</p> <p>PG&E describes an external study funded by California Energy Commission (CEC) grant EPC 18-026 to classify and identify areas with similar climate locations that already have weather stations, and areas with climate conditions that are not well measured by current stations.</p> <p>a. Provide the external study which PG&E described and used to assess the statewide data similarity.</p>	<p>The weather optimization report was developed by a third party, Pyrenergic. Pyrenergic provided us with a draft copy of the report and instructed us not to distribute the document. Therefore, we would greatly appreciate Energy Safety's understanding in honoring this instruction. To this end, we recommend that Energy Safety contact the Pyrenergic team directly through the contact information provided below to obtain the draft report. This was the same process used to obtain the report from Pyrenergic.</p> <p>Direct links to contacting Pyrenergic and the report home page are provided below.</p> <ul style="list-style-type: none"> https://pyrenergic.org/contact-us/ https://pyrenergic.org/enr/weather-and-wildfire-cl/weather-station-optimization-report 	Colin Lang	4/9/2023	4/10/2023	4/10/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-10 Justification of Weather Station Network Density
80	OEIS	001	OEIS_001	12	OEIS_001_12	<p>Regarding PG&E's Response to ACI PG&E-22-09</p> <p>a. PG&E states that "363 (circuits) dropped to the lower 80 percent" (p. 891). For each of these circuit segments, provide the following information via Excel document:</p> <p>i. Name/ID of CPZ</p> <p>ii. V2 mileage of circuit segment</p> <p>iii. V3 mileage of circuit segment</p> <p>iv. Categorization in which movement each circuit segment falls under, as outlined on p. 891 (i.e., large shift in wildfire consequence value and rank, large shift in circuit segment mileage and wildfire consequence, or shift in ignition probability)</p> <p>v. Overall risk ranking (including a footnote/written response of the total number of CPZs included in the ranking)</p> <p>vi. V2 overall risk score</p> <p>vii. V3 risk score broken out by:</p> <p>(1) Ignition probability</p> <p>(2) Wildfire consequence</p> <p>viii. V3 overall risk ranking (including a footnote/written response of the total number of CPZs included in the ranking)</p> <p>ix. V3 risk score broken out by:</p> <p>(1) Ignition probability</p> <p>(2) Wildfire consequence</p> <p>b. For the 8 circuit segments that moved due to ignition probability, describe how such ignition probability changed.</p> <p>c. PG&E states that "As a result of these changes, previously approved system hardening projects have not yet initiated construction on CPZs that are now ranked as much lower risk."</p> <p>(p. 892) Provide the following information on each of these projects via Excel document:</p> <p>i. Name/ID of CPZ</p> <p>ii. Mileage of project</p> <p>iii. Type of project (i.e., covered conductor, undergrounding)</p> <p>iv. V2 overall risk ranking (including a footnote/written response of the total number of CPZs included in the ranking)</p> <p>v. V3 overall risk score</p> <p>vi. V3 overall risk ranking (including a footnote/written response of the total number of CPZs included in the ranking)</p>	<p>Please see attachment WMP-Discovery2023_DR_OEIS_001-Q012A0c01.xlsx, tab "12-a Dropped V2 CPZs."</p> <p>b. The probability of ignition change was driven primarily by greater granularity in failure rates associated with assets in the probability calculation. Please see attachment WMP-Discovery2023_DR_OEIS_001-Q012A0c01.xlsx, tab "12-b Probability of Ignition" for specific details.</p> <p>c. As noted in the 2023-2025 WMP R1 (posted April 6, 2023), ACI PG&E-22-09, (p. 891, under "Project Impacts"), "there were no projects that were de-prioritized from the changes implemented between V2 and V3 of the models." The statement referenced on p. 892, under "Project Impacts" is a quote from the SM Quarterly report highlighting the previous model changes (V1 to V2) and noting how EAM and System Hardening approached this differently due to the associated interfaces with the work.</p>	Colin Lang	4/9/2023	4/12/2023	4/12/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-09 Evaluation of Model Rebuttal in High-Risk Areas
81	OEIS	001	OEIS_001	13	OEIS_001_13	<p>Regarding PG&E's Response to ACI PG&E-22-09</p> <p>PG&E states that "Adding drones to the detailed GO 165 inspection slowed the inspection to roughly 20 to 25 poles per day, which is slower than both the stand-alone ground inspection as well as the image capture rate for both drone-only and helicopter-only" (page 900).</p> <p>a. Provide the daily inspection rates for stand-alone ground inspections, drone-only image capture, and helicopter-only capture.</p>	<p>Please see below for the requested information.</p> <p>Drone-only Helicopter + Drone Stand-alone GO 165 inspection</p> <p>Aerial Image capture (Structures/day/inspector)</p> <p>40-280 / 20-25 / NA</p> <p>Inspection rate in field (structures/day/inspector)</p> <p>NA/NA 20-25/30-30</p> <p>Desktop Inspection rate (structures/day/inspector)</p> <p>40-45 / 40-45 / NA</p> <p>Note: the helicopter-only method can capture at a very rapid rate due to automatic image capture.</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-09 Asset Inspection Drone Program Pilot
82	OEIS	001	OEIS_001	14	OEIS_001_14	<p>Regarding PG&E's Asset Management Upgrades</p> <p>On page 433, PG&E states that "PG&E has significantly advanced our data management practices and the quality of our asset inventory (Asset Registry) database over the last two years by applying the International Organization for Standardization (ISO) 55001 standards."</p> <p>a. Do the upgrades to PG&E's asset inventory database include the location of each piece of equipment (what pole it is attached to) for the distribution system, and also includes the equipment's manufacturer, model ID, and when the equipment was placed into service?</p> <p>i. If yes, how is this being done?</p> <p>ii. If no, explain why this is not the case?</p> <p>b. PG&E relies on inspection results for making decisions on whether equipment should be replaced. Does PG&E ever replace equipment proactively based on the equipment reaching its lifecycle end, as determined by the manufacturer or industry standards?</p> <p>i. If yes, what equipment is being replaced for these reasons and why?</p> <p>ii. If no, why doesn't PG&E monitor and replace equipment at the end of its lifecycle?</p> <p>c. Does PG&E have different decision-making policies when it comes to replacing equipment in the HFTDs as opposed to the rest of PG&E territory?</p> <p>iv. Of the distribution equipment that utilities are required to report on (capacitors, conductors, connectors, fuses, splices, arresters, reclosers, and transformers) what percentage is still operating in the HFTDs because the equipment has passed inspection but is being used beyond its predicted lifecycle?</p> <p>c. Does PG&E track the performance of different types of equipment by manufacturer and model information?</p> <p>i. If yes, how does PG&E track this information and what decisions are made based on this data?</p> <p>ii. If no, explain why is equipment performance not being tracked?</p>	<p>a) Our asset inventory database (Asset Registry) does include attribute fields for location (lat/long and/or identification of support structure ID for attached equipment), manufacturer, model ID (as appropriate), and installation date. These are considered critical data elements (CDEs) and data governance and data quality metrics are being established to track the associated data quality.</p> <p>i. We collect required asset attributes as part of the As-Built process, according to process and engineering standards. This includes the attributes listed above. PG&E has also implemented an Asset Registry Data Quality (ARDQ) program to identify Critical Data Elements (CDEs) and related data quality for critical asset types. Currently, this has been applied to 12 Transmission and Distribution overhead asset types on a risk prioritized basis. Attributes captured include installation date, location, manufacturer, and model ID (as appropriate). Data quality rules being measured include completeness. This provides identification of data gaps, including attributes such as installation date, which can then be targeted for remediation. A number of utilities are underway to remediate known gaps, including the Transmission Asset Information Collection (AIC) program. The ARDQ program is being extended to include additional asset types on a risk prioritized basis. Refer to 2023 WMP sections 8.1.5 Asset Management and Inspection Enterprise System(s) and ACI PG&E-22-33 - Progress on Filing Asset Inventory Data Gaps for further details.</p> <p>ii. Not applicable. Please see the response to subpart (i) above.</p> <p>b) We do not replace equipment solely based on manufacturer or industry standard lifecycle ages. There are many other factors that can influence service life of equipment, such as environment, maintenance, life extension application, etc.</p> <p>i) Not applicable, please see the response to subpart (b) above.</p> <p>ii) We replace equipment based on condition. Lifecycle is not solely determined by manufacturer or industry information, but also depends on other factors, as explained in subpart (b) above, which influence asset replacement need.</p> <p>iii) We do not have different inspection criteria for assessing condition of assets in HFTD or non-HFTD areas. However, assets located within HFTDs are typically inspected at a higher frequency to increase understanding on wildfire ignition risk. Results from these inspections may prompt replacement work within HFTD locations. HFTD replacement work may also be prioritized before non-HFTD replacement work (not including emergency replacement) based on risk prioritization.</p> <p>iv) We replace equipment based on condition. As such, PG&E does not have a predicted</p>	Colin Lang	4/9/2023	4/10/2023	4/10/2023	0	N/A	8.1.5	Asset Management and Inspection Enterprise System(s)	N/A

83	OES	001	OES_001	15	OES_001_015	<p>Regarding PG&E's Enhanced Powerline Safety Settings (EPSS) Program</p> <p>a. On page 464, PG&E states "also referred to as high impedance faults, we plan to engineer, program, and install the Downed Conductor Detection (DCD) algorithm on recloser controllers. We will also evaluate high impedance fault detection algorithms for circuit breakers in 2023 and beyond." Then on page 374, PG&E states that the DCD pilot initiative will likely continue from 2023-2025.</p> <p>b. What is the prioritization process for deciding which circuits will receive the DCD algorithm?</p> <p>i. Will the number of outages, due to EPSS de-energizations, be looked at to identify which circuits should receive the DCD algorithm first?</p> <p>ii. In Figure 8.14-a: CPUC REPORTABLE CONDITIONS IN HFTDS (page 466) PG&E shows that through December 31, 2022, there was a greater than 30 percent reduction in CPUC reportable ignitions in HFTDs across compared to the overall 2019-2020 average. PG&E claims that this reduction is a direct result of enabling EPSS in HFTDs.</p> <p>1. Was this data adjusted for circuits that have been hardened with covered conductor or other mitigation?</p> <p>i. Did PG&E associate the ignition data to each individual circuit that was enabled showing a direct correlation to the result, or is this data an assumption that has been made by looking at the overall HFTD areas and the overall reported ignitions?</p> <p>ii. Were weather and vegetation conditions factored into this data conclusion?</p>	<p>a) DCD algorithm installation was prioritized based on the addressable risk reduction from each DCD device using PG&E's WDRM (3 risk model and maximum High Risk Area (HfRA) electric distribution line mile coverage. Addressable risk reflects the devices and circuits that are capable of accepting the DCD algorithm. By the end of 2025, DCD is planned to be installed on approximately 21,000 HfRA miles. Circuit breakers and 4-wire circuits are not currently capable of receiving DCD. Mileage is subject to change due to undergrounding of overhead lines and additional grid configuration changes anticipated through 2025.</p> <p>b) i) On page 468 of the WMP we state that the 30% reduction in HFTD reportable ignitions was primarily driven by the effectiveness of the EPSS program. EPSS is understood to be the primary driver of this overall reduction given the scope and reach of the program.</p> <p>ii) On page 468 of the WMP we state that the 30% reduction in HFTD reportable ignitions was primarily driven by the effectiveness of the EPSS program. EPSS is understood to be the primary driver of this overall reduction given the scope and reach of the program.</p> <p>1. Was this data adjusted for circuits that have been hardened with covered conductor or other mitigation?</p> <p>i. Did PG&E associate the ignition data to each individual circuit that was enabled showing a direct correlation to the result, or is this data an assumption that has been made by looking at the overall HFTD areas and the overall reported ignitions?</p> <p>ii. Were weather and vegetation conditions factored into this data conclusion?</p>	Colin Lang	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings																												
84	CaPa	Set WMP-11	CaPa_Set WMP-11	1	CaPa_Set WMP-11_01	<p>PG&E's Test Year 2023 GRC rebuttal testimony (Ex PG&E-17 on July 11, 2022) states the following:</p> <p>Q 123 Does PG&E have experience with REFCL?</p> <p>A 123 Yes. PG&E initiated a REFCL pilot project in 2018 at the Calistoga substation. After initial positive tests, the Calistoga REFCL pilot demonstration was stalled due to the failure of the substation REFCL equipment. In addition, PG&E had difficulty obtaining replacement equipment from various overseas suppliers due to supply chain issues and the ongoing COVID-19 pandemic.</p> <p>Thus, the REFCL technology could not be fully evaluated beyond the initial testing because of the equipment failure and supply chain issues. More recently, PG&E has made progress on its REFCL pilot project including completing the changes to the substation equipment after encountering equipment failures. PG&E has performed successful staged fault tests of the REFCL system and is in the process of reviewing the test data to evaluate REFCL's wildfire risk reduction for ground faults on distribution circuits. PG&E is re-taking at opportunities for REFCL deployments in its distribution substations to mitigate wildfire risk and evaluating combinations of REFCL with EPSS and other mitigations.</p> <p>Regarding the Calistoga REFCL pilot demonstration:</p> <p>a) Please break down PG&E's annual spending on the Calistoga REFCL pilot demonstration since the project initiation in 2018.</p> <p>b) Please break down PG&E's annual spending on Major Work Category (MWC) 49R since the project initiation in 2018.</p> <p>c) Where are the costs in subpart (c) of this question recorded? Please provide the specific name(s) of the accounts and subaccounts, if applicable.</p> <p>d) What is the recovery mechanism for the costs in subpart (c) of this question?</p> <p>e) In the above quote, PG&E states that "[m]ore recently, PG&E has made progress on its REFCL pilot project including completing the changes to the substation equipment after encountering equipment failures." Since 2018, how much has PG&E spent on "changes to the substation equipment" and any other equipment changes in order to test or deploy REFCL at the Calistoga substation?</p>	<p>PG&E objects to parts (a) through (e) of this request as beyond the scope of this proceeding. This question relates to PG&E's 2023 General Rate Case (GRC) proceeding and has no unexecuted connection to PG&E's WMP proceeding. Furthermore, Cal Advocates concurrently served an identical data request on PG&E in the GRC proceeding and PG&E will provide a response to this request in that proceeding as it is the more appropriate venue.</p>	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter																												
85	CaPa	Set WMP-11	CaPa_Set WMP-11	2	CaPa_Set WMP-11_02	<p>Referring to PG&E's Electric Preliminary Statement Part IV (Tariff Sheet No. 52259-E), the Electric Program Investment Charge Balancing Account (EPICBA) has three subaccounts: The EPIC Program Administered by PG&E Subaccount tracks the actual program expenses to the authorized EPIC program budgets pursuant to D.12-05-047, D.20-08-042, and D.21-11-028 through December 31, 2030 or authorized by the Commission.</p> <p>The EPIC Program Administered by California Energy Commission (CEC) Subaccount tracks the actual program expenses encumbered and remitted to the CEC program administration expenses remitted to the CEC to the authorized budget pursuant to D.12-05-047, D.20-08-042, and D.21-11-028 through December 31, 2030 or authorized by the Commission.</p> <p>The New Solar Home Partnership (NSHP) Program administered by the CEC Subaccount tracks the actual remittances to the CEC, or to program applicants, to the authorized NSHP Program budgets pursuant to D.16-06-006 encumbered by June 1, 2018 or spent by December 31, 2021. Please complete the following table by providing the status of PG&E's (a) evaluation of additional substations for suitability of additional REFCL installations? b) Given the status in subpart (a) of this question, please fill in the following table:</p> <p>c) Given the status in subpart (a) of this question, what are PG&E's spending plans on: i. MWC 49R, and ii. the REFCL pilot?</p> <p>d) As of March 27, 2023, what conclusions or findings has PG&E reached based on its "evaluation of additional substations for suitability of additional REFCL installations?"</p> <p>e) Please provide the date(s) when PG&E started "design or field work on additional sites."</p> <p>f) Please identify each site referred to in (e) and state the applicable costs for each.</p> <p>g) PG&E states that "25 distribution substations with circuits in HFTDs are candidates for potential REFCL deployments." As of March 27, 2023, how many of PG&E's distribution substations with circuits in HFTDs are currently candidates for potential REFCL deployments?</p> <p>h) For each of the candidate substations included in your response to part (e), please fill in the following table:</p>	<p>PG&E objects to this request as beyond the scope of this proceeding. This question relates to PG&E's 2023 General Rate Case (GRC) proceeding and has no unexecuted connection to PG&E's WMP proceeding. Furthermore, Cal Advocates concurrently served an identical data request on PG&E in the GRC proceeding and PG&E will provide a response to this request in that proceeding as it is the more appropriate venue.</p>	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter																												
86	CaPa	Set WMP-11	CaPa_Set WMP-11	3	CaPa_Set WMP-11_03	<p>PG&E's 2022 WMP, Section 7.1.E, Attachment 1 (Atch_03.pdf) states the following regarding the project status of EPIC 3.15--Proactive Wires Down Mitigation Demonstration Project (Rapid Earth Fault Current Limiter) as of February 25, 2022. Evaluation of additional substations for suitability of additional REFCL installations has begun but is pending results and teamings of the initial EPIC project before design or field work starts on additional sites. After an initial screening process, 25 distribution substations with circuits in HFTDs are candidates for potential REFCL deployments. a) As of March 27, 2023, what is the status of PG&E's "evaluation of additional substations for suitability of additional REFCL installations?" b) Given the status in subpart (a) of this question, please fill in the following table:</p> <p>c) Given the status in subpart (a) of this question, what are PG&E's spending plans on: i. MWC 49R, and ii. the REFCL pilot?</p> <p>d) As of March 27, 2023, what conclusions or findings has PG&E reached based on its "evaluation of additional substations for suitability of additional REFCL installations?"</p> <p>e) Please provide the date(s) when PG&E started "design or field work on additional sites."</p> <p>f) Please identify each site referred to in (e) and state the applicable costs for each.</p> <p>g) PG&E states that "25 distribution substations with circuits in HFTDs are candidates for potential REFCL deployments." As of March 27, 2023, how many of PG&E's distribution substations with circuits in HFTDs are currently candidates for potential REFCL deployments?</p> <p>h) For each of the candidate substations included in your response to part (e), please fill in the following table:</p>	<p>PG&E objects to the portions of this request relating to Major Work Category (MWC) 49R as beyond the scope of this proceeding. Notwithstanding and without waiving this objection, PG&E responds as follows:</p> <p>a. PG&E has not performed an evaluation of additional substations for suitability of additional REFCL installations since the previous list of 25 distribution substations. PG&E is still evaluating the technology in its demonstration project before making decisions about additional deployments.</p> <p>b. Given the ongoing evaluation described in response to subpart (a) above, our forecast as of 4/5/2023 is as follows:</p> <table border="1"> <tr><td>Year</td><td>2023</td></tr> <tr><td>2024</td><td></td></tr> <tr><td>2025</td><td></td></tr> <tr><td>2026</td><td></td></tr> <tr><td>Forecast Capital Expenditure for MWC 49R (\$)</td><td>\$0</td></tr> <tr><td>2023</td><td>\$0</td></tr> <tr><td>2024</td><td>\$0</td></tr> <tr><td>2025</td><td>\$0</td></tr> <tr><td>2026</td><td>\$0</td></tr> <tr><td>Forecast O&M Expenses for MWC 49R (\$)</td><td>\$0</td></tr> <tr><td>2023</td><td>\$0</td></tr> <tr><td>2024</td><td>\$0</td></tr> <tr><td>2025</td><td>\$0</td></tr> <tr><td>2026</td><td>\$0</td></tr> </table> <p>c. PG&E has no spending plans for MWC 49R in 2023 and limited spend to complete evaluation of the REFCL demonstration project under the EPIC budget.</p> <p>WMP-Disposney023_DR_CalAdvocates_01120023 Page 3</p> <p>d. REFCL is less suitable in substations which have a high percentage of underground cable circuit miles on the distribution circuits. Many of PG&E's substations serving three-wire circuits do not have physical space available for the REFCL equipment. Lastly, all the banks in the substation must have 3-wire distribution circuits. Many 4-wire distribution banks and 3-wire distribution banks in the same substation affects suitability of REFCL.</p> <p>e. PG&E has not started detailed design or capital work of additional sites for REFCL.</p>	Year	2023	2024		2025		2026		Forecast Capital Expenditure for MWC 49R (\$)	\$0	2023	\$0	2024	\$0	2025	\$0	2026	\$0	Forecast O&M Expenses for MWC 49R (\$)	\$0	2023	\$0	2024	\$0	2025	\$0	2026	\$0	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
Year	2023																																											
2024																																												
2025																																												
2026																																												
Forecast Capital Expenditure for MWC 49R (\$)	\$0																																											
2023	\$0																																											
2024	\$0																																											
2025	\$0																																											
2026	\$0																																											
Forecast O&M Expenses for MWC 49R (\$)	\$0																																											
2023	\$0																																											
2024	\$0																																											
2025	\$0																																											
2026	\$0																																											
87	CaPA	Set WMP-11	CaPa_Set WMP-11	4	CaPa_Set WMP-11_04	<p>Referring to Exhibit PG&E-04, February 25, 2022, version, PG&E states the following regarding REFCL. Based on our initial testing and the successful implementation in Australia, PG&E has developed a short-term strategy to install REFCLs in HFTD areas. PG&E forecasts deploying REFCLs at an additional two substations each year, but these plans could change pending pilot results and integration with other enhanced automation and wildfire mitigation efforts described in our testimony. As of March 27, 2023, how many of PG&E's distribution substations each year, but these plans could change. - Have these plans changed? b) If your answer to part (a) is yes, please describe PG&E's current plans regarding the future deployment of REFCLs. c) Please identify the additional substations where PG&E plans on deploying REFCLs in: i. 2023, ii. 2024, iv. 2025, and v. iv. 2026</p>	<p>a) Yes, our plans have changed over the past year from what was expressed in the quote cited above from our WMP.</p> <p>b) PG&E is not planning any REFCL deployments until after complete evaluation of the demonstration project and successful integration of the technology into normal operations. PG&E is evaluating its portfolio of wildfire risk mitigations.</p> <p>c) As described in response to subpart (b), no additional substations are planned for REFCL deployment at this time.</p>	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter																												
88	CaPA	Set WMP-11	CaPa_Set WMP-11	5	CaPa_Set WMP-11_05	<p>Referring to Exhibit PG&E-17, p. 4-3.6, Table 4-3-3, line 6, served on July 11, 2022:</p> <p>Line 6 of the above table indicates that PG&E forecasts the capital expenditures to be \$17.331 million in 2023, \$17.800 million in 2024, \$18.280 million in 2025, and \$18.774 million in 2026. Given the current status of PG&E's evaluation of additional substations for suitability and PG&E's plans for future deployment of REFCLs, as of March 27, 2023, please indicate any adjustment to the forecast capital expenditures by completing the table below:</p>	<p>Please see the table below for the requested information.</p> <table border="1"> <tr><td>Year</td><td>2023</td></tr> <tr><td>2024</td><td></td></tr> <tr><td>2025</td><td></td></tr> <tr><td>2026</td><td></td></tr> <tr><td>Forecast of MAT 49R as of July 11, 2022</td><td>\$17.331MM</td></tr> <tr><td>2023</td><td>\$17.800MM</td></tr> <tr><td>2024</td><td>\$18.280MM</td></tr> <tr><td>2025</td><td>\$18.774MM</td></tr> <tr><td>Forecast of MAT 49R as of March 15, 2023</td><td>\$0</td></tr> <tr><td>2023</td><td>\$0</td></tr> <tr><td>2024</td><td>\$0</td></tr> <tr><td>2025</td><td>\$0</td></tr> <tr><td>2026</td><td>\$0</td></tr> </table>	Year	2023	2024		2025		2026		Forecast of MAT 49R as of July 11, 2022	\$17.331MM	2023	\$17.800MM	2024	\$18.280MM	2025	\$18.774MM	Forecast of MAT 49R as of March 15, 2023	\$0	2023	\$0	2024	\$0	2025	\$0	2026	\$0	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter		
Year	2023																																											
2024																																												
2025																																												
2026																																												
Forecast of MAT 49R as of July 11, 2022	\$17.331MM																																											
2023	\$17.800MM																																											
2024	\$18.280MM																																											
2025	\$18.774MM																																											
Forecast of MAT 49R as of March 15, 2023	\$0																																											
2023	\$0																																											
2024	\$0																																											
2025	\$0																																											
2026	\$0																																											

89	CaPA	Set WMP-11	CaPA_Set WMP-11	6	CaPA_Set WMP-11_06	In December 2021, PG&E presented at the EPIC Symposium. See Atch_06_EPIC_Presentation.pdf . The presentation slides state that Rapid Earth Fault Current Limiter (REFCL) technology is an extension of resonant grounding at a distribution substation to neutralize ground fault current and prevent a spark. REFCL has been successfully deployed in Australia to reduce risk of fire from ground faults, but their substation designs are different from PG&E's. One type of REFCL is known as Ground Fault Neutralizer (GFN). REFCL could be applied to approx. 80% of PG&E HFTD distribution circuit miles (3-wire circuits). a) Is the statement quoted above accurate? b) If the answer to part (a) is no, please provide any needed corrections. PG&E presents during the 2021 EPIC Symposium (Atch_06_EPIC_Presentation.pdf) that "REFCL could be applied to approx. 80% of PG&E HFTD distribution circuit miles (3-wire circuits)." However, PG&E's 2023 WMP, at page 275, states that: "While PG&E is looking at opportunities for REFCL deployments in our distribution substations to mitigate wildfire risk and evaluating combinations of REFCL with EPSS and other mitigations, implementing it would require significant and costly changes to the grid. Instead of making costly changes to the grid, we are moving forward with more cost effective solutions such as DCD and Partial Voltage Detection." Why did PG&E state that "REFCL could be applied to approx. 80% of PG&E HFTD distribution circuit miles (3-wire circuits)" while stating that "implementing it would require significant and costly changes to the grid"?	PG&E objects to this request as beyond the scope of this proceeding. Notwithstanding and without waiving this objection, PG&E responds as follows: a) Yes, this statement remains an accurate high-level description. b) Not applicable, as described in response to subpart (a).	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
90	CaPA	Set WMP-11	CaPA_Set WMP-11	7	CaPA_Set WMP-11_07	PG&E's 2023 WMP, at page 275, states that: "While PG&E is looking at opportunities for REFCL deployments in our distribution substations to mitigate wildfire risk and evaluating combinations of REFCL with EPSS and other mitigations, implementing it would require significant and costly changes to the grid. Instead of making costly changes to the grid, we are moving forward with more cost effective solutions such as DCD and Partial Voltage Detection." Why did PG&E state that "REFCL could be applied to approx. 80% of PG&E HFTD distribution circuit miles (3-wire circuits)" while stating that "implementing it would require significant and costly changes to the grid"?	This distinction is based on the fact that REFCL is not a plug-and-play technology and requires supporting construction and equipment changes in the substation and on the distribution circuits to function. This is different from DCD and Partial Voltage Detection, which are software-based features on existing hardware and require significantly less cost to implement.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
91	CaPA	Set WMP-11	CaPA_Set WMP-11	8	CaPA_Set WMP-11_08	PG&E's 2023 WMP, at page 275, states that: "While PG&E is looking at opportunities for REFCL deployments in our distribution substations to mitigate wildfire risk and evaluating combinations of REFCL with EPSS and other mitigations, implementing it would require significant and costly changes to the grid." a) Please state the earliest date when PG&E reached the conclusion that "implementing REFCL" would require significant and costly changes to the grid. b) Why did PG&E not foresee "significant and costly changes" earlier than the date provided in part (a) of this question? c) Please provide all available documentation, analyses, or studies evidencing PG&E's response to subpart (b) of this question. d) How did PG&E reach the conclusion that "implementing REFCL" would require significant and costly changes to the grid? e) State the basis of the conclusion that "implementing REFCL" would require significant and costly changes to the grid. f) How did the Calistoga REFCL pilot demonstration contribute to or support the conclusion stated in the quotation above? g) Please provide all available documentation, analyses, or studies evidencing PG&E's response to parts (a) through (f) of this question. h) What "significant and costly changes to [PG&E's] grid" would REFCL require for its implementation? i) For each "change" to PG&E's grid, what is the cost estimate? j) What are the cost estimates for each "change to the grid" at the substation level? k) What are the cost estimates for each "change to the grid" on a per-circuit-mile basis?	a) Implementing REFCL requires significant and costly changes to the grid relative to DCD and Partial Voltage Detection. PG&E first understood the deployment cost of REFCL in early 2021. b) PG&E needed to complete the field construction of the demonstration project to determine the cost to deploy REFCL at a substation. c) Please refer to PG&E's Test Year 2023 G&C, Application 21-06-021, Exhibit PG&E-04 and Exhibit PG&E-17, which contain the requested information. d) PG&E reached this conclusion through experience gained from the Calistoga REFCL demonstration project. e) PG&E encountered distribution equipment failures during 2022 REFCL testing, indicating further costs to integrate REFCL technology. f) The Calistoga REFCL demonstration project unveiled integration challenges of REFCL technology corresponding to greater costs. g) Please see: Riley, Roger and Jon Bernardo, "J&B48-0 REFCL Functional Performance Report," October 14, 2020. This document can be accessed through the following link: https://www.evs.eip.gov.au/sites/default/files/2022-12/REFCL-Functional-Performance-Review.pdf . Please refer to page 29 of this document. h) Some of the major costs of implementing this technology are identified below: - Replacing voltage regulators in closed delta; - Installing new, matched sets of feeder breaker current transformers (CTs); - Replacing bus potential transformers (PTs); - Replacing substation service transformer with line-line connection; - Installing bank neutral bus and install neutral bus grounding resistor; - Modifications to 12 kV bus structure for new switches and redosers; - Installing Ground Fault Neutralizers; - Upgrading station battery capacity; - Upgrading feeder breaker protection and automation package to current standard; - Grounding grid improvements based on grounding study; - Replacement of auto boosters with closed delta voltage regulator banks; - Replacement of open delta voltage regulators with closed delta; - WMP/Discovery/2023_DR_CalAdvocates_011-2009 Page 3 - Replacement of line redosers and controllers for sensitive earth fault detection; - Isolation transformer for primary connected customers.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
92	CaPA	Set WMP-11	CaPA_Set WMP-11	9	CaPA_Set WMP-11_09	At which substations, other than the Calistoga substation, has PG&E tested REFCL?	We have not tested REFCL at any substations other than the Calistoga substation.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
93	CaPA	Set WMP-11	CaPA_Set WMP-11	10	CaPA_Set WMP-11_010	Has PG&E done any benchmarking study on REFCL with Southern California Edison (SCE)?	Yes, PG&E REFCL project engineers regularly engage with Southern California Edison to benchmark our findings and share results and learnings. Of note, SCE has fewer circuit miles of existing underground cable than REFCL demonstration site.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
94	CaPA	Set WMP-11	CaPA_Set WMP-11	11	CaPA_Set WMP-11_011	Has PG&E collaborated or exchanged with SCE on REFCL? If so, please detail the relevant activities.	Yes, PG&E regularly collaborates with SCE on REFCL and sharing data and information. This includes a monthly utility group call/meeting and sharing technical reports.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
95	CaPA	Set WMP-11	CaPA_Set WMP-11	12	CaPA_Set WMP-11_012	PG&E's 2023 WMP, at page 275, states that 8 "instead of making costly changes to the grid, we are moving forward with more cost-effective solutions such as DCD (Downed Conductor Detection) and Partial Voltage Detection. Regarding Downed Conductor Detection (DCD), a) What "changes to the grid" are required for PG&E to implement this technology? b) Is DCD viable on 3-wire systems, 4-wire systems, or both? c) Does PG&E have a cost estimate for the deployment of DCD? d) If the answer to part (c) is yes, please provide the cost estimate(s).	a) Depending on the existing redoser controller, DCD may not require a physical "change to the grid" or may require the retrofitting of an existing line redoser controller. b) DCD is most compatible with 3-wire systems. Implementation on 4-wire is possible but may require the benefits desired due to the higher settings thresholds that would be required. As a result, we are not currently installing DCD on 4-wire systems. c) Yes, please see the response to subpart (c) below. d) The cost estimate is as follows: \$15.6 million in 2023, \$13.1 million in 2024, and \$8.4 million in 2025.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	7.2.1	Mitigation Strategy Development	Overview of Mitigation Initiatives and Activities
96	CaPA	Set WMP-11	CaPA_Set WMP-11	13	CaPA_Set WMP-11_013	PG&E's 2023 WMP, at page 275, states that 9 "instead of making costly changes to the grid, we are moving forward with more cost-effective solutions such as DCD and Partial Voltage Detection. Regarding Partial Voltage Detection (PVD), a) What "changes to the grid" are required for PG&E to implement this technology? b) Is PVD viable on 3-wire systems, 4-wire systems, or both? c) Does PG&E have a cost estimate for the deployment of PVD? d) If the answer to part (c) is yes, please provide the cost estimate(s).	a) Partial Voltage Detection (PVD) does not require a "change to the grid," the statement quoted above refers to how this makes PVD a cost-effective solution. b) PVD is viable on both 3-wire and 4-wire systems. c) No, as there is no cost to "deploy" PVD. d) Not applicable, please see the response to subpart (c) above.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	7.2.1	Mitigation Strategy Development	Overview of Mitigation Initiatives and Activities
97	CaPA	Set WMP-11	CaPA_Set WMP-11	14	CaPA_Set WMP-11_014	Based on PG&E's evaluation of REFCLs: a) Please describe the significant changes to the grid required to implement REFCL technology. b) State PG&E's cost estimates for such changes. c) Describe the equipment installations required for such changes, and d) Describe the likely operational impacts resulting from the implementation of REFCLs on PG&E's system.	a) The significant changes to the grid required to implement REFCL are identified below: - Replacing voltage regulators in closed delta; - Installing new, matched sets of feeder breaker current transformers (CTs); - Replacing bus potential transformers (PTs); - Replacing substation service transformers with line-line connections; - Isolating the bank neutral bus and installing a neutral bus grounding resistor; - Modifying the 12 kV bus structure for new switches and redosers; - Installing Ground Fault Neutralizers; - Upgrading the station battery capacity; - Upgrading the feeder breaker protection and automation package to the current standard; - Grounding grid improvements based on grounding study; - The replacement of auto boosters with closed delta voltage regulator banks; - The replacement of open delta voltage regulators with closed delta; - The replacement of line redosers and controllers for sensitive earth fault detection; - The isolation transformer for primary connected customers; - Replacing three-phase fuse arrangements with fuses/switches; - Phase connection swaps for capacitive current balancing; and - The replacement of old, direct bury underground cable. b) The total cost estimate for these changes varies but is in the range of \$10,000,000 to \$20,000,000. c) Please see the response to subpart (a) for the requested information. d) PG&E is still gaining operational experience with REFCL on its system through the demonstration project. One impact that has been identified at this time is that the known that fault location can be a challenge for such a system.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
98	CaPA	Set WMP-11	CaPA_Set WMP-11	15	CaPA_Set WMP-11_015	Please state the dates when PG&E finished evaluating the following: a) The significant changes to the grid required to implement REFCL technology. b) The cost estimates for such changes. c) The equipment installations required due to such changes, and d) The likely operational impacts resulting from the implementation of REFCL on PG&E's system.	a) - d) We finished the evaluation of each item identified above in early 2021.	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
99	CaPA	Set WMP-11	CaPA_Set WMP-11	16	CaPA_Set WMP-11_016	Please provide all available documentation, studies, and analyses evidencing PG&E's conclusions on each of the following aspects of REFCL deployment: a) The significant changes to the grid required to implement REFCL technology. b) The cost estimates for such changes. c) The equipment installations required due to such changes, and d) The likely operational impacts resulting from the implementation of REFCL on PG&E's system.	a) Please see: Riley, Roger and Jon Bernardo, "J&B48-0 REFCL Functional Performance Report," October 14, 2020. This document can be accessed at the following link: https://www.evs.eip.gov.au/sites/default/files/2022-12/REFCL-Functional-Performance-Review.pdf . Please see page 29 of this document for the requested information. b) Please refer to PG&E's Test Year 2023 G&C, Application 21-06-021, Exhibit PG&E-04 and Exhibit PG&E-17. c) Please see: Riley, Roger and Jon Bernardo, "J&B48-0 REFCL Functional Performance Report," the same document as identified in response to subpart (a). d) Please see: Riley, Roger and Jon Bernardo, "J&B48-0 REFCL Functional Performance Report," the same document as identified in response to subpart (a) and (c).	Pui-Wa Li	4/5/2023	4/10/2023	4/10/2023	https://www.pge.com/page_global/common/pdfs/efly/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_011.zip	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter

100	TURN	003	TURN_003	1	TURN_003_Q1	<p>Please provide data in PG&E's possession that indicates the following:</p> <p>a. The SADI (System Average Interruption Duration Index) for the years 2018-2022 for underground distribution facilities.</p> <p>b. The MAIFI (Momentary Average Interruption Frequency Index) for the years 2018-2022 for underground distribution facilities.</p> <p>c. The SADI (System Average Interruption Duration Index) for the years 2018-2022 for overhead distribution facilities with covered conductor.</p> <p>d. The MAIFI (Momentary Average Interruption Frequency Index) for the years 2018-2022 for overhead distribution facilities with covered conductor.</p> <p>e. The SADI (System Average Interruption Duration Index) for the years 2018-2022 for overhead distribution facilities without covered conductor.</p> <p>f. The MAIFI (Momentary Average Interruption Frequency Index) for the years 2018-2022 for overhead distribution facilities without covered conductor.</p>	<p>Please see the attachment "WMP-Discovery2023_DR_TURN_003-Q001ACh01.xlsx" for the requested information. Please note that PG&E does not capture overhead covered conductor status in our current outage reporting, so SAID/MAIFI data for covered conductor equipment cannot be provided at this time.</p>	Tom Long	4/5/2023	4/10/2023	4/10/2023	1	N/A	N/A	N/A	N/A	N/A
101	TURN	003	TURN_003	2	TURN_003_Q2	<p>Please provide all reports or studies in PG&E's possession prepared from January 1, 2018 to the present that discuss the reliability of underground distribution facilities with covered conductor, overhead distribution facilities with covered conductor, including but not limited to a discussion of SADI and MAIFI data.</p>	<p>PG&E publishes an annual reliability report which provides a detailed report on the system's reliability performance. Please see the following attachments for the requested information:</p> <ul style="list-style-type: none"> "WMP-Discovery2023_DR_TURN_003-Q002ACh01.pdf" "WMP-Discovery2023_DR_TURN_003-Q002ACh02.pdf" "WMP-Discovery2023_DR_TURN_003-Q002ACh03.pdf" "WMP-Discovery2023_DR_TURN_003-Q002ACh04.pdf" "WMP-Discovery2023_DR_TURN_003-Q002ACh05" <p>Additionally, we are in the process of finalizing a study that is planned to be completed by June 30, 2023. This study will assess the recorded reliability improvements at locations that have been undergrounded and/or have been hardened with covered conductor. It is important to also note that the focus of our overhead system hardening and undergrounding program to date has been primarily to drive wildfire mitigation.</p>	Tom Long	4/5/2023	4/10/2023	4/10/2023	5	N/A	N/A	N/A	N/A	N/A
102	TURN	003	TURN_003	3	TURN_003_Q3	<p>Regarding Table 7-3.2, p. 296, the bottom row re PSIS:</p> <p>a. Please confirm that the targets for reduced customer impacts in 2023, 2024 and 2025 are cumulative, i.e. that the 33,000 figure for 2024 includes the 15,000 reduced impacts for 2023, and so on.</p> <p>b. Please provide the supporting data for the estimates of reduced PSIS impacts in 2023 (15,000 customer events), 2024 (10,000 customer events), and 2025 (5,000 customer events). Provide the data in the Excel format if possible.</p> <p>c. The table states that the targeted reductions are "based on Wildfire mitigation projects including but not limited to NSO replacements and undergrounding miles." For each of 2023, 2024 and 2025, please provide a breakdown of the reduced customer events by the mitigation measure to which PG&E attributes the reduced customer events, including but not limited to covered conductor installation. Explain how PG&E determined the breakdown.</p> <p>d. Provide equivalent data regarding reduced PSIS impacts for the years 2019 through 2022 and provide the supporting data for those figures in Live Excel format if possible. In addition, for each of these years, please provide a breakdown of the reduced customer events by the mitigation measure to which PG&E attributes the reduced customer events, including but not limited to covered conductor installation. Explain how PG&E determined the breakdown.</p>	<p>a) We can confirm that the targets for reduced customer impacts are cumulative for Initiative PS-07 in Table 7-3.2. Please see Table PG&E-22-36-1 (2023 WMP, p. 879) for the breakout of incremental customers for each respective year.</p> <p>b) Please see attachment WMP-Discovery2023_DR_TURN_003-Q003ACh01 for supporting data for the estimates of reduced PSIS impacts in 2023-2025 for the five-year period, 2018-2022.</p> <p>c) For breakdown of reduced customer events by mitigation measures, please see Table PG&E-22-36-1 of our 2023 WMP, or attachment WMP-Discovery2023_DR_TURN_003-Q003ACh01. In that attachment, column "Incremental Customers Mitigated" provides the number of annual customers mitigated and column "Cumulative Customers Mitigated" provides the cumulative figure for customer mitigations. For an explanation of how this calculation was performed, please see the response to ACI PG&E-22-36 on page 972 of our 2023 WMP. Covered conductor installation is not part of the mitigation measure calculation and provided the supporting data for those figures in Live Excel format if possible. Please see the response to ACI PG&E-22-11.</p> <p>d) The PSIS impact reductions are for the five-year lookback periods of 2018-2022. Completion of undergrounding and Motorized Switch Operator (MSO) mitigation in each year from 2023-2025 will reduce the customer impact in the five-year look back period.</p>	Tom Long	4/5/2023	4/10/2023	4/10/2023	1	N/A	9.1.5	Public Safety Power Shutoff	Performance Metrics Identified by the Electrical Corporation	
103	CaPA	Set WMP-12	CaPA_Set WMP-12	1	CaPA_Set WMP-12_Q1	<p>Regarding Table 9-2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 28, 29, 30, 36, 37, 38, 39, 47, 55, 62, 63, 70, 71, 97, 105, 111, 112, 120, 122, 125, 126, 148, 151, 153, 163, 178, 179, 183.</p> <p>a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" are blank.</p> <p>b) For each of the above Entry Numbers, please state whether PG&E plans to take any measures during the 2023-2025 WMP period to reduce the need for and impact of future PSIS on that circuit.</p> <p>c) For each item in part (b) where PG&E does not plan to take any measures to reduce the need for an impact of future PSIS on that circuit, please state the basis for this decision.</p>	<p>a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" of the Frequently De-energized Circuits list. We will reach out to Energy Safety to provide this corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks.</p> <p>Please note, we expect to have the table revised by April 18, 2023.</p> <p>b) See response (a).</p> <p>c) See response (a).</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	
103	CaPA	Set WMP-12	CaPA_Set WMP-12	1 SUPP	CaPA_Set WMP-12_Q1 SUPP	<p>Regarding Table 9-2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 28, 29, 30, 36, 37, 38, 39, 47, 55, 62, 63, 70, 71, 97, 105, 111, 112, 120, 122, 125, 126, 148, 151, 153, 163, 178, 179, 183.</p> <p>a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" are blank.</p> <p>b) For each of the above Entry Numbers, please state whether PG&E plans to take any measures during the 2023-2025 WMP period to reduce the need for and impact of future PSIS on that circuit.</p> <p>c) For each item in part (b) where PG&E does not plan to take any measures to reduce the need for an impact of future PSIS on that circuit, please state the basis for this decision.</p>	<p>We have updated our List of Frequently De-energized Circuits based on the errors found in our review. The Entry Numbers listed above may not reflect the latest circuits that are mitigated by PSIS protocols. Please see attachment WMP-Discovery2023_DR_CaPAAdvocates_012-Q001Supp01ACh01.xlsx for the updated List of Frequently De-energized Circuits.</p> <p>a) After updating our table, eight distribution circuits have no PSIS Mitigation Measures taken or planned to be taken. These have been marked with "No PSIS Mitigation Measures taken or planned to be taken, see footnotes below for explanation" instead of a blank cell to avoid confusion.</p> <p>Other than mitigations stated in the Frequently De-energized Table, PG&E plans to implement in-event alternatives such as remediation of asset and vegetation tags, and potential use of temporary generation where possible that could reduce customer impact.</p> <p>b) See response (a).</p> <p>c) See response (a).</p>	Holly Wehman	4/6/2023	4/18/2023	4/18/2023	1	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	
104	CaPA	Set WMP-12	CaPA_Set WMP-12	2	CaPA_Set WMP-12_Q2	<p>Regarding Table 9-2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" is blank for the following transmission circuit Entry Numbers: 200, 227 a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" are blank. b) For each of the above Entry Numbers, please state whether PG&E plans to take any measures during the 2023-2025 WMP period to reduce the need for and impact of future PSIS on that circuit. c) For each item in part (b) where PG&E does not plan to take any measures to reduce the need for an impact of future PSIS on that circuit, please state the basis for this decision.</p>	<p>a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" of the Frequently De-energized Circuits list. We will reach out to Energy Safety to provide this corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks.</p> <p>Please note, we expect to have the table revised by April 18, 2023.</p> <p>b) See response (a).</p> <p>c) See response (a).</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	
104	CaPA	Set WMP-12	CaPA_Set WMP-12	2 SUPP	CaPA_Set WMP-12_Q2 SUPP	<p>Regarding Table 9-2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" is blank for the following transmission circuit Entry Numbers: 200, 227 a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSIS of Circuit" are blank. b) For each of the above Entry Numbers, please state whether PG&E plans to take any measures during the 2023-2025 WMP period to reduce the need for and impact of future PSIS on that circuit. c) For each item in part (b) where PG&E does not plan to take any measures to reduce the need for an impact of future PSIS on that circuit, please state the basis for this decision.</p>	<p>We have updated our List of Frequently De-energized Circuits based on the errors found in our review. The Entry Numbers listed above may not reflect the latest circuits that are mitigated by PSIS protocols. Please see attachment WMP-Discovery2023_DR_CaPAAdvocates_012-Q001Supp01ACh01.xlsx for the updated List of Frequently De-energized Circuits.</p> <p>a) After updating our table, one transmission line has no PSIS Mitigation Measures taken or planned to be taken. This line has been marked with "No PSIS Mitigation Measures taken or planned to be taken, see footnotes below for explanation" instead of a blank cell to avoid confusion.</p> <p>Other than mitigations stated in the Frequently De-energized Table, PG&E plans to implement in-event alternatives such as remediation of asset and vegetation tags, and potential use of temporary generation where possible that could reduce customer impact.</p> <p>b) We deploy two Temporary Generation initiatives (Distribution Megagrids and Backup Generation) to address different types of PSIS impacts to benefit the number of customers stated. See Section 9.2.4 on p. 781 on details for additional details.</p> <p>The number of customers that benefited from Temporary Generation for each of the circuits listed, is the maximum number of customers mitigated per historic PSIS event by Distribution Megagrids and Backup Generation.</p> <p>c) We plan to continue to utilize Temporary Generation as a mitigation in any potential future PSIS events.</p> <ul style="list-style-type: none"> Deployment of the Distribution Megagrids will vary depending on the weather footprint. For Megagrids, the customers mitigated will vary from 14 customers to 3,278 customers. See below for the 2023 list of Distribution Megagrid locations and customers mitigated. Pre-staged Distribution Megagrids (8) County Pre-Stage Distribution Megagrids Customers (SPDs) Mitigated Napa Angier 48 Napa Calistoga 1574 Placer Colusa 418 Placer Foresthill 14 Lake Lake 1022 Butte Magalia 10 Lake Middletown 428 Shasta Shegwenet 86 <p>On Demand Distribution Megagrid Sites (5)</p> <ul style="list-style-type: none"> County On Demand Distribution Megagrids Customers (SPDs) Mitigated Elkblondo Palook Press 83 Lake Clearlake North 3278 Calaveras Arnold 123 El Dorado Georgetown 50 Tuolumne Groveland 61 <p>Backup Generation is offered to certain critical facilities when an outage could have a</p>	Holly Wehman	4/6/2023	4/18/2023	4/18/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	
105	CaPA	Set WMP-12	CaPA_Set WMP-12	3	CaPA_Set WMP-12_Q3	<p>Regarding Table 9-2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, distribution circuit Entry Numbers 1, 21, 22, 23, 24, 25, 26, 27, 33, 34, 44, 45, 69, 83, 84, 86, 88, 117, 118, 124, 127, 128, 130, 131, 144, 152, 157, 158, 168, 169, 172, 176, 177, 181, 184 a) Please explain how PG&E deployed Temporary Generation to benefit the number of customers stated. b) Please explain whether PG&E plans to use Temporary Generation again in future PSIS events, if so, how many customers will benefit each time? c) For entries where no number of customers is listed in Table 9-2, please explain why the number of customers was not known.</p>	<p>On Demand Distribution Megagrid Sites (5)</p> <ul style="list-style-type: none"> County On Demand Distribution Megagrids Customers (SPDs) Mitigated Elkblondo Palook Press 83 Lake Clearlake North 3278 Calaveras Arnold 123 El Dorado Georgetown 50 Tuolumne Groveland 61 <p>Backup Generation is offered to certain critical facilities when an outage could have a</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	

106	CaPA	Set WMP-12	CaPA_Set WMP-12	4	CaPA_Set WMP-12_O4	Regarding Table 9.2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, distribution circuit Entry Numbers 3, 4, 6, 8, 13, 14, 19, 20, 21, 22, 23, 24, 25, 26, 27, 32, 35, 49, 50, 51, 52, 53, 60, 61, 64, 65, 66, 67, 68, 72, 73, 75, 76, 77, 78, 79, 80, 81, 82, 84, 85, 91, 94, 96, 99, 100, 101, 102, 104, 106, 107, 108, 109, 114, 115, 116, 118, 123, 124, 127, 128, 129, 130, 132, 137, 139, 140, 142, 145, 147, 149, 150, 154, 155, 159, 164, 168, 170, 171, 173, 180, 181, 182, 184, 186, 188, 189, 191 a) Please describe the PSPS protocols referenced in these Entry Numbers. b) Please explain how customers were "Mitigated by PSPS protocols." c) Please state how many customers benefited from mitigation by PSPS protocols in past events. d) State whether the customers referenced in part (c) benefited because they were not de-energized or because they had reduced impacts from PSPS. e) Please state how many customers PG&E expects to benefit in the future due to mitigation by PSPS protocols. f) State whether the customers referenced in part (e) will benefit because they will not be de-energized or because they will have reduced impacts from PSPS.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to be Taken, to Reduce the Need for and Impact of Future PSPS of Circuit" of the Frequently De-energized Circuits list. We will reach out to Energy Safety to provide this corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response to (a). c) See response to (a). d) See response to (a). e) See response to (a). f) See response to (a).	Holly Wetman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
106	CaPA	Set WMP-12	CaPA_Set WMP-12	4 SUPP	CaPA_Set WMP-12_O4 SUPP	Regarding Table 9.2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, distribution circuit Entry Numbers 3, 4, 6, 8, 13, 14, 19, 20, 21, 22, 23, 24, 25, 26, 27, 32, 35, 49, 50, 51, 52, 53, 60, 61, 64, 65, 66, 67, 68, 72, 73, 75, 76, 77, 78, 79, 80, 81, 82, 84, 85, 91, 94, 96, 99, 100, 101, 102, 104, 106, 107, 108, 109, 114, 115, 116, 118, 123, 124, 127, 128, 129, 130, 132, 137, 139, 140, 142, 145, 147, 149, 150, 154, 155, 159, 164, 168, 170, 171, 173, 180, 181, 182, 184, 186, 188, 189, 191 a) Please describe the PSPS protocols referenced in these Entry Numbers. b) Please explain how customers were "Mitigated by PSPS protocols." c) Please state how many customers benefited from mitigation by PSPS protocols in past events. d) State whether the customers referenced in part (c) benefited because they were not de-energized or because they had reduced impacts from PSPS. e) Please state how many customers PG&E expects to benefit in the future due to mitigation by PSPS protocols. f) State whether the customers referenced in part (e) will benefit because they will not be de-energized or because they will have reduced impacts from PSPS.	We have updated our List of Frequently De-energized Circuits based on the errors found in our review. The entries listed above may not reflect the latest circuits that are mitigated by PSPS protocols. Please see attachment "WMPDeenergized2023_OR_CaAdvocates_012-QOO15up01/Abot14ax" for the updated List of Frequently De-energized Circuits. a) Please refer to Section 9.2 Protocols on PSPS beginning on p. 766 for Distribution. b) PG&E's current PSPS Protocols were updated compared to PSPS Protocols from previous years. Based on our current PSPS Protocols, our scoping improved and some of the circuits would not have been de-energized or would have fewer customers impacted than for certain past PSPS events. c) 865,626 Distribution customer-events would have been mitigated by current PSPS protocols from 2019-2022. This calculation is based on a comparison of historical PSPS events and the 2022 PSPS Five-Year Lookback Analysis, which applies the current PSPS protocols to the weather conditions present in 2018-2022. This comparison excludes 2018 because PG&E's historical PSPS events only occurred in the later part of 2018. The total number of mitigated customer-events is calculated as a net value if some circuits would increase customer impacts due to PSPS protocols, the impacted customer-events would lower the total mitigated customer count reported here. "Customer-events" refers to the count of customer impacts over the Five-Year Lookback. If the same customer is mitigated from PSPS for three PSPS events in the Five-Year Lookback, this is reported as "three customer-events mitigated" instead of "one unique customer mitigated". d) Customers referenced in part (c) benefited because they would not have been deenergized for certain past PSPS events based on the current PSPS Protocols. Some of these customers may still be de-energized in other PSPS events in the years compared for this analysis but saw a decrease in the number of PSPS event impacts. e) The number of customers mitigated in each PSPS event by PSPS Protocols depends on a look back analysis, updated PSPS Protocols, and the weather conditions seen during that future customer event. We make enhancements to our protocols, we are not able to calculate future customer impacts. See SA-04, SA-05, SA-06, PS-02, and PS-04 for additional details on evaluation of enhancements to PSPS protocols. f) See response to (e).	Holly Wetman	4/6/2023	4/18/2023	4/18/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
107	CaPA	Set WMP-12	CaPA_Set WMP-12	5	CaPA_Set WMP-12_O5	Regarding Table 9.2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, transmission circuit Entry Numbers 193, 195, 197, 198, 199, 201, 202, 203, 204, 205, 206, 208, 209, 210, 211, 212, 213, 215, 217, 218, 219, 221, 222, 223, 224, 226, 228, 231, 232, 233, 234, 236, 238 a) Please describe the PSPS protocols referenced in these Entry Numbers. b) Please explain how customers were "Mitigated by PSPS protocols." c) Please state how many customers benefited from mitigation by PSPS protocols in past events. d) State whether the customers referenced in part (c) benefited because they were not de-energized or because they had reduced impacts from PSPS. e) Please state how many customers PG&E expects to benefit in the future due to mitigation by PSPS protocols. f) State whether the customers referenced in part (e) will benefit because they will not be de-energized or because they will have reduced impacts from PSPS.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to be Taken, to Reduce the Need for and Impact of Future PSPS of Circuit" of the Frequently De-energized Circuits list. We will reach out to Energy Safety to provide this corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response to (a). c) See response to (a). d) See response to (a). e) See response to (a). f) See response to (a).	Holly Wetman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
107	CaPA	Set WMP-12	CaPA_Set WMP-12	5 SUPP	CaPA_Set WMP-12_O5 SUPP	Regarding Table 9.2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP, transmission circuit Entry Numbers 193, 195, 197, 198, 199, 201, 202, 203, 204, 205, 206, 208, 209, 210, 211, 212, 213, 215, 217, 218, 219, 221, 222, 223, 224, 226, 228, 231, 232, 233, 234, 236, 238 a) Please describe the PSPS protocols referenced in these Entry Numbers. b) Please explain how customers were "Mitigated by PSPS protocols." c) Please state how many customers benefited from mitigation by PSPS protocols in past events. d) State whether the customers referenced in part (c) benefited because they were not de-energized or because they had reduced impacts from PSPS. e) Please state how many customers PG&E expects to benefit in the future due to mitigation by PSPS protocols. f) State whether the customers referenced in part (e) will benefit because they will not be de-energized or because they will have reduced impacts from PSPS.	We have updated our List of Frequently De-energized Circuits based on the errors found in our review. The entries listed above may not reflect the latest circuits that are mitigated by PSPS protocols. Please see attachment "WMPDeenergized2023_OR_CaAdvocates_012-QOO15up01/Abot14ax" for the updated List of Frequently De-energized Circuits. a) Please refer to Section 9.2 Protocols on PSPS beginning on p. 774 for Transmission. b) See response to (a). c) 34 Transmission customer-events would have been mitigated by current PSPS protocols from 2019-2022. This calculation is based on a comparison of historical PSPS events and the 2022 PSPS Five-Year Lookback Analysis, which applies the current PSPS protocols to the weather conditions present in 2018-2022. This comparison excludes 2018 because PG&E's historical PSPS events only occurred in the later part of 2018. The number of mitigated customer-events is calculated as a net value if some circuits would have seen higher customer impacts due to PSPS protocols, the increase in impacted customer-events would have been subtracted from the mitigated customer count reported here. "Customer-events" refers to the count of customer impacts over the Five-Year Lookback. If the same customer is mitigated from PSPS for three PSPS events in the Five-Year Lookback, this is reported as "three customer-events mitigated" instead of "one unique customer mitigated". d) See response to (a). e) See response to (a). f) See response to (a).	Holly Wetman	4/6/2023	4/18/2023	4/18/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
108	CaPA	Set WMP-12	CaPA_Set WMP-12	6	CaPA_Set WMP-12_O6	PG&E's WMP p. 751, Section 9.1.2, states that "This table [Table 9.2] also includes the mitigation measures taken, or planned to be taken, to reduce the likelihood of PSPS on those circuits." Regarding Table 9.2 (Lists of Frequently De-energized Circuits) in Appendix F of PG&E's WMP. The only planned action listed in Table 9.2 is regarding "MSO device installations or replacement plan" (which is listed for 6 of 236 circuits). a) Please explain why none of the other types of mitigation measures listed on p. 751 are listed in Table 9.2 as planned actions for any circuits. b) Please explain whether PG&E plans to take any mitigation measures for any of the remaining 228 circuits in Table 9.2.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to be Taken, to Reduce the Need for and Impact of Future PSPS of Circuit" of the Frequently De-energized Circuits list. We will reach out to Energy Safety to provide this corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. Additionally, majority of the mitigation types listed on p. 751 are circuit specific and we have provided the devices installed and line miles completed for those. Besides undergrounding and MSO we currently do not have a plan to install additional devices such as sectionalizing or Microgrids locations. In our update to the Frequently De-energized Circuit list, we will add planned undergrounding as actions to the applicable circuits. b) See response to (a).	Holly Wetman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
109	CaPA	Set WMP-12	CaPA_Set WMP-12	7	CaPA_Set WMP-12_O7	Regarding ACP PG&E 22-35 (Quantify Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency) on WMP p. 972-973. a) Please explain why this table shows customer impacts (in terms of incremental PSPS mitigation) for only two mitigation methods (i.e., undergrounding and MSO), while other methods (e.g., overhead hardening, sectionalizing, etc.) are not listed in this table. b) Has PG&E analyzed customer PSPS impacts for other mitigation methods? c) If the answer to part (b) is yes, please provide the results of PG&E's analysis. d) If the answer to part (b) is no, please explain why not.	a) Table PG&E 22-35.1 shows customer impacts and not customer impacted. In the analysis, we applied the 2022 guidance in the weather lookback period of 2018-2022. Other mitigation methods such as sectionalizing devices, grid hardening, and PSPS protocols are already factored into the lookback. This allows us to calculate the number of customers we are able to mitigate with the two planned mitigations (undergrounding and MSO) we expect to complete in 2023-2025. b) We have analyzed additional mitigation methods as undergrounding and MSO as the two projects we currently plan to complete in the next 3 years. Other mitigation methods such as sectionalizing devices, grid hardening, and PSPS protocols are already factored into the lookback. c) See response to (b). d) See response to (b).	Holly Wetman	4/6/2023	4/11/2023	4/11/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACP PG&E 22-35 - Quantify Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip
110	CaPA	Set WMP-12	CaPA_Set WMP-12	8	CaPA_Set WMP-12_O8	Regarding Section 9.2.3 (Outline of Tactical and Strategic Decision-Making Protocol for Initiating a PSPS/PSPS (Such as Decision Tree)) subsection, "Decision to De-Energize," the WMP p. 780 states in part that "The OIC will determine whether alternatives to de-energization are inadequate." a) Please describe the alternatives to de-energization that are considered. b) Please state the basis of PG&E's decision regarding whether alternatives to de-energization are inadequate. c) Please describe how OIC determines whether such alternatives are adequate or inadequate.	a) We consider if alternatives, such as additional vegetation management and disabling automatic re-closers, could adequately reduce the risk of catastrophic wildfire that triggering the need for de-energization. When these measures alone cannot reduce the risk of catastrophic wildfire in areas within the PSPS scope sufficiently to protect public safety, we will move forward with PSPS. b) See response to (a). c) When alternatives are considered the OIC further evaluates the forecasted high wind speeds and wind gust speeds, which can break and blow vegetation and debris into power lines and blow sparks into dry vegetation, when it's determined these other measures are not adequate alternatives to mitigate the risk of catastrophic wildfire, and that de-energizing in the area within the PSPS scope is necessary to protect public safety. Furthermore, we implemented efforts to mitigate adverse impacts on the customers and communities in areas where power shutoffs were likely. These efforts include: • Employing granular scoping processes to significantly reduce the public safety impacts of de-energizing smaller segments of the grid within the close confines of the fire-critical weather footprint, rather than de-energizing large amounts of customers in more populated areas. • Considering the public safety impacts of de-energizing by reviewing the total count of impacted customers and the impact of potential de-energization upon Medical Baseline customers, critical facilities, and the back-up generation capabilities of critical facilities that pose societal impact risks if de-energized (e.g., critical infrastructure). • Utilizing temporary generation to energize customers outside of the forecasted risk areas. • Using sectionalizing to narrow the scope and number of customers affected. • Considering opportunities for islanding, temporary generation, and alternate grid solutions, to reduce and mitigate the number of customers de-energized. • Reducing the public safety impact of de-energizing some affected communities by using back-up generation to serve critical facilities and customers. • Providing local Community Resource Centers (CRCs) to support customers in those impacted communities. • Supporting vulnerable customers through California Foundation for Independent Living Centers (CILC) and Community Based Organizations (CBO) resource partners that offer various services to customers impacted by the event. • Making extensive use of Advanced Notifications and outreach tools to notify impacted	Holly Wetman	4/6/2023	4/11/2023	4/11/2023	0	N/A	9.2.3	Public Safety Power Shutoff	Outline of Tactical and Strategic Decision-Making Protocol for Initiating a PSPS/PSPS (Such as Decision Tree)	https://www.pge.com/page_abbot/common/pdfs/afly/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CAAdvocates_012.zip

111	CaPA	Set WMP-12	CaPA_Set WMP-12	9	CaPA_Set WMP-12_09	<p>Regarding WMP p. 783, Section 6.2.4 (Protocols for Mitigating the Public Safety Impacts of PSPS, Including Impacts on First Responders, Health Care Facilities, Operators of Telecommunications Infrastructure, and Water Electrical Corporations/Agencies), subsection ("transit- or Paratransit-Dependent Persons"):</p> <p>a) Does PG&E notify by transit- or paratransit-dependent customers of what specific resources are available, ahead of a potential PSPS event?</p> <p>b) If the answer to part (a) is yes, how far in advance of a potential PSPS event does PG&E notify transit- or paratransit-dependent customers?</p> <p>c) If the answer to part (a) is yes, please provide a sample of such a notification.</p> <p>d) Please provide an example of a map that has been provided to paratransit agencies.</p>	<p>a) PG&E provides accessible transportation through partnerships with the California Foundation for Independent Living Center (CFILC), which facilitates the Disability Disaster Access and Resources (DDAR) Program. PG&E's partnership with the California 211 Network, and PG&E's standalone agreement with four transportation organizations that provide accessible transportation in 12 counties. Furthermore, before and during a PSPS, PG&E provides known Paratransit agencies with 24-48 hour Watch Notifications, as well as any applicable Warning, Delay, Cancel, and Restoration Notifications during an event. This also includes a list of the zip codes impacted by county and the number of customers impacted. PG&E promotes all of its resources on https://www.pge.com/en_US/residential/outage/public-safety-power-shutoff/pssp-support.page.</p> <p>b) All potentially impacted customers including paratransit dependent customers and agencies begin receiving notifications up to 2 days ahead of the potential PSPS including a 3-day watch, 1 day watch, 14 hour warning and at time of reenergization. AFN and Medical Baseline customers receive unique PSPS Watch and PSPS Warning notifications. These messages include customized phone, text, and email messages that request confirmation that the notification was received. If previous alerts are not acknowledged, we will make additional attempts to notify the customer. This will continue hourly, or be conducted in person, until we are able to reach them.</p> <p>c) Sample customer notifications are referenced in attachment "WMP_Discovery2023_DR_CalAdvocates_012-0009A0101.pdf"</p> <p>d) Due to changing weather and therefore changes in projected footprint, we do not specifically provide a map to paratransit agencies, but provides paratransit agencies with a list of impacted zip codes along with the ability to look up any address or view a map of potentially impacted areas at https://gisalerts.alerts.pge.com/gisalerts/</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	1	N/A	9.2.4	Public Safety Power Shutoff	Protocols for Mitigating the Public Safety Impacts of PSPS, Including Impacts on First Responders, Health Care Facilities, Operators of Telecommunications Infrastructure, and Water Electrical Corporations/Agencies
112	CaPA	Set WMP-12	CaPA_Set WMP-12	10	CaPA_Set WMP-12_010	<p>Regarding PSPS and its relationship with EPSS settings.</p> <p>a) Please describe the decision-making process for a situation in which PG&E anticipates PSPS conditions but decides to utilize EPSS settings instead.</p> <p>b) Please list all dates in 2021 and 2022 when PG&E anticipated PSPS conditions but utilized EPSS settings instead, if this occurred.</p> <p>c) Please provide a narrative of the decision-making process for any instances listed in part (b) above.</p> <p>d) Please describe how PG&E utilizes EPSS during a PSPS event period.</p>	<p>a) Enabling EPSS instead of executing PSPS is not part of the PSPS decision making process. EPSS operates independent of PSPS based on different criteria and thresholds - see Section 6.1.1 of PG&E's WMP.</p> <p>b) There were none as EPSS is not utilized instead of PSPS. Enabling EPSS instead of executing PSPS is not part of the PSPS decision making process. See response to (a) above.</p> <p>c) As explained in response to (a) since EPSS operates independent of PSPS there is no decision-making process to utilize EPSS instead of PSPS. Each program is based on different criteria and protocols, independent of each other.</p> <p>d) EPSS is enabled based on forecasted Fire Potential Index (FPI) criteria on an individual circuit level. If there are circuits adjacent to a PSPS polygon that meet EPSS enablement criteria - including non-EPSS buffer circuits within a Red Flag Warning or Fire Weather Watch footprint or meeting Minimum Fire Potential Conditions - those circuits will be EPSS enabled.</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	N/A	N/A	Public Safety Power Shutoff & Grid Operations and Procedures	N/A
113	CaPA	Set WMP-12	CaPA_Set WMP-12	11	CaPA_Set WMP-12_011	<p>Regarding communications to customers for EPSS:</p> <p>a) Does PG&E provide notifications or other communication to customers when EPSS settings are enabled? (This may include, but is not limited to, notifications that a customer is served by a circuit that is subject to EPSS settings, notifications that an unplanned outage may occur, notifications of expected restoration time when an EPSS outage has occurred, or all clear notifications when EPSS settings are de-activated.)</p> <p>b) If the answer to part (a) is yes, please describe PG&E's approach to notifying customers about EPSS settings.</p> <p>c) Please provide an example of a message sent to a customer for each situation in part (b).</p> <p>d) At what point (i.e., number of minutes/hours) prior to enabling EPSS settings does PG&E notify customers?</p> <p>e) At what point (i.e., number of minutes/hours) after the beginning of an outage triggered by EPSS settings does PG&E notify customers?</p> <p>f) At what point (i.e., number of minutes/hours) after the line is restored, after an outage triggered by EPSS settings, does PG&E notify customers?</p>	<p>a) We have self-serve options for customers and Public Safety Partners to determine if EPSS settings are enabled on the line serving their home or business. Unlike PSPS, because EPSS is not a planned de-energization, we do not proactively notify customers as daily enablement and disablement decisions are made.</p> <p>b) Our customer outreach and education process includes information about the EPSS program, the benefits, and general information about the High Fire Risk Areas protected by EPSS settings. Customers who experienced eight or more outages on EPSS enabled circuits in 2022 will be receiving an email or letter in mid-April about the EPSS program. The letter includes language that indicates that the line serving their home or business has EPSS capability and that there could be unplanned power outages (bold added for emphasis in this response).</p> <p>c) To help prevent wildfires, we are making the electric system safer and stronger for our customers. This includes safety settings on your powerlines known as Enhanced Powerline Safety Settings (EPSS). While these settings help keep you safe, you may experience unexpected power outages. We are working hard to improve reliability across our electric grid without sacrificing safety.</p> <p>d) Near real-time enablement status is available for County agencies and Public Safety Partners through PG&E's Outage Portal. We do not proactively notify customers directly as EPSS settings are enabled or disabled on a daily basis. However, the PG&E Outage Center on pge.com offers customers the option to search for their address. If EPSS settings are enabled, regardless of current outage status, a blue bar will appear at the top of the lookup indicating that EPSS settings are enabled. Please see "WMP_Discovery2023_DR_CalAdvocates_012-0011A0h01.pdf" for an example from 2022. The language is being updated for 2023 to more clearly indicate that the EPSS settings are currently enabled. This functionality is scheduled to be re-enabled in May 2023. Customers who have not previously opted out are sent an initial outage notification when the outage occurs, regardless of EPSS enablement status. Customers can choose to receive the message via phone call, text message and/or email.</p> <p>e) Customers may choose any combination of notification preference. This notification includes an estimated time of restoration (ETOR) whenever possible. Restoration updates are sent to customers whenever the ETOR is updated.</p> <p>f) The excerpt from the pressroom letter and screenshot from the address lookup are included in response b), above. Samples of the initial outage notifications for calls, text</p>	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	1	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
114	CaPA	Set WMP-13	CaPA_Set WMP-13	1	CaPA_Set WMP-13_01	<p>Figure PG&E's 1.4.2 on p. 259 of PG&E's WMP shows Down Conductor Detection (DCD) is implemented on 4-wire distribution.</p> <p>a) Does PG&E plan to primarily implement DCD on 4-wire distribution, 3-wire distribution, or a mix?</p> <p>b) Please state the number of overhead circuit miles of 4-wire distribution in PG&E's HFTD.</p> <p>c) Please state the number of overhead circuit miles of 3-wire distribution in PG&E's HFTD.</p>	<p>a) At this time, we plan to implement Down Conductor Detection (DCD) only on 3-wire distribution (or on overhead circuits without phase to neutral connected load downstream). PG&E will continue to explore the possibility of applying DCD to 4-wire multi-grounded systems in the future. Figure 1.4.2 incorrectly identified DCD applicable to 4-wire when it should have indicated 3-wire systems.</p> <p>b) As shown in Figure 7.1.4-2, the 3-wire multi-grounded overhead mileage is estimated to be 675 miles.</p> <p>c) As shown in Figure 7.1.4-2, the 3-wire overhead mileage is estimated to be 25.540 miles.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.1.2.10.1	Grid Design and System Hardening	Downed Conductor Detection Devices
115	CaPA	Set WMP-13	CaPA_Set WMP-13	2	CaPA_Set WMP-13_02	<p>Table 6-27 on p. 588 of PG&E's WMP summarizes grid operation monitoring systems, including Distribution Fault Anticipation (DFA) and Early Fault Detection (EFD).</p> <p>a) Describe the types of faults, equipment failures, and/or other issues that DFA is capable of detecting.</p> <p>b) Describe the types of faults, equipment failures, and/or other issues that EFD is capable of detecting.</p> <p>c) Describe the types of faults, equipment failures, and/or other issues that DFA is capable of detecting, but EFD is not capable of detecting.</p> <p>d) Describe the types of faults, equipment failures, and/or other issues that EFD is capable of detecting, but DFA is not capable of detecting.</p> <p>e) Is DFA capable of locating problematic or failing equipment? Please explain your response.</p> <p>f) Is EFD capable of locating problematic or failing equipment? Please explain your response.</p> <p>g) Please summarize the results PG&E has seen from its DFA installations to date.</p> <p>h) Please summarize the results PG&E has seen from its EFD installations to date.</p>	<p>a) Distribution Fault Anticipation (DFA) is designed to detect conditions that generate current and voltage anomalies including series arcing issues (below, splices, switches) and short arcing faults (tree sap, vegetation contact, wire down). It can also detect loss of load caused by broken conductors.</p> <p>b) Early Fault Detection (EFD) is designed to detect conditions that generate accumulation of Radio Frequency (RF) signal that are caused by partial discharge from equipment components including broken conductor strands, falling splices, broken/damaged/contaminated insulators, close vegetation, and falling windings in service transformers.</p> <p>c) DFA is capable of detecting issues in which events are short and of low repeat occurrences, which are not detected by EFD. DFA, unlike EFD, can also detect issues that are more evident in power quality data (current, voltage, power factor, and harmonics).</p> <p>d) EFD is capable of detecting issues which are very subtle and early within the future mode that are not detectable by DFA. Examples of these issues include broken conductor strands, falling insulators, vegetation near conductors, and transformer windings.</p> <p>e) DFA is capable of identifying issues in a circuit. It can locate issues when used in combination with faulted circuit impedance models and line sensors. SmartMeters in the future will be able to improve location accuracy. DFA is used to accurately classify the type of issue and the other tools (circuit impedance models, line sensors and SmartMeters) help reduce the issue area so that field investigators can be targeted to a small area.</p> <p>f) EFD is capable of locating issues with high accuracy, to within a span on mainline and large tapline sections directly covered by EFD (with sensors on both ends of segment).</p> <p>g) As of Dec 31, 2022, PG&E has 74 DFA devices deployed and is currently in the phase of Operational Development (pre-production). As a result of this work, the DFA system has been used to identify four arcing connections in underground equipment and detect one fault-induced conductor slap. Other use cases have not been fully developed.</p> <p>h) PG&E has EFD deployed on four circuits as of Dec 31, 2022, and the technology is still in the pilot phase. As a result of this work, PG&E has been able to detect 11 damaged conductors (frayed or bridged), two arcing fuses, and one broken insulator.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.3.3.1	Situational Awareness and Forecasting	Existing Systems, Technologies, and Procedures

116	CaPA	Set WMP-13	CaPA_Set WMP-13	3	CaPA_Set WMP-13_03	<p>Table 7.3-1 on p. 261 of PG&E's WMP states the following objective with an estimated completion date of 12/31/2023:</p> <p>Develop a process of centralizing constraints resolution. As part of the build out of the centralized constraints team, three major categories will be addressed: customer constraints, environmental constraints (including internal PG&E procedures required to perform work) and permitting constraints (including both Land and Environmental permits).</p> <p>a) Describe what is meant by the phrase "centralizing constraints resolution."</p> <p>b) Please describe the benefits PG&E anticipates from "centralizing constraints resolution."</p> <p>c) Please describe the process PG&E plans to take to centralize customer constraints.</p> <p>d) Please describe the process PG&E plans to take to centralize environmental constraints.</p> <p>e) Please describe the process PG&E plans to take to centralize permitting constraints.</p>	<p>a) Constraints Management Organization (CMO) was created to act as the responsible group for developing and managing processes for constraints resolution. Following the initial lessons learned from the Enhanced Vegetation Management (EVM) program, this team will be formalizing processes and procedures concerning how the various types of constraints that occur within the Vegetation Management (VM) department should be managed.</p> <p>b) In previous years, the Constraints Management Team (CMT) worked within the EVM program to improve our approach to addressing constraints. The team was focused on coordinating efforts with PG&E teams to work with local governments, agencies, and landowners to address permitting or access constraints that temporarily prevented or delayed work from being performed. The CMT was able to gather additional information regarding constraints, review data, and work with other internal teams to resolve permitting or property access issues. As a result, by the end of 2021 the CMT had successfully resolved approximately 350 miles of constrained work for the EVM program. Within the EVM program in 2022, 703 miles of constrained work were resolved, which represents an ~80% increase from the prior year.</p> <p>c) The CMT is in the process of updating our customer constraints processes by reviewing and updating procedures. In addition to this process, the CMT is also working with other customer focused groups within PG&E to request assistance with notifications if we are unable to contact the customer or if additional support is necessary. Beyond these steps, we are working to streamline our processes in an effort to reduce the time from work order creation to work order completion.</p> <p>d) The CMT is working as a point of contact between our VM Operations teams and our Environmental team to better track our environmentally sensitive work and ensure that review and release of work is occurring according to plan. The CMT is also evaluating the benefits of performing reviews of our environmental submittals before they are sent to PG&E's Environmental team to ensure all needed information is accurate and complete in an effort to streamline the process.</p> <p>e) The CMT has created a central email inbox where encroachment-type constraints can be submitted to the CMT for review. This work can be reviewed to see if existing encroachment permits would cover the planned work or if site-specific permits would be needed. The CMT can also assist in submitting for the site specific permits and working with other stakeholders on behalf of VM operational teams as needed.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.2.6	Vegetation Management and Inspections	Open Work Order
117	CaPA	Set WMP-13	CaPA_Set WMP-13	4	CaPA_Set WMP-13_04	<p>Table 7.3-1 on p. 262 of PG&E's WMP states the following objective with an estimated completion date of 12/31/2023:</p> <p>For each major constraint category build a process for addressing each constraint type, implement the new process, and create metrics to track each constraint type.</p> <p>a) When does PG&E expect to begin implementing its process for centralizing customer constraints?</p> <p>b) When does PG&E expect to begin implementing its process for centralizing environmental constraints?</p> <p>c) When does PG&E expect to begin implementing its process for centralizing permitting constraints?</p> <p>d) What is the earliest date PG&E expects to begin realizing benefits (e.g. reduced time to resolve constraints) as a result of the objective quoted above?</p> <p>e) Why does PG&E expect that it will take until December 2025 to achieve the objectives in the passage quoted above?</p> <p>f) Between now and December 2025, how is PG&E addressing each constraint type?</p>	<p>a) For some Vegetation Management (VM) programs within the VM department, the Constraints Management Team (CMT) will be implementing process improvements to the customer constraints process as early as Q2 of 2023.</p> <p>b) The CMT has already begun facilitating regular check-in meetings with our Environmental teams to discuss environmental permitting needs, discuss opportunities for process improvement, and to generally engage on upcoming work.</p> <p>c) The CMT has already begun to utilize a centralized email box for submitting encroachment-type permitting support. We expect to continue to review what could be best management practices and to look for process improvement opportunities with the process as it evolves.</p> <p>d) For some VM programs in 2023, we are already seeing benefits of the CMT in that as process improvement ideas are put into action and VM Operational teams are engaged early.</p> <p>e) The VM CMT will be integrating additional VM programs into our support model in the coming years and expect to achieve our objectives by December 2025.</p> <p>f) The CMT is working to better identify the various types of constraints that can affect VM's ability to complete needed work, to understand the current processes in place, to identify if process improvement opportunities exist, and to better create and track metrics for these constraints.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.2.6	Vegetation Management and Inspections	Open Work Order
118	CaPA	Set WMP-13	CaPA_Set WMP-13	5	CaPA_Set WMP-13_05	<p>Table 7.4 on pp. 307-313 of PG&E's WMP lists the top risk circuit segments (i.e., riskiest segments when sorted by total wildfire risk)</p> <p>a) Footnote b in the column entitled "Jan. 1, 2023 Overall Risk" states, "Accounts for risk reduction associated with EPSS." Please explain how PG&E quantified the risk reduction associated with EPSS for each of the circuit segments in Table 7.4.</p> <p>b) Do the values in the column entitled "Jan. 1, 2024 Overall Risk" account for risk reduction associated with EPSS?</p> <p>c) Do the values in the column entitled "Jan. 1, 2026 Overall Risk" account for risk reduction associated with EPSS?</p> <p>d) Do the values in the column entitled "Jan. 1, 2026 Overall Risk" account for risk reduction associated with EPSS?</p> <p>e) Please supplement Table 7.4 with the following additional columns: i. Forecast SANDI in 2023 if EPSS were not utilized; Forecast SANDI in 2023 with EPSS.</p>	<p>a) Yes, a deductive sensitivity analysis was performed to determine the possible effect of these values on the output of PG&E's WFC model. Please see our response to part b) for an explanation of our deductive analysis.</p> <p>b) For points within High Fire Risk Areas (HFRA) (or non-HFRA), there is only a single variable that determines the consequences, which is the fraction of days that a location or point spends in predicted destructive or non-destructive conditions. There are no other dependencies. Only the ordinality in the predicted destructive fraction of days matters to the overall consequence ranking of points within the HFRA (or within the non-HFRA). Changing thresholds (i.e. flame length, rate of spread) to determine predicted destructive conditions did not substantially alter the ordinality of the points by fraction of predicted destructive days, therefore rankings within HFRA (or within the non-HFRA) would not change much.</p> <p>Additionally, we evaluated whether changing predicted destructive values could result in HFRA locations or points dropping below the consequence ranking of locations or points not in the HFRA. The CoRE from Mean MAFV of Historic Fire values for HFRA (True) categories in table PG&E 6.2.2-1 are at least 3 orders of magnitude larger than any of the CoRE MAFV values for the non-HFRA (False) categories. Based on our analysis, we determined that changes to consequence beyond 1 order of magnitude were not likely. Therefore, in order for changes to result in significant consequence rank shifts, the category values represented in Table PG&E 6.2.2-1 would need to be much closer.</p> <p>c) N/A, please see the responses to subparts a) and b).</p> <p>d) N/A, please see the responses to subparts a) and b).</p>	Holly Wehman	4/6/2023	4/28/2023			7.2.2.3	Risk Mitigation Strategy Devic	Projected Risk Reduction on Highest-Risk Circuits Over the 3-Year WMP Cycle	
119	CaPA	Set WMP-13	CaPA_Set WMP-13	6	CaPA_Set WMP-13_06	<p>Table PG&E 6.2.2-1 on p. 168 of PG&E's WMP lists four consequence values derived from the mean MAFV of historical fires.</p> <p>a) Has PG&E performed a sensitivity study to determine the effect of these values on the output of PG&E's WFC model? A sensitivity analysis could involve (for example) perturbations in how the mean MAFV of historical fires is calculated, or which historical fires are included in the calculation.</p> <p>b) If the answer to part (a) is yes, please summarize the results of this sensitivity study. c) If the answer to part (a) is no, please explain why not. d) If the answer to part (a) is no, does PG&E plan to perform a study or analysis similar to what is described in part (a)?</p>	<p>a) Yes, a deductive sensitivity analysis was performed to determine the possible effect of these values on the output of PG&E's WFC model. Please see our response to part b) for an explanation of our deductive analysis.</p> <p>b) For points within High Fire Risk Areas (HFRA) (or non-HFRA), there is only a single variable that determines the consequences, which is the fraction of days that a location or point spends in predicted destructive or non-destructive conditions. There are no other dependencies. Only the ordinality in the predicted destructive fraction of days matters to the overall consequence ranking of points within the HFRA (or within the non-HFRA). Changing thresholds (i.e. flame length, rate of spread) to determine predicted destructive conditions did not substantially alter the ordinality of the points by fraction of predicted destructive days, therefore rankings within HFRA (or within the non-HFRA) would not change much.</p> <p>Additionally, we evaluated whether changing predicted destructive values could result in HFRA locations or points dropping below the consequence ranking of locations or points not in the HFRA. The CoRE from Mean MAFV of Historic Fire values for HFRA (True) categories in table PG&E 6.2.2-1 are at least 3 orders of magnitude larger than any of the CoRE MAFV values for the non-HFRA (False) categories. Based on our analysis, we determined that changes to consequence beyond 1 order of magnitude were not likely. Therefore, in order for changes to result in significant consequence rank shifts, the category values represented in Table PG&E 6.2.2-1 would need to be much closer.</p> <p>c) N/A, please see the responses to subparts a) and b).</p> <p>d) N/A, please see the responses to subparts a) and b).</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	6.2.2.2	Risk Methodology and Assessment	Consequence
120	CaPA	Set WMP-13	CaPA_Set WMP-13	7	CaPA_Set WMP-13_07	<p>In section 7.2.1 on pp. 275-276 of PG&E's WMP, PG&E states, "We determined that EPSS is more effective at mitigating wildfire risk at a lower cost as shown by comparing the RSEs for the two programs: at the time we filed the 2023 GRC, the RSE for EVM was 14.5 compared to the EPSS RSE of 102."</p> <p>a) Other than RSE, what other criteria did PG&E evaluate in the decision to move away from EVM?</p> <p>b) EPSS is a reactive mitigation program in contrast to EVM which is proactive. Does this reactive vs. proactive characterization have any impact on PG&E's decision to transition away from EVM?</p> <p>c) How does PG&E's RSE estimate for EPSS take into account the negative reliability impacts on customers?</p>	<p>a) There were several factors that we considered when deciding between the mitigation programs Enhanced Powerline Safety Settings (EPSS) and Enhanced Vegetation Management (EVM). Besides mitigation effectiveness and implementation and operating costs described by the Risk Spend Efficiency (RSE), we considered the faster pace of implementing EPSS compared to EVM, which results in faster risk reduction. The ability to expand EPSS across all circuits in the High Fire Threat Districts (HFTD), High Fire Risk Area (HFRA), and specific buffer areas quickly provides more immediate and ongoing operational mitigation benefits when compared to the individual miles of EVM scope executed each year.</p> <p>b) Our objective is to evaluate the effectiveness of minimizing catastrophic wildfires, regardless of whether mitigations are reactive or proactive. In fact, we do not use the labels "proactive" and "reactive" to categorize these mitigations. EPSS is better suited for managing overall risk because it more effectively mitigates multiple drivers of failure that could lead to an ignifer, which ultimately reduces the chance of an ignition propagating into a catastrophic wildfire.</p> <p>c) The negative reliability impact to customers is captured as part of the Failure of Distribution Overhead asset risk. These impacts are detailed in A. 21-04-01, Exhibit PG&E-A. Ca. letter 3, Figure 3-2 (below) in which PG&E showed the risk reduction of wildfire risk along with the relative impacts of reliability.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	7.2.1	Risk Mitigation Strategy Devic	Overview of Mitigation Initiatives and Activities
121	CaPA	Set WMP-13	CaPA_Set WMP-13	8	CaPA_Set WMP-13_08	<p>For each of the following programs, what metrics does PG&E track to validate their impact and effectiveness at mitigating the impacts of PSPS events?</p> <p>a) Temporary Distribution Microgrids</p> <p>b) Community Microgrid Enablement Program</p> <p>c) Microgrid Incentive Program</p>	<p>a) We track Megawatts (MW), customers mitigated, and the number of outages per location each season to validate the impact and effectiveness of Temporary Distribution Microgrids.</p> <p>b) We track at minimum the frequency and duration of the microgrid's usage, along with the number of benefiting customer locations.</p> <p>c) Please see our response to subpart (b).</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.1.2.7	Grid Design and System Hardening	Microgrids
122	CaPA	Set WMP-13	CaPA_Set WMP-13	9	CaPA_Set WMP-13_09	<p>Do the following programs have any impact on customer reliability (e.g., frequency or duration of outages) in general? Please explain your response for each program.</p> <p>a) Temporary Distribution Microgrids</p> <p>b) Community Microgrid Enablement Program</p> <p>c) Microgrid Incentive Program</p>	<p>a) Distribution microgrids are designed to power communities' central corridors, or "Main Streets," to help safely provide electricity to critical facilities and shared community resources and reduce the number of customers impacted by PSPS. In general, customers being served by a temporary distribution microgrid will experience two brief outages, one as the microgrid is connected and one when the microgrid is disconnected after the PSPS outage.</p> <p>b) The Community Microgrid Enablement Program and Microgrid Incentive Programs are designed to have a positive impact on customer resiliency. The community microgrids developed through each program can reduce the duration of outages by providing energy within the microgrid during a broader grid outage.</p> <p>c) Please see our response to subpart (b).</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	8.1.2.7	Grid Design and System Hardening	Microgrids
123	CaPA	Set WMP-13	CaPA_Set WMP-13	10	CaPA_Set WMP-13_010	<p>Figure 7.1 on p. 268 shows a sharp decline in risk after 2026.</p> <p>a) Please provide context as to what drives this decline.</p> <p>b) Why does PG&E anticipate a significantly more rapid rate of decline in residual risk after 2026 than in the 2023-2026 period?</p>	<p>a) The context for this sharper decline in risk after 2026 represents the expected, continued ramp-up of undergrounding miles to be installed each year.</p> <p>b) The more rapid rate of decline in residual risk after 2026 is due to the increase of the number of undergrounding miles expected to be installed each year that are focused on the highest risk (top 20%) circuit segments, in which the benefits of undergrounding are cumulative over time. See section 8.1.2.2, specifically table 8.1.2-3, which shows the current undergrounding portfolio increasingly addresses the top 20 percent risk-ranked circuit segments so that by 2025, 95 percent of the portfolio addresses the top risk, and in 2026, almost 100 percent of the targeted annual undergrounding miles are focused on the top risk. Note that all current fire rebuild projects are anticipated to complete before 2026. Future wildfires, or any cause, damage or destroy distribution overhead facilities and the decision is made to rebuild underground, this would impact the project portfolio in the relevant year(s) after such a fire.</p>	Holly Wehman	4/6/2023	4/12/2023	4/12/2023	0	N/A	7.2.2.1	Risk Mitigation Strategy Devic	Projected Overall Risk Reduction

124	CaPA	Set WMP-14	CaPA_Set WMP-14	1	CaPA_Set WMP-14_01	<p>P. 347 of PG&E's WMP states (regarding PG&E's undergrounding program), "Among other benefits, the reduced pace (as compared to prior projections) will decrease costs in the initial years of the program." Please list the "other benefits" referenced in the quote above.</p>	<p>There are also additional benefits to reducing the near-term undergrounding mileage targets, including providing more time to drive process improvements that may reduce long term costs and drive long term efficiency of the program.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
125	CaPA	Set WMP-14	CaPA_Set WMP-14	2	CaPA_Set WMP-14_02	<p>P. 347 of PG&E's WMP states (regarding PG&E's undergrounding program), "Among other benefits, the reduced pace (as compared to prior projections) will decrease costs in the initial years of the program." Please list the "other benefits" referenced in the quote above.</p>	<p>ANSWER 002 a) No. DTS-FAST does not have the capability to re-energize a line. Currently, DTS FAST is monitoring only, and is not automatically sending the trip (de-energize) signal to operators until the system has more testing to ensure accuracy. b) DTS-FAST sensor data will report alarm conditions in real time. For example, if vegetation has fallen into the alarm zone and remains (i.e., leaning on the conductor line), the alarm will remain. However, if the vegetation falls away from the alarm zone, then the alarm will clear. Regardless, we will use the video cameras to validate the alarm and take appropriate actions. c) DTS-FAST does not have the capability to re-energize a line, but it will provide data to operators of sensor alarm statuses. In addition, DTS-FAST cameras will provide remote visual awareness of the alarm location. d) We do not currently have enough field data to draw formal conclusions about reliability impacts, but our goal is to ensure the DTS-FAST sensors report accurate wildfire risks with no false alarms.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.6.1	Grid Design and System Hardening	Distribution, Transmission, and Substation Fire Action Schemes and Technology
126	CaPA	Set WMP-14	CaPA_Set WMP-14	3	CaPA_Set WMP-14_03	<p>P. 350 of PG&E's WMP discusses Breakaway Connectors, and states, "The breakaway disconnect uses a weak link to provide a predictable point of separation and the service will then fall to the ground de-energized." a) What is the maximum wind speed that Breakaway Connectors can handle without separating? b) Have PG&E studied whether conditions exist that could cause a temporary fault and minimal or no damage to a non-breakaway connection, but would cause a Breakaway Connector to separate? For example, a small branch falling on the line. c) If the answer to part (a) is yes, please provide any results of such studies? d) If the answer to part (b) is no, does PG&E plan to perform such a study? e) What reliability impacts does PG&E forecast from Breakaway Connector installation? f) Please quantify the ignition risk associated with a Breakaway Connector separating. If this risk has not been quantified, describe the ignition risk in qualitative terms. g) Do Breakaway Connectors increase the likelihood of an EPSS-induced outage? Please explain your answer. h) If the answer to part (g) is yes, please quantify the increased likelihood of an EPSS-induced outage on circuits where Breakaway Connectors are installed.</p>	<p>a) Maximum wind speed is not easily defined. Span length, tension, conductor size and wind direction all influence the maximum wind speed. General Order 95 rule 49.4 Table 8 and 49.4-C3 require Supply service drops to have a minimum strength of 66 soft or annealed copper. This is 478.8 pounds. The service breakaway has two available weak links 500 lbs. for services 75' and shorter. 750 pounds for services longer than 75 feet and up to 150 feet. The pilot location for the service breakaway has experienced three storms with winds exceeding 100 mph with no breakage of the weak links (both links are 750 lbs. due to span length). b) Yes, we have studied these issues. c) Two limp strikes were observed with limbs weighing 125 lbs. and 200 lbs., respectively. No damage was found, and the weak links did not activate. d) Not applicable. Please see the response to part (b) above. e) We do not expect any reliability impacts. f) No ignition risk is expected by the service breakaway activating. Our tests showed no spark from the breakaway activating at the rated ampereage of the conductor. The conductor will fail before the service breakaway. g) EPSS is not affected by secondary conductors. It is primary voltage only. h) Not applicable, please see the response to part (g) above.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.6.2	Grid Design and System Hardening	Breakaway Connector
127	CaPA	Set WMP-14	CaPA_Set WMP-14	4	CaPA_Set WMP-14_04	<p>P. 359 of PG&E's WMP states, "Breakaway disconnect does not impact PPSR Risk." Please state the basis for the above quote.</p>	<p>Breakaway disconnects are used to prevent energized wire down to minimize ignition risk. At this point in time, the presence of breakaway disconnects is not included in PPSR scoring decisions, therefore, breakaway disconnects do not impact the PPSR risk.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.6.2	Grid Design and System Hardening	Breakaway Connector
128	CaPA	Set WMP-14	CaPA_Set WMP-14	5	CaPA_Set WMP-14_05	<p>P. 363 of PG&E's WMP states, "Temporary distribution microgrids are designed to support community resilience and reduce the number of customers impacted by PPS by engaging 'main street corridors' with clusters of shared services and critical facilities so that those resources can continue serving surrounding residents during PPS events." a) Please list the temporary distribution microgrids that PG&E had available in 2020, 2021, and 2022 to mitigate the effect of a possible PPS event. b) For each temporary distribution microgrid listed in part (a), state the number of times the temporary distribution microgrid was used in 2020, 2021, and 2022 to mitigate the effects of a PPS event. c) For each instance in part (b), list the number of customers that remained energized during a PPS event. d) How does PG&E determine what locations would warrant deployment of a temporary distribution microgrid? e) How does PG&E determine when to deploy a temporary distribution microgrid? f) How does PG&E determine when to remove a deployed temporary distribution microgrid?</p>	<p>a-c) Responses are summarized in the tables below, by year: 2020: Temporary Distribution Microgrid available to operate in 2020 Number of 2020 PPS events supported Approx. # of service pts energized per 2020 PPS event Shingletown 479 Caltoga 3 104 Placerville (temporary configuration without a pre installed interconnection hub) 1 487 Chualar North (temporary configuration without a pre installed interconnection hub) 0 n/a 2021: Temporary Distribution Microgrid available to operate in 2021 Number of 2021 PPS events supported Approx. # of service pts energized per 2021 PPS event Angren 1 48 Shingletown 1 83 Caltoga 1 156 Magalia 1 83 Georgetown 0 n/a Pulaski Pines 0 n/a ForestHill 0 n/a</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.7.2	Grid Design and System Hardening	Temporary Distribution Microgrids
129	CaPA	Set WMP-14	CaPA_Set WMP-14	6	CaPA_Set WMP-14_06	<p>P. 365 of PG&E's WMP states, "The Redwood Coast Airport Redwood (RCAM) was built through a California Energy Commission (EC) grant to the Schatz Energy Center and loan from United States of America to the Redwood Coast Energy Authority (a Community Choice Aggregator), in collaboration with PG&E's EPIC 3.11, "Multi-Use Microgrid," project." a) What was the total cost of the RCAM project? b) Please provide disaggregated costs associated with the RCAM fulfilled in whole or in part by the California Energy Commission EPIC grant, loan(s) from the United States of America, and any other distinct funding sources.</p>	<p>a) PG&E's total costs for the RCAM project were approximately \$3.3MM. PG&E does not have direct financials of our project partners. Please contact Schatz Energy Research Center at Cal-Poly Humboldt and Redwood Coast Energy Authority for details on their total project cost and funding sources. b) Of PG&E's total project costs, i. \$3,088,000 was funded through CE's EPIC grant (EPIC 3.11, Multi-Use Microgrid), ii. \$224,140 in cost offsets were provided to the Redwood Coast Energy Authority pursuant to the Community Microgrid Enablement Program (CMEP) (D 20-065017). ii. PG&E received no loans from the United States of America nor any other funding sources for this project.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.7.3	Grid Design and System Hardening	Community Microgrid Enablement Program and Microgrid Incentive Program
130	CaPA	Set WMP-14	CaPA_Set WMP-14	7	CaPA_Set WMP-14_07	<p>P. 366 of PG&E's WMP states, "The successful deployment of RCAM provides a model for other communities for collaborative development of multi-customer microgrids for energy resilience." a) How does PG&E determine the success of the RCAM? b) Please provide data to support the success of the RCAM.</p>	<p>Attachments to this data response contain CONFIDENTIAL information provided pursuant to the Non-Disclosure Agreement in this proceeding. a) Prior to the start of the Project, PG&E defined the following metrics to calculate the full deployment benefits at RCAM: 1. Increase reliability at critical facilities - Post-deployment measurements of outage number, frequency and duration reductions. Below is a summary of the "RCAM Islanding Events" log current as of 4/17/2023. In addition to the frequency and duration of RCAM islanding events which were not a result of Jones Creek 1103 de-energizing and therefore require fine-tuning of the protection scheme configurations that make up the microgrid. These "Nuisance Events" do not impact customer experience or service quality. Nevertheless, PG&E is researching how to reduce the metric. 2. Successful operation of the microgrid in island mode will illustrate resilience benefits which can be scaled to energize wildfire resilience zones during Public Safety Power Shutoff. The microgrid has performed as expected since it has been placed in operation, providing over 37 hours of incremental resilience to support critical regional infrastructure and (re)wiring activities at the Redwood Coast Airport and U.S. Coast Guard Air Station. Notable islanding events have been in response to a 6.4 magnitude Earthquake on December 20th that hit 39 miles south of the RCAM site and multiple islanding events as a result of a sequence of storms in January and February of this year. We are attaching the after-event retrospective of the Earthquake WMP-Discovery2023_DR_CalAdvocates_014-Q007&AD10CONF.pdf and a presentation PG&E gave to Energy Division on February 6th describing RCAM's performance across a variety of hazards WMP-Discovery2023_DR_CalAdvocates_014-Q007&AD2023.pdf. 3. ATS Power-Hardwire-in-the-Loop (PHL) testing facilities are now capable of verification testing of 3rd party microgrid controllers and DER equipment for compatibility/stability under various microgrid operational schemes. ATS constructed a microgrid testbed facility and completed PHL Testing for the RCAM project which verified and validated the SEL-3005 microgrid controller (remote after equipment) and validated the operational safety and performance.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	4	N/A	8.1.2.7.3	Grid Design and System Hardening	Community Microgrid Enablement Program and Microgrid Incentive Program
131	CaPA	Set WMP-14	CaPA_Set WMP-14	8	CaPA_Set WMP-14_08	<p>P. 368 of PG&E's WMP states, "For 2023, we have planned to install devices that will provide significant reliability benefits on five tap lines that are in the scope of EPSS." a) Please quantify the "significant reliability benefits" that will be provided from devices installed in 2023. b) Please provide any available workpapers or studies to support your response to part (a).</p>	<p>a) Significant reliability benefits are projected at 18,000 CEISO savings and 14,618 resident customer minutes. During EPSS enablement, upstream protective devices are required to see faults beyond fuses to provide a gang trip of all three phases upon a fault condition. This practice nullifies the benefits of traditional line fuse protection. With these additional protective devices installed, protection granularity and corresponding reliability impact can be returned to the tapline or more downstream location where the new protective devices are replacing fuses. As an additional non-EPSS benefit, these devices can also function as traditional reclosers outside of EPSS enablement thereby reducing the occurrence of isolated outages through reclosing. b) Historical outage data was obtained for thousands of existing fuses on EPSS circuits. Outage data was used to prioritize existing fuses and their effect on reliability. Fuses are then replaced with SCADA operable Fuse Savers and Reclosers to realize the reliability benefits outlined in all of this response. No work paper has been prepared in connection with this reliability benefit calculation.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/page_aloha/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.2.8.1	Grid Design and System Hardening	Installation of System Automation Equipment - Distribution Protective Devices

132	CaPA	Set WMP-14	CaPA_Set WMP-14	9	CaPA_Set WMP-14_O9	P. 386 of PG&E's WMP states that it will perform a "Substation Animal Abatement Effectiveness Study" in 2023. When does PG&E expect to begin the Substation Animal Abatement Effectiveness Study? When does PG&E expect to complete the Substation Animal Abatement Effectiveness Study?	a) The study was officially kicked off on January 26, 2023. The "P51" team at Electric Power Research Institute (EPRI) was provided with PG&E historical animal catch records, existing and historical animal abatement strategies employed by PG&E, and other pertinent information needed to perform the study. b) The study is expected to conclude by July 18, 2023.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.2.12.2	Grid Design and System Hardening	Other Technologies and Systems - Substation Animal Abatement
133	CaPA	Set WMP-14	CaPA_Set WMP-14	10	CaPA_Set WMP-14_O10	P. 383 of PG&E's WMP states, "In 2022 PG&E implemented relocations made to TD-2205, which incorporated industry best practices as well as adjusted the pole rejection criteria." Please list the adjustments that PG&E made to the pole rejection criteria.	Please see our current procedure TD-2205P-01 for the requested information: https://www.pge.com/page_global/common/pdfs/safety/emergency_preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.3.1.5	Asset Inspections	Intrusive Pole Inspection
134	CaPA	Set WMP-14	CaPA_Set WMP-14	11	CaPA_Set WMP-14_O11	P. 400 of PG&E's WMP states, "PG&E designated pilot maps as extreme, severe, high, medium, or low based on the average wildfire consequence of the structures within that pilot map." a) Is the designation described above based on the wildfire consequence scores from the WDRM v2 or the WDRM v3? b) How frequently does PG&E plan to re-evaluate the pilot map designations described above? c) When PG&E re-evaluates the pilot map designations, what steps will it take regarding a pilot map that has increased in severity, such as from high to severe or severe to extreme?	a) The quote referenced above is based on the wildfire consequence scores from the WDRM v3. b) We plan to review wildfire risk model results annually and evaluate how to update the inspection plan accordingly. c) After we review risk model results each year, we will evaluate whether the plan needs to be adjusted. Updates to the plan may include reassigning a pilot map to a different consequence level or adding individual structures to the inspection plan to account for increased risk or consequence.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.3.2.1	Asset Inspections	Detailed Ground Inspection
135	CaPA	Set WMP-14	CaPA_Set WMP-14	12	CaPA_Set WMP-14_O12	Table PG&E-8.1.7.4 on p. 458 of PG&E's WMP shows that PG&E added 41,869 distribution work orders to its HFTD/HFRA backlog in 2022. a) What measures has PG&E implemented to ensure that it will be able to reduce its backlog in 2023 by closing more tags than it opens? b) What factors may prevent PG&E from reaching its targets regarding backlog reduction in 2023? c) For each factor in part (b), what measures has PG&E taken to mitigate the risk that this factor will prevent PG&E from reducing its backlog in 2023?	a) In order to ensure we will continue to reduce our backlog of asset tags, as of January 1, 2023, all new HFTD/HFRA tags will be completed by the compliance date. Thus, these tags will be in a "steady state" where the population is no longer growing. In addition to this work, we will continue with the plan set out in our 2022 and 2023 WMPs where we target the HFTD/HFRA tags in our backlog with the highest risk, eliminating first our "non-pole ignition risk tags" then our "pole ignition risk tags," and finally our "non-ignition risk tags." However, while we can forecast the number of new tags that we create every year based on historical data, there are circumstances outside our control, which we identify in the WMP as "External Factors," which may prevent us from being able to close more tags than were opened in a particular year. An excellent example of these types of External Factors would be the unprecedented storms that occurred this winter, and which have substantially delayed some of our inspection work. While we currently forecast being able to get back on course before the end of the year, any future External Factors might prevent us from being able to close more tags than we opened and irreversibly delay the work this year. b) As explained in our response WMP-Discovery2023_CalAdvocates_010-Q012, and on page 83 of our 2022 WMP, External Factors represent reasonable circumstances which may impact execution against targets, objectives, other work, or performance metrics including, but not limited to, physical conditions, landholder refusals, environmental delays, customer refusals or non-contacts, permitting delays/restrictions, weather conditions, removed or destroyed assets, active wildfires, exceptions or exemptions to regulatory/utility requirements, and other safety considerations. c) As explained in our response WMP-Discovery2023_CalAdvocates_010-Q012, to mitigate the impacts of physical conditions, we work with our leadership and industry leaders to create solutions specifically tailored to the individual situation. However, despite these efforts, there are times where we must simply accept the removal of the external physical condition in order to proceed with work as there is no other reasonable alternative.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.7.2	Open Work Orders	Open Work Orders - Distribution Tags
136	CaPA	Set WMP-14	CaPA_Set WMP-14	13	CaPA_Set WMP-14_O13	P. 463 of PG&E's WMP states, "EPSS does not cause a power outage." Given that EPSS settings can de-energize a line without prior warning, and without an apparent cause, please explain what is meant by the above quote.	Enhanced Powerline Safety Settings (EPSS) enable capable protective devices on a circuit to operate in 0.1 seconds or less in order to de-energize and isolate affected portions of our distribution system when a fault or abnormal condition is detected that could generate a spark and subsequent wildfire ignition as well as detecting higher impedance faults. Outages that occur when EPSS settings are enabled on protection devices are unplanned and only occur when an external event occurs on the distribution line causing a fault on the circuit. Stated another way, EPSS does not cause outages but rather outages may result from a line being quickly de-energized when a tree, vegetation or other foreign debris makes contact with the EPSS-enabled line. Unknown cause outages – or "outages without an apparent cause" – also occur without EPSS enabled. This does not mean there was not an actual fault condition present. Note that in 2022 PG&E reported 104 of 2,375 EPSS outages as "Company Initiated." In these limited instances, devices can trip as a result of switching, in-rush current (e.g., a pump or heavy machinery starting up), or other utility operations while EPSS is enabled. In these instances the outage is reported as "Company Initiated" and our protection engineers will review the EPSS settings, coordinate with customers, and/or coordinate with the Distribution Control Center to identify design setting adjustments or other corrective actions as appropriate and technically feasible.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
137	CaPA	Set WMP-14	CaPA_Set WMP-14	14	CaPA_Set WMP-14_O14	Per PG&E's January 2023 EPSS monthly report, PG&E experienced 2,375 EPSS outages in 2022. a) Of the EPSS-triggered outages in 2022, in how many of these outages did PG&E find that no corrective actions were required prior to re-energizing (i.e., there was no persistent condition that PG&E needed to resolve upon inspecting the location of the outage)? b) Were there any EPSS-triggered outages in 2022 that PG&E determined were triggered by events that did not pose an ignition risk? c) If the answer to part (b) is yes, how many such EPSS-triggered outages occurred in 2022?	a) PG&E reported 1,083 unknown cause outages in 2022. Note that while this is indicative that a conclusive corrective action was not identified during the outage period and restoration process, it is not indicative of no ignition risk. Our focus during outage patrols and restoration is to restore power as soon as it is safe to do so for our customers and communities. b) Outages that occurred as a result of planned switching or from in-rush current (e.g. a pump or heavy machinery start up) are examples of outages that do not present an ignition risk. c) There were 108 of these outages in 2022.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
138	CaPA	Set WMP-14	CaPA_Set WMP-14	15	CaPA_Set WMP-14_O15	P. 465 of PG&E's WMP states, "In 2022, we expanded the scope of EPSS to all HFRA in our service territory and select adjacent EPSS buffer areas." a) In 2022, did PG&E expand the scope of EPSS to all HFRA and all HFTD? b) If PG&E did not expand the scope of EPSS to all HFTD in 2022, please state the basis for this decision. c) In 2023, will the scope of EPSS cover all HFRA and all HFTD? d) If the answer to part (c) is no, please state the basis for this decision.	a) EPSS availability was extended to 100% of HFRA in 2022. 100% of HFTD was not targeted. b) PG&E's HFRA map is a purpose-built map to inform the Public Safety Power Shutoff (PSPS) and EPSS sooping process by identifying areas in PG&E's service area where overhead electrical infrastructure could be the source of an ignition that results in a catastrophic wildfire and accordingly, is used for EPSS sooping. The processes P&E used to develop the HFRA were described in PG&E's 2021 and 2022 WMPs. See PG&E's 2021 WMP (June 3, 2021), starting at page 85, and PG&E's 2022 WMP (Feb. 28, 2022), starting at page 75. c) In 2023 EPSS will target 100% of HFRA and select HFRA-adjacent areas, referred to as EPSS Buffer Areas. HFTD is not targeted. d) Please see response to Question 15.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
139	CaPA	Set WMP-14	CaPA_Set WMP-14	16	CaPA_Set WMP-14_O16	Cal Advocates understands that a circuit segment that has been undergrounded may still experience PSPS outages, if segments upstream or downstream of the undergrounded circuit segment are subject to PSPS. a) Is the above understanding correct? If not, please correct the above. b) During the 2023-2025 WMP period, does PG&E intend to utilize temporary microgrids or other mitigations to fully eliminate the risk of a PSPS event de-energizing undergrounded lines? c) If the answer to part (b) is no, please explain why not. d) If the answer to part (b) is yes, please describe PG&E's plans.	a) Yes, that statement is correct. While it is unlikely that a downstream segment would affect the undergrounded section, it is possible if there are no available downstream isolation devices. b) In cases where undergrounding segments are affected by upstream overhead segments, mitigations such as Temp Microgrids may be placed to bring the undergrounded section from scope. However, it may not be feasible to utilize temporary microgrids due to resource constraints, and/or rapid changing weather conditions. c) See response to b). d) See response to b).	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	9.1.5	Public Safety Power Shutoff	Performance Metrics Identified by the Electrical Corporation
140	CaPA	Set WMP-14	CaPA_Set WMP-14	17	CaPA_Set WMP-14_O17	a) Has PG&E performed a study or back cast to predict the likelihood that an undergrounded segment will be subject to PSPS de-energizations due to upstream or downstream segments becoming subject to PSPS? b) If the answer to part (a) is yes, please provide the results of any such studies. c) If the answer to part (a) is no, please explain why not.	a) No, we have not performed a study or back cast mentioned in the question. b) See response to a). c) Predicting likelihood of an undergrounded segment being subject to PSPS is possible but would take significant manual effort. However, back cast weather-to-date would result in a catastrophic wildfire and accordingly, is used for EPSS sooping. For underground work.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	9.1.5	Public Safety Power Shutoff	Performance Metrics Identified by the Electrical Corporation
141	CaPA	Set WMP-14	CaPA_Set WMP-14	18	CaPA_Set WMP-14_O18	a) Has PG&E performed a study or back cast to predict the likelihood that an undergrounded segment will be subject to an EPSS-triggered de-energization due to upstream or downstream segments becoming subject to EPSS? b) If the answer to part (a) is yes, please provide the results of any such studies. c) If the answer to part (a) is no, please explain why not.	a) We have not performed this type of study. b) Not applicable. Please see the response to subpart a). c) PG&E has not yet performed this type of study because the volume of mileage that has been placed underground is relatively small. The analysis would need to be circuit specific. For this type of study to be more meaningful, a greater number of underground miles would need to be analyzed. It is also important to note that undergrounding occurs on targeted line segments, which often means that other portions of the same circuit remain overhead and would require the protection of EPSS applied to the entire line segment, not just the undergrounded portion.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
142	CaPA	Set WMP-14	CaPA_Set WMP-14	19	CaPA_Set WMP-14_O19	Please provide a list of all dip-in incidents that occurred from 2020-2022 and involved an underground electric distribution line. For each incident, please provide: a) Date of the incident b) Whether the dip-in was caused by PG&E employees, PG&E contractors, or a third-party c) Duration of the resulting outage, if applicable d) Fatalities associated with the dip-in, if any e) Injuries associated with the dip-in, if any f) Damage to non-PG&E structures associated with the dip-in, if any	a) We have not performed this type of study.	Holly Wehman	4/11/2023	4/28/2023		0	8.4.2.1	Emergency Preparedness Plan	Overview of Wildfire and PSPS Emergency Preparedness	
143	CaPA	Set WMP-14	CaPA_Set WMP-14	20	CaPA_Set WMP-14_O20	a) During the period from 2020-2022, did PG&E replace any distribution poles as part of its WMP activities for which PG&E had not fully recovered the original cost of the poles? b) If the answer to part (a) is yes, what was PG&E's practice regarding cost recovery on the unrecovered portion of the value associated with the replaced poles? c) If the answer to part (a) is yes, please provide the number of such poles that PG&E replaced.	(a) - (c) We cannot provide the requested data. Our asset registry and work execution systems are not set up to enable this cross-referenced data consolidation and we do not track the volume of assets replaced that have not been fully recovered.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.2.3	Grid Design and System Hardening	Distribution Pole Replacements and Reinforcements
144	CaPA	Set WMP-14	CaPA_Set WMP-14	21	CaPA_Set WMP-14_O21	a) During the period from 2020-2022, did PG&E replace any distribution conductor as part of its WMP activities for which PG&E had not fully recovered the original cost of the conductor? b) If the answer to part (a) is yes, what was PG&E's practice regarding cost recovery on the unrecovered portion of the value associated with the replaced conductor? c) If the answer to part (a) is yes, please provide the number of circuit miles of such conductor that PG&E replaced.	(a) - (c) We cannot provide the requested data. PG&E's asset registry and work execution systems are not set up to enable this cross-referenced data consolidation and we do not track the volume of assets replaced that have not been fully recovered.	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	0	N/A	8.1.2.5.2	Grid Design and System Hardening	Traditional Overhead Hardening - Distribution

145	CaPA	Set WMP-14	CaPA_Set WMP-14	22	CaPA_Set WMP-14_Q022	<p>a) During the period from 2020-2022, did PG&E replace any distribution transformers as part of its WMP activities for which PG&E had not fully recovered the original cost of the transformer?</p> <p>b) If the answer to part (a) is yes, what was PG&E's practice regarding cost recovery on the unrecovered portion of the expense associated with the replaced transformer?</p> <p>c) If the answer to part (a) is yes, please provide the number of such transformers that PG&E replaced.</p> <p>d) In 2022, how many ignitions did PG&E experience related to overhead covered conductor distribution lines?</p> <p>e) In 2022, how many ignitions did PG&E experience related to overhead bare conductor distribution lines?</p> <p>f) In 2022, how many ignitions did PG&E experience related to underground distribution lines?</p> <p>g) In 2022, how many ignitions did PG&E experience related to overhead secondary distribution lines?</p> <p>h) In 2022, how many ignitions did PG&E experience related to overhead service lines?</p>	<p>a) - (c) We cannot provide the requested data. Our asset registry and work execution systems are not set up to enable this cross-reference data consolidation and we do not track the volume of assets replaced that have not been fully recovered.</p> <p>d) In 2022, PG&E observed 1 CPUC reportable ignition where the equipment type associated with the ignition was insulated distribution primary overhead conductor.</p> <p>e) In 2022, PG&E observed 183 CPUC reportable ignitions where the equipment type associated with the ignition was bare distribution primary overhead conductor.</p> <p>f) In 2022, PG&E observed 1 CPUC reportable ignition where the equipment type associated with the ignition was underground conductor.</p> <p>g) In 2022, PG&E observed 44 CPUC reportable ignitions associated with overhead secondary facilities.</p> <p>h) In 2022, PG&E observed 54 CPUC reportable ignitions associated with overhead distribution service facilities.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	8.1.4.11	Grid Design and System Hardening	Transformers
146	CaPA	Set WMP-14	CaPA_Set WMP-14	23	CaPA_Set WMP-14_Q023	<p>a) Please see "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01.pdf" for the requested information.</p> <p>b) The specific referenced non-compliances were with General Order (GO) 95, Rules 12.2 and 44.3. Please see page 1 of "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01".</p> <p>c) The specific referenced condition is when both the remaining strength of the pole and the loading on the pole results in a calculated safety factor below the replacement value specified in rule 44.3. An example of this is described in "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01.pdf" starting on page 1.</p> <p>d) "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01.pdf" pages 3-4 includes the immediate risk remediation and longer-term corrective actions.</p> <p>e) List the corrective actions PG&E has implemented to remediate the non-compliances described in its self-report.</p>	<p>a) Please see "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01.pdf" for the requested information.</p> <p>b) 213 out of the 950 poles sampled (22%) did not have evidence of intrusive inspections within the compliance timeframe. Please see pages 2 through 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>c) The legacy issues referenced include eliminating the issues identified with "No Pole" or "Visual Only" records where these inspections were not properly meeting the General Order requirements. Please see pages 1 through 2 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf" for additional details.</p> <p>d) The changes in utility procedure include removing procedure 102-2029-01 to eliminate the option to complete Pole Test & Treat (PT&T) inspections based only on visual inspections. Please see page 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>e) The corrective actions implemented to remediate these issues include those identified in response to Question 25, subpart (c) as well as those listed on pages 3 through 4 of attachment WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-08 – Addressing Increase in Risk Events
147	CaPA	Set WMP-14	CaPA_Set WMP-14	24	CaPA_Set WMP-14_Q024	<p>P. 88 of PG&E's 2022 Joint Annual Report to Shareholders states: On October 26, 2022, the Utility notified the CPUC that the Utility's procedure for wood pole replacements did not comply with CPUC requirements for replacement of poles under certain conditions and, accordingly, in some instances, the Utility failed to replace wood poles with safety factors below the required minimum 5.</p> <p>a) Please provide a copy of the October 26, 2022 self-report referenced above.</p> <p>b) List the specific non-compliances referenced in the statement, "the Utility's procedure for wood pole replacements did not comply with CPUC requirements for replacement of poles under certain conditions."</p> <p>c) List the specific conditions referenced in the statement, "the Utility's procedure for wood pole replacements did not comply with CPUC requirements for replacement of poles under certain conditions."</p> <p>d) List the corrective actions PG&E has implemented to remediate the non-compliances described in its self-report.</p>	<p>a) Please see "WMP-Discovery2023_DR_CalAdvocates_014-Q025Ach01.pdf" for the requested information.</p> <p>b) 213 out of the 950 poles sampled (22%) did not have evidence of intrusive inspections within the compliance timeframe. Please see pages 2 through 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>c) The legacy issues referenced include eliminating the issues identified with "No Pole" or "Visual Only" records where these inspections were not properly meeting the General Order requirements. Please see pages 1 through 2 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf" for additional details.</p> <p>d) The changes in utility procedure include removing procedure 102-2029-01 to eliminate the option to complete Pole Test & Treat (PT&T) inspections based only on visual inspections. Please see page 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>e) The corrective actions implemented to remediate these issues include those identified in response to Question 25, subpart (c) as well as those listed on pages 3 through 4 of attachment WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-08 – Addressing Increase in Risk Events
148	CaPA	Set WMP-14	CaPA_Set WMP-14	25	CaPA_Set WMP-14_Q025	<p>P. 89 of PG&E's 2022 Joint Annual Report to Shareholders states: On December 22, 2022, the Utility submitted an update to the CPUC explaining the Utility had identified a population of wood poles that had not received intrusive inspections in accordance with GO 165's deadlines due to legacy issues, which should no longer be an issue due to changes in Utility procedures.</p> <p>a) Please provide a copy of the December 22, 2022 update referenced above.</p> <p>b) Describe the population of wood poles that had not received intrusive inspections in accordance with GO 165, referenced in the quote above.</p> <p>c) Describe the "legacy issues" referenced in the quote above.</p> <p>d) The changes in utility procedures" referenced in the quote above.</p> <p>e) List the corrective actions PG&E has implemented to remediate the issues described in its update to the CPUC.</p>	<p>a) Please see "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf" for the requested information.</p> <p>b) 213 out of the 950 poles sampled (22%) did not have evidence of intrusive inspections within the compliance timeframe. Please see pages 2 through 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>c) The legacy issues referenced include eliminating the issues identified with "No Pole" or "Visual Only" records where these inspections were not properly meeting the General Order requirements. Please see pages 1 through 2 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf" for additional details.</p> <p>d) The changes in utility procedure include removing procedure 102-2029-01 to eliminate the option to complete Pole Test & Treat (PT&T) inspections based only on visual inspections. Please see page 3 of "WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf".</p> <p>e) The corrective actions implemented to remediate these issues include those identified in response to Question 25, subpart (c) as well as those listed on pages 3 through 4 of attachment WMP-Discovery2023_DR_CalAdvocates_014-Q026Ach01.pdf.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	1	N/A	8.1.2.3	Grid Design and System Hardening	Distribution Pole Replacements and Reinforcements
149	CaPA	Set WMP-14	CaPA_Set WMP-14	26	CaPA_Set WMP-14_Q026	<p>PG&E states in response to Question 1 (b) of CalAdvocates-PGE-2023WMP-08: PG&E will maintain clearances where EVM work occurred. PG&E will also be prescribing a minimum radial clearance of 12 feet throughout the system within HFTD and HFRA. Two new programs, Vegetation Management for Operational Mitigation (VMOM) and Focused Tree Inspection, are likely to result in individual trees that warrant enhanced clearance where EVM was not implemented. These programs inform clearances based on available outage data and trends, as well as site and tree specific conditions. While not called out as a uniform scope, clearances in portions of these targeted circuit segments may have similarities to EVM.</p> <p>a) Are the abovementioned two new programs (Vegetation Management for Operational Mitigation and Focused Tree Inspections) to take place through PG&E's system, as opposed to just in the HFTD or HFRA?</p> <p>b) Please describe the circumstances in which an individual tree would warrant enhanced clearance under the Vegetation Management for Operational Mitigation program.</p> <p>c) Please describe the circumstances in which an individual tree would warrant enhanced clearance under the Focused Tree Inspections program.</p> <p>d) Please describe how each of the two new programs "inform clearances based on available outage data and trends, as well as site and tree specific conditions".</p>	<p>a) Vegetation Management for Operational Mitigation (VMOM) will be primarily focused in HFTD and HFRA. There are instances where a circuit segment may cross in or out of HFTD/HRFA and VMOM would complete work on the whole circuit segment including the areas outside HFTD/HRFA. Focused Tree Inspections are planned for HFTD areas in the plan developed for 2023.</p> <p>b) Enhanced clearances under the VMOM may be warranted under a variety of circumstances because the driver for outages can vary by region. Examples include but are not limited to:</p> <ol style="list-style-type: none"> 1. A tree identified under the Extent of Conditions patrol as having defects where enhanced clearances are needed to avoid tree-line conflicts. 2. A scenario where larger overhang clearance will be prudent to avoid limb or branch failure towards the line. 3. A tree where under regional tree failure patterns based on historical outage data and local knowledge, such as sudden oak death in the California Coastal areas. <p>4. A tree identified because of site specific conditions such as wind exposure, erosion concerns, or other environmental factors.</p> <p>c) The Focused Tree Inspection program will require inspection by Tree Risk Assessment Qualification (TRAQ) inspectors utilizing the Basic Tree Assessment Form as needed. Enhanced clearances may be required if the assessment identifies potential for tree-line conflicts. Circumstances where this would lead to enhanced clearances include, but are not limited to, when trimming work needed will result in more than 30% of the canopy being removed, making tree removal a better overall mitigation due to potential tree health impacts, and when lean or other structural defects of an otherwise healthy green tree has potential to strike assets.</p> <p>d) For the FTI pilots please refer to response provided for CalAdvocates_015-Q-012 a and b for details on how outage data and trends inform inspections. The TRAQ certified Arborists are expected to determine appropriate clearances based on this knowledge in addition to their evaluation of site-specific tree conditions. For VMOM, historical outage data and is being utilized to develop regional inspection criteria based on species composition and failure patterns. The VMOM extent of condition patrols start by evaluating the tree that caused the outage and then patrolling 5 spans in all directions looking for additional trees that may exhibit similar site and Outage clearance consistent with GO 95 Rule 30 at the time-of-firm recommendations in the HFTD may often require enhanced clearance beyond those recommendations to address tree conditions, the overall impacts of pruning to tree health, may compel tree removal, which can be interpreted as enhanced clearance. As a methodology, the goal is to mitigate identified problematic tree conditions between inspection cycles and obtaining 2-3 years of clearance whenever possible with landowner cooperation, permitting and other regulatory requirements. With this methodology we work the whole tree or portion of trees to mitigate potential impact to facilities.</p>	Holly Wehman	4/11/2023	4/17/2023	4/17/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_014.zip	1	N/A	8.1.2.3	Grid Design and System Hardening	Distribution Pole Replacements and Reinforcements
150	CaPA	Set WMP-15	CaPA_Set WMP-15	1	CaPA_Set WMP-15_Q01	<p>PG&E states in response to Question 1 (c) of CalAdvocates-PGE-2023WMP-08 that its strategy for determining desired clearance distances going forward will be "Minimum of 12 feet of clearance or enough clearance to mitigate potential impacts to facilities if tree (whole or portion of) failure were to occur."</p> <p>Please describe PG&E's planned methodology for determining sufficient clearance to mitigate clearance impacts in the event of tree failure as mentioned above.</p>	<p>a) As a program being performed in addition to Routine VM, the objective of FTI is not based on a uniform or regional clearance specification or a "desired clearance". Outage analysis and data is intended to help inform the Vegetation Management Inspector (VMI) to identify which species and failure types are increasing localized outage trends. For example, this information can help determine if overhanging branch failure is a problematic local trend. In that situation, targeted tree removal would be considered based on site and tree response characteristics. To the contrary, if overhanging data is not a local trend, targeted tree removal, targeting overhang elimination or reduction may not yield as effective results as other forms of vegetation work. The completion of regional pilots is intended to help address how PG&E will guide the program moving forward.</p> <p>b) Yes, that is correct.</p> <p>c) MDR is tied to all conductor clearance based on regulations in California, including GO 95 Rule 35 and PRC 4293.</p> <p>d) N/A.</p> <p>e) VM EPSS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where EPSS-VM Outages took place.</p> <p>f) Historical VM outage data was used to identify CPZs where recurring VM outages took place.</p> <p>g) Customer outage impact data was used to identify customers who experienced more frequent outages.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_015.zip	0	N/A	8.2.2.2.6	Vegetation Management and Inspections	Discontinued Programs
151	CaPA	Set WMP-15	CaPA_Set WMP-15	2	CaPA_Set WMP-15_Q02	<p>PG&E states in response to Question 2 (b) of CalAdvocates-PGE-2023WMP-08: "Two new programs, Vegetation for Operational Mitigation (VMOM) and Focus Tree Inspections (FTI) will identify new trees for the sort of work identified in this [tree] inventory. Additionally, if any newly trees are discovered while completing the FTI sort of work, they would be listed for work consistent with all other VM programs."</p> <p>Please describe how PG&E intends to track trees identified for work under VMOM and FTI.</p> <p>PG&E states in its response to Question 1 (c)(ii) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on analysis of outage data and trends by AOC. Additionally, any tree which is within MDR, will be within the MDR before next work completion cycle or is showing signs of imminent failure before next work completion cycle."</p> <p>a) Please provide how PG&E will determine desired clearance distances using analysis of outage data and trends by AOC.</p> <p>b) Does "MDR" stand for "Minimum Distance Requirement" in this instance? Please define if not.</p> <p>c) If yes, is the "Minimum Distance Requirement" referred to here from General Order 95, or from PG&E's internal procedures?</p> <p>d) If no, please reference which procedure PG&E is utilizing.</p>	<p>a) As a program being performed in addition to Routine VM, the objective of FTI is not based on a uniform or regional clearance specification or a "desired clearance". Outage analysis and data is intended to help inform the Vegetation Management Inspector (VMI) to identify which species and failure types are increasing localized outage trends. For example, this information can help determine if overhanging branch failure is a problematic local trend. In that situation, targeted tree removal would be considered based on site and tree response characteristics. To the contrary, if overhanging data is not a local trend, targeted tree removal, targeting overhang elimination or reduction may not yield as effective results as other forms of vegetation work. The completion of regional pilots is intended to help address how PG&E will guide the program moving forward.</p> <p>b) Yes, that is correct.</p> <p>c) MDR is tied to all conductor clearance based on regulations in California, including GO 95 Rule 35 and PRC 4293.</p> <p>d) N/A.</p> <p>e) VM EPSS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where EPSS-VM Outages took place.</p> <p>f) Historical VM outage data was used to identify CPZs where recurring VM outages took place.</p> <p>g) Customer outage impact data was used to identify customers who experienced more frequent outages.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_015.zip	0	N/A	8.2.2.2.8	Vegetation Management and Inspections	Discontinued Programs
152	CaPA	Set WMP-15	CaPA_Set WMP-15	3	CaPA_Set WMP-15_Q03	<p>PG&E states in its response to Question 2 (b) of CalAdvocates-PGE-2023WMP-08: "Two new programs, Vegetation for Operational Mitigation (VMOM) and Focus Tree Inspections (FTI) will identify new trees for the sort of work identified in this [tree] inventory. Additionally, if any newly trees are discovered while completing the FTI sort of work, they would be listed for work consistent with all other VM programs."</p> <p>Please describe how PG&E intends to track trees identified for work under VMOM and FTI.</p> <p>PG&E states in its response to Question 1 (c)(ii) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on analysis of outage data and trends by AOC. Additionally, any tree which is within MDR, will be within the MDR before next work completion cycle or is showing signs of imminent failure before next work completion cycle."</p> <p>a) Please provide how PG&E will determine desired clearance distances using analysis of outage data and trends by AOC.</p> <p>b) Does "MDR" stand for "Minimum Distance Requirement" in this instance? Please define if not.</p> <p>c) If yes, is the "Minimum Distance Requirement" referred to here from General Order 95, or from PG&E's internal procedures?</p> <p>d) If no, please reference which procedure PG&E is utilizing.</p>	<p>a) As a program being performed in addition to Routine VM, the objective of FTI is not based on a uniform or regional clearance specification or a "desired clearance". Outage analysis and data is intended to help inform the Vegetation Management Inspector (VMI) to identify which species and failure types are increasing localized outage trends. For example, this information can help determine if overhanging branch failure is a problematic local trend. In that situation, targeted tree removal would be considered based on site and tree response characteristics. To the contrary, if overhanging data is not a local trend, targeted tree removal, targeting overhang elimination or reduction may not yield as effective results as other forms of vegetation work. The completion of regional pilots is intended to help address how PG&E will guide the program moving forward.</p> <p>b) Yes, that is correct.</p> <p>c) MDR is tied to all conductor clearance based on regulations in California, including GO 95 Rule 35 and PRC 4293.</p> <p>d) N/A.</p> <p>e) VM EPSS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where EPSS-VM Outages took place.</p> <p>f) Historical VM outage data was used to identify CPZs where recurring VM outages took place.</p> <p>g) Customer outage impact data was used to identify customers who experienced more frequent outages.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_015.zip	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
153	CaPA	Set WMP-15	CaPA_Set WMP-15	4	CaPA_Set WMP-15_Q04	<p>PG&E states in its response to Question 2 (c) of CalAdvocates-PGE-2023WMP-08 that it "utilized VM EPSS-enabled outage data, historical VM outage data, and customer outage impact data" in devising the VMOM scope of work.</p> <p>a) Please describe how PG&E has utilized each of the following data types in devising the VMOM scope of work: i. VM EPSS-enabled outage data ii. Historical VM outage data iii. Customer outage impact data</p>	<p>a) As a program being performed in addition to Routine VM, the objective of FTI is not based on a uniform or regional clearance specification or a "desired clearance". Outage analysis and data is intended to help inform the Vegetation Management Inspector (VMI) to identify which species and failure types are increasing localized outage trends. For example, this information can help determine if overhanging branch failure is a problematic local trend. In that situation, targeted tree removal would be considered based on site and tree response characteristics. To the contrary, if overhanging data is not a local trend, targeted tree removal, targeting overhang elimination or reduction may not yield as effective results as other forms of vegetation work. The completion of regional pilots is intended to help address how PG&E will guide the program moving forward.</p> <p>b) Yes, that is correct.</p> <p>c) MDR is tied to all conductor clearance based on regulations in California, including GO 95 Rule 35 and PRC 4293.</p> <p>d) N/A.</p> <p>e) VM EPSS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where EPSS-VM Outages took place.</p> <p>f) Historical VM outage data was used to identify CPZs where recurring VM outages took place.</p> <p>g) Customer outage impact data was used to identify customers who experienced more frequent outages.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_015.zip	0	N/A	8.2.2.2.6	Vegetation Management and Inspections	Discontinued Programs
154	CaPA	Set WMP-15	CaPA_Set WMP-15	5	CaPA_Set WMP-15_Q05	<p>PG&E states in its response to Question 2 (c) of CalAdvocates-PGE-2023WMP-08 that it "utilized VM EPSS-enabled outage data, historical VM outage data, and customer outage impact data" in devising the VMOM scope of work.</p> <p>a) Please describe how PG&E has utilized each of the following data types in devising the VMOM scope of work: i. VM EPSS-enabled outage data ii. Historical VM outage data iii. Customer outage impact data</p>	<p>a) As a program being performed in addition to Routine VM, the objective of FTI is not based on a uniform or regional clearance specification or a "desired clearance". Outage analysis and data is intended to help inform the Vegetation Management Inspector (VMI) to identify which species and failure types are increasing localized outage trends. For example, this information can help determine if overhanging branch failure is a problematic local trend. In that situation, targeted tree removal would be considered based on site and tree response characteristics. To the contrary, if overhanging data is not a local trend, targeted tree removal, targeting overhang elimination or reduction may not yield as effective results as other forms of vegetation work. The completion of regional pilots is intended to help address how PG&E will guide the program moving forward.</p> <p>b) Yes, that is correct.</p> <p>c) MDR is tied to all conductor clearance based on regulations in California, including GO 95 Rule 35 and PRC 4293.</p> <p>d) N/A.</p> <p>e) VM EPSS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where EPSS-VM Outages took place.</p> <p>f) Historical VM outage data was used to identify CPZs where recurring VM outages took place.</p> <p>g) Customer outage impact data was used to identify customers who experienced more frequent outages.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	https://www.pge.com/pge_global/common/pdfs/efity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_015.zip	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory

155	CaPA	Set WMP-15	CaPA_Set WMP-15	6	CaPA_Set WMP-15_06	<p>PG&E states in its response to Question 2 (c) of CalAdvocates-PGE-2023WMP-08 that:</p> <p>For FTI Areas of Concern (AOCs) we identified through a cross-functional effort utilizing county-based regional reviews to create polygons which are geographic areas. Initial polygon development utilized WDRM3 consequence scores. Public Safety Specialist circuit-based evaluations, expertise, 30-year lookback of meteorology data, and analysis, identified PSPS Lookback Polygons, PSPS Vegetation Damage Locations, vegetation caused ignition data, and vegetation caused outage data. The process is intended to be performed annually to identify where trends, models, or emerging available data indicated higher likelihood of tree caused damage or outages.</p> <p>i) Please explain how the following types of data will be utilized in developing AOC polygons for the FTI scope of work:</p> <p>i) WDRM3 consequence scores</p> <p>ii) Public Safety Specialist circuit-based evaluations and expertise</p> <p>iii) 30-year lookback of meteorology data and analysis</p> <p>iv) Identified PSPS Lookback Polygons</p> <p>v) PSPS Vegetation Damage Locations</p> <p>vi) Vegetation caused ignition data</p> <p>vii) Vegetation caused outage data.</p> <p>viii) Please define and describe "PSPS Lookback Polygons".</p> <p>ix) What is the threshold of "likelihood of tree caused damage or outages" at which a particular location is determined to be an AOC?</p>	<p>a) WDRM3 Consequence scores aided in quality checking the AOC polygons. Adding this to the process resulted in adding two additional AOC polygons containing 52 circuit miles. WDRM3 was also used to rank and prioritize the AOC into the transects.</p> <p>i. Public Safety Specialist (PSS) circuit-based risk assessments were not specifically developed to identify vegetation risks but often aligned the outage cluster data also utilized for the project. When string alignment existed between circuit PSS ranked very high to severe and overlapped with other VM specific outage, ignition, or PSPS damage data an AOC polygon was developed. If a PSS very high to severe circuit ranking conflicted or did not align with other VM specific data or expertise, AOC polygons were not developed.</p> <p>ii. 30-year meteorology re-analysis data was provided to the AOC Development team to understand historical Diablo wind and PSPS-VP conditions at the regional level. This was additional context and utilized on a limited basis to develop AOC polygons. At the recommendation of the Meteorology Team it was determined that the PSPS Lookback Polygons described in iv. were a better catalyst for use in AOC development.</p> <p>iii. PSPS Lookback polygons consolidated all geographic areas impacted by PSPS 2018-2021. When there strongly aligned with other VM specific outage, ignition and PSPS damage data, AOC polygons were developed.</p> <p>v. PSPS asset damage attributed to vegetation was utilized to further inform AOC polygon development. AOC development methodology was specific to prioritizing work for Vegetation Management to reduce tree caused outages and ignitions.</p> <p>vi. Vegetation Caused ignition data 2018-2021 was consolidated into buffered clusters by frequency. This data was further filtered for winter season and summer season. Outages were used as a proxy for potential ignitions. This was considered a strong predictive contributing dataset based on the assumption that areas experiencing higher frequency of historical outages were more likely to experience future outages without additional mitigation.</p> <p>b) Please see response a) iv.</p> <p>c) No predetermined thresholds were created to develop AOCs for 2023. This effort was intended to blend localized knowledge and best available data to identify areas that could be evaluated against existing models. This is a new process intended to improve situational awareness.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
156	CaPA	Set WMP-15	CaPA_Set WMP-15	7	CaPA_Set WMP-15_07	<p>PG&E states in its response to Question 2 (h) of CalAdvocates-PGE-2023WMP-08 that "The Tree Inventory Program" is planned to last 9 years in Question 9 (i) of CalAdvocates-PGE-2023WMP-08, it provides a pace for the next three years of 15,000 trees in 2023, 20,000 trees in 2024, and 25,000 trees in 2025.</p> <p>i) Please explain why PG&E is forecasting it will take 9 years to work down its previously identified tree inventory.</p> <p>ii) Please state the basis for the abovementioned pace of work up to the year 2025.</p> <p>iii) Does PG&E have current goals or targets for the program past the year 2025?</p> <p>iv) If not, please state such goals or targets.</p> <p>v) Please describe, based on the currently available knowledge, the ignition risk posed by the tree inventory.</p> <p>vi) If PG&E had not discontinued EVM at the end of 2022, how long would the EVM program have taken to work down its current tree inventory?</p>	<p>a) The pace was provided for the first three years of the program with intent to ramp up to annual pace. 9 years is a starting point to plan the pace for program completion (lower level lessons learned will inform the completion timing).</p> <p>b) We anticipate that there will be opportunities in the initial years of the program for lessons learned regarding safety, efficiency, and coordination with other system hardening actions, so the program has been designed to ramp up over the first three years.</p> <p>c) The goals for 2025 and beyond are not yet determined. The program and lessons learned in the first three years will inform goals for 2025 and beyond.</p> <p>d) No. We do not have the explicit ignition risk posed by the tree inventory. However, based on the WDRM v3 weighted vegetation trunk risk total, vegetation trunk risk represents an ignition risk score of 4,088 (448 WDRM v3 risk points). "Enterprises (Wetfire MAWF calculation factor 11.41). This tree inventory is identified to reduce the ignition risk driven by vegetation trunk failure.</p> <p>e) It is difficult to predict how long the inventory would have taken to work down if the program persisted since new work would be continually added while working down existing inventory. As long as the program persisted the inventory would likely have continued due to ongoing addition and completion of trees.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory
157	CaPA	Set WMP-15	CaPA_Set WMP-15	8	CaPA_Set WMP-15_08	<p>PG&E states in its response to Question 3 (h) of CalAdvocates-PGE-2023WMP-08 that "The Wetfire Data Risk Model (WDRM v3) was utilized to prioritize nine CPZs for the VMOM program."</p> <p>i) Please provide the CPZs that were prioritized for the VMOM program.</p> <p>ii) How was the WDRM v3 model utilized in prioritizing the nine CPZs?</p> <p>iii) What risk threshold, or other criteria, was used in prioritizing the nine CPZs?</p>	<p>a) Narrow 21052828 Morgan Hill 211149388 Lauretes 1112020 Tempeston 211058160 Big Basin 11010720 Seward 21052828 Bellevue 21052822 Panorama 11021342 Green Valley 21018920</p> <p>b) The WDRM v3 model includes a trunk failure component, which was used to identify the prioritization of work along with the miles to be patrolled.</p> <p>c) Please see our response to Question 8b).</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.3	Vegetation Management and Inspections	VM for Operational Mitigations
158	CaPA	Set WMP-15	CaPA_Set WMP-15	9	CaPA_Set WMP-15_09	<p>PG&E states in its response to Question 3 (j) of CalAdvocates-PGE-2023WMP-08 that "PG&E will utilize EPSS Outage Extent of Condition (EOC) patterns to identify and generate additional tree work throughout the year. Additionally, EPSS outage data will be utilized in the scope of work development for the following year."</p> <p>i) Please describe the time frame or other when PG&E would plan to complete the additional tree work that is generated throughout the year.</p>	<p>The additional tree work that is generated throughout the year will be worked according to normal VM program timelines.</p> <p>If vegetation is determined to be an immediate risk to PG&E facilities, described as a Priority 1 in the VM Priority Tag Procedure, the condition will be mitigated within 24 hours of identification as long as conditions are safe for the crew to proceed with work. Priority 2 tags are issued for vegetation that is within Minimum Distance Requirement (MDR) to the electric lines and will be mitigated within 20 business days.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.3	Vegetation Management and Inspections	VM for Operational Mitigations
159	CaPA	Set WMP-15	CaPA_Set WMP-15	10	CaPA_Set WMP-15_10	<p>PG&E states in its response to Question 4 (e) of CalAdvocates-PGE-2023WMP-08 that "Pilot AOCs are prioritized using WDRM3. The four pilot AOCs selected for 2023 incorporated additional reviews from the VM Execution Operational Team to select appropriate regional areas to inform the program development."</p> <p>i) Please describe how the Pilot AOCs were prioritized using WDRM3.</p> <p>ii) Did reviews from the VM Execution Operational team change the WDRM3-generated prioritization? If so please describe how.</p>	<p>a) WDRM3 vegetation scores were aggregated at the AOC level for each circuit segment within AOC polygon boundaries. The resulting WDRM3 aggregated scores were averaged AOC level, leading to a ranking which was used to prioritize AOCs. The pilot AOCs were selected among the top 25 ranked AOCs. Pilot AOC selection process is described in response b).</p> <p>b) The four pilot areas are all selected from the highest ranked tranches as prioritized by WDRM3. These tranches had ranked values from 1-25. After review from VM Execution AOCs ranked 2 (Napa County) 3 (Butte County) 8 (El Dorado County) and 15 (Calaveras County) were selected for pilots. While these selections do not directly follow a 1-n WDRM3 ranking they align as top model prioritized rankings and meet the goal to pilot in regions with different vegetation types to support broader program development business requirements, processes and potential variations in execution.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
160	CaPA	Set WMP-15	CaPA_Set WMP-15	11	CaPA_Set WMP-15_11	<p>PG&E states in its response to Question 4 (g)(i) of CalAdvocates-PGE-2023WMP-08 that the scope of work for Focused Tree Inspection pilots is to:</p> <p>Complete a focused tree inspection pilot project of ~300 OH line miles in 2023 to calibrate processes and optimize efficiencies. Inspectors will utilize Tree Risk Assessment Questionnaire (TRAQ) Certified Arborists. Tree mitigations will be determined as necessary based on site and individual tree conditions. Pilots will begin in Q2 2023 and are intended to inform detailed SOJ during the regional implementations.</p> <p>i) How was the initial scope of 300 OH line miles determined?</p> <p>ii) Please list and describe the criteria PG&E will utilize to determine tree mitigations "as necessary" within the above-detailed scope of work and within the FTI program.</p> <p>iii) Please define the term "regional implementations" in the above information.</p> <p>iv) Please clarify whether the scope referenced above is 300 line miles or 300 circuit miles. Cal Advocates understands "line mile" to typically refer to actual miles of conductor, such that one circuit mile of a three-phase circuit would be approximately three line miles.</p>	<p>a) With a goal to identify regionally variable AOCs to pilot the initial program the four AOCs were selected (See response to Question 10b). The 300 miles represents approximately 10% of the overall prioritized AOCs available for 2023 and is intended to yield the learnings needed to support and inform future work plans.</p> <p>Certified Arborists with the additional TRAQ certification can implement industry best standards and guidance to identify, evaluate, perform appropriate inspection level(s) and prescribe work for the trees that require mitigation to reduce outage risks between inspection cycles.</p> <p>b) PG&E's territory is regionally diverse and composed of variable forest and stand conditions in proximity to assets. It is anticipated that the listing practices and clearance types and prescriptions will vary between distinct regions and forest types. For example, mitigations that are acceptable and effective in the Sierra Nevada Mountain Range are expected to be different in Coastal Zone and Coastal Forest areas and varied oak-woodland and mixed conifer foothill systems.</p> <p>c) This program will measure based on circuit line miles. One-mile will equal one-mile, regardless of the single or three-phase configurations.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
161	CaPA	Set WMP-15	CaPA_Set WMP-15	12	CaPA_Set WMP-15_12	<p>PG&E states in its response to Question 4 (h)(i) of CalAdvocates-PGE-2023WMP-08 that "While inspection tools and data collection are expected to be standardized it is anticipated that more regional guidance will utilize historical outage data to help us identify problematic tree species and failure modes and site conditions to support focused inspection decisions and prescriptions."</p> <p>a) Does "more regional guidance" mean guidance specific to each Area of Concern that will be developed after the pilots are complete? Please specify if not.</p> <p>b) If yes, please explain and provide relevant examples of how guidance would differ between AOCs.</p>	<p>a) The following clarifications are to provide more detail on what "more regional guidance" is intended to accomplish. Guidance associated with tools utilized and data collected are expected to be standardized for the FTI program in all AOCs during the initial pilots. The outage, species and tree failure details available for each AOC will vary and are expected to be reviewed prior to starting pilots. The data is situational awareness, some of which may be unique within an AOC but does not alter the guidance to have each span inspected by a TRAQ certified Arborist. Learnings from the pilot will better inform a unique regional guidelines can improve the program and standardize its execution. Examples of regional factors that could impact regional guidance include Coastal Zone Areas and Timberlands where California Forest Practices Regulations apply. In areas such as these, there may be limitations or restrictions to what trees or portions of trees can be mitigated based on the regional factors, environmental restrictions, Limited Operating Periods, etc.</p> <p>b) For the AOC polygons, regional guidance is a data-informed review prior to inspections. Each AOC is subject to deep-dive analysis of historical outages and overlap with other past or future WMP mitigations and treatments. This data informed approach is localized and will help the TRAQ certified inspectors better understand the types of tree failures and species profiles that can provide insights and inform their site and tree specific evaluations and prescriptions. This approach is intended to foster greater overall situational awareness.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
162	CaPA	Set WMP-15	CaPA_Set WMP-15	13	CaPA_Set WMP-15_13	<p>PG&E states in its response to Question 4 (k) of CalAdvocates-PGE-2023WMP-08 that "Pass or Fail criteria is not anticipated for the FTI program. FTI will use TRAQ Certified Arborists to perform inspections and prescribe work based on site and tree specific conditions. Some trees will be trimmed and other will be removed to address associated risk between inspection cycles."</p> <p>Please provide all criteria that PG&E will employ to determine tree trimming and removal, including the abovementioned "and tree specific conditions".</p>	<p>Level 1 inspections are to be performed during patrols. Site specific and tree specific conditions will help inspectors determine when Level 2 inspections are needed to determine if a tree needs to be completely removed or trimmed to mitigate risks between inspection cycles in the AOC. Guidance provided in the California Power Line Fire Prevention Field Guide, "HAZARD TREE/VEGETATION CLEARANCE", notes that "inspections should be performed at the appropriate level of inspection. Please see https://aim.nrel.gov/wp-content/uploads/2021/10/power-line-fire-prevention-field-guide-fm-fj_202105.pdf.</p> <p>The TRAQ Certified Arborists will utilize the Basic Tree Risk Assessment Form when performing a level 2 inspection to document the site and tree specific conditions that are relevant to the inspection. See attachment WMP Discovery2023_DR_CalAdvocates_015-0013462901 to review the Basic Tree Risk Assessment Form.</p>	Holly Wehman	4/11/2023	4/14/2023	4/14/2023	1	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections

163	CaPA	Set WMP-15	CaPA_Set WMP-15	14	CaPA_Set WMP-15_014	<p>PG&E states in its response to Question 6 (f) of CalAdvocates-PGE-2023WMP-08 that: "PG&E has performed lab testing which has shown DCO is able to detect and de-energize downed conductors reducing ignition risk where installed."</p> <p>a) Please describe the methods, scope, and findings of the above-mentioned lab testing.</p> <p>b) Please provide any documents generated from the above-mentioned lab testing, including reports, etc.</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	1	N/A	8.2.3.4	Vegetation Management and Inspections	Fail-in Mitigation
164	CaPA	Set WMP-15	CaPA_Set WMP-15	15	CaPA_Set WMP-15_015	<p>PG&E states in its response to Question 12 of CalAdvocates-PGE-2023WMP-08 that: "Should a program fall below a 90% pass rate, catch back plans will be developed in partnership with VM execution to mitigate for specific cause of deficient rate."</p> <p>Please describe the nature of the above-mentioned "catch back plans."</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.5	Vegetation Management and Inspections	Quality Assurance/Quality Control
165	CaPA	Set WMP-15	CaPA_Set WMP-15	16	CaPA_Set WMP-15_016	<p>PG&E states in its response to Question 13 (parts a, b, and c) of CalAdvocates-PGE-2023WMP-08 that: "Improved quality verticals have been established for 2023, allowing for greater insight into overall VM work product throughput and risk identification/mitigation. Clear definitions of acceptance criteria, sampling methodology, population eligibility, and pass rate calculations were established and communicated across the VM organization prior to beginning 2023 audits."</p> <p>a) Please define the term "improved quality verticals."</p> <p>b) Please list and describe the "improved quality verticals" that have been established for 2023.</p> <p>c) Please describe the "greater insight into overall VM work product throughput and risk identification/mitigation" that was provided by the improved quality verticals.</p> <p>d) Please provide the definitions of the following terms that "were established and communicated across the VM organization prior to beginning 2023 audits":</p> <ol style="list-style-type: none"> Acceptance criteria Sampling methodology Population eligibility Pass rate calculations 	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.5.1	Vegetation Management and Inspections	Quality Assurance and Quality Verification
166	CaPA	Set WMP-15	CaPA_Set WMP-15	17	CaPA_Set WMP-15_017	<p>PG&E states in its response to Question 17(a) of CalAdvocates-PGE-2023WMP-08 that: "For Routine and Second Patrol, PG&E does not currently have standards specific to high-risk species", but that species types will be incorporated into Focused Tree Inspections pilots in 2023. PG&E states in its response to question 17(b) that "Development of any standards related to high-risk species is still being determined and contingent upon completion of FTI pilots in 2023. A determination will be made specific to that program as its guidance is formalized following the pilots."</p> <p>a) Why does PG&E not have standards specific to high-risk species for routine and second patrol?</p> <p>b) Why does PG&E only plan to develop standards related to high-risk species for Areas of Concern, rather than throughout its service territory?</p> <p>c) How is PG&E establishing the standards for high-risk species?</p> <p>d) What method is PG&E using to establish the standards for high-risk species?</p> <p>e) What experts is being used and/or consulted?</p> <p>f) Is PG&E undertaking independent third party review, peer review, or some other method to provide independent assurance of their proposed standards?</p> <p>g) Would PG&E plan to expand standards related to high-risk species developed for its Areas of Concern for use throughout its service territory?</p> <p>o) If yes, please describe PG&E's planned process for doing so.</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.3.6	Vegetation Management and Inspections	High-Risk Species
167	CaPA	Set WMP-15	CaPA_Set WMP-15	18	CaPA_Set WMP-15_018	<p>PG&E states in its response to Question 18 of CalAdvocates-PGE-2023WMP-08 that: "The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission."</p> <p>Please state the basis, provide the method, and supporting documentation for the above-mentioned 88% target pass rate.</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	2	N/A	8.2.3.6	Vegetation Management and Inspections	High-Risk Species
168	CaPA	Set WMP-15	CaPA_Set WMP-15	19	CaPA_Set WMP-15_019	<p>In its response to Question 5 of CalAdvocates-PGE-2023WMP-08, PG&E provides the following table of actual and forecasted costs for vegetation management programs. PG&E further states that "The EVM Transitional programs for VM are Focused Tree Inspections, VM for Operational Mitigations, and Tree Removal Inventory."</p> <p>a) Please see the updated table which includes forecast costs for each EVM transitional program. These programs were not active in 2022 therefore actual costs are not available.</p> <p>ACT FOST COSTS</p> <p>2022 2023 2024</p> <p>Tree Mortality \$ 108,128 \$ 100,617 \$ 98,112</p> <p>EVM \$ 590,071 N/A N/A</p> <p>(EVM) Transitional Programs N/A \$ 160,357 \$ 156,366</p> <p>VM for Operational Mitigations \$ 23,455 \$ 22,872</p> <p>Tree Removal Inventory \$ 53,484 \$ 52,153</p> <p>Focused Tree Inspections in ACC \$ 83,418 \$ 81,342</p> <p>Routine VM \$ 607,751 \$ 711,944 \$ 694,225</p> <p>VC Pole Clearing \$ 23,369 \$ 23,000 \$ 23,353</p> <p>Totals \$ 1,300,440 \$ 988,919 \$ 974,057</p> <p>b) The difference of \$331,522,000 between 2022 and 2023 is achieved due to the conclusion of the EVM program. These reductions are reflected in the Vegetation Management GRC Supplemental Testimony submitted in February 2022.</p> <p>i. The difference of \$24,961,000 between 2023 and 2024 is due to several factors, this is how PG&E will achieve this reduction: (1) Transitioning from EVM to three new programs; (2) reducing the amount of Routine VM work conducted each year commensurate with the amount of undergrounding miles completed; and (3) reducing unit costs through efficiencies over the rate case period through targeted programmatic adjustments that refine processes and improve resource efficiency.</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.5.2	Vegetation Management and Inspections	Quality Control
169	CaPA	Set WMP-15	CaPA_Set WMP-15	20	CaPA_Set WMP-15_020	<p>In its response to Question 19(e) of CalAdvocates-PGE-2023WMP-08, PG&E says, "We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time."</p> <p>a) Does PG&E plan to develop a source for tracking planned work date for individual trees? If the answer to part (a) is yes, when does PG&E expect to have such a system implemented?</p> <p>b) If the answer to part (a) is no, please explain why not.</p>	Holly Wetman	4/11/2023	4/14/2023	4/14/2023	0	N/A	8.2.3.4	Vegetation Management and Inspections	Fail-in Mitigation
170	TURN	004	TURN_004	1	TURN_004_01	<p>Following up on the response to TURN Data Request 3, Question 2, please provide PG&E's data showing the "recorded reliability improvements at locations that have been completed and/or have been hardened with covered conductor" that will be assessed in the study planned for completion on June 30, 2023.</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	1	Yes	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution

171	TURN	004	TURN_004	2	TURN_004_02	<p>Regarding Table PG&E-22-35-1 (PSPS Events Lookback Analysis) on page 972 of PG&E's 2023-2025 WMP:</p> <p>a. For each column with numerals, provide a verbal description of all input data and of how the numerals in each column were calculated.</p> <p>b. Provide the table in its Excel format.</p>	<p>a. Input Data: the columns in Table PG&E-22-35-1 used the following input data: 2022 PSPS Five-Year Lookback Analysis (2018-2022); this is an analysis which shows the hypothetical PSPS events created by applying 2022 PSPS guidance to the weather from 2018-2022. This is our most accurate method of estimating PSPS impacts based on our latest PSPS guidance and results in a dataset identifying the list of customers impacted per hypothetical event. This list of customers is used in this WMP to calculate projected PSPS customer impacts. Customers whose PSPS impact is prevented due to existing mitigations (as of the end of 2022) are not included in this dataset. Some customers in this dataset may experience short-duration outages due to use of a downstream MSO device in the hypothetical PSPS events. When scoring PSPS events, we also add areas to scope based on the presence of certain asset and vegetation tags, if those areas also meet Minimum Fire Potential Conditions. This results in an incremental expansion of the PSPS scope. The number and location of these asset and vegetation tags on our system varies day-by-day and cannot be accurately forecasted in future PSPS events. This expansion in scope due to asset and vegetation tags is incorporated as a 10.0% multiplier. The asset and vegetation multiplier was calculated using 2021 actual PSPS events, excluding the January 19, 2021 PSPS Event (which used the 2022 PSPS guidance and thus did not have a scope increase due to tags).</p> <p>Since we cannot determine which specific customers will be added to scope due to asset and vegetation tags, this 10.2% increase can only be applied to the aggregated customer count for each PSPS event.</p> <p>In this table specifically, this dataset is used in conjunction with the other input data to identify customers mitigated by MSO device replacements and undergrounding. This dataset also serves as the baseline or denominator for calculating the columns showing the percentage of customers mitigated.</p> <p>MSO Device Replacement Workplan (2023-2024): this dataset identifies the list of MSO devices that are planned to be replaced with non-MSO devices in 2023 and 2024. This dataset was used in conjunction with the 2022 PSPS Five-Year Lookback Analysis described above to identify customers whose PSPS outages would be mitigated by planned MSO device replacements.</p> <p>Scoped Undergrounding Projects: this dataset identifies the undergrounding projects scoped for future work. An analysis was performed using this dataset to determine the customer count expected PSPS customer mitigation per mile of undergrounding completed, among the:</p> <ul style="list-style-type: none"> • The 2022 WMP and 2023 WMP collectively discuss the following mitigations with the potential to mitigate the scale, scope, frequency, or duration of PSPS events: <ul style="list-style-type: none"> • Distribution Sectionalizing Devices • Transmission Line Sectionalizing or Gating • Distribution Line Motorized Switch Operator (MSO) Replacements • Temporary Distribution Microgrids • System Hardening (Distribution) • Undergrounding • b. We currently do not have initiatives to add additional mitigations devices such as Sectionalizing devices and Temporary Microgrids as described in subpart (a). In each of the 2022-2023 WMP, we examined the projected impact of future planned mitigations initiatives on PSPS events. Thus, Table 22-35-1 only looks at the impact of the mitigation initiatives planned for future implementation in the 2022 WMP (undergrounding and MSO Replacements) and does not further examine the impact of past pre-existing mitigations (including the additional mitigations discussed in the 2022 WMP). • c. The analysis presented in Table 22-35-1 was only performed for the mitigation initiatives planned for implementation in the 2023 WMP: Undergrounding and MSO Replacements. The combined or total impacts of the 2023 WMP mitigations is reflected in the following tables: <ul style="list-style-type: none"> • Table PG&E-22-35-2: Target Reductions as a Result of PG&E's WMP Mitigations • Table 7-3-2: PG&E's WMP Targets • Targets PS-07 • QDR Table 10 <p>The impact of the remaining mitigations identified in the response to subpart (a) on PSPS events were analyzed in the 2022 WMP, in the following tables:</p> <ul style="list-style-type: none"> • Table PG&E-8-1-1: Estimated Impact of 2022 WMP Planned Mitigations • Table PG&E-8-3-1: PSPS Direct Impact Initiative Targets to be Completed by September 1, 2022 • Table PG&E-8-3-2: PSPS Direct Initiative Targets to be Completed After September 1, 2022 and Prior to the Next WMP Update <p>Furthermore, the combined or total impacts of the 2022 WMP mitigations is reflected in the following tables:</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-35 Quantify Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency
172	TURN	004	TURN_004	3	TURN_004_03	<p>Regarding PG&E's response to ACI PG&E 22-35, beginning on page 971 of its WMP:</p> <p>a. Please identify each mitigation discussed in PG&E's current WMP in its 2022 WMP that has the potential to mitigate the scale, scope, frequency, or duration of PSPS events. To please explain why Table 22-35-1 only looks at the impact of two mitigations, undergrounding and MSO, and does not consider the other mitigations identified in response to subpart (a).</p> <p>b. Please provide all PG&E analyses similar to what is presented in Table 22-35-1 regarding the impact on PSPS scale, scope, frequency, or duration of any or all of the other mitigations identified in response to subpart (a).</p> <p>c. Regarding the statement on page 971: "We concluded that none of the 2022 mitigation initiatives eliminated any event."</p> <p>d. Please identify each of the "2022 mitigation initiatives" that are referenced in this statement. It is the meaning of this statement that none of the 2022 mitigation initiatives reduced the scale, scope, frequency or duration of any event? If not, please explain what is meant by the statement and how it relates to the analysis presented in Table 22-35-1.</p>	<p>1. Fill in the attached spreadsheet "Wildfire Mitigation Table DR - PG&E". The first tab is a "Discovery" which provides stratifications for each attribute. The other tabs, "Data Input," "Asset Inspections," and "VM Inspections," all need to be completed with data inputted from PG&E.</p> <p>2. In "PGE 2023 WMP RD Section 642_Ach01" SPD has observed the mitigation effectiveness of Covered Conductor is on the order of 49% compared to the value reported in the WMP which is 64% (page 340). Explain the discrepancy.</p> <p>The cited information is incorrect in the WMP. We have corrected it in response to this discovery request. We will reach out to Energy Safety to discuss this update and making corrections to the WMP pursuant to Energy Safety's Guidelines.</p> <p>The 49% effectiveness cited above was due to an incorrect link in the original file and has been corrected in "WMP-Discovery2023_DR_SPD_003-Q001Ach01" which is the completed Wildfire Mitigation Table DR - PG&E template provided to us by SPD.</p> <p>PG&E confirms that our Butte County OH to UG conversion factor for the 2023-2025 WMP is 1.57.</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-35 Quantify Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency
173	PUC - SPD (Safety Policy Division)	003	CPUC - SPD (Safety Policy Division)_003	1	CPUC - SPD (Safety Policy Division)_003_01	<p>1. Fill in the attached spreadsheet "Wildfire Mitigation Table DR - PG&E". The first tab is a "Discovery" which provides stratifications for each attribute. The other tabs, "Data Input," "Asset Inspections," and "VM Inspections," all need to be completed with data inputted from PG&E.</p> <p>2. In "PGE 2023 WMP RD Section 642_Ach01" SPD has observed the mitigation effectiveness of Covered Conductor is on the order of 49% compared to the value reported in the WMP which is 64% (page 340). Explain the discrepancy.</p>	<p>Please see attachment "WMP-Discovery2023_DR_SPD_003-Q001Ach01" which is the completed Wildfire Mitigation Table DR - PG&E template provided to us by SPD.</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	1	N/A	8	Wildfire Mitigation	N/A
174	PUC - SPD (Safety Policy Division)	003	CPUC - SPD (Safety Policy Division)_003	2	CPUC - SPD (Safety Policy Division)_003_02	<p>2. In "PGE 2023 WMP RD Section 642_Ach01" SPD has observed the mitigation effectiveness of Covered Conductor is on the order of 49% compared to the value reported in the WMP which is 64% (page 340). Explain the discrepancy.</p>	<p>The cited information is incorrect in the WMP. We have corrected it in response to this discovery request. We will reach out to Energy Safety to discuss this update and making corrections to the WMP pursuant to Energy Safety's Guidelines.</p> <p>The 49% effectiveness cited above was due to an incorrect link in the original file and has been corrected in "WMP-Discovery2023_DR_SPD_003-Q004Ach1" which is the completed Wildfire Mitigation Table DR - PG&E template provided to us by SPD.</p> <p>The correct effectiveness factor is approximately 64%. As seen in the attachment there is some minor variation in effectiveness per circuit segment depending on the specific sub-branches.</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.1	Grid Design and System Hardening	Covered Conductor Installation - Distribution
175	PUC - SPD (Safety Policy Division)	003	CPUC - SPD (Safety Policy Division)_003	3	CPUC - SPD (Safety Policy Division)_003_03	<p>3. Confirm or revise PG&E's Butte County OH to UG conversion factor in the 2023-2025 WMP (currently 1.57 in the GRC) based on actual and estimated UG miles for 2023-2026. In the PG&E 2023 GRC: Heavy line (Over 22) PG&E forecast 2,000 SH UG miles (MAT 880) and 100 Butte County UG miles (MAT 95F) for 2023-2026.</p>	<p>PG&E confirms that our Butte County OH to UG conversion factor for the 2023-2025 WMP is 1.57.</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
176	PUC - SPD (Safety Policy Division)	003	CPUC - SPD (Safety Policy Division)_003	4	CPUC - SPD (Safety Policy Division)_003_04	<p>4. Based on WSPS initial review of the wildfire ignitions and general understanding of PG&E's undergrounding program, it appears that undergrounding would have prevented only 67% of CPUC-reportable ignitions in the HFTD area between 2002-2022 primarily due to the impact of secondary and service conductor ignitions. Additionally, SPD noted ten CPUC-reportable ignitions in PG&E territory during 2022 which were related to undergrounding. [The data used is the fire ignition data stored here: Wildfire and Wildfire Safety (ca.gov). Please note, WSPS is still cleaning the data and determining the best methodology to analyze the data.]</p> <p>a. Provide the justification for the 69% mitigation effectiveness value for undergrounding reported in the Wildfire Mitigation Plan. Explain how secondary, service conductor, and underground ignitions are accounted for in the 69% mitigation effectiveness.</p> <p>b. Provide the percentage of CPUC-reportable ignitions in the HFTD that undergrounding would be expected to remediate, accounting for secondary and service conductors.</p> <p>c. Provide a description of each CPUC-reportable ignition related to undergrounding that occurred in 2022 and describe how PG&E's undergrounding approach would or would not mitigate this ignition.</p> <p>d. SPD's general understanding is that ignitions from secondary conductors and service drops are accounted for in the methodology for calculating the effectiveness for both covered conductor and EPSS, but this risk does not appear to be accounted for in the same way for undergrounding. Explain the difference in the methodology for how the 99% mitigation effectiveness for undergrounding is calculated as compared to the 64% mitigation effectiveness for covered conductor and 62% effectiveness for EPSS.</p> <p>e. Explain how the mitigation effectiveness is applied to the risk calculation (such as that approach used in PGE 2023 WMP RD Section 642_Ach01) and contrast this approach to the approach used for covered conductor and EPSS.</p> <p>f. Provide the number of CPUC-reportable ignitions related to HFTDs in secondary and service conductors for each year starting in 2014 onward.</p>	<p>a) In the 2022 WMP discovery process, we provided a data response that showed how PG&E estimated the effectiveness of undergrounding in reducing ignitions (WMP-Discovery2023_DR_Callicott004-Q004). As PG&E explained in that data request, PG&E's estimate of the effectiveness of undergrounding in reducing ignitions is based on subject matter expertise. We validated this estimation using the ignition rate per mile for overhead and underground circuits respectively.</p> <p>Based on 2015-2021 historical CPUC-reportable ignitions and the system circuit miles, the effectiveness of undergrounding is approximately 66-69% from an ignition rate perspective as indicated in Table 1 below. However, Table 1 does not fully represent wildfire risk reduction as an ignition is different than wildfire frequency or consequences. Based on the 2015-2021 dataset, no underground ignition resulted in a fire greater than 10 acres, further substantiating undergrounding represents an even lower wildfire risk than overhead facilities.</p> <p>As such, we determined that the CPUC-reportable ignition data information is consistent with subject matter expert estimations of 99%. The reportable ignition data considered includes the ignitions associated with secondary and service conductors.</p> <p>b) Our current workplan is to underground primary conductor. At this time, we do not underground lateral secondary lines and service conductors. As noted in part a, we assume that undergrounding is 99% effective at reducing ignitions on the distribution primary lines where the undergrounding has taken place. However, as part of the undergrounding projects, we will eventually harden remaining secondary and service lines by replacing open wire secondary, gray services, and tree-connects with the current standard covered aerial conductor. PG&E has also recently started to apply "breakaway" connectors to our standard conductor system-wide to help mitigate any residual risk on the service and secondary wire. While the exact wildfire risk mitigation benefits associated with these enhancements to the lateral secondary and service lines has not been quantified, it will provide some enhanced wildfire mitigation value to the lateral secondary and service lines touched by the undergrounding program.</p> <p>c) We understand this question as a request for ignitions related to undergrounding work conducted in 2022. PG&E has not identified any ignitions related to our undergrounding work in 2022.</p> <p>d) The effectiveness in mitigating wildfire risk from services and secondary lines for the three mitigations referenced (OH Hardening / Covered Conductor, Undergrounding, and EPSS) is actually very similar. OH Hardening and Undergrounding both result in the same hardening of</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	1	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution

177	CPUC - SPD (Safety Policy Division)	003	CPUC - SPD (Safety Policy Division)_003_05	5	CPUC - SPD (Safety Policy Division)_003_05	<p>5.Regarding the UG workplan table provided by PG&E, 2023-03-27_PGE_2023_WMP_PD_Appendix D ACI PG&E-22-16_Ach01_CONF.xlsx: a. Why does Column "O" Risk Rank (V2) begin at Rank 7 (as opposed to 1) for circuits? i. Why does it end at 325? ii. Why do the gaps in rank 1.N exist? b. Why does Column "R" Risk Rank (V3) begin at Rank 6 (as opposed to 1) for circuits? i. Why does it end at 325? ii. Why do the gaps in rank 1.N exist?</p>	<p>a. There are three primary reasons why the risk ranking does not begin at 1: 1. If the circuit segment length is less than 1 mile then those smaller segments are bundled with other larger projects (e.g., the circuit segments that are risk ranked 1, 3, 4, and 5 were all less than 1 mile and bundled with other larger groups of circuit segments). 2. Some of the circuit segments are privately owned lines; we send an annual letter to the owner reminding them of their responsibility to maintain the line but do not take action on these circuits (e.g., the circuit segment that is risk ranked 2 is privately owned). 3. Some circuits are in the risk model data but work has been completed on that circuit segment and therefore the circuit segment is not included in planned work in the 2023-2026 work plan (e.g., work on a circuit segment that is risk ranked 3 has already been completed). i. We have approximately 1,600 CPZs identified in the HFTD as part of the 2021 WDRM V2. The data provided is only for the circuit segments in the current workplan which represents a subset of the overall 10,000 mile undergrounding program (~2,700 miles) which is only a portion of the overall electric distribution lines in HFTD. The Risk Rank (V2) ends at 3,328 in the workplan because not all circuit segments are represented in the 2023-2026 workplan, including a number of the circuit segments that are lower on the risk priority list (3,328-3,600). ii. Some of the numbers/risk ranks that would be expected in the current 1-N dataset are missing from the workplan data provided primarily because this data only represents the projects in our 2023-2026 workplan which is a subset of the overall 10,000 mile undergrounding program (~2,700 miles), and only a portion of the overall electric distribution lines in HFTD (which total ~25,500 miles). To a lesser extent the exceptions noted in the response to subpart (a) above also apply in that a risk rank number may be skipped if that circuit segment: (1) is small and bundled with the larger project which is represented in the workplan using the mean risk pool of the larger CPZ, (2) has already had work completed on it, or (3) is privately owned and not included in PG&E's scope of work. b. There are three primary reasons why the risk ranking does not begin at 1: 1. Using the Wildlife Feasibility Efficiency (WFE) score, PG&E bundles smaller projects (circuit segment is less than 1 mile) with other larger projects (e.g., circuit segment risk ranked 1 is bundled with the large project that is risk ranked 68, segment with risk rank 2 is bundled with segment that is risk ranked 132, and segment with risk rank 4 is bundled with segment risk that is ranked 41). 2. Some of the circuit segments are privately owned lines; we send an annual letter to the owner reminding them of their responsibility to maintain the line but do not take action on it. i. No, PG&E has not used its Targeted Tree Species study to identify additional clearances for inventory of trees with the highest growth and highest failure potential and there is currently no plan to begin such an inventory. The Targeted Tree Species Study (TTSS) did not include in its objective any analysis of tree growth rates or make any recommendations on clearances to be obtained at time of tree pruning. ii. PG&E does not have a plan to perform this analysis at this time. b. We are currently reviewing the Process and Procedures for field inspections and current clearance guidance: i. The plan is to complete the review by year end 2023, any updates deemed necessary will be incorporated for operationalization in 2024. ii. The plan is currently in progress. c. Yes, we began reviewing mid-cycle inspection areas during the development of Areas of Concern in Q4 2022. These reviews supported a proposal and plan to continue refinements to mid-cycle areas on November 30, 2023. Refinements during this time will inform 2024 mid-cycle inspection planning and workplan development. In addition to developing and implementing the Focused Tree Inspection Program in 2023, adjustments to mid-cycle inspection areas and sequencing are anticipated for VM operations beginning in 2024. d. Yes, we have evaluated the feasibility of developing a multi-year historical tree data set. i. We will have multi-year historical tree data with the One VM Tool. The dataset will inform inspectors about previous work on a vegetation point as well as associated clearances. This will also assist with analysis related to tree growth, allowing the inspector to make a well-informed decision regarding a vegetation point needing to be worked.</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-16 - Progress and Updates on Undergrounding and Risk Prioritization
178	OEIS	002	OEIS_002	1	OEIS_002_01	<p>a. Has PG&E used its Targeted Tree Species study to identify additional clearances for and begin inventory of trees with the highest growth and highest failure potential? i. If so, explain the results and how PG&E has and will integrate this knowledge into its VM programs. ii. If not, please explain PG&E's plan to perform this analysis and provide a timeline for completion and operationalization. b. Has PG&E reviewed the Process and Procedures for collecting and enhancing checklists for field inspections and current clearance guidance? i. If so, explain the results and how PG&E has and will integrate this knowledge into its VM programs. ii. If not, please explain PG&E's plan to perform this review and provide a timeline for completion and operationalization. c. Has PG&E evaluated how mid-cycle inspections sequence can be adjusted to align with Areas of Concern in highest risk regions? i. If so, explain the results and how PG&E has and will integrate this knowledge into its VM programs. ii. If not, please explain PG&E's plan to perform this review and provide a timeline for completion and operationalization. d. Has PG&E evaluated the feasibility of developing a multi-year historical tree data set? i. If so, explain the results and how PG&E has and will integrate this knowledge into its VM programs. ii. If not, please explain PG&E's plan to perform this evaluation and provide a timeline for completion and operationalization.</p>	<p>a. No, PG&E has not used its Targeted Tree Species study to identify additional clearances for inventory of trees with the highest growth and highest failure potential and there is currently no plan to begin such an inventory. The Targeted Tree Species Study (TTSS) did not include in its objective any analysis of tree growth rates or make any recommendations on clearances to be obtained at time of tree pruning. ii. PG&E does not have a plan to perform this analysis at this time. b. We are currently reviewing the Process and Procedures for field inspections and current clearance guidance: i. The plan is to complete the review by year end 2023, any updates deemed necessary will be incorporated for operationalization in 2024. ii. The plan is currently in progress. c. Yes, we began reviewing mid-cycle inspection areas during the development of Areas of Concern in Q4 2022. These reviews supported a proposal and plan to continue refinements to mid-cycle areas on November 30, 2023. Refinements during this time will inform 2024 mid-cycle inspection planning and workplan development. In addition to developing and implementing the Focused Tree Inspection Program in 2023, adjustments to mid-cycle inspection areas and sequencing are anticipated for VM operations beginning in 2024. d. Yes, we have evaluated the feasibility of developing a multi-year historical tree data set. i. We will have multi-year historical tree data with the One VM Tool. The dataset will inform inspectors about previous work on a vegetation point as well as associated clearances. This will also assist with analysis related to tree growth, allowing the inspector to make a well-informed decision regarding a vegetation point needing to be worked.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-24 - Progression of Vegetation Management Maturity
179	OEIS	002	OEIS_002	2	OEIS_002_02	<p>a. What are the minimum qualifications for an inspector performing the tree-risk assessment for the Focused Tree Inspections? b. Why and how did PG&E choose to use the American National Standards Institute (ANSI) A300 tree risk assessment standard over PG&E's Tree Assessment Tool (TAT) for Focused Tree Inspections? Include a comparison of the benefits and drawbacks of ANSI A300 and PG&E's TAT.</p>	<p>a) The minimum qualifications for an inspector performing the tree-risk assessment for the Focused Tree Inspection is a Tree Risk Assessment Qualification (TRAQ) through the International Society of Arboriculture (ISA). b) We will utilize the International Society of Arboriculture (ISA) Basic Tree Risk Assessment Form for the Focused Tree Inspections. The Basic Tree Risk Assessment Form is provided with the ISA Tree Risk Assessment Manual, which is based on ANSI A300. We utilized industry standards, regulatory guidance, and existing commitments in the decision to select ANSI A300 as a beneficial framework as guidance for the FTI program. • ANSI A300 is an industry wide standard that was created independent of PG&E with decades of proven use in the field and research employed. • A300 is called out for use and guidance in California Power Line Fire Prevention Field Guide (2021 EDITION). • Recommended Changes to the CPUC's General Orders on Page#11 of Envista Forensic, Inc dated July 6, 2022. • Modification of GO 95, Rule 35 to emphasize safety, reliability and hazard tree assessment that would direct and enable electric utilities to better focus on the root cause of tree-related fires by requiring utilities to use the following standards and best management practices: • ANSI A300 (Part 9) Tree Risk Assessment a. Tree Failure American National Standards for Tree Care Operations-Tree, Shrub, and other Woody Plant Management-Standard Practices (Tree Risk Assessment a. Tree Failure) Latest Edition • International Society of Arboriculture's Best Management Practices Utility Tree Risk Assessment Practices Edition 2020 The ISA Tree Risk Assessment Qualification provides an industry accepted tree risk assessment methodology that benefits by being supported by a qualification program designed to train and assess candidates in a specialized field of arboriculture. The TRAQ also has pre-requisites for candidates to be eligible to apply for the TRAQ course. The TAT was built specifically for the EVM program at PG&E and was not consistent with industry standards. The TAT also did not have the same level of pre-requisites or level of training and assessment as does the TRAQ.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
180	OEIS	002	OEIS_002	3	OEIS_002_03	<p>On page 621, PG&E references its Company Emergency Response Plan (CERP). Provide an unredacted version of the CERP and all annexes.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration. a. Please see attachment "WMP_Discovery2023_DR_OEIS_002-0004Ach01CONF.pdf" for an unredacted version of our CERP. Please see attachments "WMP_Discovery2023_DR_OEIS_002-0004Ach02CONF.pdf" and "WMP_Discovery2023_DR_OEIS_002-0004Ach03CONF.pdf" for our unredacted Wildfire Annex and PESP Annex, respectively. a. Please see the attachment "WMP_Discovery2023_DR_OEIS_002-0004Ach01CONF.pdf" for the requested information. b. i. Please see the attachment "WMP_Discovery2023_DR_OEIS_002-0004Ach01Ach02CONF.pdf" for the requested information. We developed our calibration procedure in coordination with Western Weather Group, who provides guidance on calibration and maintenance cycles. ii. Over the last 3 years, 611 out of 622 stations were calibrated in 2020, 981 out of 991 stations in 2021, and 1297 out of 1315 stations were calibrated in 2022. The remainder of these stations were not able to be serviced due to External Factors such as customer relocations, environmental-concern related relocations, weather conditions, and safety issues. We are unable to provide the historical maintenance performed on each station but based on historical data—we forecast 90% of our weather stations to have an incident ticket issued per year. This is corrective maintenance as opposed to preventive (calibration) maintenance. During preventive maintenance (calibrations), technicians are instructed to inspect the weather station for issues such as missing or damaged hardware and equipment. They are also instructed to document weather station information, perform tests on equipment, upgrade software, and replace any equipment that is not working correctly. iii. Over the last 3 years, 6 weather stations could not be calibrated in 2021 and 3 in 2022 due to the remoteness of the location and weather conditions. iv. Below is a table with estimated life span for weather station equipment. This was provided by our partner, Western Weather Group.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	3	N/A	8.4.1	Emergency Preparedness	Overview
181	OEIS	002	OEIS_002	4	OEIS_002_04	<p>a. On page 567, PG&E references the weather stations deployed over their 70,000 square mile territory for monitoring conditions. i. Provide the installation standard that all PG&E weather stations are installed to. Include height from ground, direction of cross-arm, and which side of the pole/tower they are installed on. ii. On page 570, PG&E references the maintenance for their weather stations and calibrations performed to "our standards". i. Provide the PG&E specific standard that is being referenced for the calibrations as compared to the manufacturers standards. ii. Provide the total number of stations that are serviced annually over the past 3 years, and the maintenance performed on each station. iii. Provide the total number of stations not serviced annually over the past 3 years due to "remoteness of location" and "weather conditions". iv. Provide the estimated life span of each sensor and the replacement cycle for each.</p>	<p>i. Over the last 3 years, 611 out of 622 stations were calibrated in 2020, 981 out of 991 stations in 2021, and 1297 out of 1315 stations were calibrated in 2022. The remainder of these stations were not able to be serviced due to External Factors such as customer relocations, environmental-concern related relocations, weather conditions, and safety issues. We are unable to provide the historical maintenance performed on each station but based on historical data—we forecast 90% of our weather stations to have an incident ticket issued per year. This is corrective maintenance as opposed to preventive (calibration) maintenance. During preventive maintenance (calibrations), technicians are instructed to inspect the weather station for issues such as missing or damaged hardware and equipment. They are also instructed to document weather station information, perform tests on equipment, upgrade software, and replace any equipment that is not working correctly. iii. Over the last 3 years, 6 weather stations could not be calibrated in 2021 and 3 in 2022 due to the remoteness of the location and weather conditions. iv. Below is a table with estimated life span for weather station equipment. This was provided by our partner, Western Weather Group.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	2	N/A	8.3.2.1	Situational Awareness and Forecasting	Existing Systems, Technologies, and Procedures
182	OEIS	002	OEIS_002	5	OEIS_002_05	<p>Please provide an Excel version of Table 7-4- Summary of Risk Reduction for Top Risk Circuit Segments from PG&E's 2023 WMP.</p>	<p>In reviewing this request, we discovered that some of the information in Table 7.4 is incorrect. We have corrected it in response to this discovery request. We will reach out to discuss this update and making corrections to the WMP pursuant to Energy Safety's Guidelines. Please see WMP attachment "WMP_Discovery2023_DR_OEIS_002-0005Ach01.xlsx".</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	1	N/A	7.2.2.3	Wildfire Mitigation Strategy	Projected Risk Reduction on Highest-Risk Circuits Over the 3-Year WMP Cycle
183	OEIS	002	OEIS_002	6	OEIS_002_06	<p>Under Section 8.1.2.6, PG&E only includes additional information for distribution protective devices. What programs does PG&E currently have for system automation equipment that the transmission line?</p>	<p>As indicated in Section 8.1.2.2 of the 2023-2026 WMP, "the transmission system, auto reclosing is disabled for the entire wildfire season when the FIR rating reaches R3 or greater. In addition, in Section 9.2.1, we explained how our Transmission Asset Health Specialist reviews the system to identify if there are low impact lines that do not meet our PESP scoping criteria (e.g. Asset health, Vegetation Risk, Wildfire Consequence) but can be denegated without incremental impact to customers or other adverse effects to the grid. In addition, we have implemented EPSS on some transmission lines and are evaluating expanding EPSS protection or other enhanced protection schemes on additional transmission lines.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	0	N/A	8.1.2.9.1	Grid Design and System Hardening	T Line removal (in HFTD) - Transmission

184	OEIS	002	OEIS_002	7	OEIS_002_07	<p>a. Provide a definition for PG&E's "Critical Pass Rate" for its asset inspection QC, as shown in Table PG&E-22-21. This should include criteria for what would constitute a "critical" including any risk thresholds, associated equipment types, or other relevant determinations.</p> <p>b. Does "Critical Pass Rate" differ from the "QA Review HFTD Pass Rate" provided in Table RN-PG&E-22-08-G in response to Critical Issue RN-PG&E-22-08 (F)? If not, describe how the two differ.</p> <p>c. Does "Critical Pass Rate" differ from the inverse of the "QC Review HFTD - Failure Rate" provided in Table RN-PG&E-22-08-A in response to Critical Issue RN-PG&E-22-08 (F)? If not, describe how the two differ.</p>	<p>a. "Critical Pass Rate" is the number of assets reviewed by QC that did not have a Critical Attribute (as defined by Asset Strategy) failure or miss divided by the number of assets reviewed by QC. This is shown as a percentage. A Critical Attribute is defined as: a condition that could lead to either an ignition point or wire down situation that could result in a potential fire ignition.</p> <p>b. "Critical Pass Rate" does not differ from "QA Review HFTD Pass Rate." Critical attributes are defined by Asset Strategy.</p> <p>c. "Critical Pass Rate" is not the inverse of "QC Review HFTD-Failure Rate." These items differ because "Critical Pass Rate" only looks at Critical Attributes as defined by Asset Strategy, whereas "QC Review HFTD-Failure Rate" is a measure of all errors within the QC review checklist, not just Critical Attributes. "QC Review HFTD-Failure Rate" is the number of reviews completed by QC that have at least one QC finding divided by the total number of reviews completed by QC and is displayed as a percentage.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-21 Asset Inspections Quality Assurance and Quality Control ACI PG&E-22-08 Better Application of Specific Lessons Learned From Utility-Caused Fires
185	OEIS	002	OEIS_002	8	OEIS_002_08	<p>a. How many ignitions were evaluated via PG&E's EIA program in 2021, 2022, and 2023 (if applicable) respectively?</p> <p>b. When would PG&E perform an EIA?</p> <p>c. Provide an example of an ignition PG&E performed EIA for, including supporting documentation and reports as applicable.</p> <p>d. Via Excel format, provide the following information for each ignition in which PG&E performed an EIA, following the same definitions as Table 6 of the QDR:</p> <p>i. CPZ in which ignition occurred</p> <p>ii. HFTD tier</p> <p>iii. Date of ignition</p> <p>iv. Qualifier for performing EIA (HFTD tier, EPSS protected facility, etc.)</p> <p>v. Metric type</p> <p>vi. Ignition driver</p> <p>vii. Line type</p> <p>viii. Summary/detail on the cause of ignition as identified via EIA</p>	<p>a. We completed EIA evaluative actions for 118 ignitions in 2021, we established the EIA program in 2021 and the scope/breadth of these evaluative may vary. Under the EIA program, we completed 147 ignition evaluations in 2022, and 17 ignition evaluations year-to-date in 2023.</p> <p>b. As outlined in our Utility Procedure: RSK-4306P-02 Fire Incident Enhanced Ignition Analysis Procedure (first published in September 2022), ignitions with these conditions meet EIA criteria:</p> <ul style="list-style-type: none"> PG&E Facility Ignitions in a High Fire Risk Area (HFRA) or High Fire Threat District (HFTD) Note: Facility ignitions caused by insulator tracking that do not result in a CPUC reportable ignition will not be included in scope for Enhanced Ignition Analysis. Ignitions on an Enhanced Powerline Safety Settings (EPSS) enabled circuit protection zone (CPZ) All CPUC Reportable Transmission and Substation Ignitions <p>The EIA Program may not perform some or all of fire activities described in the above-mentioned Procedure if the ignition investigation is being performed under the direction of course:</p> <p>c. We are attaching three reports associated with ignition #20220450 as an example of typical EIA work products.</p> <ol style="list-style-type: none"> WMP-Discovery2023_DR_OEIS_002-0008Aa(1)CONF.pdf WMP-Discovery2023_DR_OEIS_002-0008Aa(2)CONF.pdf WMP-Discovery2023_DR_OEIS_002-0008Aa(3)CONF.pdf <p>The ignition occurred on April 18th, 2022 because of an improperly installed connection device. As a result of this fire, we proactively replaced additional connection devices and jumpers from the incident circuit, and are in the process of revising guidance documents related to connection device installation methods. The reports include the following: (1) A Preliminary Ignition Investigation Report (PIIR) with event details and location history; (2) material analysis report produced by Applied Technology Services department (ATS) identifying the suspected failure mode, and (3) an Extent of Condition Report produced by our Asset Strategy department related to corrective and evaluative actions associated with that failure mode.</p> <p>d. Please see "WMP-Discovery2023_DR_OEIS_002-0008Aa(4).xlsx" for table of ignitions where PG&E has completed EIA-related evaluative actions. Note the following:</p> <ol style="list-style-type: none"> The list contains events where CPUC reportability may not have been met and ignitions a. The table defines each of the four (4) values appearing in column "J" of the spreadsheet PG&E provided. EPSS Outage Type ETS "Fast Trip Setting", Post-Optimized Circuit Settings HLT "Hot Line Tag", Pre-Optimized Circuit Settings T-EPSS Transmission-EPSS EPSS settings on transmission lines CPUC "Receiving Call-out". Only subject to reduce blocking <p>b. EPSS does not cause outages. Any time there is a fault condition on powerlines, there is an inherent risk of sparks and/or thermal energy dissipation from that fault condition leading to a potential wildfire ignition. Those conditions have been simulated in a laboratory environment to both demonstrate that a fault condition can ignite vegetation as well as demonstrate that de-energization of the line with EPSS significantly reduces the fault energy and associated sparks contacting the vegetation. It is acknowledged that certain fault types may not present as high of a risk of wildfire ignition. An example of this could be an underground cable fault within a milled overhead and underground system protected by a common protective device. Out of the total outages experienced during EPSS enabled only a small fraction of the outages could be characterized as having a low ignition potential.</p> <p>c. More than 95% of outages that occurred in 2022 while EPSS protection was enabled presented a potential ignition risk.</p> <p>d. In 2021, there were five Reportable Fire Ignitions (RFIs) in HFTD on circuits enabled with EPSS over the time period of July 28th - October 20th when the EPSS pilot was implemented on 170 circuits. In 2022, there were thirty-one RFIs on EPSS-enabled circuits in HFTD over the time period of May 20th - Oct 20th. There have been 0 ignitions with EPSS enabled in 2023 year to date.</p> <p>e. We understand this question to be asking about RFIs that occurred downstream of an EPSS capable device when EPSS was not enabled. In 2021, there were 2 RFIs in HFTD downstream of an EPSS capable device that was not EPSS enabled. In 2022, there were 20 RFIs in HFTD downstream of an EPSS capable device that was not EPSS enabled, and in 2023 year to date there have been 3.</p> <p>f. Yes.</p> <p>g. GIS file is attached/included "WMP-Discovery2023_DR_OEIS_002-0008Aa(1)CONF.html" (in KMZ format). Please note a redacted version of the requested document is not being provided because it could not be reasonably redacted.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	4	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-08 Better Application of Specific Lessons Learned From Utility-Caused Fires
186	OEIS	002	OEIS_002	9	OEIS_002_09	<p>a. Provide the definitions for the EPSS Outage Types under Column J for the tab labeled "2022 EPSS Outage Data".</p> <p>b. What analysis has PG&E performed on EPSS-caused outages to determine which outages would have led to an ignition?</p> <p>c. What percentage of EPSS-caused outages since the establishment of the EPSS program would have led to an ignition had EPSS not been enabled?</p> <p>d. Broken down by year since establishment of the EPSS program, how many ignitions have occurred on EPSS-enabled circuits while EPSS was enabled at the time of ignition?</p> <p>e. Broken down by year since establishment of the EPSS program, how many ignitions have occurred on EPSS-enabled circuits while EPSS was not enabled at the time of ignition?</p> <p>f. In PG&E's response to RN-PG&E-22-12, PG&E provided additional reliability measures in Table RN-PG&E-22-12-05: EPSS System Reliability Remediation & Correction Actions, such as targeted equipment repairs. Is PG&E still using all of the identified reliability measures within that table? If not, provide a list of reliability measures PG&E is no longer using, as well as an explanation as to why it is no longer being used.</p> <p>g. Provide the GIS file for Figure PG&E-22-10: Circuits by Number of EPSS Outages.</p> <p>h. Provide an updated Excel version of 2023-03-27_PGE_2023_WMP_R0_Appendix A(2) PG&E-22-12_Ach01 with additional columns on the tab labeled "2022 CPZ Data".</p> <p>i. Whether or not the CPZ qualifies for additional mitigations based on the results of the study (i.e. the mitigation type(s) being used on the CPZ as a result of vegetation management, installation of animal guards, etc.)</p>	<p>1. The list contains events where CPUC reportability may not have been met and ignitions a. The table defines each of the four (4) values appearing in column "J" of the spreadsheet PG&E provided.</p> <p>b. EPSS Outage Type</p> <p>c. FTS "Fast Trip Setting", Post-Optimized Circuit Settings</p> <p>d. HLT "Hot Line Tag", Pre-Optimized Circuit Settings</p> <p>e. T-EPSS Transmission-EPSS EPSS settings on transmission lines</p> <p>f. CPUC "Receiving Call-out". Only subject to reduce blocking</p> <p>b. EPSS does not cause outages. Any time there is a fault condition on powerlines, there is an inherent risk of sparks and/or thermal energy dissipation from that fault condition leading to a potential wildfire ignition. Those conditions have been simulated in a laboratory environment to both demonstrate that a fault condition can ignite vegetation as well as demonstrate that de-energization of the line with EPSS significantly reduces the fault energy and associated sparks contacting the vegetation. It is acknowledged that certain fault types may not present as high of a risk of wildfire ignition. An example of this could be an underground cable fault within a milled overhead and underground system protected by a common protective device. Out of the total outages experienced during EPSS enabled only a small fraction of the outages could be characterized as having a low ignition potential.</p> <p>c. More than 95% of outages that occurred in 2022 while EPSS protection was enabled presented a potential ignition risk.</p> <p>d. In 2021, there were five Reportable Fire Ignitions (RFIs) in HFTD on circuits enabled with EPSS over the time period of July 28th - October 20th when the EPSS pilot was implemented on 170 circuits. In 2022, there were thirty-one RFIs on EPSS-enabled circuits in HFTD over the time period of May 20th - Oct 20th. There have been 0 ignitions with EPSS enabled in 2023 year to date.</p> <p>e. We understand this question to be asking about RFIs that occurred downstream of an EPSS capable device when EPSS was not enabled. In 2021, there were 2 RFIs in HFTD downstream of an EPSS capable device that was not EPSS enabled. In 2022, there were 20 RFIs in HFTD downstream of an EPSS capable device that was not EPSS enabled, and in 2023 year to date there have been 3.</p> <p>f. Yes.</p> <p>g. GIS file is attached/included "WMP-Discovery2023_DR_OEIS_002-0008Aa(1)CONF.html" (in KMZ format). Please note a redacted version of the requested document is not being provided because it could not be reasonably redacted.</p>	Colin Lang	4/13/2023	4/18/2023	4/18/2023	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-32 - Updates on EPSS Reliability Study
187	OEIS	002	OEIS_002	10	OEIS_002_10	<p>a. Provide an Excel sheet listing all work orders closed by PG&E in 2022 following the same format and information as Table 13 of the QDR, with the additional columns:</p> <p>i. Date the work order was closed</p> <p>ii. LPGA&E Priority (A, B, E, H, and F)</p> <p>iii. Whether or not the infraction qualified as an "Ignition-Risk HFTD/HFRA" tag</p> <p>iv. Whether the infraction is Non-Pole or Pole</p> <p>b. Provide an updated Excel sheet listing all current open work orders following the same format and information as Table 13 of the QDR, with the additional columns:</p> <p>i. LPGA&E Priority (A, B, E, H, and F)</p> <p>ii. Whether or not the infraction qualifies as an "Ignition-Risk HFTD/HFRA" tag</p> <p>iii. Whether the infraction is Non-Pole or Pole</p>	<p>PG&E has used three relevant decision trees to scope work for System Hardening: (1) System Hardening, (2) Targeted Undergrounding, and (3) Fire Rebuild taking place in an HFTD. Before the Targeted RISK UG program, PG&E predominantly used the System Hardening (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach03)) and Fire Rebuild Decision Trees (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) to scope work. Most of the system hardening work in 2023 was scoped using these decision trees.</p> <p>Since late 2021, PG&E has completed most of our new planned scoping using a Targeted Undergrounding decision tree (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) after line removal is considered (if feasible). If undergrounding is ultimately determined to be infeasible, we typically proceed with overhead covered conductor. Since our current scoping efforts primarily utilize the Targeted undergrounding decision tree, and the fire rebuild decision tree (where appropriate), we provide additional context regarding these trees below in response to this request.</p> <p>The primary approach for selecting undergrounding miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v3 and (2) the Wildlife Feasibility Efficiency (WFE) ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility. Both approaches used to select undergrounding projects represent our current approach of our total wildfire risk.</p> <p>Please see attachment "WMP-Discovery2023_DR_TURN_005-0001(Ach01)". This decision tree reflects the process we followed to further analyze our highest risk undergrounding circuits included in the WMP. The process, as shown on the decision tree attachment and described below, is split into four key phases:</p> <ol style="list-style-type: none"> Circuit Segment Risk Ranking (purple box): First prioritize circuit segments in the locations where wildfire risk is the highest based on the latest wildfire distribution risk model (currently WDRM v3). Circuit Selection Prioritization Process (blue boxes): Then identify potential environmental conditions that impact feasibility of undergrounding (water crossing, rock type, gradient), and calculate wildfire feasibility efficiency (WFE) by circuit segment to prioritize undergrounding in the locations where WFE is the highest. Feasibility Study (green boxes): First, we confirm the segment identified is not already completed or included in existing work. Then, engineering review identifies opportunities to improve efficiencies and mitigate additional impacts, including adjusting the project to mitigate EPSS or EPSS impacts, determining if undergrounding is unfeasible if so, identifying. Not applicable. PG&E has a decision tree. Please see our response to TURN_005-0001. 	Colin Lang	4/13/2023	5/5/2023			8.1.7		Open Work Orders	N/A
188	TURN	005	TURN_005	1	TURN_005_01	<p>1. Please provide any decision tree schematic in PG&E's possession that shows, for a given location where PG&E believes that system hardening is necessary, how PG&E decides which mitigation technique to use - i.e., undergrounding, covered conductor, remote grid installation, etc. - including without limitation the criteria that PG&E uses to select the mitigation technique for that location. Please provide a narrative explanation of what the decision tree schematic shows.</p>	<p>PG&E has used three relevant decision trees to scope work for System Hardening: (1) System Hardening, (2) Targeted Undergrounding, and (3) Fire Rebuild taking place in an HFTD. Before the Targeted RISK UG program, PG&E predominantly used the System Hardening (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach03)) and Fire Rebuild Decision Trees (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) to scope work. Most of the system hardening work in 2023 was scoped using these decision trees.</p> <p>Since late 2021, PG&E has completed most of our new planned scoping using a Targeted Undergrounding decision tree (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) after line removal is considered (if feasible). If undergrounding is ultimately determined to be infeasible, we typically proceed with overhead covered conductor. Since our current scoping efforts primarily utilize the Targeted undergrounding decision tree, and the fire rebuild decision tree (where appropriate), we provide additional context regarding these trees below in response to this request.</p> <p>The primary approach for selecting undergrounding miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v3 and (2) the Wildlife Feasibility Efficiency (WFE) ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility. Both approaches used to select undergrounding projects represent our current approach of our total wildfire risk.</p> <p>Please see attachment "WMP-Discovery2023_DR_TURN_005-0001(Ach01)". This decision tree reflects the process we followed to further analyze our highest risk undergrounding circuits included in the WMP. The process, as shown on the decision tree attachment and described below, is split into four key phases:</p> <ol style="list-style-type: none"> Circuit Segment Risk Ranking (purple box): First prioritize circuit segments in the locations where wildfire risk is the highest based on the latest wildfire distribution risk model (currently WDRM v3). Circuit Selection Prioritization Process (blue boxes): Then identify potential environmental conditions that impact feasibility of undergrounding (water crossing, rock type, gradient), and calculate wildfire feasibility efficiency (WFE) by circuit segment to prioritize undergrounding in the locations where WFE is the highest. Feasibility Study (green boxes): First, we confirm the segment identified is not already completed or included in existing work. Then, engineering review identifies opportunities to improve efficiencies and mitigate additional impacts, including adjusting the project to mitigate EPSS or EPSS impacts, determining if undergrounding is unfeasible if so, identifying. Not applicable. PG&E has a decision tree. Please see our response to TURN_005-0001. 	Tom Long	4/13/2023	4/19/2023	4/19/2023	3	N/A	8.1.2	Grid Design and System Hardening	ALL
189	TURN	005	TURN_005	2	TURN_005_02	<p>2. If the response to question 1 is that PG&E has no such decision tree schematic, then please describe the process that PG&E uses to decide, for a given location, which mitigation technique to use - i.e., undergrounding, covered conductor, remote grid installation, etc. - including without limitation the criteria that PG&E uses to select the mitigation technique for that location.</p>	<p>PG&E has used three relevant decision trees to scope work for System Hardening: (1) System Hardening, (2) Targeted Undergrounding, and (3) Fire Rebuild taking place in an HFTD. Before the Targeted RISK UG program, PG&E predominantly used the System Hardening (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach03)) and Fire Rebuild Decision Trees (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) to scope work. Most of the system hardening work in 2023 was scoped using these decision trees.</p> <p>Since late 2021, PG&E has completed most of our new planned scoping using a Targeted Undergrounding decision tree (see attachment WMP-Discovery2023_DR_TURN_005-0001(Ach01)) after line removal is considered (if feasible). If undergrounding is ultimately determined to be infeasible, we typically proceed with overhead covered conductor. Since our current scoping efforts primarily utilize the Targeted undergrounding decision tree, and the fire rebuild decision tree (where appropriate), we provide additional context regarding these trees below in response to this request.</p> <p>The primary approach for selecting undergrounding miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v3 and (2) the Wildlife Feasibility Efficiency (WFE) ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility. Both approaches used to select undergrounding projects represent our current approach of our total wildfire risk.</p> <p>Please see attachment "WMP-Discovery2023_DR_TURN_005-0001(Ach01)". This decision tree reflects the process we followed to further analyze our highest risk undergrounding circuits included in the WMP. The process, as shown on the decision tree attachment and described below, is split into four key phases:</p> <ol style="list-style-type: none"> Circuit Segment Risk Ranking (purple box): First prioritize circuit segments in the locations where wildfire risk is the highest based on the latest wildfire distribution risk model (currently WDRM v3). Circuit Selection Prioritization Process (blue boxes): Then identify potential environmental conditions that impact feasibility of undergrounding (water crossing, rock type, gradient), and calculate wildfire feasibility efficiency (WFE) by circuit segment to prioritize undergrounding in the locations where WFE is the highest. Feasibility Study (green boxes): First, we confirm the segment identified is not already completed or included in existing work. Then, engineering review identifies opportunities to improve efficiencies and mitigate additional impacts, including adjusting the project to mitigate EPSS or EPSS impacts, determining if undergrounding is unfeasible if so, identifying. Not applicable. PG&E has a decision tree. Please see our response to TURN_005-0001. 	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2	Grid Design and System Hardening	ALL
190	TURN	005	TURN_005	3	TURN_005_03	<p>3. In choosing among alternative system hardening mitigation techniques - i.e., undergrounding, covered conductor, remote grid installation, etc. - for a given location, please explain how PG&E takes into account the execution and schedule risks associated with undergrounding compared to other alternatives. PG&E discusses those risks in its 2023-2022 WMP at pages 344-346. They were also discussed in PG&E's Revised 2021 WMP (version dated 6/30/21) at pages 600-601 (Section 7.3.3.17.1, Subsection 3(b)), where PG&E uses the terms "execution risk" and "schedule risk."</p>	<p>During the field scoping process, the team reviews all high-impact dependencies that could extend the execution. During review, we evaluate alternative undergrounding routes to avoid such impacts, design decisions that could mitigate that risk, and the steps we can take to work with the applicable agencies to address potential scheduling and execution risk issues (e.g., permitting and land rights).</p> <p>Our current strategy is to plan for potential schedule and execution risks and work with agency partners to remove roadblocks where encountered. If there is a location where undergrounding is infeasible that we cannot solve through relocation, or other mitigation measures, then other design alternatives (e.g., covered conductor) may be considered later in the design stage.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2	Grid Design and System Hardening	ALL

191	TURN	005	TURN_005	4	TURN_005_04	<p>4. For the undergrounding work described in PG&E's 2023-2025 WMP, please describe PG&E's policy concerning undergrounding of service connections and the removal of poles on which service connections are attached. To the extent that this determination varies by project, please describe the criteria that PG&E uses to decide whether PG&E undergrounds service connections in a given location.</p>	<p>Our 10,000-mile undergrounding program is focused on undergrounding higher-voltage primary distribution powerlines in areas of high fire risk. While there is a degree of anywhere there are energized overhead facilities, historically, we have observed more frequent ignitions and larger wildfires associated with the overhead primary distribution powerlines. This is compared to lower voltage secondary distribution lines, service connections, and high voltage transmission lines. At this time, we are not undergrounding lower voltage secondary lines or service drops to address risk. In most cases overhead lower voltage secondary lines and service drops will remain overhead. There are some cases in which we may underground secondary powerlines, such as when lines run parallel to the trench path or for consistency with existing lines. In these special cases, the poles attached to the secondary lines will be removed. We will overhead harden remaining secondary and service lines by replacing open-wire secondary, gray services, and tree-connects with the current standard overhead aerial conductor. We have also recently started to apply "breakaway" connectors to our standard construction system-wide to help mitigate any residual risk on the service and secondary wire. Poles will remain in these instances to continue to support the remaining service/secondary wire and any communication lines remaining on those poles.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
192	TURN	005	TURN_005	5	TURN_005_05	<p>5. For the undergrounding work described in PG&E's 2023-2025 WMP, please describe PG&E's policy concerning undergrounding of secondary distribution lines (as opposed to primary lines) and the removal of poles on which secondary lines are attached. To the extent that this determination varies by project, please describe the criteria that PG&E uses to decide whether PG&E undergrounds secondary lines in a given location.</p>	<p>Please see response to TURN_005-004, which includes our policy as it relates to secondary distribution lines.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
193	TURN	005	TURN_005	6	TURN_005_06	<p>6. For the distribution circuits on which PG&E plans System Hardening undergrounding (as opposed to Rebuild undergrounding) as that term is used in PG&E's WMP (see, e.g., Table PG&E-8.1.2.2 on page 347), please provide PG&E's best estimate of the percentage of existing poles in the affected circuits (including poles supporting primary lines, secondary lines, and services) that will be removed as a result of the planned System Hardening undergrounding mileage in 2023-2025. Please explain how PG&E made this calculation and provide all inputs and assumptions.</p>	<p>PG&E does not currently track the existing poles that will be removed by undergrounded circuits. The analysis would require manual review at the individual project level and would include:</p> <ul style="list-style-type: none"> Determining the poles that are to be removed Determining the poles that will be topped Determining the poles that are jointly owned and will remain after undergrounding <p>In the absence of any material data on this front, PG&E does not have an estimate available for the percentage of existing poles in the affected circuit(s) to provide in response to this request at this time. Even if historical data was available, PG&E expects that the number of poles that will be removed will vary substantially from one project to the next based on many factors including: the presence of joint pole utilities (like telecom lines) who would need to maintain the poles and the density of homes and services which would have service poles remaining. In addition, our UG workplan submitted with the WMP includes miles that exceed our annual targets to account for unforeseen delays related to factors such as access, weather, permitting, land rights acquisition, materials or other constraints that may be experienced during the project lifecycle.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
194	TURN	005	TURN_005	7	TURN_005_07	<p>7. With respect to the values for 2023-2025 in the column for Estimated System Hardening Undergrounding Miles in Table PG&E-8.1.2.2 on page 347 of PG&E's 2023-2025 WMP: a. For each year, please provide PG&E's estimate of the overhead circuit miles that will be replaced and explain how this estimate was determined. b. For the figures provided in response to subpart "a", please provide an estimated breakdown of the overhead circuit miles replaced by: primary lines, secondary lines, and services.</p>	<p>a. Based on subject matter expertise and a sample of completed projects, the estimated overhead to underground conversion rate is 125 miles of underground line installed for every 1 mile of overhead primary line removed. Our target undergrounding miles for 2023-2025 is 1,100 miles. Using the estimated conversion rate, the overhead primary miles removed is projected to be approximately 1,680 miles.</p> <p>b. The estimate provided in part a is for the primary lines only. This information is not available for secondary and service lines.</p> <p>As described in TURN_005-004, at this time, we are not undergrounding lower voltage secondary lines or service drops to address risk. In most cases overhead lower voltage secondary lines and service drops will remain overhead. There are some cases in which we may underground secondary powerlines, such as when lines run parallel to the trench path or for consistency reasons.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
195	TURN	005	TURN_005	8	TURN_005_08	<p>8. With respect to the values for 2023-2025 in the column for Estimated Butte County Rebuild Miles in Table PG&E-8.1.2.2 on page 347 of PG&E's 2023-2025 WMP: a. For each year, please provide PG&E's estimate of the overhead circuit miles that will be replaced and explain how this estimate was determined. b. For the figures provided in response to subpart "a", please provide an estimated breakdown of the overhead circuit miles replaced by: primary lines, secondary lines, and services.</p>	<p>a. As described in our GRC1, the estimated overhead to underground conversion rate in the Butte Rebuild area is 1.57 miles of underground line installed for every 1 mile of overhead primary line removed. The 1.57 factor was based on relocated Community Rebuild overhead miles (2022-2025) and local topography.</p> <p>Our current estimate for Butte County undergrounding mileage for 2023-2026 is 115 miles. Using the estimated conversion rate, the overhead primary miles removed are projected to be 111 miles.</p> <p>b. The estimate provided in part a is for the primary lines only. This information is not available for secondary and service lines.</p>	Tom Long	4/13/2023	4/19/2023	4/19/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
196	CaPA	Set WMP-16	CaPA_Set WMP-16	1	CaPA_Set WMP-16_01	<p>Regarding PG&E's SCADA Underground (UG) Switches:</p> <p>a) Please explain PG&E's operating procedure for operating a SCADA UG switch to energize and de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after opening a normally closed switch, the switch is returned to its normally closed position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a normally open switch, the switch is returned to its normally open position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>a) For distribution operations operating procedures, SCADA UG switch when de-energizing is an open command in RT SCADA with load shed on SCADA devices before and after de-energizing. Energizing with a SCADA UG switch will have source side protective device reclosing relay cut out, the ground relay will be checked to verify cut in, close command will be given in RT SCADA to energize the section, and then the load shed will be taken once closed. Reclosing relay will then be cut in on source side protective device if not EPSS enabled.</p> <p>b) Please reference "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch01CONF.pdf" for our Operating Procedures for Primary Underground Separable Terminations. Please also reference "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch01CONF.pdf" for our Distribution Switching Procedures.</p> <p>c) For distribution operations operating procedures, if a line is currently energized from an alternate source when switching normal to a closed position, a parallel will be made by closing the abnormally opened switch and then opening the abnormally closed switch to separate parallel and return circuit to its normal source. When creating a parallel path reclosing and ground relays are cut out on all protective devices in the parallel path and Bank CLOSOS are placed on manual. All protective device relays are cut in following parallel separation. Load relays will be taken before, during, and after the parallel. It should be noted that reclosing relays may or may not be cut in if devices in the parallel path are EPSS enabled. EPSS enabled devices have reclosing relay cut out.</p> <p>d) For distribution operations operating procedures, see the answer to subpart c). The abnormally closed switch will be opened to separate the parallel, setup, and load leads, which will be the same as operating circuit.</p>	Holly Wetman	4/18/2023	4/21/2023	4/21/2023	2	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
197	CaPA	Set WMP-16	CaPA_Set WMP-16	2	CaPA_Set WMP-16_02	<p>Regarding PG&E's Load Break Elbows:</p> <p>a) Please explain PG&E's operating procedure for operating a load break elbow in a vault to energize or de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after opening a circuit segment via a load break elbow that is normally in a closed position, the circuit segment is returned to its normally closed position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a circuit segment via a load break elbow that is normally in an open position, then the circuit segment is returned to its normally open position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>a) For distribution operations operating procedures, if de-energizing or energizing from Load break elbows that are not protected by fuses on the source side, then reclosing a relay is first cut out or verified out on the source side protective device as well as ground relay verified out in. Following the source side protective setup (reclosing relay out/ground relay out), the sk is then given to the field operators to then manually remove or place load break elbow to de-energize/energize circuit segment. De-energizing elbows will be placed on insulated stand off and protective equipment is removed. Energizing elbows, protective equipment is removed, and elbows are placed/closed in operating position. Once operation is complete, relays are then placed to their previous state.</p> <p>Load Break elbows are not to be used when energizing a segment with a known or potential fault.</p> <p>b) Please reference "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch01CONF.pdf" and "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch02CONF.pdf" provided in response to Question 001b) of this Data Request Set for a copy of these Procedures.</p> <p>c) For distribution operations operating procedures, see the answer to subpart a) for energizing/deenergizing. If the segment to place normal is already energized, a parallel cannot be made using load break elbows. However, a parallel can be made adjusting the 2 circuits at a different location (i.e. an UG SCADA switch) in order to loop switch with the load break elbow. Protection schemes for a parallel have ground and reclosing relays cut out, as well as any fuses in the path bypassed.</p> <p>Before closing load breaks in a loop, while still in parallel, ground relays must be cut in, reclosing relays verified cut out, and then the sk will be given to the field to perform the operation of closing the load break elbow on a loop. The abnormally closed device will then be opened to separate the loop. Relays will then be placed in their proper configuration to address the current parallel, and then parallel will be separated and relays and fuses placed into their beginning state, placing the circuit normal. If no parallel is needed (i.e. only one circuit involved), cut out the source side protective devices reclosing relay and verify the ground relay is cut in, bypass fuses before closing on a loop, and then open the abnormally closed device to separate the loop. Protective schemes will be then placed in their previous state.</p> <p>d) For distribution operations operating procedures, please see the answer to subpart c). The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p>	Holly Wetman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.10.3	Grid Design and System Hardening	Motor Switch Operator Switch Replacement
198	CaPA	Set WMP-16	CaPA_Set WMP-16	3	CaPA_Set WMP-16_03	<p>Regarding PG&E's Junction Boxes:</p> <p>a) Please explain PG&E's operating procedure for operating a junction box in a vault to energize or de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a circuit segment via a junction box that is normally in an open position, the circuit segment is returned to its normally open position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a circuit segment via a junction box that is normally in a closed position, the circuit segment is returned to its normally closed position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>a) For distribution operations operating procedures, junction boxes may contain either Load break elbows or dead break elbows. For Load break operations, see the responses to question 2 of this data request set. Dead Break elbows cannot be used to energize or de-energize circuit segments. Dead break elbows are only to be opened or closed on a de-energized circuit segment after checking that the cables are de-energized.</p> <p>b) Please reference "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch01CONF.pdf" and "WMP-Discovery2023_DR_CalAdvocates_016-001A4ch02CONF.pdf" provided in response to Question 001 of this data request set for a copy of these Procedures.</p> <p>c) For distribution operations operating procedures, see the responses to Question 2 of this data request set for load break elbow operation. For dead break elbows, after checking cables are de-energized, elbows are then placed on insulated stand off and protective equipment installed.</p> <p>d) For distribution operations operating procedures, please see the responses to Question 2 of this data request set for load break elbow operation. For dead break elbows, after checking cables are de-energized, protective equipment is removed, and elbows are placed/closed in operating position. Circuit segments can then be energized.</p>	Holly Wetman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.10	Grid Design and System Hardening	Other Grid Topology Improvements to Minimize Risk of Ignition

199	CalPA	Set WMP-16	CalPA_Set WMP-16	4	CalPA_Set WMP-16_04	<p>Please explain PG&E's selection criteria for where to install the following equipment on underground circuits:</p> <p>a) SCADA UG switches b) Junction boxes c) Load break elbows</p>	<p>a) SCADA underground switches are typically only installed at mainline intersections. The 3-way SCADA switch can have up to two positions enabled with SCADA due to the space constraints on the top of the switch. Additionally, a communications signal to enable SCADA is not always available at the location where we would otherwise like to install a SCADA-enabled switch. While SCADA-enabled switches are preferred in these locations (mainline intersections where communication are available), it is at the discretion of the Electric Distribution Planning Engineer to specify the appropriate device as part of the project design.</p> <p>b) PG&E installs junction boxes on both mainline (800 Amp, AKA 600A) and tap-line(200A) systems.</p> <p>i. A mainline junction is the connection of multiple 600A separable connectors tied together in a subsurface enclosure and mounted on a wall of the enclosure. This connection could also include a 200A elbow mounted on top to feed a nearby radial tap-line. PG&E typically designs the underground system such that there is a switching device at every other enclosure allowing the use of a single junction in between. (Technically speaking, this design approach is due to the 600A single junction (also called a "separable" being a dead-break device requiring a clearance to open.)</p> <p>ii. A tap-line junction is typically a load-break elbow installed on a bus bar mounted on the wall of a subsurface enclosure. These can be 3-way or 4-way connections. These junctions are typically designed to be back-to-back on 200A radial systems and are not the preferred connection for 200A loops, but they can be used to serve a single transformer on a loop system if it is more cost efficient than looping in and out of a transformer. In some cases, the 200A junction can also be pad-mounted (installed inside a pad-mounted enclosure).</p> <p>c) The use of 200A Load-Break (LB) elbows is required when terminating 200A cable (ending the cable run, generally into a piece of equipment like a transformer) on all subsurface installations installed after July 2016. The use of 200A LB elbows has been required for terminating 200A cable on most new pad-mounted installations since the early 1990s. (Please note that when performing work on existing underground installations that involves the replacement of existing 200A Dead Break (DB) elbows, it may not be feasible to convert 200A DB to LB elbows. The overall height of the 200A-type LB elbow is 0.5' taller than the existing DB elbow and the enclosure covers must be able to be securely closed when cables are placed on an insulated or grounded standoff in the enclosure. In the cases where a LB elbow cannot fit safely in the existing enclosure, DB elbows are approved for use.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2	Grid Design and System Hardening	Other Grid Topology Improvements to Minimize Risk of Ignitions
200	CalPA	Set WMP-16	CalPA_Set WMP-16	5	CalPA_Set WMP-16_05	<p>Please explain PG&E's selection criteria for where to install the following equipment on underground circuits:</p> <p>a) Pad-mounted transformers b) Subsurface transformers</p>	<p>a) PG&E's standard is to install pad-mounted transformers on underground circuits where transformers are needed. See the response to subject b for when a pad-mount may not be used in favor of a subsurface transformers (For residential customers, we prefer to install pad-mounted transformers in the street transverse easement, or right-of-way areas for multiple customers or on the customer's property for a single service. For non-residential customers, the preference is to install pad-mounted transformers outside / adjacent to the building on a concrete pad.)</p> <p>b) Subsurface transformers are typically not installed unless it is required to support easement acquisition, there is no space available for a pad-mounted transformer to be installed, or it is otherwise specified due to project-specific concerns. Reasons that subsurface transformers are not preferred include that a subsurface transformer located in an enclosure where the air circulation is restricted and the ambient temperature is high, such as in the Central Valley or some of the HFTD areas that see high summer temperatures, may exceed its capabilities at nameplate loading due to excessive temperature. Space is also limited in a subsurface enclosure, so load requirements that influence the size of the transformer may limit the option of installing a sub-surface transformer. When one is needed, the preferred location for a subsurface transformer (from most preferred to least preferred) is generally:</p> <p>i. On the customer's property beside a sidewalk.</p> <p>ii. In a planned area between the curb and the sidewalk.</p> <p>iii. In the sidewalk.</p> <p>iv. In the paved portion of a parking lot.</p> <p>v. In the parking / shoulder area of a street.</p> <p>vi. In the trafficked portion of the street.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
201	CalPA	Set WMP-16	CalPA_Set WMP-16	6	CalPA_Set WMP-16_06	<p>For each of the undergrounding projects that PG&E has planned for 2023, please answer the following questions on each project:</p> <p>a) How many SCADA underground switches will be installed? b) How many overhead switches will be removed? c) How many tie switches to adjacent circuits currently exist? d) How many OH tie switches to adjacent circuits will be removed? e) How many tie switches (OH or UG) will exist when the project is complete? f) How many SCADA overhead switches will be removed? g) How many SCADA underground switches will be installed as tie points to adjacent circuits? h) How many SCADA underground switches will be installed for sectionalizing? i) How many subsurface transformers will be installed? j) How many pad-mounted transformers will be installed? k) How many risers will be installed? l) How many junction boxes will be installed? m) How many junction boxes will be installed for sectionalizing? n) How many junction boxes will be installed as tie points to adjacent circuits? o) How many load break elbows will be installed? p) How many load break elbows will be installed for sectionalizing? q) How many load break elbows will be installed as tie points to adjacent circuits? r) How many handholes will be installed? s) How many risers will be installed?</p>	<p>PG&E objects to this request as overbroad and unduly burdensome. We do not maintain the requested information in a manner that allows it to be aggregated without a manual review of each project's engineering and construction documentation. Manually collecting the data across hundreds of projects would require significant time and resources and the development of multiple processes to ensure data accuracy. If you would like to discuss this request further, please feel free to reach out to us.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
202	CalPA	Set WMP-16	CalPA_Set WMP-16	7	CalPA_Set WMP-16_07	<p>For each of the undergrounding projects that PG&E has planned for 2024, please answer the following questions on each project:</p> <p>a) How many SCADA underground switches will be installed in each circuit. b) How many overhead switches will be removed? c) How many tie switches to adjacent circuits currently exist? d) How many OH tie switches to adjacent circuits will be removed? e) How many tie switches (OH or UG) will exist when the project is complete? f) How many SCADA overhead switches will be removed? g) How many SCADA underground switches will be installed as tie points to adjacent circuits? h) How many SCADA underground switches will be installed for sectionalizing? i) How many subsurface transformers will be installed? j) How many pad-mounted transformers will be installed? k) How many risers will be installed? l) How many junction boxes will be installed? m) How many junction boxes will be installed for sectionalizing? n) How many junction boxes will be installed as tie points to adjacent circuits? o) How many load break elbows will be installed? p) How many load break elbows will be installed for sectionalizing? q) How many load break elbows will be installed as tie points to adjacent circuits? r) How many handholes will be installed? s) How many risers will be installed?</p>	<p>PG&E objects to this request as overbroad and unduly burdensome. We do not maintain the requested information in a manner that allows it to be aggregated without a manual review of each project's engineering and construction documentation. Manually collecting the data across hundreds of projects would require significant time and resources and the development of multiple processes to ensure data accuracy. If you would like to discuss this request further, please feel free to reach out to us.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
203	CalPA	Set WMP-16	CalPA_Set WMP-16	8	CalPA_Set WMP-16_08	<p>8.1.2.3 - Distribution Pole Replacements and Reinforcements Page 352 of PG&E's WMP states, "Pole replacement and reinforcement reduce outage likelihood which decreases the chances of the area being impacted in future PSPS events. These programs also support public and employee safety because they improve the overall health of the distribution poles." Please provide the average, median, minimum and maximum age of poles that PG&E:</p> <p>a) Replaced in 2020 b) Replaced in 2021 c) Replaced in 2021 d) Replaced in 2021 e) Replaced in 2022 f) Replaced in 2022</p>	<p>PG&E objects to this request as overbroad and unduly burdensome. We do not maintain the requested information in a manner that allows it to be aggregated without a manual review of each project's engineering and construction documentation. Manually collecting the data across hundreds of projects would require significant time and resources and the development of multiple processes to ensure data accuracy. If you would like to discuss this request further, please feel free to reach out to us.</p>	Holly Wehman	4/18/2023	5/5/2023			8.1.2.3	Grid Design and System Hardening	Distribution Pole Replacements and Reinforcements	

204	CaPA	Set WMP-16	CaPA_Set WMP-16	9	CaPA_Set WMP-16_O9	<p>8.1.2.10 - Other Grid Topology Improvements to Minimize Risk of Ignitions</p> <p>8.1.2.10.1 - Overhead Conductor Detection Devices Pg 374-375 of PG&E's WMP states, "Installation of DCD on existing, new, and retrofitted redfoer controllers is expected to reduce the number of ignitions due to high impedance line-ground faults by quickly detecting and de-energizing the fault, which is the primary existing gap in EPSS protection on primary overhead distribution conductor. Approximately half of the CPUC-reportable ignitions in HFTD that occurred in 2022 while EPSS was enabled were the result of high-impedance faults."</p> <p>a) Explain the existing gap on EPSS. b) Explain how DCD technology can mitigate this gap to encompass all high impedance faults. c) List the advantages of having both programs working simultaneously. d) What percentage of high-impedance faults does PG&E anticipate could be mitigated by EPSS alone? e) What percentage of high-impedance faults does PG&E anticipate could be mitigated by DCD alone? f) What percentage of high-impedance faults does PG&E anticipate could be mitigated by the combination of EPSS and DCD?</p>	<p>a) While EPSS has proven to be highly effective in lowering the incident energy during traditional faults and associated potential ignitions, reliable detection and de-energization of high impedance fault conditions continues to be a gap that we are working to close. As part of EPSS, we deployed an expansive use of low set, non directional ground fault overcurrent protection, commonly referred to as Sensitive Ground Fault (SGF) to aid in this effort. While SGF has been effective in closing the gap on high impedance faults, it also has effectiveness limits and further protection strategies like DCD that are being explored to allow for even greater sensitivity, detection, and de-energization of high impedance fault conditions. In addition to SGF and DCD, partial voltage (PV) force out and the gang trip functionality which are incorporated under the core EPSS strategy have also been deployed to help close the gap. These practices are all part of a defense in depth strategy to provide layered levels of protection against high impedance faults. b) DCD implements very sensitive and sophisticated levels of ground fault protection that specifically look for characteristics of arcing associated with line to ground faults. With high sensitivity, there is a higher likelihood of protective relay misoperation which may result in an outage for a non-fault condition. DCD works to overcome this by looking for the specific arcing characteristics that must be present for an actual fault condition. c) DCD is a further enhancement to EPSS, rather than a separate program. EPSS is designed to lower the incident energy for traditional faults, add gang, three phase tripping past fuses, and introduce higher impedance fault detection down to 15 amps. DCD and other high impedance fault detection methods assist in de-energizing fault conditions which are below the normal detection capabilities of traditional ground overcurrent protection, as low as 1 amp. d) As mentioned above, EPSS is a suite of enhanced protection schemes. It is not separate from DCD. Further, given the nature of these fault conditions, we do not readily have access to the data to support this statistic. e) As mentioned above, EPSS is a suite of enhanced protection schemes. It is not separate from DCD. DCD requires EPSS to be enabled to function. Further, given the nature of these fault conditions, we do not readily have access to the data to support this statistic. f) Based upon limited field experience and post event data analysis, we estimate that incrementally approximately 25% of all 2022 EPSS high impedance line to ground fault ignitions would have been mitigated by DCD.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	0	N/A	8.1.2.10	Grid Design and System Hardening	Other Grid Topology Improvements to Minimize Risk of Ignitions
205	CaPA	Set WMP-16	CaPA_Set WMP-16	10	CaPA_Set WMP-16_O10	<p>Please provide an Excel sheet listing each circuit (in its own row) that had circuit outages that occurred from 2020 to 2022 in any HFTD area. A circuit outage is when the Substation outage breaker trips and de-energizes the entire circuit due to a fault. For each circuit with an outage, the Excel sheet should list each Circuit Outage as a row. Please provide the following additional information (in columns): a) ID number of the circuit affected b) The date of the outage c) Cause of outage d) For all equipment failure outages, please state the specific type of failure (i.e., OH Transformer failure, overload, cross arms, UG transformer failure, cable failure, splice failure, etc.) e) The outage duration in minutes f) The total number of customers impacted. g) If all or part of the circuit is currently undergrounded, provide the date that OH to UG conversion was completed. h) If all or part of the circuit is in scope of a planned undergrounding project, the forecast completion date of the OH to UG conversion project.</p>	<p>Please see "WMP-Discovery2023_DR_CalAdvocates_016-0010A6h01.xlsx" for a list of sustained outages in a HFTD in 2020 through 2022. The undergrounding information in response to subsections C and H is based on the undergrounding workplan submitted in the 2023-2025 WMP. a) See Column C b) See Column D c) See Column F and Column G d) See Column J e) See Column H f) See Column L g) See Column M h) See Column N i) Cells with multiple years indicate that individual projects have been completed on that circuit within the years listed. * 'N/A' indicates that there are no completed projects for that circuit. * Cells with multiple years indicate that individual projects are forecasted for that circuit within the years listed. * 'N/A' indicates that there are no forecasted projects for that circuit.</p>	Holly Wehman	4/18/2023	4/21/2023	4/21/2023	1	N/A	QDR	N/A	N/A
206	CaPA	Set WMP-16	CaPA_Set WMP-16	11	CaPA_Set WMP-16_O11	<p>Regarding PG&E's Average Peak Load for UG Projects. For the purposes of this question, if any portion of a circuit was or will be undergrounded as part of an OH to UG conversion project, the circuit should be included. a) Provide the average peak load to circuit ampacity in percent from 2017 to 2019 for the circuits with OH to UG conversion completed in 2020. b) Provide the average peak load to circuit ampacity in percent from 2018 to 2020 for the circuits with OH to UG conversion completed in 2021. c) Provide the average peak load to circuit ampacity in percent from 2019 to 2021 for the circuits that will be undergrounded in 2022. d) Provide average peak load to circuit ampacity in percent from 2020 to 2022 for the circuits that will be undergrounded in 2024. e) Provide the average peak load to circuit ampacity in percent from 2020 to 2022 for all adjacent circuits to the circuits that have OH to UG conversion projects in 2023. f) Provide the average peak load to circuit ampacity in percent from 2020 to 2022 for all adjacent circuits to the circuits that have OH to UG conversion projects in 2024. END OF</p>	<p>Please see "WMP-Discovery2023_DR_CalAdvocates_016-0011A6h01.xlsx" for the requested information. The attachment includes a separate worksheet for each subsection to the response and is labeled accordingly (a, b, c, etc.). In response to subsections f and g, "adjacent circuit" is defined as a circuit that shares an open point. The adjacent circuit included in the response may also be a circuit included in the workplan if it is adjacent to another in the workplan.</p>	Holly Wehman	4/18/2023	4/26/2023	4/26/2023	1	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment
207	MGRA	Data Request No. 2	MGRA_Data Request No. 2	1	MGRA_Data Request No. 2_O1	<p>With regard to PG&E's response to CaPA_Set WMP-11_O14, PG&E states that one of the significant changes to the grid required for REFCL is "The replacement of old, direct bury underground cable" with REFCL. Please explain the incompatibility of "old, direct bury underground cable" with REFCL.</p>	<p>During the demonstration project, we released primary distribution equipment insulation ratings. During REFCL operation, line-to-ground voltage increases by 1.7 times, so the equipment must be able to withstand this increased voltage. A long run of old (1970 build), direct bury underground cable was identified during the review. The cable was tested for concentric neutral resistance and tan delta. The cable sections did not pass the tests and would likely fail during REFCL operation, so the cable sections were replaced. Underground cable replacements like this may be needed before a REFCL can be put into service for a given distribution substation.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
208	MGRA	Data Request No. 2	MGRA_Data Request No. 2	2	MGRA_Data Request No. 2_O2	<p>With regard to PG&E's response to CaPA_Set WMP-11_O14, PG&E states that one of the significant changes to the grid required for REFCL is "The replacement of old, direct bury underground cable". Does PG&E have any recently undergrounded segments that are also "direct bury"? If so would these be incompatible with REFCL?</p>	<p>Direct bury of underground cable, meaning tying the cable directly in a dirt trench and not inside a conduit, is not a standard, approved design for our underground electric distribution system at this point in time. As such, we have not recently undergrounded any electric distribution segments via direct bury. The direct bury underground cable design itself would not be incompatible with REFCL, however, many direct bury underground cable installations are old and the cable insulation may not withstand the 1.7 times normal line-to-ground voltages required during REFCL operation.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
209	MGRA	Data Request No. 2	MGRA_Data Request No. 2	3	MGRA_Data Request No. 2_O3	<p>With regard to PG&E's response to CaPA_Set WMP-11_O14, PG&E states that one of the significant changes to the grid required for REFCL is "The replacement of old, direct bury underground cable". Does PG&E's future undergrounding plans include "direct bury" and if so would that make these segments incompatible with REFCL?</p>	<p>No, PG&E's undergrounding plans include cable in conduit with standard voltage ratings exceeding REFCL operating voltage.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	N/A	8.1.8.1.3.1	Grid Operations and Procedures	Rapid Earth Fault Current Limiter
210	MGRA	Data Request No. 2	MGRA_Data Request No. 2	4	MGRA_Data Request No. 2_O4	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q007A6h03CONF.pdf</p>	<p>Please see "WMP-Discovery2023_DR_OEIS_001-Q007A6h03_Redacted.pdf."</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	N/A	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definitions	Detailed Model Documentation
211	MGRA	Data Request No. 2	MGRA_Data Request No. 2	5	MGRA_Data Request No. 2_O5	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q007A6h04CONF.pdf</p>	<p>Please see "WMP-Discovery2023_DR_OEIS_001-Q007A6h04_Redacted.pdf."</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	N/A	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definitions	Detailed Model Documentation
212	MGRA	Data Request No. 2	MGRA_Data Request No. 2	6	MGRA_Data Request No. 2_O6	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q007A6h04CONF.pdf</p>	<p>Please see "WMP-Discovery2023_DR_OEIS_001-Q007A6h04_Redacted.pdf."</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	N/A	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definitions	Detailed Model Documentation
213	MGRA	Data Request No. 2	MGRA_Data Request No. 2	7	MGRA_Data Request No. 2_O7	<p>Please provide a GIS file of 2022 outages occurring on circuits where EPSS was enabled.</p>	<p>The method of providing a geospatial file with the location of 2022 outages on EPSS enabled circuits would require the disclosure of device location and therefore the geospatial representation of outage location that would be provided in the GIS file data request involves the identification of Critical Energy Infrastructure Information (CEII), which we are required by law to maintain as confidential and cannot produce without the requesting party agreeing to protect the information through a non-disclosure agreement.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
214	MGRA	Data Request No. 2	MGRA_Data Request No. 2	8	MGRA_Data Request No. 2_O8	<p>Please provide a GIS file of 2022 ignitions occurring on circuits where EPSS was enabled.</p>	<p>Please see "WMP-Discovery2023_MGRA_002-Q008A6h01.xlsx."</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings

215	OEIS	003	OEIS_003	1	OEIS_003_01	<p>Regarding Activities that Exceed GO 166</p> <p>On page 624, PG&E states it "is currently working with internal and external stakeholders, including CalOES, to develop and implement activities that exceed compliance requirements in CPUC General Order (GO) 166, Standards for Operation, Reliability, and Safety During Emergencies and Disasters."</p> <p>a. List and describe the referenced activities. b. Explain how each listed activity exceeds GO 166.</p>	<p>CPUC General Order 166 Standard 1A, Internal Coordination, requires California electric utilities to provide as part of their emergency plans a description of internal coordination functions how they gather, process, and disseminate information within their service areas, set priorities, allocate resources, and coordinate activities to restore service. GO 166 Standard 1D, Internal and Government Coordination, requires California electric utilities to address as part of their emergency planning coordination with Essential Customers and state and local government agencies.</p> <p>a) The additional items referenced above that are not required by GO 166 are listed below: i. We have drafted a Threat Identification Risk Assessment (HIRA) and will be sharing the results with external agency partners. ii. We participate in quarterly MARAC meetings. iii. We hold quarterly Operational Area calls with our PG&E Public Safety Specialists. iv. We conduct more than the minimum one single exercise and include public partners in integrated exercise play; this includes inviting them to be part of the planning exercises.</p> <p>Internal and External Coordination</p> <p>Additionally, although not required as part of GO 166, Standard 1A compliance, a key element of PG&E's internal and external coordination strategy is the alignment of PG&E's functional areas to the frameworks provided by the California Standardized Emergency Management System (SEMS) and SEMS component Incident Command System (ICS). The adoption of these frameworks aligns PG&E with public partners to execute a coordinated response that supports safe restoration of service and whole community recovery. Specifically, PG&E has adopted the following SEMS/ICS consistent operational components:</p> <ul style="list-style-type: none"> • Use of the same framework as the SEMS Operational Area concept in the context of emergency organizational structure and levels, with emergencies beginning at the local level (Level 1) which is PG&E's base emergency posture. • Whole community engagement through PG&E's presence in County Emergency Operations Centers and the State Operations Center, and actions of PG&E's Liaison Officer and team leveraging coordination calls and collaboration of community and customer support. • SEMS Operational Area coordination framework details can be found in GERP subsection 5.4, Local Government, Operational Area. Whole community engagement, including PG&E Liaison Officer actions are described in GERP sections 4 and 9. Coordination and Communication, and External Relationships-PG&E Customer Training. <p>General Order 166, Standard 3C, requires California utilities to annually train designated a. The table below provides our current plans beyond the objectives in Table 8-33 and Table 8-34 of our WMP.</p> <ul style="list-style-type: none"> • Cybersecurity (NERC CIP-008 compliance), EMER-3102M • Disaster Relief, EMER-3012M • Extreme Weather Annex (EMER-3108M) • Infectious Disease and Pandemic Response Annex, EMER-3103M • Nuclear Annex • Electric, EMER-3002M • Emergency Communications, EMER-3008M • Information Technology, EMER-3007M • Tsunami Annex, EMER-3104M • Aviation Services Annex, EMER-3010M • Logistics, EMER-3009M • Earthquake, EMER-3101M • Canal Entry Annex, EMER-3011M • Gas, EMER-3003M • Human Resources, EMER-3006M • Power Generation, EMER-3004M • Workforce Management/Contact Center Operations, EMER-3005M • Physical Threat Annex <p>b. The other emergency plan (annexes) are not WMP commitments however they may be used during any response, including a wildfire. They are either requirements of GO 166 or have been developed to address a specific hazard and/or response. As they are not commitments specifically for wildfire mitigation they are not presented as objectives. However, we have included expansion of all hazard planning in 8.4.3.1 KPI EP-04-2023.</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.4.1.1	Emergency Preparedness	Objectives
216	OEIS	003	OEIS_003	2	OEIS_003_02	<p>Regarding Emergency Preparedness Plans Beyond Stated Objectives</p> <p>On page 624, PG&E states that there are, "current plans for wildfire-related activities beyond the objectives in Table 8-33 and Table 8-34."</p> <p>a. List and describe the activities beyond the objectives. b. Explain why plan beyond the objectives are not presented as objectives in WMP Table 8-33 and 8-34.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>a. We interpret "wildfire-related emergency" as wildfire events for which our Emergency Operations Center was activated. Please reference "WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf" for the After Action Report for the wildfire-related emergency that occurred in 2021. Please note, the EOC was not activated for any wildfire-related emergencies in 2022.</p> <p>b. Yes, please reference the following attachments for the requested information:</p> <ul style="list-style-type: none"> • WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf • WMP_Discovery2023_DR_OEIS_003-0003ACh3.pdf • WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf 	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.4.1.1	Emergency Preparedness	Objectives
217	OEIS	003	OEIS_003	3	OEIS_003_03	<p>Regarding After Action Reports</p> <p>a. Provide After Action Reports (or similar post-event reports) for each wildfire-related emergency in 2021 and 2022. b. Does PG&E have internal After-Action Reports (or similar post event reports) for both actual and potential PSPS events that differ from reports filed with the CPUC? If so, provide these internal reports for events in 2021 and 2022.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>a. We interpret "wildfire-related emergency" as wildfire events for which our Emergency Operations Center was activated. Please reference "WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf" for the After Action Report for the wildfire-related emergency that occurred in 2021. Please note, the EOC was not activated for any wildfire-related emergencies in 2022.</p> <p>b. Yes, please reference the following attachments for the requested information:</p> <ul style="list-style-type: none"> • WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf • WMP_Discovery2023_DR_OEIS_003-0003ACh3.pdf • WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.pdf 	Colin Lang	4/21/2023	4/26/2023	4/26/2023	4	N/A	8.4	Emergency Preparedness	N/A
218	OEIS	003	OEIS_003	4	OEIS_003_04	<p>Regarding Support for Medical Baseline Customers</p> <p>a. How does PG&E support Medical Baseline (MBL) customers during wildfire emergencies?</p>	<p>PG&E evaluates the scope of the wildfire emergency and partners with Community Based Organizations (CBOs) to activate services based on the wildfire footprint and estimated customer impact. Two contact centers are activated during emergencies to provide 24/7 emergency live agent service for customers to report emergencies and obtain information on support resources. PG&E's partnership with 211 connects customers identified as Access and Functional Need (AFN), including Medical Baseline (MBL) customers, with approximately 11,000 CBOs and government agencies across PG&E's service area. 2-1-1 provides emergency needs screening via incoming calls and texts, outbound efforts, and in-person visits to identify the needs of households during wildfire emergencies. 2-1-1 provides Care Coordinator. Through the Care Coordination process, individuals will undergo an intake assessment with a 2-1-1 Care Coordinator, including their current household situation, electricity needs, and medication and/or assistive technology usage to determine their needs during a wildfire emergency. Care Coordination provides a personalized safety plan that lists the individual's emergency contacts, local emergency or customer organizations' contact information, health and medical information, and other similar items. 2-1-1 Care Coordinators will contact the individual customer to check whether they require additional support. PG&E also partners with local food banks to provide customers with support during wildfires. For additional information, please refer to PG&E's 2023 AFN Plan at https://www.pge.com/en_US/residential/outages/public-safety-power-shutoff/pssp-support-page. At times, PG&E may also make Live Agent phone calls to Medical Baseline customers daily, in parallel to the automated notifications, as an additional attempt to reach the customer during a wildfire event.</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.4.6	Emergency Preparedness	Customer Support in Wildfire and PSPS Emergencies
219	OEIS	003	OEIS_003	5	OEIS_003_05	<p>Regarding Emergency Operations Customer Surveys</p> <p>a. Provide an example of each customer survey sent in 2021 and 2022 regarding emergency operations and any reports analyzing those surveys' results.</p>	<p>Please see attachment "WMP_Discovery2023_DR_OEIS_003-0003ACh3CONF.zip" for the following survey questionnaires and executive summaries for surveys regarding outreach effectiveness and general customer awareness of PSPS:</p> <ul style="list-style-type: none"> • 2021 PSPS Pre-season Questionnaire and Executive Summaries; • 2021 PSPS Post-Season Questionnaire and Executive Summaries; • 2021 PSPS Outreach Effectiveness Questionnaire and Executive Summaries; • 2022 PSPS Pre-season Questionnaire and Executive Summaries; • 2022 PSPS Post-Season Questionnaire and Executive Summaries; and • 2022 PSPS Outreach Effectiveness Questionnaire and Executive Summaries. <p>Due to limitations around uploading compressed documents (zip files) to OEIS's Docket portal, we are unable to serve this attachment through the confidential Docket. We have placed the confidential attachment within OEIS's secure SharePoint.</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	1	N/A	8.4.4	Emergency Preparedness	Public Emergency Communication Strategy
220	OEIS	003	OEIS_003	6	OEIS_003_06	<p>Regarding PG&E's Areas of Concern</p> <p>a. Provide a GIS layer of PG&E's Areas of Concern (AOC) with the following attributes for each AOC polygon:</p> <ol style="list-style-type: none"> Name of the AOC Number of overhead circuit miles in the AOC that are in scope for Focused Tree Inspections AOC in PSP? (Yes/No) Cumulative probability of ignition caused by vegetation coupled with consequence of ignition as given by WDRM v3 (wdrm3_v_c) Average probability of ignition caused by vegetation coupled with consequence of ignition as given by WDRM v3 (wdrm3_v_c) Cumulative Overall Liability Risk as defined by the 2023-2025 WMP Technical Guidelines, Appendix B Cumulative Ignition Risk as defined by the 2023-2025 WMP Technical Guidelines, Appendix B Cumulative PSPS Risk as defined by the 2023-2025 WMP Technical Guidelines, Appendix B Cumulative Contact from Vegetation Likelihood of Ignition as defined by the 2023-2025 WMP Technical Guidelines, Appendix B <p>b. Has PG&E used any vegetation related data source to identify the density/presence of overstore trees to create the AOCs? (e.g., LiDAR, satellite, if so, list the data source(s) and the date the data were collected. (e.g., distribution LiDAR from by PG&E in 2019)</p> <p>c. Has PG&E used any tree mortality data sets to:</p> <ol style="list-style-type: none"> Create the AOCs? If so, list the data set(s) and the date the data were collected. Determine the prioritization of inspection among the AOCs? If so, list the data set(s) and the date the data were collected. 	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.2	Vegetation Management and Inspections	N/A	

221	OEIS	003	OEIS_003	7	OEIS_003_07	<p>Regarding Focused Tree Inspections</p> <p>a. During the decision process to discontinue use of the Tree Assessment Tool (TAT) and adopt the ISA's Basic Tree Risk Assessment Form (ISA form), did PG&E consider incorporating elements from the ISA's form into the TAT?</p> <p>b. Is PG&E collecting a digital record of each ISA form generated by inspectors, in OneM or another system?</p> <p>c. How does PG&E plan to incorporate known localized risk factors (e.g., wind, outage rates by species) into tree risk assessments?</p> <p>d. Did PG&E perform any analysis or study that compared the outcomes of the TAT and the ISA's checklist in the field? If so, provide this analysis or study.</p> <p>e. Has PG&E benchmarked and/or discussed the most recent version of its TAT and the associated risk assessment procedure and its new tree risk assessment procedures using the ISA's checklist with other utilities, including, but not limited to, SCE and its Tree Risk Calculator? If so, provide a summary of that benchmarking/discussion.</p> <p>f. Provide the logic and any documentation of methodologies, stakeholders, and data sources for the most recent version of the TAT. Include a list of the factors considered in TAT scoring methodology.</p>	Colin Lang	4/21/2023	4/28/2023			8.2	Vegetation Management and Inspections	N/A	
222	OEIS	003	OEIS_003	8	OEIS_003_08	<p>Regarding Confidential Stakeholder Data Requests</p> <p>a. Provide PG&E's confidential responses and attachments to the following Data Requests: i. WMP-Discovery2023_CalAdvocates_002-Q001 ii. WMP-Discovery2023_CalAdvocates_006-Q007 iii. WMP-Discovery2023_CalAdvocates_006-Q008 iv. WMP-Discovery2023_CalAdvocates_006-Q011 v. WMP-Discovery2023_CalAdvocates_006-Q012 vi. WMP-Discovery2023_CalAdvocates_009-Q016</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	7	Wildfire Mitigation Strategy Development	N/A
223	OEIS	003	OEIS_003	9	OEIS_003_09	<p>Regarding PG&E's Asset Inspection Program</p> <p>a. Provide the inspection checklists used for both PG&E's patrols and detailed inspections.</p> <p>b. If PG&E tailors its inspections specifically to inspect wildfire risk specific items, identify which items within the checklist this applies to, particularly if such differs from standard OQ 95 inspections.</p> <p>c. On average, how many detailed inspections are completed by inspectors per day?</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	5	N/A	8.1.3	Asset Inspections	N/A
224	OEIS	003	OEIS_003	10	OEIS_003_10	<p>Regarding PG&E's Asset Inventory</p> <p>a. Provide a list of all fields that PG&E's asset inventory captures (i.e. equipment, equipment type, age, installation date).</p> <p>b. Provide a list of all types of equipment captured within PG&E's asset inventory.</p> <p>c. Provide a percentage in which PG&E is missing data for each data field listed in part (a) within its asset inventory.</p> <p>d. Provide an estimated percentage for the amount of assets missing from PG&E's asset inventory.</p>	Colin Lang	4/21/2023	5/10/2023			8.1.5	Asset Management and Inspection Enterprise System(s)	N/A	
225	OEIS	003	OEIS_003	11	OEIS_003_11	<p>Regarding PG&E's Response to P-WMP_2023-PG&E-002-Q07</p> <p>a. PG&E states that a Critical Attribute is defined as "a condition that could lead to either an ignition point or wire down situation that could result in a potential fire ignition." Provide all supporting documentation for procedures PG&E uses to determine whether something is a Critical Attribute, if such procedures do not exist, PG&E must provide the following: i. A description of PG&E's process for how it determines what qualifies as a Critical Attribute. ii. A list of criteria PG&E uses to qualify an asset as a Critical Attribute. iii. What does PG&E mean by "as defined by Asset Strategy"?</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-21 Asset Inspections Quality Assurance and ACI PG&E-22-08 Better Application of Specific Lessons Learned from Utility-Caused Fires
226	OEIS	003	OEIS_003	12	OEIS_003_12	<p>Regarding PG&E's Response to P-WMP_2023-PG&E-002-Q09</p> <p>a. PG&E states that it is still performing targeted equipment repairs relating to EPSS. Is this a program separate from that described within Section 8.1.7 of its WMP? If so, provide the following: i. Description and procedures in which PG&E uses to decide when and where it will perform EPSS-related targeted equipment repairs. ii. How PG&E reallocates resources to address these EPSS-related targeted equipment repairs (particularly in relation to the program described in Section 8.1.7). iii. The scale of such EPSS-related targeted equipment repairs (i.e. number of work orders, number of CPs included in this program). iv. In the attachment "WMP-Discovery2023_DR_OEIS_002-Q09A0402.xlsx", targeted equipment repairs are not included as part of the additional mitigations being completed. Why were these not included if PG&E is still using this measure? v. Provide a GIS file with the locations of CPs scoped for additional reliability mitigations based on EPSS impacts.</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-32 - Updates on EPSS Reliability Study

227	OEIS	003	OEIS_003	13	OEIS_003_013	Regarding PG&E's Response to P-WMP_2023-PG&E-002-008 a. Provide all Enhanced Ignition Analysis (EIA) reports completed for instances in which the qualifier was an EPSS protected facility. b. Provide all Enhanced Ignition Analysis (EIA) reports completed for instances in which the qualifier was an EPSS protected facility.	The confidential attachments are being provided pursuant to the accompanying confidentiality declaration. In response to Question 8 of Energy Safety's Second Data Request, subpart (d), PG&E provided a list of ignitions that were evaluated/partially evaluated in the Enhanced Ignition Analysis (EIA) program and listed why each ignition event qualified to be included in the program. The program is primarily focused on analyzing ignitions in HFTD and HFRAs, but PG&E includes ignitions in EPSS protected facilities in the process as an exception, regardless of location. As indicated in the spreadsheet in response to Question 8(d), there were 22 ignitions on circuits protected by EPSS that were included into the EIA program when the location criteria was not also met. PG&E understands this request is a follow-up asking for the deliverables for the 22 events where the only qualifier was EPSS. The time to respond to this request, PG&E is providing the summary investigation reports prepared by the EIA program for each of the 22 ignitions in "WMP-Discovery23_DR_OEIS_003-Q013CONF-zip." Please note this entire zip file is confidential. We note that this population of events is not inclusive of all ignitions associated with EPSS protected facilities that were analyzed as part of this program and qualified for review based on other factors like location (i.e. HFTD or HFRAs as indicated in response to Question 8 (e)). Please feel free to reach out if you have any additional questions regarding this response.	Colin Lang	4/21/2023	4/26/2023	4/26/2023	1	N/A	Appendix D	Areas for Continued Improvement	ACI PG&E-22-08 Better Application of Specific Lessons Learned from Utility-Caused Fires	
228	OEIS	003	OEIS_003	14	OEIS_003_014	Regarding PG&E's Fault Tamer Replacements a. Provide the numbers of fault tamers PG&E has replaced by year since 2020. b. Provide PG&E's targets for fault tamer replacements in 2023 and 2024, as applicable. c. Provide the number of fault tamer devices within PG&E's HFTD. d. Provide the number of fault tamer devices identified as needing replacement within PG&E's HFTD.	a. We interpret "replaced" to mean a proactive changing of an in-service fault tamer fuse that had not failed or operated normally due to a fault. In July 2021, in response to our 2020 causal evaluation of a separate fault tamer failures, we published a bulletin that requires replacement of the entire fuse after a fault (no re-use of the backup limiter portion of the fuse). We replaced fuses at seven locations associated with recent transformer changeouts in high wildfire consequence zones. At the time, there was a hypothesis that fault tamer failures were correlated with transformer changeouts. That hypothesis has since been disproven. Several fault tamer replacements from circuits in the Sonoma division were completed in August 2022 to support our failure evaluation. On 10/06/2022, after identifying an internal weld separation issue as the root cause of a recent increase in failures associated with 2021 and newer vintage fuses, we issued a full stop of new fault tamer installs, and we purged and returned all fault tamer inventory. b. We do not have any defined targets for proactive replacements in 2023 and 2024, unless they are identified in our Q016 inspection program guidance, as revised for 2023 to better assess for fuse end of life conditions and to reflect recent updates in manufacturer guidelines. New fault tamers are not currently being installed, so when a fault tamer fuse operates after a fault, it is replaced with a substitute fuse. c. We have records indicating there are 59,102 fault tamer fuses in service for transformer protection in HFTD, installed between 2020-2022, through the October 2022 surge of fault tamer inventory. There are additional fault tamers installed prior to 2020 and a separate smaller population of fault tamers installed for line protection. Those totals are not available in the limited amount of time to respond to this data request. d. Please reference our response to Q14 subpart (b).	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	N/A	N/A	N/A	N/A
229	OEIS	003	OEIS_003	15	OEIS_003_015	Regarding PG&E's V4 of its Wildfire Distribution Risk Model (WDRM) a. What is PG&E's status for review and approval of V4? b. When does PG&E intend to use V4 output to influence its undergrounding plan? Include discussion on details of how this may affect PG&E's undergrounding plan. c. Provide a list of the differences and improvements being made to V4 in comparison to V3. d. Is V4 undergoing third-party review similar to V2 and V3? If so, provide a status update on the review, including expected completion date for the related report.	a. The WDRM v4 is currently in review and validation prior to an anticipated approval in Q2 2023. b. The WDRM v4 will be available as an input to the underground program development after approval in Q2 2023. Beyond the response provided to AIO PG&E-22-34, the impact to the undergrounding program—i.e., how it will be applied and which years it will be used to plan—has not yet been determined. c. WDRM v4 has not yet been finalized, so we do not have a final list of differences and improvements being made to v4 in comparison to v3. However, in our 2023-2025 WMP, we discussed potential changes and improvements to WDRM v4 at high level. In Section 0.7 (page 213), we discussed our Risk Assessment Improvement Plan, including potential model improvements. Similarly, on page 848 in Appendix B we discussed WDRM v4 as part of our model development schedule. And AIO 22-07 (page 860) discusses our lessons learned from third party review of our models. d. Yes, as part of the review and validation model development step, the WDRM v4 is currently undergoing third-party review. The final validation report is scheduled for Q3 2023.	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	6.2.1	Risk Methodology and Assessment	Risk and Risk Component Identification	
230	OEIS	003	OEIS_003	16	OEIS_003_016	Regarding PG&E's response to OEIS Data Request 2 Question 5 Attachment 1 a. How did PG&E determine a mitigation effectiveness of 11.8% for down conductor detection (DCD)? b. In Table 8.4, PG&E has included 2023, 2024 and 2025 targets for DCD. Additionally, in response to CalAdvocate Data Request 10 Question 1, PG&E states that 21,000 miles will be covered by DCD by 2025. However, within the attachment, PG&E only demonstrates goals of approximately 27.34, 1.40, and 0 miles in 2023, 2024, and 2025 respectively. 2. Explain this discrepancy. c. Include the number of miles DCD covered in 2022, as well as how many additional miles will be covered based on PG&E's targets for 2023, 2024, and 2025 broken down by year. d. How did PG&E determine a mitigation effectiveness of 69% for EPSS? e. Why is partial voltage detection (PVD) not included within PG&E's mitigations within the attachment? If it were, what would the mitigation effectiveness be for including PVD?	a) The mitigation effectiveness for down conductor detection was based on the incremental benefit to EPSS. The mitigation effectiveness was determined by reviewing the ignitions that occurred during EPSS enablement periods. Out of the 30 ignitions reviewed, 14 of them are high impedance faults. Of the 14 ignitions, we estimate that 29% can be prevented based on subject matter expert review. That review considered the fault characteristics relative to DCD's ability to detect high impedance faults as small as 1 amp, and that DCD can detect line to ground faults, but not line to line faults. Based on the above, the calculation of effectiveness is as follows: 14/30 * 29% = 11.8% b) The approximate miles that OEIS calculates is only the miles in the Top 5% of risk (41 circuit segments) and not the full mileage across all locations in which DCD is covering. c) Approximately 3,500 HFRAs miles were covered by Down Conductor Detection (DCD) in 2022, with another 17,000 HFRAs miles planned in 2023, 700 HFRAs miles in 2024 and 30 HFRAs miles in 2025. HFRAs map utilizes the same methodology as CPUC-approved HFTD map, but also factors in incremental adds or exclusions to the HFTD map boundaries in consideration of risk factors for potential catastrophic fires originating from utility infrastructure. d) The effectiveness of 69% was a conservative estimation of EPSS effectiveness prior to the final calculated effectiveness of 69% based on review of 2022 EPSS ignitions. e) We do not possess sufficient data on Partial Voltage Detection in order to adequately represent an effectiveness.	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.10	Grid Design and System Hardening	Downed Conductor Detection Devices	
231	OEIS	003	OEIS_003	17	OEIS_003_017	Regarding undefined terms in 8.4.6 PG&E discusses "red tagged" customers, "impacted" communities, and "impacted" customers (including cities, counties, and tribal governments) in Section 8.4.6; however, definitions of such terms are not provided. a. Provide a definition, as it pertains to both wildfire and PSPS events in the context of Section 8.4.6, and the criteria for these groups being identified as such for: i. "Red tagged" customers ii. "Impacted" communities iii. "Impacted" customers	Red Tag: For natural disasters, including wildfires, in which the Governor or POTUS declares a State of Emergency, the official definition comes from D 19-01/518 (page 16) "...when a disaster(s) has resulted in the destruction or damage of a structure, such that utility service is disrupted voluntarily or involuntarily due to safety concerns or reconstruction activities to address the damage from a proclaimed state of emergency event..." Impacted Communities: this term was used as shorthand for all impacted customers and facilities. Impacted Customers: In a typical wildfire event, PG&E uses the fire perimeter maps available on National Inter-Agency Fire Center website and expand them by 2 miles each day. Any customer attached to a meter within the extended perimeter becomes an "impacted customer". The list of impacted customers and structures are refreshed daily, until the fire is contained.	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.4.6	Emergency Preparedness	Customer Support in Wildfire and PSPS Emergencies	
232	CalPA	Set WMP-17	CalPA_Set WMP-17	1	CalPA_Set WMP-17_01	<<BEGIN CONFIDENTIAL>> Table 1 - Projects not pursued for Undergrounding in first 2100 miles PG&E's WDRM V3 ranks circuit protection zones (CPZs) based on risk measured across 17 risk models to create a "cumulative risk score" for each CPZ. In Table 1 above, select CPZs that PG&E has decided not to pursue Undergrounding in its first 2100 miles of UG projects are compared by: • Cumulative risk score for the CPZ in WDRM V3 • Total CPZ length in miles measured by projecting the feature class in WDRM V3 to a UTM projection and calculating geometry in GIS • A calculated "risk per mile" or "average risk" value derived from the two previous values • Whether the CPZ has experienced outages from PSPS or EPSS in the past three years • PG&E 2023 WMP's decision to which program the CPZ belongs (crossed referenced against Question 8 on "PGE-2023WMP-06_VM_inspection_SH_questions" for projects in the 2023-2024 timeframe) • PG&E 2023 WMP's risk rank for each CPZ (crossed referenced against Question 8 on "PGE-2023WMP-06_VM_inspection_SH_questions" for projects in the 2023-2024 timeframe) • PG&E 2023 WMP Wildfire Feasibility Efficiency (WFE Score) for each CPZ (crossed referenced against Question 16 on "PGE-2023WMP-09_VM_WTRM_UG_vs_CC_costs_and_RSE" for projects in the 2023-2026 timeframe). a. Please explain why these selected CPZs in Table 1, with large average risk profiles in WDRM V3 and some with reliability concerns from PSPS or EPSS outages, are not being considered potential projects for Undergrounding in the first 2,100 miles. b. Please identify all factors in the selection of CPZ_EL CORADO PH 210119752" for "BASE SH" (base system-hardening) rather than Undergrounding in PG&E's 2023 WMP project selection. c. Please identify all factors in the selection of CPZ "PEORIA 17019000" for "BASE SH" (base system-hardening) rather than Undergrounding in PG&E's 2023 WMP project selection. d. Please identify all factors that resulted in CPZ "DANFURST 110310147" not being selected for any WMP system hardening program (including Base SH, Community Rebuild, Fire Rebuild, Targeted UG, Site Facilities, Other) despite it being targeted for PSPS and EPSS outages and having a larger average risk profile than other projects in Table 1. In general, identify all the factors PG&E considers when deciding that a CPZ with a large average risk profile or large total risk in WDRM V3 should not be prioritized in PG&E's 2023 WMP project selection.	Matthew Taul	4/21/2023	4/26/2023	4/26/2023	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution				
233	CalPA	Set WMP-17	CalPA_Set WMP-17	2	CalPA_Set WMP-17_02		Matthew Taul	4/21/2023	4/26/2023	4/26/2023	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution				

234	CaPA	Set WMP-17	CaPA_Set WMP-17	3	CaPA_Set WMP-17_03	<p><<BEGIN CONFIDENTIAL>></p> <p>In Table 2 above, select CPZs that PG&E has decided to pursue Undergrounding in its first 2100 miles of UG project⁶ are compared by:</p> <ul style="list-style-type: none"> • Cumulative risk score for the CPZ in WDRM V3 • The total mile length of Undergrounding which PG&E quoted for each UG project in Confidential response to Question 1 on "WMP-Discovery2022_DR_Calendar2023_2023" • A calculated "risk per mile" or "average risk" value derived from the two previous values • Whether the CPZ has experienced outages due to PSPS or EPPS in the past three years • PG&E 2023 WMP's decision to which program the CPZ belongs (crossed referenced against Question 8 on "PGE-2023WMP-06_VM_Inspection_SH_Questions" for projects in the 2023-2024 timeframe) • PG&E 2023 WMP's risk rank for each CPZ (crossed referenced against Question 8 on "PGE-2023WMP-06_VM_Inspection_SH_Questions" for projects in the 2023-2024 timeframe) • PG&E 2023 WMP Wireline Feasibility Efficiency (WFE Score) for each CPZ (crossed referenced against Question 16 on "PGE-2023WMP-09_VM_WTRN_UG_IG_CCS_sans_and_RISE" for projects in the 2023-2026 timeframe) <p>Please explain why these select CPZs in Table 2, with small total risk profiles and small average risk profiles in WDRM V3, are being considered as potential projects for Undergrounding.</p> <p>b. Please provide reasons why PG&E did not opt for alternatives to underground CPZ "PINE GROVE 11021848" given that the CPZ is comparatively long with both a low average and small cumulative risk profile. "Alternatives to underground" include other means by which to reduce risk such as use of Covered Conductor or a hybrid UG/OH approach.</p> <p>c. Please provide reasons why PG&E did not opt for alternatives to underground CPZ "STANISLAUS 17021888" given that the CPZ is comparatively long with both a low average and small cumulative risk profile. "Alternatives to underground" include other means by which to reduce risk such as use of Covered Conductor or a hybrid UG/OH approach.</p> <p>d. Please identify all factors under consideration that resulted in priority given to CPZ "STANISLAUS 17021888" with a cumulative risk score of 2.44 and distance to underground of 24.19 miles in PG&E's 2023 WMP for mitigation over other CPZs such as:</p> <ul style="list-style-type: none"> • "CAKARST 110310140" with a cumulative risk score of 9.19 and distance to underground <19 miles. 	Matthew Taul	4/21/2023	4/26/2023			8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution	
235	CaPA	Set WMP-17	CaPA_Set WMP-17	4	CaPA_Set WMP-17_04	<p>In general, identify all the factors PG&E considers when deciding that a CPZ with small total risk profiles and small average risk profiles in WDRM V3 should be prioritized in PG&E's 2023 WMP project selection.</p> <p>1. Regarding the System Hardening Decision Tree provided as Attachment 3 to the response to TURN data request 5-1, please define the following acronyms used in the Decision Tree:</p> <ul style="list-style-type: none"> a. PSS = Public Safety Specialist. PG&E PSS team members with extensive, local wildfire operations experience. Many had a previous career with CAL FIRE or other fire agencies. b. FSD = Field Scoping Desktop Meeting. Meeting to scope potential undergrounding project sites held in office as opposed to in the field. c. EASOP = Economic Analysis Software Program. Program used by PG&E to evaluate project economics. d. WGC = Wireline Governance Committee. Also referred to as PG&E's Wireline Risk Governance Steering Committee (WRGSC). It makes decisions about developing and prioritizing mitigation initiatives. e. EOOP = Electric Correction Optimization Program. This program considers existing open electric work when prioritizing, leveraging opportunities to gain efficiency by bundling multiple construction work into a project. 	Matthew Taul	4/21/2023	4/26/2023			8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution	
236	TURN	006	TURN_006	1	TURN_006_01	<p>a) No. The System Hardening Decision Tree was used to scope base system hardening projects in the workplan from 2023-2028 that were selected using the WDRM version 2. Much of this work was initiated for scoping prior to the 10K UG program announcement in late 2021. This System Hardening Decision Tree is not and will not be used for newly scoped work.</p> <p>b) N/A.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution
237	TURN	006	TURN_006	2	TURN_006_02	<p>a) No. The System Hardening Decision Tree was used to scope base system hardening projects in the workplan from 2023-2028 that were selected using the WDRM version 2. Much of this work was initiated for scoping prior to the 10K UG program announcement in late 2021. This System Hardening Decision Tree is not and will not be used for newly scoped work.</p> <p>b) N/A.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution
238	TURN	006	TURN_006	3	TURN_006_03	<p>a) Circuit Segment Risk Ranking – The WDRM risk model is the first step in identifying the list of circuit segments where wildfire risk is the highest. This data is updated roughly on an annual basis.</p> <p>Circuit Selection Process – The inputs to the feasibility score, bundling methodology following the previous year's lessons learned, and new inputs are developed in parallel, but require multiple reviews of the analysis and ultimate approval. This can take 2-3 months, but the first discussions often start before the risk model is finalized. Once the model is available, and barring any major modifications to inputs, it can be 1-2 months following release of the new risk model and associated Circuit Segment Risk Ranking.</p> <p>Feasibility study – Currently, the outlook for steady state output from this step is 40-70 miles per month with many activities being done in parallel. The Grid Design team can usually complete this step in about 1 month.</p> <p>Field Scoping – This is often the longest step due to the coordination of multiple groups, field checks, and finalization of documents and decisions related to the details of the project being scoped. Typically, this step can take ~2-3 months with high variation in that number for specific projects.</p> <p>b) In this context, infeasible and unfeasible are used interchangeably, to represent an option as impractical to actually construct. Typically, locations deemed infeasible would require substantial re-routing of the line or must cross simply non-passable terrain that would impede a potential UG route for the circuit. In these cases, targeted use of OH hardening is considered.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution
239	TURN	006	TURN_006	4	TURN_006_04	<p>a) PH – Pre-installed Interconnection Hub – In this context this refers to a tie-in point to facilitate generation connection to serve customers on a radially fed circuit with no available (left-side) operational ties (AKA "backfeed").</p> <p>EASOP – Economic Analysis Software Program – Program used by PG&E to evaluate project economics.</p> <p>A OEC – Operations Emergency Center – Regional operation center activated during an emergency event to manage resources and response locally.</p> <p>DG – Distribution Generators – Generators installed on the primary voltage system serving multiple customers.</p> <p>SG – Service Generators – Generators installed in the secondary/service conductor often serving only one customer.</p> <p>b) Yes.</p> <p>c) PG&E will use this Fire Rebuild Decision Tree to provide guidance to the OEC and supporting teams on how to rebuild the system (when damaged by a major storm or fire event).</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution
240	TURN	006	TURN_006	5	TURN_006_05	<p>a) Gray Services – An older type of insulated service aerial conductor that is more susceptible to water ingress and deterioration.</p> <p>b) Tree-connects – In this context, a service or secondary wire that is tied / connected directly to trees instead of poles.</p> <p>c) Break-away connectors – A connector system, primarily used at the service pole, that is designed to separate safely (AKA "break-away"), in the event of a tree or branch falling into the line, at the pole instead of pulling down the energized service wire or disconnecting at the weather head. The breakaway connector system is designed to leave no exposed energized components on the de-energized service line.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution
241	TURN	006	TURN_006	6	TURN_006_06	<p>a. When the primary conductor is removed and only communication wire remains, the top of the pole above the cross-arms will be removed out off to leave only the height of the pole necessary to support the remaining connections.</p> <p>b. No. PG&E is not able to offer a rough approximation that is reasonably accurate of the percentage of existing poles on the impacted distribution circuits that will be removed as part of the underground plans from 2023-2025. PG&E cannot provide this information because we have not completed the engineering design for each of the 2023-2025 undergrounding projects. Individual undergrounding projects vary significantly in the amount of poles that will be removed, topped, or left in place as part of the construction process.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment – Distribution

242	TURN	007	TURN_007	1	TURN_007_01	<p>1. Regarding the 2023-2026 Undergrounding Workplan referenced on page 910 of the WMP (R1) and provided in Excel format in response to TURN Data Request 2.4:</p> <p>a. Please explain how, if at all, either or both of Simplified Wildfire Risk Spend Efficiency (SWRSE) and Wildfire Feasibility Efficiency (WFE) values (discussed on p. 968 of the WMP (R1)) were used in developing this workplan.</p> <p>b. Please explain what measure(s) PG&E used to prioritize projects in this workplan and how such measure(s) were used.</p> <p>c. Please add to the Excel spreadsheet columns showing the SWRSE and WFE for each listed circuit segment.</p> <p>d. Comparing this Workplan with Table 7.2 of the WMP, please explain how the HFTD miles in Table 7.2 for a given circuit segment relate to the Planned UG miles in Columns V through AA of the Undergrounding Workplan. For example, the second highest risk ranked circuit segment in Table 7.2, Bonnie Nook 1101CB, is shown to have 17.80 HFTD miles, but the Undergrounding Workplan shows projects for 2023-2026 totaling only 0.31 miles. Please explain all of the reasons why the miles in the Undergrounding Workplan would differ from the miles in Table 7.2 for a given circuit segment. Please also specifically explain, for the Bonnie Nook 1101CB circuit segment, why the planned undergrounding mileage only addresses a small portion of the mileage identified in Table 7.2.</p>	<p>The confidential attachment is being provided pursuant to a signed NDA with PG&E.</p> <p>The circuits listed in Table 7.2 are the same circuits listed in Table 7.4 where additional detail is provided.</p> <p>a. As described in AD 22-34, PG&E used the SWRSE and WFE to identify where we could most efficiently reduce risk at specific locations. We selected the roughly 8,100 OH miles with the highest SWRSE to produce roughly 10,000 miles of undergrounding.</p> <p>b. We describe these measures in WMP (R1) section 6.1.2.2 (page 343)</p> <p>c. Please refer to attachment "WMP-Discovery2023_DR_TURN_007_001AtoH01COMB.xlsx"</p> <p>- See column AD for HF_WFE Score</p> <p>- See column AD for HF_WFE Ranking</p> <p>- We do not provide a separate SWRSE score because, as indicated on page 968 of the 2023-2026 WMP, "we in practice the standard cost per mile of undergrounding is expected to decline over time, we assumed it to be fixed at 1 for all circuit segments so that the selection is only driven by feasibility and risk."</p> <p>d. In the amount of time available to respond to this request, there are several reasons why the project mileage may be different from the quoted OH HFTD miles. These reasons include:</p> <ul style="list-style-type: none"> The total OH HFTD miles does not equal the required mileage for an underground project. Projects can span multiple years. Projects can include multiple circuit segments. Projects can include remote grid or hybrid alternatives. Some portion of the line may already be hardened. Relocation of the line can result in a difference in resultant project miles. Portions of the line may be private or customer owned. There may be projects targeting the remote grid only in the near term. 	Tom Long	4/21/2023	4/26/2023	4/26/2023	1	Yes	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
243	TURN	007	TURN_007	2	TURN_007_02	<p>Regarding Table 7.2 in the WMP:</p> <p>a. TURN understands from Table 6.5 that the Overall Risk Score values in Table 7.2 are the sum of Total Ignition Risk Score and the Total PSPS Risk Score. Please explain how these input values to the Overall Risk Score column were calculated. Please include in the explanation the relevant mathematical equations(s).</p> <p>b. If not applicable in response to "a", please explain how the Overall Risk Score relates to the Wildfire Mean Risk Score.</p> <p>c. Please provide, in the Excel format, a table that shows the information in Table 7.2 for all HFTD circuit segments. If PG&E has the same information for its self-identified HFRA circuit segments, please include that information also, and indicate which circuit segments are HFRA.</p>	<p>a. The Overall Risk Score is calculated by the calibration of the Wildfire Risk and PSPS Risk scores to the overall Enterprise Risk Model in the form of Multi-Attribute Value Function (MAVF) units. This is shown in Section 7.2.2.2</p> $= (23.082 * (72 + 4 * x^2) + (21270 * (0.038 * x^2)))^{0.25}$ <p>b. As stated in Section 6.4.2, We consider circuit segment ranking by high to low mean_risk, by sorting in this Excel workbook. The length of the circuit segment is different to the length of the circuit segment. However, the length of the circuit segment based on the mean_risk affects the total risk. In order to calculate Total Ignition Risk Score to arrive at Overall Risk Score, this mean risk is multiplied by the risk pixels it crosses, to arrive at total_risk from WDRM. This total_risk score is then multiplied by 11.41 to convert the WDRM (i) risk score to the enterprise wildfire risk score as it relates to distribution.</p> <p>c. Please see attachment WMP-Discovery2023_DR_TURN_007_002AtoH1.xlsx. Two additional columns N/O were added to this "TopRisk_Table" and the rows were extended to capture applicable circuit segments. Table 7.2 contents can be seen in Columns EN:EQ. Please note, line items outside of the top 5% risk circuit segments do not have same level of detailed review given the amount of time to respond to this request.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	1	N/A	7.1.3	Wildfire Mitigation Strategy Development	Risk-Informed Prioritization
244	TURN	007	TURN_007	3	TURN_007_03	<p>Regarding the System Hardening Workplan provided as Attachment 1 to the response to TURN data request 2.2 (which in turn asked for a response provided to Cal Advocates):</p> <p>a. The first tab in this Excel workbook is named "SH Workplan_2023-2026_Conf", which suggests that this response to Cal Advocates was taken from a document that also included the years 2025 and 2026. Please provide the most up-to-date version of this workbook for the period 2023-2026. Indicate the date of the information in the workbook that is provided.</p> <p>b. It appears that some of the circuit segments listed as high risk in Table 7.2 of the WMP and in the 2023-2026 Undergrounding Work Plan referenced on page 910 of the WMP (R1), e.g., Indian Flat 1104GB and Bonnie Nook 1102CB (only Bonnie Nook 1102CB is shown), are not listed in this workbook. Please explain why this is the case, even though this workbook includes planned undergrounding miles.</p> <p>c. Are there discrepancies in the names of the circuit segments between this workbook, and Table 7.2 and the 2023-2026 Undergrounding Work Plan referenced on page 910 of the WMP (R1)? If so, please modify the version of this workbook provided in response to "b" to make the circuit segment names consistent with Table 7.2 and the 2023-2026 Undergrounding Work Plan referenced on page 910 of the WMP (R1).</p>	<p>a) Please see attachment WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx. Two additional columns N/O were added to this "TopRisk_Table" and the rows were extended to capture applicable circuit segments. Please note, line items outside of the top 5% risk circuit segments do not have same level of detailed review given the limited time to respond to this request.</p> <p>b) Please see attachment WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx. Two additional columns N/O were added to this "TopRisk_Table" and the rows were extended to capture applicable circuit segments. Please note, line items outside of the top 5% risk circuit segments do not have same level of detailed review given the limited time to respond to this request.</p> <p>c) RSEs were not a requirement of the 2023-2026 WMP, only risk reduction. The risk reduction is provided in tab "Data_Pct" of WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx"</p> <p>d) Responses below:</p> <p>i. The values are determined by the subdivider effectiveness against the subdivider probability of each circuit segment.</p> <p>ii. This was an error. The corrected file has been provided in response to Cal Advocates and OES data requests and will be corrected in an errata filing on April 26, 2023. The corrected values are used in attachment "WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx".</p> <p>iii. These values are based on the blended average effectiveness based on the subdivider composition for each circuit segment. As per Table 7.2, the contribution of vegetation, equipment, and contact from object is different for each circuit segment, so the effectiveness varies by circuit.</p> <p>iv. It is part of the consideration, however, the overall risk reduction benefit is much higher for undergrounding as compared to covered conductor, even after taking into account the variations in covered conductor effectiveness.</p>	Tom Long	4/21/2023	4/27/2023	4/27/2023	1	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
245	TURN	007	TURN_007	4	TURN_007_04	<p>Regarding Attachment 2023-03-27_PGE_2023_WMP_R1_Section 6.4.2_Ach01, which is referenced on page 195, fn. 17 of the WMP (R1):</p> <p>a. Please provide a version of this Excel workbook that includes the same information for all of PG&E's HFTD circuit segments, or as many of those segments for which PG&E has such information.</p> <p>b. If PG&E has comparable information for its self-identified HFRA segments, please provide that information.</p> <p>c. Has PG&E calculated RSEs at the circuit segment level for any of the various mitigations shown in this workbook? If so, which mitigations? Provide those calculated RSEs, preferably as additional columns in the workbook(s) provided in response to "a" and "b".</p> <p>d. Regarding the Coerced Conductor Mitigation Effectiveness values in Columns U (2022), AE (2023), BP (2024), and DA (2025):</p> <p>i. Please explain how these values were determined.</p> <p>ii. Why are the values for 2023-2025 much lower than the values for 2022?</p> <p>iii. Why do the values differ (slightly) based on circuit segment?</p> <p>iv. Are the values shown the values that are being used in PG&E's process for selecting among different wildfire mitigation techniques (e.g., undergrounding vs. covered conductor) for the listed circuit segments.</p>	<p>a) Please see attachment WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx. Two additional columns N/O were added to this "TopRisk_Table" and the rows were extended to capture applicable circuit segments. Please note, line items outside of the top 5% risk circuit segments do not have same level of detailed review given the limited time to respond to this request.</p> <p>b) Please see attachment WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx. Two additional columns N/O were added to this "TopRisk_Table" and the rows were extended to capture applicable circuit segments. Please note, line items outside of the top 5% risk circuit segments do not have same level of detailed review given the limited time to respond to this request.</p> <p>c) RSEs were not a requirement of the 2023-2026 WMP, only risk reduction. The risk reduction is provided in tab "Data_Pct" of WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx"</p> <p>d) Responses below:</p> <p>i. The values are determined by the subdivider effectiveness against the subdivider probability of each circuit segment.</p> <p>ii. This was an error. The corrected file has been provided in response to Cal Advocates and OES data requests and will be corrected in an errata filing on April 26, 2023. The corrected values are used in attachment "WMP-Discovery2023_DR_TURN_007-Q002AtoH1.xlsx".</p> <p>iii. These values are based on the blended average effectiveness based on the subdivider composition for each circuit segment. As per Table 7.2, the contribution of vegetation, equipment, and contact from object is different for each circuit segment, so the effectiveness varies by circuit.</p> <p>iv. It is part of the consideration, however, the overall risk reduction benefit is much higher for undergrounding as compared to covered conductor, even after taking into account the variations in covered conductor effectiveness.</p>	Tom Long	4/21/2023	4/26/2023	4/26/2023	0	N/A	6.4.2	Risk Methodology and Assessment	Top Risk-Contributing Circuits/Segments
246	CalPA	Set WMP-18	CalPA_Set WMP-18	1	CalPA_Set WMP-18_01	<p>PG&E states in response to Question 1(a) of CalAdvocates-PGE-2023WMP-15: "Vegetation Management for Operational Mitigation (VMOM) will be primarily focused in HFTD and HFRA. There are instances where a circuit segment may cross in or out of HFTD/EFRA and VMOM would complete work on the whole circuit segment including the areas outside HFTD/EFRA. Focused Tree Inspections are planned for HFTD areas in the plan developed for 2023."</p> <p>Is it correct to interpret the statement above to mean that Focused Tree Inspections will take place only in HFTD areas (and will not include the HFRA, as VMOM will) in 2023?</p> <p>b) If Focused Tree Inspections will take place only in HFTD areas and not in HFRA, please explain why.</p> <p>c) Will Focused Tree Inspections take place outside of the HFTD area by the year 2023?</p> <p>d) If yes, please state where (in addition to the HFTD) Focused Tree Inspections are likely to take place after the year 2023.</p>	<p>Holly Wehman</p>	4/24/2023	4/27/2023	4/27/2023	1	Yes	8.2.2.6	Vegetation Management and Inspections	Discontinued Programs	
247	CalPA	Set WMP-18	CalPA_Set WMP-18	2	CalPA_Set WMP-18_02	<p>PG&E states in response to Question 3 of CalAdvocates-PGE-2023WMP-15 that "PG&E intends to track trees identified for work under VMOM and FTI using the OneVM tool."</p> <p>Please provide the following regarding the OneVM tool:</p> <p>a) Its purpose(s)</p> <p>b) How the tool works (i.e. what mechanisms or procedures it will use to achieve outputs)</p> <p>c) When the tool was developed</p> <p>d) When PG&E will begin utilizing the tool.</p>	<p>Holly Wehman</p>	4/24/2023	4/27/2023	4/27/2023	1	Yes	8.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory	
248	CalPA	Set WMP-18	CalPA_Set WMP-18	3	CalPA_Set WMP-18_03	<p>PG&E states in its response to Question 5(a)(i) of CalAdvocates-PGE-2023WMP-15: "VM (SPS-enabled outage data was used to determine both a planned unit forecast and identify CPZs where SPS VM Outages took place."</p> <p>Please explain what "planned unit forecast" refers to in the above instance.</p>	<p>Holly Wehman</p>	4/24/2023	4/27/2023	4/27/2023	1	Yes	8.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory	
249	CalPA	Set WMP-18	CalPA_Set WMP-18	4	CalPA_Set WMP-18_04	<p>PG&E states in its response to Question 7(a) of CalAdvocates-PGE-2023WMP-15 that its forecasted 9 year pace of work for its Tree Inventory Program "was provided for the first three years of the program with intent to ramp up annual pace, 9 years is a starting point to plan the pace of work completion however, the lessons learned will inform the completion timing."</p> <p>a) Please explain your reasoning for using nine years as a "starting point."</p> <p>b) Did PG&E consider durations other than nine years "to plan the pace of work completion"? Please explain.</p> <p>c) Does PG&E intend for the Tree Inventory Program to continue for more than nine years?</p>	<p>Holly Wehman</p>	4/24/2023	4/27/2023	4/27/2023	1	Yes	8.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory	

250	CaPA	Set WMP-18	CaPA_Set WMP-18	5	CaPA_Set WMP-18_05	In response to question 18(b)(ii) of CalAdvocates-PGE-2023WMP-18, PG&E states: The difference in projected vegetation management costs of \$24,861,000 between 2023 and 2024 is due to several factors, this is how PG&E will achieve this reduction: (1) Transitioning from EVM to three new programs; (2) reducing the amount of Routine VM work conducted each year commensurate with the amount of undergrounding miles completed; and (3) reducing unit costs through efficiencies over the rate case period through targeted programmatic adjustments that refine processes and improve resource efficiency. a) How does transitioning from EVM to three new programs result in a cost reduction? b) Please provide the following information about anticipated VM cost reductions from undergrounding in the below table: Year Number of Undergrounding Miles to be Completed Planned reduction in Number of Routine VM Miles Amount of Routine VM Cost Savings from Undergrounding (\$\$\$) 2023 2024 2025	Holly Wehman	4/24/2023	4/27/2023			8.2.5.2	Vegetation Management and Inspections	Quality Control
251	CaPA	Set WMP-18	CaPA_Set WMP-18	6	CaPA_Set WMP-18_06	In response to question 18(b)(ii) of CalAdvocates-PGE-2023WMP-18, PG&E states: The difference in projected vegetation management costs of \$24,861,000 between 2023 and 2024 is due to several factors. ... (3) reducing unit costs through efficiencies over the rate case period through targeted programmatic adjustments that refine processes and improve resource efficiency. a) For which specific programs does PG&E anticipate reducing unit costs as mentioned in the quote above? b) For each individual program identified in your response to the previous part, please state the following: i. Program/initiative name ii. What efficiencies does PG&E anticipate realizing? iii. Describe the "targeted programmatic adjustments" that PG&E is considering or planning to make. iv. State the current unit costs and the applicable units. v. State the unit costs that PG&E anticipates achieving in 2024 (on average for the year). vi. State the unit costs that PG&E anticipates achieving in 2025 (on average for the year). Please provide the following information regarding actual and projected costs for each WMP initiative under Chapter 8.2 (Vegetation Management and Inspections). Each initiative should be a row in the table below.	Holly Wehman	4/24/2023	4/27/2023			8.2.5.2	Vegetation Management and Inspections	Quality Control
252	CaPA	Set WMP-18	CaPA_Set WMP-18	7	CaPA_Set WMP-18_07	WMP Initiative Number Initiative Name 2022 Capital Expenditure (Actual) 2023 Capital Expenditure (Forecast) 2024 Capital Expenditure (Forecast) 2022 Operating Expense (Actual) 2023 Operating Expense (Forecast) 2024 Operating Expense (Forecast)	Holly Wehman	4/24/2023	4/27/2023			8.2	Vegetation Management and Inspections	N/A
253	TURN	008	TURN_008	1	TURN_008_01	Please provide PG&E's most recent calculation of RSEs for Undergrounding, by year from 2023-2025, at the most granular level for which PG&E has computed them. For this question, "Undergrounding" refers to all programs that underground distribution lines for wildfire mitigation purposes and/or the related purposes. Please provide the worksheets with the supporting inputs and calculations for these RSEs in Excel format.	Tom Long	4/24/2023	4/27/2023			7.2	Wildfire Mitigation Strategy	Risk Impact of Mitigation Initiatives
254	TURN	008	TURN_008	2	TURN_008_02	Please provide PG&E's most recent calculation of RSEs for Covered Conductor, by year from 2023-2025, at the most granular level for which PG&E has computed them. Please identify all activities that PG&E includes in the calculation of RSEs for Covered Conductor. Please provide the worksheets with the supporting inputs and calculations for these RSEs in Excel format.	Tom Long	4/24/2023	4/27/2023			7.2.2	Wildfire Mitigation Strategy	Risk Impact of Mitigation Initiatives
255	TURN	008	TURN_008	3	TURN_008_03	Regarding the Undergrounding Decision Tree provided in response to Data Request 5-1, ADR 1, is there an error in the alternative responses to the question at the far right: "Will a route or project scope change mitigate impediments?" It appears that the "Yes" and "No" alternatives should be flipped. If there is an error, please provide a corrected Decision Tree. The first paragraph of the response to TURN data request 5-4 states that, historically, PG&E has observed more frequent ignitions and larger wildfires associated with the overhead primary distribution powerlines, compared to lower voltage secondary distribution lines, service connections and high voltage transmission lines. a. Please provide, in the Excel format, the data on which this statement was based, and provide an explanation of what PG&E believes the data show. b. Please provide data, from 2015 to the present, showing for each of primary distribution overhead lines, secondary distribution overhead lines, service connections, and high voltage transmission lines: i. Number of ignitions ii. Number of ignitions normalized by mileage; iii. Size (e.g., acres) of fires resulting from ignitions; and iv. Number of structures destroyed by fires resulting from ignitions.	Tom Long	4/24/2023	4/27/2023			8.1.2	Grid Design and System Hardening	ALL
256	TURN	008	TURN_008	4	TURN_008_04	a. Please provide data, from 2015 to the present, showing for each of primary distribution overhead lines, secondary distribution overhead lines, service connections, and high voltage transmission lines: i. Number of ignitions ii. Number of ignitions normalized by mileage; iii. Size (e.g., acres) of fires resulting from ignitions; and iv. Number of structures destroyed by fires resulting from ignitions.	Tom Long	4/24/2023	4/27/2023			8.1.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
257	TURN	008	TURN_008	5	TURN_008_05	In response to TURN DR 5-4, after stating that PG&E is not undergrounding service drops and is not undergrounding secondary lines in most cases, PG&E states in the last paragraph, "We will overhead remaining secondary and service 3 lines by replacing open-wire secondary, gray services, and tree-connects with the current standard covered aerial conductor." (emphasis added) a. What is meant by the word "remaining" in this quote? b. Does this mean that, in a project PG&E describes as an undergrounding project, some of the "undergrounding" work typically consists of overhead hardening of secondary and service lines? Please explain your answer. c. Please explain the conditions under which an undergrounding project would include overhead hardening of secondary and service lines and when an undergrounding project would not include such overhead hardening work. Please provide an estimate of the percentage of undergrounding projects that include overhead hardening of secondary and service lines. d. In Table B-3 of the WMP, for the row "10K undergrounding" (initiative GH 04), do the target miles for "undergrounding work" include overhead hardening of secondary and service lines? If not, where is the overhead hardening of secondary and service lines described in this DR response accounted for in Table B-3? e. Do PG&E's unit cost estimates for "undergrounding" include the costs of overhead hardening of secondary and service lines that may be included in "undergrounding" projects? Please explain your response. f. Do PG&E's RSE calculations for "undergrounding" include miles, costs, and risk reduction benefits from overhead hardening of secondary and service lines that may be included in "undergrounding" projects? Please explain your response.	Tom Long	4/24/2023	4/27/2023			8.1.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
258	TURN	008	TURN_008	6	TURN_008_06	DCR's WMP (60), p. 252, states that: "PG&E has determined that lines with covered conductor have a 90% risk in PSPS activations. When a circuit (or fully isolatable circuit segment) is all covered conductor, the de-energization threshold is increased to 40/56 mph (sustained wind/gusts)." a. Please provide any data, studies or reports in PG&E's possession that address whether lines with covered conductor have experienced a reduction in PSPS activations. b. Please provide any reports or studies in PG&E's possession that assess whether any de-energization thresholds should be changed for circuits (or portions thereof) with covered conductor. c. Does PG&E have plans to do any studies in the future to assess whether any de-energization thresholds should be changed for circuits (or portions thereof) with covered conductor? If so, describe what will be studied and the planned timing for the study or studies.	Tom Long	4/24/2023	4/27/2023			8.1.2.1 & 9	Grid Design and System Hardening & PSPS	Covered Conductor and PSPS
259	CaPA	Set WMP-19	CaPA_Set WMP-19	1	CaPA_Set WMP-19_01	Please list PG&E's expected average useful life for the planned installation of the following technologies: a) DDC b) REFL	Holly Wehman	4/25/2023	4/28/2023			8.1.2.10 and 8.1.8.1.3.1	Grid Design, Operations, and Maintenance Grid Operations and Procedures	Down Conductor Detection Devices Rapid Earth Fault Current Limiter
260	CaPA	Set WMP-19	CaPA_Set WMP-19	2	CaPA_Set WMP-19_02	a) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for asset inspection and maintenance for a covered conductor distribution line installed in the HFTD? b) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for asset inspection and maintenance for an underground distribution line installed in the HFTD? c) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for asset inspection and maintenance for a bare distribution line installed in the HFTD? d) Please state the assumptions and limitations of your estimates for parts (a) through (c).	Holly Wehman	4/25/2023	4/28/2023			8.1.5	Grid Design, Operations, and Maintenance	Asset Management and Inspection Enterprise System(s)
261	CaPA	Set WMP-19	CaPA_Set WMP-19	3	CaPA_Set WMP-19_03	a) State the total number of circuit-miles of covered conductor distribution lines that PG&E had in the HFTD as of January 1, 2022. b) State the total number of circuit-miles of covered conductor distribution lines that PG&E had in the HFTD as of January 1, 2022. c) State the total number of circuit-miles of underground distribution lines that PG&E had in the HFTD as of January 1, 2022. d) State the total number of circuit-miles of underground distribution lines that PG&E had in the HFTD as of January 1, 2022. e) State the total number of circuit-miles of bare overhead distribution lines that PG&E had in the HFTD as of January 1, 2022. f) State the total number of circuit-miles of bare overhead distribution lines that PG&E had in the HFTD as of January 1, 2022.	Holly Wehman	4/25/2023	4/28/2023			8.1.2	Grid Design, Operations, and Maintenance	Grid Design and System Hardening

262	CaPA	Set WMP-19	CaPA_Set WMP-19	4	CaPA_Set WMP-19_04	a) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for vegetation management for an overhead distribution line installed in the HFTD? b) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for vegetation management for an underground distribution line installed in the HFTD? c) State the total costs that PG&E incurred in 2022 for vegetation management on overhead distribution lines in the HFTD.	Holly Wehman	4/25/2023	4/28/2023				8.2	Vegetation Management and Inspections	N/A
263	CaPA	Set WMP-19	CaPA_Set WMP-19	5	CaPA_Set WMP-19_05	a) Please describe the vegetation management activities that PG&E currently undertakes on rights-of-way with underground lines in the HFTD. b) Please describe any changes PG&E plans to make during the 2023-2025 WMP period regarding the vegetation management activities that PG&E plans to undertake on rights-of-way with underground lines in the HFTD. c) Please provide any protocols, procedures, or manuals that describe PG&E's approach to vegetation management where PG&E has underground lines in the HFTD. Pages 454-455 of PG&E's WMP describe PG&E's plan to reduce its backlog of open distribution work orders. As part of this plan, PG&E states that it plans to eliminate the ignition-risk backlog by the end of 2023, and the non-ignition risk backlog by the end of 2025. a) Does the plan described above apply to PG&E's entire service territory, or only those tags in the HFTD/HFRA? b) When does PG&E expect to eliminate its backlog of ignition-risk distribution work orders that exist outside the HFTD/HFRA? c) When does PG&E expect to eliminate its backlog of non-ignition-risk distribution work orders that exist outside the HFTD/HFRA?	Holly Wehman	4/25/2023	4/28/2023				8.2	Vegetation Management and Inspections	N/A
264	CaPA	Set WMP-19	CaPA_Set WMP-19	6	CaPA_Set WMP-19_06	Page 454 of PG&E's WMP states, "We divide remaining notifications into two groups: (1) ignition risk notifications in the HFTD/HFRA, and (2) non-ignition risk notifications in the HFTD/HFRA." a) How does PG&E determine whether a maintenance issue is an "ignition risk notification" or a "non-ignition risk notification"? b) Are there circumstances where a tag is a "non-ignition risk tag" but still poses other public safety hazards? c) If the answer to part (b) is yes, please list all such circumstances.	Holly Wehman	4/25/2023	4/28/2023				8.1.7.2	Grid Design, Operations, and Maintenance	Open Work Orders - Distribution Tags
265	CaPA	Set WMP-19	CaPA_Set WMP-19	7	CaPA_Set WMP-19_07	Page 895 of PG&E's WMP references an external study that stated, "for fire weather purposes, it may be necessary to position additional weather stations in canyons and other regions where short-term winds can rapidly spread wildfires." a) In response to this report, has PG&E assessed the need to position additional weather stations in canyons and other regions where short-term winds can rapidly spread wildfires? b) If the answer to part (a) is yes, please describe the results of any such assessment. c) In the 2023-2025 period, does PG&E plan to assess (or continue assessing) the need to position additional weather stations in canyons and other regions where short-term winds can rapidly spread wildfires?	Holly Wehman	4/25/2023	4/28/2023				Appendix D	ACI PG&E-22-10 - Justification of Weather Station Network Density	N/A
266	CaPA	Set WMP-19	CaPA_Set WMP-19	8	CaPA_Set WMP-19_08	Table PG&E-22-11.3 on page 903 of PG&E's WMP lists the component costs of covered conductor installation. Below the table, PG&E states, "The costs in Table PG&E-22-11.3 include the components for CC that are comparable with the other IOUs as part of the Joint IOU efforts. They do not include all cost components that make up our comprehensive Overhead System Hardening Program." a) Please add rows to Table PG&E-22-11.3 for the components that are part of PG&E's comprehensive overhead system hardening program but were not included in Table PG&E-22-11.3. b) For each item in Table PG&E-22-11.3, including the elements noted in part (a), please provide a brief description of the work and materials that are included in each component.	Holly Wehman	4/25/2023	4/28/2023				Appendix D	ACI PG&E-22-11 - Covered Conductor Effectiveness Lessons Learned	N/A
267	CaPA	Set WMP-19	CaPA_Set WMP-19	9	CaPA_Set WMP-19_09	Pages 898-899 of PG&E's WMP describe PG&E's completed wildfire risk spend efficiency (SWRSE), used to prioritize its undergrounding projects. Page 1000 states, "For the Undergrounding Program, we selected the roughly 8,000 OH miles with the highest SWRSE to produce roughly 10,000 miles of undergrounding." a) Is there a threshold SWRSE value at which PG&E determines that covered conductor is a more suitable mitigation than undergrounding? Please explain your answer. b) Is there a threshold SWRSE value at which PG&E determines that undergrounding is not a suitable mitigation? Please explain your answer. c) Does PG&E plan to underground any portion of line with a lower SWRSE than those top 8,000 OH miles that were selected for undergrounding (as described in the quote above)? Please explain your answer.	Holly Wehman	4/25/2023	4/28/2023				Appendix D	ACI PG&E-23-34 - Review Process of Prioritizing Wildfire Mitigations	N/A
268	CaPA	Set WMP-19	CaPA_Set WMP-19	10	CaPA_Set WMP-19_010	Attachment 1 to PG&E's response to data request CalAdvocates-PGE-2023WMP-14 states that on November 18, 2019, an intrusion inspection indicated that a pole had 18% remaining strength. On January 14, 2020, the inspector issued a priority E tag to replace the pole by January 13, 2021. a) Why was the tag for the above pole created approximately two months after the initial finding? b) Describe any actions that PG&E took between November 18, 2019 and January 14, 2020 to address the safety of the pole noted above. c) Why was the tag created with a one-year deadline based on the tag creation date, rather than a deadline based on the date of the initial finding? d) Under PG&E's current procedures and process, is the compliance deadline for a new tag based on the tag creation date or the date of the initial finding? Please explain your answer. e) Was a priority E tag the appropriate priority level in this instance? Why or why not?	Holly Wehman	4/25/2023	4/28/2023				8.1.3.2.3	Grid Design, Operations, and Maintenance	Intrusive Pole Inspections
269	CaPA	Set WMP-19	CaPA_Set WMP-19	11	CaPA_Set WMP-19_011	The PG&E Independent Safety Monitor Status Update Report by Filanergy Energy Partners on October 4, 2022, page 9 states: During the period, the ISM reviewed data provided by PG&E related to PG&E's Underground Transmission asset ages and the average age of certain PG&E Underground Transmission assets. For example, 60% of one type of underground transmission cable is beyond its useful life (U). Footnote 18 states, "Internal PG&E Report." Page 9 of the ISM report further states, "PG&E also states in an internal report published in May 2022 that underground transmission provides a low-risk score." a) Please provide a copy of the internal PG&E report referenced in footnote 18. b) Please provide a copy of the internal PG&E report published in May 2022, referenced above.	Holly Wehman	4/25/2023	4/28/2023				8.1.2.5	Grid Design, Operations, and Maintenance	Traditional Overhead Hardening - Transmission Conductor and Distribution
270	CaPA	Set WMP-19	CaPA_Set WMP-19	12	CaPA_Set WMP-19_012	On April 13, 2023, Cal Advocates met with a Senior Director of Grid Research and Development at PG&E. During this meeting, PG&E stated that REFCL is not a scalable product. a) Does the above statement accurately reflect PG&E's current assessment of REFCL? Please explain your answer. b) If the answer to part (a) is yes, please state all the reasons why PG&E believes REFCL is not a scalable product. c) Has PG&E performed a study to estimate the combined effectiveness of one or more combinations of covered conductor, EPSS, DCD, PVD, and REFCL in mitigating wildfires, when installed on distribution circuits in the HFTD? d) If the answer to part (a) is no, please explain why not. e) If the answer to part (b) is no, does PG&E plan to perform such a study? If so, provide the timeline for initiating and completing it. f) If the answer to part (c) is yes, please provide the results of any such study, including any reports, workpapers, or other work products.	Holly Wehman	4/25/2023	4/28/2023				8.1.8.1.3.1	Grid Design, Operations, and Maintenance	8.1.8.1.3.1 Rapid Earth Fault Current Limiter
271	CaPA	Set WMP-19	CaPA_Set WMP-19	13	CaPA_Set WMP-19_013	Table 7 on page 20 of the Joint IOU Covered Conductor Working Group Report lists SCE's estimate of the combined effectiveness of its covered conductor program, asset inspections, and several vegetation management programs. a) Has PG&E performed a similar estimate of the combined effectiveness of covered conductor, asset inspections, and vegetation management? b) If the answer to part (a) is yes, please explain the results of PG&E's estimate. c) If the answer to part (b) is no, please explain why not. d) If the answer to part (a) is no, does PG&E plan to perform such a study?	Holly Wehman	4/25/2023	4/28/2023				Appendix D	ACI PG&E-22-11 - Covered Conductor Effectiveness Lessons Learned	N/A
272	CaPA	Set WMP-20	CaPA_Set WMP-20	1	CaPA_Set WMP-20_01	a) Describe PG&E's standard process for retiring an asset from service. b) Describe how PG&E records the retirement of an asset from service.	Holly Wehman	4/26/2023	5/1/2023				8.1.5	Grid Design and System Hardening	Asset Management and Inspection (Enterprise System(s))
273	CaPA	Set WMP-20	CaPA_Set WMP-20	2	CaPA_Set WMP-20_02	a) In 2022, as part of its WMP system hardening activities, did PG&E retire from service (i.e., replace, remove, destroy, or decommission) any assets that had not been fully depreciated at the time of retirement? b) Please describe how PG&E recorded the retirement of assets during 2022 system hardening activities.	Holly Wehman	4/26/2023	5/1/2023				8.1.2	Grid Design and System Hardening	All
274	CaPA	Set WMP-20	CaPA_Set WMP-20	3	CaPA_Set WMP-20_03	a) In 2023, as part of its WMP system hardening activities, does PG&E intend to retire from service (i.e., replace, remove, destroy, or decommission) any assets that are not fully depreciated at the time of retirement? b) Please describe how PG&E will record the retirement of assets during 2023 system hardening activities.	Holly Wehman	4/26/2023	5/1/2023				8.1.2	Grid Design and System Hardening	All
275	CaPA	Set WMP-20	CaPA_Set WMP-20	4	CaPA_Set WMP-20_04	What is PG&E's standard practice for tracking assets that are retired from service before they are fully depreciated? a) If PG&E retires from service an asset that has not been fully depreciated, does it remove the remaining undepreciated value of the asset from its rate base? b) How does PG&E determine the remaining undepreciated value of an asset at the time the asset is retired from service? c) Please describe any scenario in which PG&E would retire from service an asset that has not been fully depreciated, but would keep the remaining undepreciated value of the asset in its rate base.	Holly Wehman	4/26/2023	5/1/2023				8.1.5	Grid Design and System Hardening	Asset Management and Inspection (Enterprise System(s))
276	CaPA	Set WMP-20	CaPA_Set WMP-20	5	CaPA_Set WMP-20_05	a) As of the date of this data request, does PG&E's rate base currently include any portion of the value of any assets that are no longer in service? b) If the answer to part (a) is yes, please explain why. c) If the answer to part (a) is no, let the controls in place that ensure PG&E's rate base does not currently include any portion of the value of assets that are no longer in service.	Holly Wehman	4/26/2023	5/1/2023				8.1.5	Grid Design and System Hardening	Asset Management and Inspection (Enterprise System(s))
277	CaPA	Set WMP-20	CaPA_Set WMP-20	6	CaPA_Set WMP-20_06	a) As of the date of this data request, does PG&E's rate base currently include any portion of the value of any assets that are no longer in service? b) If the answer to part (a) is yes, please explain why. c) If the answer to part (a) is no, let the controls in place that ensure PG&E's rate base does not currently include any portion of the value of assets that are no longer in service.	Holly Wehman	4/26/2023	5/1/2023				8.1.5	Grid Design and System Hardening	Asset Management and Inspection (Enterprise System(s))

281	CaPA	Set WMP-20	CaPA_Set WMP-20	7	CaPA_Set WMP-20_07	In its response to data request CalAdvocates-PGE-2023WMP-14, questions 20-22, PG&E stated: "We cannot provide the requested data. Our asset registry and work execution systems are not set up to enable this cross-referenced data consolidation and we do not track the volume of assets replaced that have not been fully recovered." a) Please explain what is meant by the statement, "Our asset registry and work execution systems are not set up to enable this cross-referenced data consolidation." b) Please explain what is meant by the statement, "We do not track the volume of assets replaced that have not been fully recovered." c) Is PG&E able to determine the number of assets that have not been fully depreciated that it retired from service as part of its 2020-2022 WMP activities? d) Is PG&E able to determine the total remaining undepreciated value of assets that it retired from service as part of its 2020-2022 WMP activities?	Holly Wehman	4/28/2023	5/1/2023					8.1.2.3 8.1.4.11 8.1.5.2	Grid Design and System Hardening	Distribution Pole and Replacements Traditional Overhead Hardening Transformers
282	TURN	009	TURN_009	1	TURN_009_01	1. Regarding the 2023-2026 Undergrounding Workplan referenced on page 910 of the WMP (R1) and provided in Excel format in response to TURN Data Request 2-4: a. For each undergrounding project listed in this document, please provide the RSE calculated in accordance with the CPU's S-MWP Settlement (see pp. 242 et seq of PG&E's WMP-R1) (not SWRSE or WFE) that PG&E calculated for the undergrounding project. Please provide all inputs and calculations for these RSE values, in live Excel format. b. For each undergrounding project listed in this document, please provide the RSE calculated in accordance with the CPU's S-MWP Settlement (see pp. 242 et seq of PG&E's WMP-R1) that PG&E calculated for any alternative mitigation for the project location, including but not limited to covered conductor. Please provide all inputs and calculations for these RSE values, in live Excel format. Please provide for Asset Point data for Camera, Fuse, Support Structure, and Weather Station. Provide Asset Line data for Transmission Line (as permitted as non-confidential), Primary Distribution Line, and Secondary Distribution Line. Provide PSPS Event data, Include Event Log, Event Line, Event Polygon data. Please exclude customer meter data. Provide all PSPS Event Asset Damage data including photos. Provide Risk Event Point data, including Wire Down, Ignition, Transmission unplanned outage (as classified non-confidential), Distribution Unplanned Outage data, Distribution Vegetation Caused Unplanned Outage, Risk Event Asset Log. Under Initiative, please provide Grid Hardening data, including Hardening Log, Hardening Point, and Hardening Line data. Inspection data is not requested at this time. Under Initiative, please provide Other Initiative data for point, line, polygon features and the Other Initiative Log. Under Other Required Data, please provide Red Flag Warning Day polygon data.z	Tom Long	4/28/2023	5/1/2023	Appendix D	Areas for Continued Improvement	ACI PG&E-23-16 - Progress and Updates on Undergrounding and Risk Prioritization				
283	MGRA	Data Request No. 3	MGRA_Data Request No. 3	1	MGRA_Data Request No. 3_01		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
284	MGRA	Data Request No. 3	MGRA_Data Request No. 3	2	MGRA_Data Request No. 3_02		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
285	MGRA	Data Request No. 3	MGRA_Data Request No. 3	3	MGRA_Data Request No. 3_03		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
286	MGRA	Data Request No. 3	MGRA_Data Request No. 3	4	MGRA_Data Request No. 3_04		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
287	MGRA	Data Request No. 3	MGRA_Data Request No. 3	5	MGRA_Data Request No. 3_05		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
288	MGRA	Data Request No. 3	MGRA_Data Request No. 3	6	MGRA_Data Request No. 3_06		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
289	MGRA	Data Request No. 3	MGRA_Data Request No. 3	7	MGRA_Data Request No. 3_07		Joseph Mitchell	4/27/2023	5/2/2023	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation				
Pre-Discovery 01	CaPA	Set WMP-01	CaPA_Set WMP-01	1	CaPA_Set WMP-01_01	a. Please explain what is meant by the word "topped" in the phrase: GENERAL OBJECTIONS TO THIS SET OF DATA REQUESTS CalAdvocates-PGE-2023WMP-01 that purport to impose any obligations greater than those provided by the applicable rules and decisions of the Commission on and any other statutes, orders, rules, or laws limiting the regulatory authority and jurisdiction of the Commission. In particular, PG&E objects to the instruction that purports to place a burden on the responding party to reach out to the requesting party to clarify any unclear questions, definitions, or instructions. The duty to prepare precise and well-written instructions, definitions, and requests is on the party seeking the information and cannot be shifted to the responding party. Additionally, PG&E objects to the instruction that PG&E must "include the name and title of the responding individual" as burdensome and not reasonably calculated to lead to the discovery of admissible evidence. Our responses to data requests are not the product of a single individual but of numerous individuals working together from different departments of the company. If the requesting party wishes to contact PG&E with questions or concerns about a data request, it may do so by contacting the appropriate individuals in the Regulatory Relations or Law Department upon whom the request was served PG&E also objects to the following definitions: • The definitions of "plateau" or "concern" which are overbroad and burdensome to the extent they request materials' mention, or be connected with, in any way, the subject of the data requests. • The definitions of the terms "document," "documents," and "documentary material," which include "correspondence" and "communications," making these terms overbroad, unduly burdensome, and not reasonably calculated to lead to the discovery of admissible evidence in this proceeding. • The definition of the phrase "state the basis," which is overbroad and burdensome to the extent it requests "every fact, statistic, inference, supposition, estimate, consideration, conclusion, study, report, and analysis..." ANSWER 001 In addition to all general objections, PG&E specifically objects to this request on the grounds that it is unduly burdensome. PG&E further objects to this request as the information requested is vague, ambiguous, and overbroad. Lastly, PG&E objects to this request on the Attachment "WMP-Discovery2023_DIR_CalAdvocates_001-G026ch01CONP.pdf" is our WMP pre-submission to Energy Safety. Please note that this document is not our final WMP submission and may be subject to revision before the final WMP is submitted in March. Additionally, we have designated this entire submission as confidential to align with Energy Safety's pre-submission process and guidelines which stipulate that the pre-submission documents are not to be made public. In addition to all general objections, PG&E specifically objects to this request on the grounds that it is unduly burdensome. PG&E further objects to this request as the information requested is vague, ambiguous, and overbroad. Lastly, PG&E objects to this request on the grounds that it seeks to impose a continuing response obligation on the responding party. Continuing discovery obligations are not permitted under California law. <i>Biles v. Exxon Mobil Corp.</i> , 124 Cal.App.4th 1315, 1328 (2004); Code Civ. Proc. § 2030.000(g). Notwithstanding and without waiving these objections, PG&E responds as follows. We will do our best to provide the requested information within the requested timeframe, or as soon as possible thereafter. However, please note that due to the timing and voluminous nature of our submissions to Energy Safety, it may not always be possible to provide the information sought within the requested timeframe. In these instances, we will provide the requested information as soon as it is reasonably possible. Additionally, with the exception of confidential and spatial data, please note that we post our WMP-related submissions on our website, www.pge.com/development/infocenter , on the same business day that the documents are provided to Energy Safety. Furthermore, all submissions to Energy Safety are also posted to the relevant docket on the Energy Safety website, https://efiling.energy.ca.gov/ , and are nearly always publicly available within one business day of submission. Public email notifications of the availability of these documents are sent to all parties who subscribe to the service lists for those dockets.	Holly Wehman	2/7/2023	2/14/2023	2/14/2023	https://www.pge.com/pge_ebocal/common/pdfs/efile/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_001_01	0	N/A	N/A	N/A	N/A
Pre-Discovery 02	CaPA	Set WMP-01	CaPA_Set WMP-01	2	CaPA_Set WMP-01_02	"Determining the poles that will be topped." b. Is PG&E unable to offer even a rough approximation of the percentage of	Holly Wehman	2/7/2023	2/15/2023	2/15/2023	https://www.pge.com/pge_ebocal/common/pdfs/efile/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_001_02	1	N/A	N/A	N/A	N/A
Pre-Discovery 03	CaPA	Set WMP-01	CaPA_Set WMP-01	3	CaPA_Set WMP-01_03		Holly Wehman	2/7/2023	2/14/2023	2/14/2023	https://www.pge.com/pge_ebocal/common/pdfs/efile/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_001_03	0	N/A	N/A	N/A	N/A
Pre-Discovery 04	CaPA	Set WMP-01	CaPA_Set WMP-01	4	CaPA_Set WMP-01_04	existing poles in the affected distribution circuits -- including poles	Holly Wehman	2/7/2023	2/14/2023	2/14/2023	https://www.pge.com/pge_ebocal/common/pdfs/efile/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_001_04	0	N/A	N/A	N/A	N/A

Pre-Discovery 05	CaIPA	Set WMP-02	CaIPA_Set WMP-02	1	CaIPA_Set WMP-02_01	supporting primary lines, secondary lines and service - that would be	<p>PG&E understands this question to refer to reports from our internal Quality Control, Quality Assurance, and Quality Verification programs as set forth below.</p> <p>System Inspections Department</p> <p>Please see the attachment below for the System Inspections QC Department's daily and weekly dashboards communicating Key Performance Indicators (KPIs) and analysis.</p> <ul style="list-style-type: none"> •WMP-Discovery2023_DR_CalAdvocates_002-0001Ach01CONF.pdf <p>Please note the above attachment contain confidential information.</p> <p>Electric Compliance Quality Management</p> <ul style="list-style-type: none"> - GO 165 Inspections <p>Please see attachment listed below for the Electric Compliance Quality Management Department's audits of GO 165 inspections. One Distribution and one Transmission system inspections audits were conducted in 2022. Please see attachments "WMP-Discovery2023_DR_CalAdvocates_002-0001Ach02CONF.pdf" and "WMP-Discovery2023_DR_CalAdvocates_002-0001Ach03CONF.pdf".</p> <p>Please note the above attachments contain confidential information.</p> <ul style="list-style-type: none"> •Vegetation Quality Verification (QV) <p>The 2022 WMP submission for Vegetation QV is broken down to the following components: Distribution Reviews, Transmission Reviews, Vegetation Control Reviews, Enhanced Vegetation Management (EVM), and Break-In Audits. Please see the following reports for each of these components:</p> <ul style="list-style-type: none"> o QV/M Work Log (attached as "xlsx") is a comprehensive log for all QV reviews completed in 2022 including a summary of findings for each review as well as a detailed report of those findings. o 2022 EVM Report, attached as "WMP-Discovery2023_DR_CalAdvocates_002-0001Ach05.pdf". •Vegetation Quality Assurance (QA) <p>The 2022 WMP submission for Vegetation QA is broken down by "bundles".</p> <p>Final reports are available for bundles that have been completed to date. Please see the attached zip file for a total of 37 QA Report Packages:</p> <p>"WMP-Discovery2023_DR_CalAdvocates_002-0001Ach06CONF.zip".</p> <p>Please note the above attachments in the Zip folder contain confidential information.</p>	Holly Wetman	2/7/2023	3/7/2023	3/7/2023	https://www.pge.com/page_eboba/common/pdfs/4/ef/ef/emergency-preparedness/catastrophic-wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_002.zip	6	N/A	N/A	N/A	N/A
Pre-Discovery 06	CaIPA	Set WMP-02	CaIPA_Set WMP-02	2	CaIPA_Set WMP-02_02	removed as a result of the planned undergrounding mileage in 2023-2025?	<p>The PG&E Independent Safety Monitor Status Update Report, dated October 4, 2022, discusses programs and initiatives described in our 2022 WMP. Please find the document here: https://www.cpuc.ca.gov/media/cpuc-website/independant-status-update-report-q3-2022.pdf and https://documents.dps.ca.gov/energy-and-enforcement/ism-status-update-report-q3-2022.pdf.</p> <p>Please note the above attachments in the Zip folder contain confidential information.</p>	Holly Wetman	2/7/2023	3/7/2023	3/7/2023	https://www.pge.com/page_eboba/common/pdfs/4/ef/ef/emergency-preparedness/catastrophic-wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_002.zip	1	N/A	N/A	N/A	N/A
Pre-Discovery 07	CaIPA	Set WMP-02	CaIPA_Set WMP-02	3	CaIPA_Set WMP-02_03	Please provide such a rough approximation if possible.	<p>Please see attachment "WMP-Discovery2023_DR_CalAdvocates_002-0001Ach01CONF.xlsx" for a list of all alleged defects identified in December 2021 by the Office of Energy Infrastructure Safety ("Energy Safety"). Please note these defects were issued as notification of defects in March 2022.</p> <p>Please note the following:</p> <ul style="list-style-type: none"> • The data provided for "Defect type", "Description of defect", and "Date that the defect was reported" are all based on Energy Safety's inspection reports. • Not all corrective actions required Electric Corrective (EC) notifications (or "EC tags"). For example, while reviewing the alleged defects from Energy Safety, some work was addressed directly in the field (e.g., trimming of vegetation), and no EC tag was created. • This attachment contains confidential information. 	Holly Wetman	2/7/2023	2/22/2023	2/22/2023	https://www.pge.com/page_eboba/common/pdfs/4/ef/ef/emergency-preparedness/catastrophic-wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_002.zip	1	N/A	8.1.3	Asset Inspections	N/A
Pre-Discovery 08	CaIPA	Set WMP-03	CaIPA_Set WMP-03	1	CaIPA_Set WMP-03_01	<p>Provide an Excel table of all distribution circuits existing as of January 1, 2023 (as rows) that includes the following information in separate columns:</p> <ol style="list-style-type: none"> Circuit name Circuit ID number Total circuit miles Circuit miles in Non-HFTD Areas Circuit miles in Other HFTD Circuit miles in HFTD Tier 2 Circuit miles in HFTD Tier 3 Circuit voltage Circuit SADI (System Average Interruption Duration Index) for 2021 Circuit SADI (System Average Interruption Duration Index) for 2022 Circuit SAIFI (System Average Interruption Frequency Index) for 2021 Circuit SAIFI (System Average Interruption Frequency Index) for 2022 Circuit MAIFI (Momentary Average Interruption Frequency Index) for 2021 Circuit MAIFI (Momentary Average Interruption Frequency Index) for 2022 Total customer-minutes of de-energization on the circuit due to PSPS events in 2021 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to PSPS events in 2022 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2021 Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2022 Number of trees that were worked on for EVM in Non-HFTD in 2021 Number of trees that were worked on for EVM in Non-HFTD in 2022 Number of trees that were worked on for EVM in Other HFTD in 2021 Number of trees that were worked on for EVM in Other HFTD in 2022 Number of trees that were worked on for EVM in HFTD Tier 2 in 2021 Number of trees that were worked on for EVM in HFTD Tier 2 in 2022 Number of trees that were worked on for EVM in HFTD Tier 3 in 2021 Number of trees that were worked on for EVM in HFTD Tier 3 in 2022 Miles of covered conductor installed in Non-HFTD in 2021 <p>Provide an Excel table of all transmission circuits existing as of January 1, 2023 (as rows) that includes the following information in separate columns:</p> <ol style="list-style-type: none"> Circuit name Circuit ID number Total circuit miles Circuit miles in Non-HFTD Areas Circuit miles in Other HFTD Circuit miles in HFTD Tier 2 Circuit miles in HFTD Tier 3 Circuit voltage Total customer-minutes of de-energization on the circuit due to PSPS events in 2021 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to PSPS events in 2022 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2021 Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2022 Number of support structures replaced in Non-HFTD in 2021 Number of support structures replaced in Non-HFTD in 2022 Number of support structures replaced in Other HFTD in 2021 Number of support structures replaced in Other HFTD in 2022 Number of support structures replaced in HFTD Tier 2 in 2021 Number of support structures replaced in HFTD Tier 2 in 2022 Number of support structures replaced in HFTD Tier 3 in 2021 Number of support structures replaced in HFTD Tier 3 in 2022 Miles of LDAR inspection in Non-HFTD in 2021 Miles of LDAR inspection in Non-HFTD in 2022 Miles of LDAR inspection in Other HFTD in 2021 Miles of LDAR inspection in Other HFTD in 2022 Miles of LDAR inspection in HFTD Tier 2 in 2021 Miles of LDAR inspection in HFTD Tier 2 in 2022 Miles of LDAR inspection in HFTD Tier 3 in 2021 	Holly Wetman	2/7/2023	3/10/2023	3/10/2023	https://www.pge.com/page_eboba/common/pdfs/4/ef/ef/emergency-preparedness/catastrophic-wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_003.zip	2	N/A	8.1.3	Asset Inspections	Distribution	
Pre-Discovery 09	CaIPA	Set WMP-03	CaIPA_Set WMP-03	2	CaIPA_Set WMP-03_02	<p>Provide an Excel table of all transmission circuits existing as of January 1, 2023 (as rows) that includes the following information in separate columns:</p> <ol style="list-style-type: none"> Circuit name Circuit ID number Total circuit miles Circuit miles in Non-HFTD Areas Circuit miles in Other HFTD Circuit miles in HFTD Tier 2 Circuit miles in HFTD Tier 3 Circuit voltage Total customer-minutes of de-energization on the circuit due to PSPS events in 2021 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to PSPS events in 2022 (sum of customer-minutes across all PSPS events) Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2021 Total customer-minutes of de-energization on the circuit due to fast-trip settings in 2022 Number of support structures replaced in Non-HFTD in 2021 Number of support structures replaced in Non-HFTD in 2022 Number of support structures replaced in Other HFTD in 2021 Number of support structures replaced in Other HFTD in 2022 Number of support structures replaced in HFTD Tier 2 in 2021 Number of support structures replaced in HFTD Tier 2 in 2022 Number of support structures replaced in HFTD Tier 3 in 2021 Number of support structures replaced in HFTD Tier 3 in 2022 Miles of LDAR inspection in Non-HFTD in 2021 Miles of LDAR inspection in Non-HFTD in 2022 Miles of LDAR inspection in Other HFTD in 2021 Miles of LDAR inspection in Other HFTD in 2022 Miles of LDAR inspection in HFTD Tier 2 in 2021 Miles of LDAR inspection in HFTD Tier 2 in 2022 Miles of LDAR inspection in HFTD Tier 3 in 2021 	Holly Wetman	2/7/2023	3/10/2023	3/10/2023	https://www.pge.com/page_eboba/common/pdfs/4/ef/ef/emergency-preparedness/catastrophic-wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_003.zip	0	N/A	8.1.3	Asset Inspections	Transmission	

Pre-Discovery 10	CaPA	Set WMP-03	CaPA_Set WMP-03	3	CaPA_Set WMP-03_03	<p>Provide an Excel table of all distribution circuits existing as of January 1, 2022 (as rows) that were removed or decommissioned in 2022, either partially or entirely. This includes permanent removal, removal of overhead lines that were moved underground, or overhead lines that were decommissioned but not physically removed. Include the following information in separate columns:</p> <p>a. Circuit name b. Circuit ID number c. Circuit miles removed or decommissioned in Non-HFTD Areas d. Circuit miles removed or decommissioned in Other HFTD e. Circuit miles removed or decommissioned in HFTD Tier 2 f. Circuit miles removed or decommissioned in HFTD Tier 3 g. Reason(s) for removal or decommissioning</p>	<p>Attached is "WMP-Discovery2023_DR_CaAdvocates_003-0004A01.xlsx", which provides information regarding removal of primary distribution lines in HFTD in 2022, which is the subset of the requested information available at this time. PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD. Further, our GIS cannot be used to obtain this information retroactively because when mapping removals, the electric assets are removed from GIS. Below we provide additional information to clarify the data provided in the attachment in response to the request.</p> <p>a. Circuit name: See column C b. Circuit ID number: See column D c. Circuit miles removed or decommissioned in Non-HFTD Areas: NA. As noted above, PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD d. Circuit miles removed or decommissioned in Other HFTD: NA. PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD e. Circuit miles removed or decommissioned in HFTD Tier 2: Column E indicates if the project in the unique circuit segment is in either a Tier 2 and/or Tier 3 HFTD, and column G includes the associated circuit miles. f. Circuit miles removed or decommissioned in HFTD Tier 3: Column E indicates if the project in the unique circuit segment is in either a Tier 2 and/or Tier 3 HFTD, and column G includes the associated circuit miles. g. Reason(s) for removal or decommissioning: See Column F, which notes the name of one of three programs: (1) Fire Rebuild – Removal based on rebuilding in the aftermath of wildfires; (2) Idle Facilities – Unused facilities with no foreseeable future use; or (3) Base SH (System Hardening) – Removal based on the risk-informed criteria used in PG&E's System Hardening Program.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	1	N/A	8.1.2	Grid Design and System Hardening	Work Performed in 2022
Pre-Discovery 11	CaPA	Set WMP-03	CaPA_Set WMP-03	4	CaPA_Set WMP-03_04	<p>Provide an Excel table of all transmission circuits existing as of January 1, 2022 (as rows) that were removed or decommissioned in 2022, either partially or entirely. This includes permanent removal, removal of overhead lines that were moved underground, or overhead lines that were decommissioned but not physically removed. Include the following information in separate columns:</p> <p>a. Circuit name b. Circuit ID number c. Circuit miles removed or decommissioned in Non-HFTD Areas d. Circuit miles removed or decommissioned in Other HFTD e. Circuit miles removed or decommissioned in HFTD Tier 2 f. Circuit miles removed or decommissioned in HFTD Tier 3 g. Reason(s) for removal or decommissioning</p>	<p>Please see "WMP-Discovery2023_DR_CaAdvocates_003-0004A01.xlsx."</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	1	N/A	Grid Design and System Hardening	System Hardening	Work Performed in 2022
Pre-Discovery 12	CaPA	Set WMP-03	CaPA_Set WMP-03	5	CaPA_Set WMP-03_05	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influenced where you performed work in 2022.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of distribution assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. EVM work in 2022 was informed by a modification of the 2021 Wildfire Distribution Risk Model (WDRM). The refined output from the 2021 WDRM is referred to as the EVM Tree-Weighted Prioritization. The EVM Tree-Weighted Prioritization prioritized the high risk OZP with the associated miles and estimated tree work to produce the 2022 EVM Scope of Work as described in the 2022 WMP Section 7.1.B. In 2022, the goals for the EVM program were (1) to perform at least 80% of our 2022 EVM work on the highest 20% of the risk-ranked miles; and (2) to perform approximately 1,800 miles of EVM work by the end of the year. b. As described in the 2022 WMP Section 7.3.1.1 "System Hardening – Distribution," PG&E targeted the highest wildfire risk miles and applied various mitigations such as line removal, conversion from overhead to underground, application of remote grid alternatives, mitigation of exposure through relocation of overhead facilities, and in-place overhead system hardening (emphasis added). For 2022, the highest wildfire risk miles were separated into four categories: 1. The top 20 percent of circuit segments as defined by PG&E's 2021 WDRM v2 for System Hardening. 2. Fire and Major Emergency rebuild within HFTD. 3. PPSIS mitigation projects, and 4. Locations identified by PG&E's Public Safety Specialist (PSS) team as presenting elevated wildfire risk. The primary approach used for selecting and prioritizing circuit segments for covered conductor installation was based on the 2021 WDRM v2. c. As described in the 2022 WMP Section 7.3.1.1 "System Hardening – Distribution," PG&E targeted the highest wildfire risk miles and applied various mitigations such as line removal, conversion from overhead to underground(emphasis added), application of remote grid alternatives, mitigation of exposure through relocation of overhead facilities, and in-place overhead system hardening. For 2022, the highest wildfire risk miles were separated into four categories: 1. The top 20 percent of circuit segments as defined by PG&E's 2021 WDRM v2 for System Hardening. 2. Fire and Major Emergency rebuild within HFTD. 3. PPSIS mitigation projects, and 4. Locations identified by PG&E's Public Safety Specialist (PSS) team as presenting elevated wildfire risk.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	2022 WMP Section 7.1	Wildfire Mitigation Strategy	N/A
Pre-Discovery 13	CaPA	Set WMP-03	CaPA_Set WMP-03	6	CaPA_Set WMP-03_06	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influenced how work in 2022 was sequenced.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of distribution assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. The 2022 EVM Scope of Work was based on the prioritization from the 2021 list of circuit protection zones informed by the EVM Tree Weighted Prioritization barring external factors and regarding efficiency of bundling where possible. b. The circuit segments selected for the installation of covered conductor in the System Hardening program were based on the highest wildfire risk criteria described in response to Question 5(b). To then sequence projects, PG&E assesses the dependencies and readiness of each project based on the stage of the work (e.g., designing/estimating, permit acquisition, construction) to appropriately schedule each individual project, as the development phase for each project can vary widely. Once projects are in the construction phase, schedules can continue to evolve based on various factors that impact project execution including unanticipated weather, material availability, customer preference of timing of re-connection. c. The circuit segments selected for the installation of underground lines in the System Hardening program were based on the highest wildfire risk criteria described in response to Question 5(b). To then sequence projects, PG&E assesses the dependencies and readiness of each project in each stage of the work (e.g., designing/estimating, permit acquisition, land rights acquisition, construction) to appropriately schedule each individual project, as the development time for each project can vary widely. Once projects are in the construction phase, schedules can continue to evolve based on various factors that impact project execution including unanticipated weather, material availability, customer preference of timing of re-connection, discovery of hard rock, and/or detection of unanticipated existing utility infrastructure. d. After the work for 2022 was prioritized based on the process described in Q005, the pole replacement sequencing was determined based on each pole's priority bucket, estimating and material readiness, and crew and clearance availability. Wildfire risk scores were not factors in determining sequencing after prioritization. e. For grid sectionalization, Wildfire Risk scores were not factors in determining how work was sequenced. f. In 2022, wildfire risk scores were not factors in how distribution ground inspections were sequenced. Inspections were sequenced based on field conditions including physical access, environmental restrictions, permitting constraints and customer refusals. g. In 2022, the overhead transmission assets in the work plan for inspection were each bucketed by the average wildfire risk of their host circuit for consideration in inspection. h. PG&E is not conducting EVM in 2023. i. As described in the 2022 WMP Section 8.1.2 "Covered Conductor Installation – Distribution," PG&E's System Hardening program, which includes targeted CC installation, focuses on mitigating potential catastrophic wildfire risk caused by distribution overhead assets. The System Hardening Program applies various mitigations to circuit segments that have the highest wildfire risk. For 2023, the highest wildfire risk miles are identified using the following categories: 1. Top Risk Based on Wildfire Distribution Risk Models (WDRM). The primary approach for selecting system hardening miles used two risk prioritization methodologies: (1) top 20 percent circuit segments based on the 2021 WDRM v2 and (2) the Wildfire Feasibility Efficiency (WFE) ranked circuit segments based on the 2022 WDRM v3. Overhead hardening was selected where undergrounding was deemed infeasible for the WDRM v3 selection. 2. Fire Rebuilds: Rebuilding electric distribution lines within towns and communities in the aftermath of catastrophic wildfires. Overhead hardening Fire Rebuild work is identified through a decision tree to determine the type of rebuild (overhead hardening, undergrounding, or other solution) in areas that have been impacted by a wildfire and may include fire-impacted areas in both HFTD and non-HFTD. 3. PG&E's Public Safety Specialist (PSS) Identified: Locations identified by PG&E's PSS team as presenting elevated wildfire risk, such as ingress/egress constraints and community risk factors. c. As described in the 2022 WMP Section 8.1.2.2 "Undergrounding of Electric Lines and/or Equipment – Distribution," the 2023-2028 undergrounding portfolio is focused on undergrounding lines in the highest risk areas, which include the following: 1. Top Risk-Ranked Circuit Segments Based on WDRM: The primary approach for selecting miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v2; and (2) the WFE-ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility. Both approaches used to select undergrounding projects represent approximately 70 percent of our total wildfire risk. 2. Fire Rebuilds: Undergrounding electric distribution lines within towns and communities that are rebuilding in the aftermath of catastrophic wildfires. Undergrounding work in Fire Rebuild areas typically results from the use of a decision tree to determine the type of asset to rebuild and occurs in areas that have been impacted by an actual wildfire that may include fire-impacted areas in both HFTD and non-HFTD.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	2022 WMP Section 7.1	Wildfire Mitigation Strategy	N/A
Pre-Discovery 14	CaPA	Set WMP-03	CaPA_Set WMP-03	7	CaPA_Set WMP-03_07	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influence where you plan to perform work in 2023.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of distribution assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. PG&E is not conducting EVM in 2023. b. As described in the 2022 WMP Section 8.1.2.2 "Undergrounding of Electric Lines and/or Equipment – Distribution," the 2023-2028 undergrounding portfolio is focused on undergrounding lines in the highest risk areas, which include the following: 1. Top Risk-Ranked Circuit Segments Based on WDRM: The primary approach for selecting miles used two risk prioritization methodologies: (1) Top 20 percent circuit segments based on the 2021 WDRM v2; and (2) the WFE-ranked circuit segments based on the 2022 WDRM v3 and considering undergrounding feasibility. Both approaches used to select undergrounding projects represent approximately 70 percent of our total wildfire risk. 2. Fire Rebuilds: Undergrounding electric distribution lines within towns and communities that are rebuilding in the aftermath of catastrophic wildfires. Undergrounding work in Fire Rebuild areas typically results from the use of a decision tree to determine the type of asset to rebuild and occurs in areas that have been impacted by an actual wildfire that may include fire-impacted areas in both HFTD and non-HFTD.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy

Pre-Discovery 15	CaPA	Set WMP-03	CaPA_Set WMP-03	8	CaPA_Set WMP-03_08	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influence how work in 2023 will be sequenced.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of transmission assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. PG&E is not conducting EVM in 2023. b. The circuit segments selected for the installation of covered conductor in the System Hardening program were based on the highest wildfire risk criteria described in response to Question 7(b). To then sequence projects, PG&E assesses the dependencies and readiness of each project based on the stage of the work (e.g., design/estimating, permit acquisition, construction) to appropriately schedule each individual project, as the development time for each project can vary widely. Once projects are in the construction phase, schedules can continue to evolve based on various factors that impact project execution, including unanticipated weather, material availability, and customer preference of timing of re-connection. c. The circuit segments selected for the installation of underground lines in the System Hardening program were based on the highest wildfire risk criteria described in response to Question 7(c). To then sequence projects, PG&E assesses the dependencies and readiness of each project in each stage of the work (e.g., design/estimating, permit acquisition, land rights acquisition, construction) to appropriately schedule each individual project, as the development time for each project can vary widely. Once projects are in the construction phase, schedules can continue to evolve based on various factors that impact project execution, including unanticipated weather, material availability, community limitations (e.g., for road closures), customer preference of timing of re-connection, discovery of hard rock, and/or detection of unarmored existing utility infrastructure. d. After the work for 2023 is prioritized based on the process described in response to Q007 part d, the pole replacement sequencing is determined based on each pole's priority bucket, estimating and material readiness, and crew and clearance availability. e. For transmission line, there is no targeted work planned in 2023 for grid sectionalization. For distribution, the 2023 additional sectionalizing and protective device installation work is prioritized by highest reliability benefits and not wildfire risk. f. In 2023, PG&E's sequencing for the ground inspection plan is informed by wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. Detailed inspection activities in HTD and HFRA are scheduled such that extreme, severe, and high consequence pilot maps will be completed by July 31. Medium consequence pilot maps will be completed by October 1. Low consequence pilot maps will be completed by December 31. Inspections are also sequenced based on field conditions including physical access, environmental restrictions, permitting constraints and customer refusals. g. In 2023, PG&E's sequencing for the ground inspection plan is informed by wildfire risk and wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. PG&E developed a frequency recommendation for each level of wildfire consequence: extreme and severe consequence pilot maps will be inspected annually, high consequence pilot maps will be inspected every other year, and all other pilot maps will be inspected once every three years. Structures that constitute the top 10 percent of wildfire risk but are not already included in a pilot map that is being inspected by ground or aerial are also included in the 2024 ground inspection plan. h. In 2024, wildfire risk and wildfire consequence will inform the annual overhead detailed inspection scope at a structure level (in addition to other considerations such as inspection trends and a baseline frequency of every three years for HTD/HFRA assets). Specifically, highest wildfire risk and wildfire consequence locations were included in the 2024 scope. i. In 2024, PG&E's distribution aerial inspection pilot will be informed by wildfire risk and wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. For aerial inspections, PG&E used the same prioritization framework with the same pilot map level designation that we used for detailed ground inspections and is described in Section 6.1.3.2.1. The specific structures and pilot maps to be included for inspection in 2024 will depend on 2023 pilot results. j. In 2024, wildfire risk and wildfire consequence will inform the annual overhead detailed inspection scope at a structure level (in addition to other considerations such as inspection trends and a baseline frequency of every three years for HTD/HFRA assets). Specifically, highest wildfire risk and wildfire consequence locations were included in the 2024 scope. k. PG&E does not have a stand-alone LIDAR distribution inspection program but collects LIDAR data on distribution to support various needs, including flight planning for aerial inspections and engineering analyses, such as pole loading calculations. PG&E did not use the wildfire risk model in 2022 or 2023 to select locations or sequence LIDAR collection activities.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy
Pre-Discovery 16	CaPA	Set WMP-03	CaPA_Set WMP-03	9	CaPA_Set WMP-03_09	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influence where you plan to perform work in 2024.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of distribution assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. PG&E is not conducting EVM in 2024. b. Please refer to the response to Question 7b, which also applies to 2024. c. Please refer to the response to Question 7c, which also applies to 2024. d. Please refer to the response to Question 7d, which also applies to 2024. e. For transmission line, there is no targeted work planned in 2024 for grid sectionalization. For distribution, there is no targeted work planned in 2024 for grid sectionalization as future work related to EPSS reliability will be incorporated into base reliability programs. f. In 2024, PG&E's detailed ground inspection plan will be informed by wildfire risk and wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. PG&E developed a frequency recommendation for each level of wildfire consequence: extreme and severe consequence pilot maps will be inspected annually, high consequence pilot maps will be inspected every other year, and all other pilot maps will be inspected once every three years. Structures that constitute the top 10 percent of wildfire risk but are not already included in a pilot map that is being inspected by ground or aerial are also included in the 2024 ground inspection plan. g. In 2024, wildfire risk and wildfire consequence will inform the annual overhead detailed inspection scope at a structure level (in addition to other considerations such as inspection trends and a baseline frequency of every three years for HTD/HFRA assets). Specifically, highest wildfire risk and wildfire consequence locations were included in the 2024 scope. h. In 2024, PG&E's distribution aerial inspection pilot will be informed by wildfire risk and wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. For aerial inspections, PG&E used the same prioritization framework with the same pilot map level designation that we used for detailed ground inspections and is described in Section 6.1.3.2.1. The specific structures and pilot maps to be included for inspection in 2024 will depend on 2023 pilot results. i. In 2024, wildfire risk and wildfire consequence will inform the annual overhead detailed inspection scope at a structure level (in addition to other considerations such as inspection trends and a baseline frequency of every three years for HTD/HFRA assets). Specifically, highest wildfire risk and wildfire consequence locations were included in the 2024 scope. j. PG&E does not have a stand-alone LIDAR distribution inspection program but collects LIDAR data on distribution to support various needs, including flight planning for aerial inspections and engineering analyses, such as pole loading calculations. PG&E did not use the wildfire risk model in 2022 or 2023 to select locations or sequence LIDAR collection activities.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy
Pre-Discovery 17	CaPA	Set WMP-03	CaPA_Set WMP-03	10	CaPA_Set WMP-03_10	<p>For each WMP initiative listed below, please state how the modeled Wildfire Risk Scores for each circuit or circuit-segment influence how work in 2024 will be sequenced.</p> <p>a. EVM b. Covered conductor installation c. Undergrounding d. Distribution pole replacement e. Grid sectionalization f. Detailed inspections of distribution assets g. Detailed inspections of transmission assets h. Aerial inspections of distribution assets i. Aerial inspections of transmission assets j. LIDAR inspections of distribution assets k. LIDAR inspections of transmission assets</p>	<p>a. PG&E is not conducting EVM in 2024. b. Please refer to the response to Question 7b, which also applies to 2024. c. Please refer to the response to Question 7c, which also applies to 2024. d. Please refer to the response to Question 7d, which also applies to 2024. e. There is no targeted work planned in 2024 for grid sectionalization for both transmission or distribution. f. In 2024, PG&E's sequencing for the ground inspection plan will be informed by wildfire consequence as described in 2023 WMP Section 6.1.3.2.1. Detailed inspection activities in HTD and HFRA are scheduled such that extreme, severe, and high consequence pilot maps will be completed by July 31. Medium consequence pilot maps will be completed by October 1. Low consequence pilot maps will be completed by December 31. Inspections are also sequenced based on field conditions including physical access, environmental restrictions, permitting constraints and customer refusals. g. In 2024, the overhead transmission assets in scope for inspection are each labeled with the average wildfire risk of their host circuit for consideration in inspection sequencing. Assets are typically grouped by line for execution efficiency. The sequence prioritization also considers operational field knowledge and constraints, including restricted physical access periods, to inform the schedule for completion. h. In 2024, PG&E's sequencing for the pilot aerial inspections will not be directly based on wildfire risk score. However, in areas of overlap with detailed ground inspections, aerial inspections are scheduled to take place in the same time frame as the scheduled ground inspection, which is based on wildfire consequence. Sequencing is based on the scheduled ground inspection as well as operational field knowledge and constraints, including restricted physical access periods. The specific structures and pilot maps to be included for inspection in 2024 will depend on 2023 pilot results. i. In 2024, the overhead transmission assets in scope for inspection are each labeled with the average wildfire risk of their host circuit for consideration in inspection sequencing. Assets are typically grouped by line for execution efficiency. The sequence prioritization also considers operational field knowledge and constraints, including restricted physical access periods, to inform the schedule for completion. j. PG&E does not have a stand-alone LIDAR distribution inspection program but collects LIDAR data on distribution to support various needs, including flight planning for aerial inspections and engineering analyses, such as pole loading calculations. PG&E did not use the wildfire risk model in 2022 or 2023 to select locations or sequence LIDAR collection activities.</p>	Holly Wehman	2/7/2023	3/10/2023	3/10/2023	0	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy
Pre-Discovery 18	CaPA	Set WMP-04	CaPA_Set WMP-04	1	CaPA_Set WMP-04_01	<p>For each WMP initiative for which you forecast capital expenditures in 2023 to be at least two times actual capital expenditures in 2022, please provide:</p> <p>a) The name of the initiative as it is identified in your 2023-2025 WMP b) The WMP initiative number in Table 11 of your 2023-2025 WMP c) The name of the initiative as it is identified in your 2022 WMP Update d) The WMP initiative number in Table 12 of your 2022 WMP Update e) An explanation for the projected increase.</p>	<p>a) 2023 WMP financials are mapped per WMP Initiative Activities as laid out in Table 11 from Energy Safety. As the 2023 WMP is a new cycle with new mapping of financials by activities that align with the 2023 WMP narrative, there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view. Below are the 2023 WMP activities and section numbers where 2023 capital forecast is at least two times compared to the 2022 recorded costs: - Customer support in wildfire and PSPS emergencies – section 8.4.6 - Traditional Overhead Hardening Transmission – 6.1.2.5 b) See the response to part a). c) N/A. As explained in response to part a), there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view of 2022 recorded costs. d) N/A, please refer to part c). e) Explanations for the projected increase are below: - Customer support in wildfire and PSPS emergencies – There was a minor cost adjustment/correction in the 2022 recorded costs which resulted in a credit/negative in the 2022 recorded costs as shown in Table 11. - Traditional Overhead Hardening Transmission – We look to complete 43 miles in 2023 as compared to 38 miles in 2022. In addition, the 2022 recorded costs reported in Table 11 are low due to missing some costs. The 2022 recorded cost for this initiative should be \$7.1M instead of \$4.9M. We will correct this item in Table 11 pursuant to the 2023-2025 WMP Guidelines from Energy Safety.</p>	Holly Wehman	2/7/2023	3/7/2023	3/7/2023	0	N/A	Section 4.3	Proposed Expenditures	N/A
Pre-Discovery 19	CaPA	Set WMP-04	CaPA_Set WMP-04	2	CaPA_Set WMP-04_02	<p>For each WMP initiative for which you forecast capital expenditures in 2024 to be at least two times actual capital expenditures in 2022, please provide:</p> <p>a) The name of the initiative as it is identified in your 2023-2025 WMP b) The WMP initiative number in Table 11 of your 2023-2025 WMP c) The name of the initiative as it is identified in your 2022 WMP Update d) The WMP initiative number in Table 12 of your 2022 WMP Update e) An explanation for the projected increase.</p>	<p>a) 2023 WMP financials are mapped per WMP Initiative Activities as laid out in Table 11 from Energy Safety. As the 2023 WMP is a new cycle with new mapping of financials by activities that align with the 2023 WMP narrative, there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view. Below are the 2023 WMP activities and section number where the 2024 capital forecast is at least two times compared to the 2022 recorded costs: - Customer support in wildfire and PSPS emergencies – section 8.4.6 c) N/A. As explained in part a) there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view of 2022 recorded costs. d) N/A, please refer to the response to part c). e) Explanations for the projected increase are below: - Customer support in wildfire and PSPS emergencies – There was a minor cost adjustment/correction in the 2022 recorded costs which resulted in a credit/negative in the 2022 recorded costs as shown in Table 11.</p>	Holly Wehman	2/7/2023	3/7/2023	3/7/2023	0	N/A	Section 4.3	Proposed Expenditures	N/A

Discovery	Year	Activity	Category	Priority	Owner	Start	End	Due Date	Status	Notes	Impact	Dependencies	
Pre-Discovery 20	2020	CalPA	Set WMP-04	CalPA_Set WMP-04	3	CalPA_Set WMP-04_03			0	N/A	Section 4.3	Proposed Expenditures	N/A
<p>For each WMP initiative for which you forecast operating expenditures in 2023 to be at least two times actual operating expenditures in 2022, please provide:</p> <p>a) The name of the initiative as it is identified in your 2023-2025 WMP b) The WMP initiative number in Table 11 of your 2023-2025 WMP c) The name of the initiative as it is identified in your 2022 WMP Update d) The WMP initiative number in Table 12 of your 2022 WMP Update e) An explanation for the projected increase.</p>						<p>a) 2023 WMP Financials are mapped per WMP Initiative Activities as laid out in Table 11 from Energy Safety. As the 2023 WMP is a new cycle with new mapping of financials by activities that align with the 2023 WMP narrative, there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view. Below are the 2023 WMP activities and section numbers where 2023 operating expense forecasts are at least two times compared to the 2022 recorded costs: • Other technologies and systems not listed above – section 8.1.2.12 • Environmental monitoring systems – 8.3.2 • Fall-in mitigation 8.2.3.4 b) See the response to part a). c) N/A. As explained in part a) there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view of 2022 recorded costs. d) N/A. Please refer to the response to part c). e) Explanations for the projected increases are below: • Other technologies and systems not listed above – The 2022 recorded costs in Table 11 are too low due to missing some costs. The 2022 recorded costs need to be adjusted to pull in recorded costs for Substation animal abatement. We will correct this item in Table 11 pursuant to the 2023-2025 WMP Guidelines from Energy Safety. • Environmental monitoring systems – The forecast increase in 2023 is mainly driven by anticipated weather station maintenance work such as calibrations. • Fall-in mitigation – The forecast increase is due to implementing three new VM programs starting in 2023 that support fall-in mitigations (VM for Operational Mitigations, Tree Removal Inventory, Focused Tree Inspections). Please refer to the 2023 WMP narrative in section 8.2.3.4 for additional details.</p>							
Pre-Discovery 21	2021	CalPA	Set WMP-04	CalPA_Set WMP-04	4	CalPA_Set WMP-04_04			0	N/A	Section 4.3	Proposed Expenditures	N/A
<p>For each WMP initiative for which you forecast operating expenditures in 2024 to be at least two times actual operating expenditures in 2022, please provide:</p> <p>a) The name of the initiative as it is identified in your 2023-2025 WMP b) The WMP initiative number in Table 11 of your 2023-2025 WMP c) The name of the initiative as it is identified in your 2022 WMP Update d) The WMP initiative number in Table 12 of your 2022 WMP Update e) An explanation for the projected increase.</p>						<p>a) 2023 WMP Financials are mapped per WMP Initiative Activities as laid out in Table 11 from Energy Safety. As the 2023 WMP is a new cycle with new mapping of financials by activities that align with the 2023 narrative, there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view. Below are the 2023 WMP activities and section numbers where 2024 operating expense forecasts are at least two times the 2022 recorded costs: • Other technologies and systems not listed above – section 8.1.2.7 • Microgrids – section 8.1.2.7 • Environmental monitoring systems – 8.3.2 • Fall-in mitigation 8.2.3.4 b) See the response to part a). c) N/A. As explained in part a) there is not an apples-to-apples re-mapping of costs back to the 2022 WMP view. Thus, the comparison can only be made using the 2023 WMP view of 2022 recorded costs. d) N/A. Please refer to the response to part c). e) Explanations for the projected increases are below: • Other technologies and systems not listed above – The 2022 recorded costs are too low by anticipated weather station maintenance work such as calibrations. • Fall-in mitigation – The forecast increase is due to implementing three new VM programs that support fall-in mitigations (VM for Operational Mitigations, Tree Removal Inventory, Focused Tree Inspections). Please refer to the narrative in section 8.2.3.4 of the 2023 WMP for more details due to missing some costs. The 2022 recorded costs need to be adjusted to pull in recorded costs for Substation animal abatement. We will correct this item in Table 11 pursuant to the 2023-2025 WMP Guidelines from Energy Safety. • Microgrids – The projected increase is based on forecast and anticipated projects put forward to the CPUC in PG&E's Microgrids Incentive Program Implementation Plan. The plan is currently awaiting a CPUC Decision. • Environmental monitoring systems – The forecast increase in 2023/2024 is mainly driven.</p>							
Pre-Discovery 22	2022	CalPA	Set WMP-05	CalPA_Set WMP-05	1	CalPA_Set WMP-05_01			0	N/A	2022 WMP Section 4.5	Model Metrics and Calculation Methodologies	WORM v3
<p>In response to Data Request CalAdvocates-PGE-2022WMP-31 on September 8, 2022, PG&E provided information regarding its Wildlife Distribution Risk Model version 3 (WDRM v3). Please provide an updated response to questions 1-7 of the above-referenced data request, including any new or changed information since PG&E's original response. If the response to a question has not changed, please so indicate.</p>						<p>No changes have been made to WDRM v3 since the September 8, 2022 response.</p>							
Pre-Discovery 23	2023	CalPA	Set WMP-05	CalPA_Set WMP-05	2	CalPA_Set WMP-05_02			0	N/A	8.1.3	Asset Inspections	N/A
<p>a) Have you identified transportation corridors within your service territory where falling or falling lines or poles could currently impede ingress and/or egress during an emergency? If the answer to part (a) is yes, please describe how you identify such transportation corridors. If available, please provide a geospatial data file that contains all current identified transportation corridors with ingress and egress hazards.</p>						<p>a) The potential of falling or falling lines or poles near identified transportation corridors is not currently reflected in our risk modeling. PG&E Public Safety Specialists with experience as career wildland firefighters have reviewed general ingress and/or egress considerations when evaluating circuits or circuit segments for potential system hardening work. b) Not applicable c) Not applicable</p>							
Pre-Discovery 24	2024	CalPA	Set WMP-05	CalPA_Set WMP-05	3	CalPA_Set WMP-05_03			1	N/A	8.1.3	Asset Inspections	Inspections completed in 2022
<p>Please fill out the attached spreadsheet, CalAdvocates-PGE-2023WMP-05 Attachment 1, requesting information regarding your asset inspections in 2022.</p>						<p>Please see attachment 'WMP-Discovery2023_DR_CalAdvocates_005-0003A0ch01.xlsx' for the requested information</p>							
Pre-Discovery 25	2023	CalPA	Set WMP-05	CalPA_Set WMP-05	4	CalPA_Set WMP-05_04			2	N/A	2022 Q4 ODR	Asset Management and Inspections	tags
<p>Please augment Table 13 of the non-spatial data tables in your WMP Quarterly Data Report for Q4 of 2022, which reports asset-related corrective notifications on electric circuits that were open at the end of the quarter, as follows:</p> <p>a. Add the following information in separate columns: i. Name of the associated circuit ii. ID number of the associated circuit iii. Geographic latitude in decimal degrees, truncated to seven decimal places iv. Geographic longitude in decimal degrees, truncated to seven decimal places v. Priority of the original notification, using PG&E's internal priority level codes vi. Object/damage code or other external description of defect vii. Please complete column b ('Equipment type') of Table 13. c. Please complete or explain why each of the below columns is not applicable: i. Column j ii. Column k iii. Column l</p>						<p>a-b. Please see attachments 'WMP-Discovery2023_DR_CalAdvocates_005-0004A0ch01.xlsx' for the requested Distribution Information and 'WMP-Discovery2023_DR_CalAdvocates_005-0004A0ch02.xlsx' for the requested Transmission Information. c. Please note that columns i, j, k, and l will not be available for Distribution and Transmission circuits until the 2023 Q1 Quarterly Data Report (QDR) because the data is not ready, and due to recent changes to the standard that resulted in a substantial reassessment of our notification data.</p>							
Pre-Discovery 26	2023	CalPA	Set WMP-06	CalPA_Set WMP-06	1	CalPA_Set WMP-06_01			0	N/A	2023-2025 WMP 8.2.3	Vegetation Management	EVN
<p>Provide your workplan that describes where you will undertake EVN projects in 2023. This workplan should be in an Excel format, with circuit-segments as rows. Please include the following information in separate columns in the Excel spreadsheet at a minimum: a) Circuit name b) Circuit ID number c) Circuit-segment name d) EVN miles to be completed in 2023 e) Risk ranking(s) for the circuit segment</p>						<p>The EVN program concluded at the end of 2022. There is no EVN workplan for 2023.</p>							
Pre-Discovery 27	2023	CalPA	Set WMP-06	CalPA_Set WMP-06	2	CalPA_Set WMP-06_02			0	N/A	2023-2025 WMP 8.2.3	Vegetation Management	EVN
<p>Provide your workplan that describes where you will undertake EVN projects in 2024. This workplan should be in an Excel format, with circuit-segments as rows. Please include the following information in separate columns in the Excel spreadsheet at a minimum: a) Circuit name b) Circuit ID number c) Circuit-segment name d) EVN miles to be completed in 2024 e) Risk ranking(s) for the circuit segment</p>						<p>The EVN program concluded at the end of 2022. There is no EVN workplan for 2024.</p>							
Pre-Discovery 28	2022	CalPA	Set WMP-06	CalPA_Set WMP-06	3	CalPA_Set WMP-06_03			1	N/A	2022 WMP 7.3.5.2	Vegetation Management and Inspections	Enhanced Vegetation Management
<p>In response to Data Request CalAdvocates-PGE-2022WMP-11, Question 2, March 3, 2022, PG&E provided its 2022 EVN workplan. Please provide an updated version of this workplan that lists the actual EVN mileage performed in each circuit-segment in 2022 as a new column. Rows should be added as needed to cover all circuit-segments where you performed EVN work in 2022 (even if those circuit-segments were not included in the original workplan).</p>						<p>Please see 'WMP-Discovery2023_DR_CalAdvocates_006-0003A0ch01.xlsx' for actual 2022 EVN mileage data broken down by circuit segment. Column G on tab '2022 EVN Miles Planned' contains the number of miles planned for EVN work in 2022. Column G on tab '2022 EVN Miles Completed' contains the number of miles that were completed and work settled in 2022.</p>							
Pre-Discovery 29	2023	CalPA	Set WMP-06	CalPA_Set WMP-06	4	CalPA_Set WMP-06_04			0	N/A	2022 WMP 7.3.5	Vegetation Management and Inspections	Program Costs
<p>In response to Data Request CalAdvocates-PGE-2022WMP-16, Question 11, March 23, 2022, PG&E stated the following: "Through 2022, the EVN program includes strike tree evaluation and hazard trees mitigation, overhead clearing and radial clearance. Starting in 2023, Enhanced VM only includes overhead clearing." a) Is the statement above still accurate as of the date of this request? b) If the answer to part (a) is no, please update the above statement to reflect PG&E's vegetation management strategy for 2023. c) If the answer to part (a) is no, please update the above statement to reflect PG&E's vegetation management strategy for 2024.</p>						<p>a) To maximize reduction of wildfire risk effectively and efficiently, the Enhanced Vegetation Management (EVM) program concluded at the end of 2022. b) Three new VM programs will be incorporated into the 2023 workplan. These programs for VM are Focused Tree Inspections, VM for Operational Mitigations, and Tree Removal Inventory. • Focused Tree Inspections: We developed specific areas of focus (referred to as Areas of Concern (AOC)), primarily in the HARA, where we will concentrate our efforts to inspect and address high-risk locations, such as those that have experienced higher volumes of vegetation damage during PSPS events, outages, and/or ignitions. • VM for Operational Mitigations: This program is intended to help reduce outages and potential ignitions using a risk informed, targeted plan to mitigate potential vegetation contacts based on historic vegetation-caused outages on EPSS-enabled circuits. We will initially focus on mitigating potential vegetation contacts in circuit protection zones that have experienced vegetation-caused outages. Scope of work will be developed by using EPSS and historical outage data and vegetation failure from the WDRM v3 risk model. EPSS-enabled devices-vegetation outages extent of condition inspections may generate additional tree work. • Tree Removal Inventory: This is a long-term program intended to systematically work down trees that were previously identified through EVM inspections. We will develop annual risk-ranked work plans and mitigate the highest risk-ranked areas first and will continue monitor the condition of these trees through our established inspection programs. c) The three programs identified above will continue in 2024. These combined three programs are also referred to as EVN Transitional programs.</p>							

Pre-Discovery 30	CalPA	Set WMP-06	CalPA_Set WMP-06	5	CalPA_Set WMP-06_05	In response to Data Request CalAdvocates-PGE-2022WMP-16, Question 16, March 18, 2022, PG&E provided the following table, which shows spending on vegetation management programs in thousands of dollars (actual figures for 2019-2021 and forecast figures for 2022-2023). Please update this table as follows: a) Update the 2022 column to state actual spending in 2022. b) Update the 2023 column to show PG&E's current forecasts for 2023. c) Add a column that shows PG&E's current forecasts for 2024. d) Please add rows as necessary, if any changes in PG&E's vegetation management strategy have created new initiatives or categories of spending.	Please see updated table below with 2022 Actuals, and our current forecasts for 2023 and 2024.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	0	N/A	Vegetation Management	N/A	N/A
Pre-Discovery 31	CalPA	Set WMP-06	CalPA_Set WMP-06	6	CalPA_Set WMP-06_06	Please provide a list of any incidents in 2022 where the actions of a VM contractor posed a safety risk to workers and/or the public. "Safety risk" here is defined as any occurrence on a worksite where the contractor's actions created a safety hazard for either workers or the general public. For each instance, please provide: a) The date you were informed of the safety issue b) The date that the original work that created the safety issue was performed c) Whether the safety issue concerned a transmission or distribution circuit d) The vegetation management initiative involved in the original work e) A brief description of the safety issue involved.	Please refer to Attachment "WMP-Discovery2023_DR_CalAdvocates_006-Q006Ach01CONF.xlsx" for a list of all contractors involved safety incidents that took place in 2022. This data includes, but is not limited to: • Contractor Name/ParentCo: The contractor/parent company involved in the incident. • InDate: The date of the incident. • Date EN: The date the incident was formally reported and logged. • Division: The division where the incident took place. • InCo: Types: The incident type (ie line strike) • Incident Description: A brief description of the incident. • Program: Description on which initiative a contractor was working on, on the date of incident. • Corrective Action: A description of the action(s) PG&E took to prevent recurrence. Please note, both Distribution and Transmission contractor incidents are included in the attachment. These records are pulled from the Enterprise Contractor Incident Records Tool (ECIRT) database. The ECIRT database incident recording process does not have a space for inputting Distribution or Transmission circuit information, therefore we are unable to provide that information on the spreadsheet because our system does not track the incidents that way.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	1	N/A	Vegetation Management	N/A	N/A
Pre-Discovery 32	CalPA	Set WMP-06	CalPA_Set WMP-06	7	CalPA_Set WMP-06_07	In response to Data Request CalAdvocates-PGE-2022WMP-14, Question 13, March 15, 2022, PG&E provided its 2022 system hardening workplan for the categories referred to in parts (a)-(f) below. Please provide an updated version of this workplan with additional columns to show the actual system hardening work performed in each circuit-segment in 2022 for each of these categories. Please add rows as needed to cover all circuit-segments where PG&E performed system hardening work in 2022 (even if those circuit-segments were not included in the original workplan). a) Installation of covered conductor b) Installation of underground conductor c) Removal of overhead conductor d) Removal of overhead conductor associated with remote grid work.	Note, for CalAdvocates-PGE-2022WMP-14, Question 13, the projects listed in the 2022 columns were only for projects that overlapped with 2021 completed miles. It did not represent a comprehensive list of 2022 projects. Similarly, the 2020 columns were only for projects that overlapped with 2021 completed miles. It did not represent a comprehensive list of 2020 projects. See "WMP-Discovery2023_DR_CalAdvocates_006-Q007Ach01CONF.xlsx." This file includes the 2022 system hardening completed work in the below columns: a. Installation of covered conductor: See column O b. Installation of underground conductor: See column P c. Removal of overhead conductor: See column Q. Note, this removal work is not associated with the lines removed from overhead for installation of underground projects. It is strictly overhead conductor completely de-energized and removed. d. Removal of overhead conductor associated with remote grid work: N/A. There are no removals from remote grid work in 2022. Since the installation of remote grid generating units work occurred late in 2022, the associated line removal of de-energized conductor will take place in 2023. Similar to the response to CalAdvocates-PGE-2022WMP-14, Question 13, the data includes project information from 2021 and 2023 only where projects overlap with those years. Thus, the 2021 and 2023 data is not comprehensive. Additionally, because this question is associated with the System Hardening workplan only, this data does not include underground mileage associated with the Butte Reservoir.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	1	N/A	2022 WMP Section 7.3.3.17	Grid Design and System Hardening	System Hardening
Pre-Discovery 33	CalPA	Set WMP-06	CalPA_Set WMP-06	8	CalPA_Set WMP-06_08	Provide your workplan that describes where and when you will perform system hardening on distribution circuits in 2023. For projects that you expect to partially complete in 2023 (i.e., projects that started before 2023 and are expected to continue in 2023), or projects that are expected to be completed after 2023, please include the project and report the work that you forecast will actually be performed in calendar year 2023. For each project, include the following information in separate columns, at a minimum: a) Order number b) MAT code c) Program d) Circuit ID number e) Circuit-segment name or ID number (if the project affects more than one circuit-segment, please identify each one) f) Relevant wildfire risk score(s) from the wildfire risk model that you are using to estimate distribution risk in your 2023-2025 WMP filing g) The expected or actual start date of the project. h) The expected completion date of the project. i) Length (in circuit miles) of covered conductor to be installed in 2023. j) Length (in circuit miles) of underground conductor to be installed in 2023. k) Length (in circuit miles) of overhead conductor to be permanently removed in 2023 and replaced by underground conductor (note that this may differ slightly from the previous section due to differing overhead and underground routes). l) Length (in circuit miles) of overhead conductor to be permanently removed in 2023 and not replaced with covered conductor or underground). m) Length (in circuit miles) of any other type of system hardening project to be installed in 2023 (if this is greater than zero, please describe the type of system hardening project).	Please see attachment "WMP-Discovery2023_DR_CalAdvocates_006-Q008Ach01CONF.xlsx." a. See columns A (order number), and B (order description) b. See column C c. See column D d. See column E e. See column F f. See columns G, I and K Column G shows the Applicable Risk Model that was used for selecting the project and putting it into scope. Risk Rank scores, shown in Columns I and K, are based on the Wildfire Distribution Risk Model (WDRM) for Version 2 and Version 3, respectively. The Risk ranking outcomes are the results of the relevant risk model (e.g., WDRM v2, WDRM v3) where circuit segments are ranked on a 1 to N basis, where 1 is the highest risk circuit segment, and N is the lowest risk. g. See column L h. See column M i. See column AA j. See column AB k. N/A - PG&E does not track length (in circuit miles) of overhead conductor to be permanently removed and replaced by underground. l. See column AB m. N/A The data includes project information from prior to 2022 and 2022 where projects overlap with these years. Data is provided in the same file for 2024 that is responsive to Question Q009. Additionally, because this question is associated with the System Hardening workplan only, this data does not include underground mileage associated with the Butte Reservoir.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	1	N/A	2023 WMP Section 8.1.2.5	System Hardening	N/A
Pre-Discovery 34	CalPA	Set WMP-06	CalPA_Set WMP-06	9	CalPA_Set WMP-06_09	Provide your workplan that describes where and when you will perform system hardening on distribution circuits in 2024. For projects that you expect to partially complete in 2024 (i.e., projects that are expected to start before 2024 and are expected to continue in 2024), or projects that are expected to be completed after 2024, please include the project and report the work that you forecast will actually be performed in calendar year 2024. For each project, include the following information in separate columns, at a minimum: a) Order number b) MAT code c) Program d) Circuit ID number e) Circuit-segment name or ID number (if the project affects more than one circuit-segment, please identify each one) f) Relevant wildfire risk score(s) from the wildfire risk model that you are using to estimate distribution risk in your 2023-2025 WMP filing g) The expected or actual start date of the project. h) The expected completion date of the project. i) Length (in circuit miles) of covered conductor to be installed in 2024. j) Length (in circuit miles) of underground conductor to be installed in 2024. k) Length (in circuit miles) of overhead conductor to be permanently removed in 2024 and replaced by underground conductor (note that this may differ slightly from the previous section due to differing overhead and underground routes). l) Length (in circuit miles) of overhead conductor to be permanently removed in 2024 and not replaced with covered conductor or underground). m) Length (in circuit miles) of any other type of system hardening project to be installed in 2024 (if this is greater than zero, please describe the type of system hardening project).	Please see "WMP-Discovery2023_DR_CalAdvocates_006-Q009Ach01CONF.xlsx." a. See columns A (order number), and B (order description) b. See column C c. See column D d. See column E e. See column F f. See columns G, I and K Column G shows the Applicable Risk Model that was used for selecting the project and putting it into scope. Risk Rank scores, shown in Columns I and K, are based on the Wildfire Distribution Risk Model (WDRM) for Version 2 and Version 3, respectively. The Risk ranking outcomes are the results of the relevant risk model (e.g., WDRM v2, WDRM v3) where circuit segments are ranked on a 1 to N basis, where 1 is the highest risk circuit segment, and N is the lowest risk. g. See column L h. See column M i. See column AD j. See column AE k. N/A - PG&E does not track length (in circuit miles) of overhead conductor to be permanently removed and replaced by underground. l. See column AF m. N/A The data includes project information from prior to 2022, 2022, and 2023 where projects overlap with these years. Data is provided in the same file for 2024 that is responsive to Question Q008. Additionally, because this question is associated with the System Hardening workplan only, this data does not include underground mileage associated with the Butte Reservoir.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	0	N/A	2023 WMP Section 8.1.2.5	System Hardening	N/A
Pre-Discovery 35	CalPA	Set WMP-06	CalPA_Set WMP-06	10	CalPA_Set WMP-06_010	For each of your 2023-2025 WMP system hardening initiatives, please provide disaggregated information related to expenditures and circuit miles treated in the attached table, CalAdvocates PGE-2023WMP-06 Attachment 1. Add columns as needed.	Please see details on the cost and mileage breakdowns in attached file "WMP-Discovery2023_DR_CalAdvocates_006-Q010Ach01CONF.xlsx"	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_azobal/common/pdfs/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/2023/CalAdvocates_006.zip	1	N/A	2023 WMP Section 4.3	Proposed Expenditures	System Hardening

Pre-Discovery 36	CalPA	Set WMP-06	CalPA_Set WMP-06	11	CalPA_Set WMP-06_011	Please provide a spreadsheet listing (as rows) each undergrounding project completed during the period of January 1, 2022, through December 31, 2022. For each project, please provide the following information (as columns): a) Project ID number or other identifier b) Circuit ID c) ID of each circuit segment that was entirely undergrounded in the project d) ID of each circuit segment that was partially undergrounded in the project e) County or counties where undergrounding took place f) Project start date g) Project completion date h) Total circuit-miles undergrounded i) Total miles of trenching required j) Total life-cycle electric costs of the project (i.e., costs attributed to your electric facilities), including costs for planning, design, permitting, and construction k) Total life-cycle costs of the project, including costs attributed to non-electric utilities, including costs for planning, design, permitting, and construction l) Whether this was a Rule 20 project (yes/no) m) Whether this was a WMP project (yes/no) n) Whether this was a post-wildfire rebuild project (yes/no) o) Whether you shared trenches for this project with any telecommunications utilities (yes/no) p) Whether you shared trenches for this project with gas facilities (yes/no)	See "WMP-Discovery2023_DR_CalAdvocates_006-Q011AaCh1CONF.xlsx." a) Project ID number or other identifier - See columns A (Order Number) and B (Order Description) b) Circuit ID - See column C c) ID of each circuit segment that was entirely undergrounded in the project - Our undergrounding projects are split into multiple phases within a given circuit protection zone (CPZ) shown in Column E. The undergrounding of complete CPZs is a multi-year effort that cannot be captured in the data shown for a single year. d) ID of each circuit segment that was partially undergrounded in the project - Per response to (c), our undergrounding projects are split into multiple phases within a given circuit protection zone (CPZ). By reviewing data solely from a single year, it is not possible to determine completion of an entire CPZ. e) County or counties where undergrounding took place - See column I f) Project start date - see column J g) Project completion date - See column K h) Total circuit-miles undergrounded - Column U i) Total miles of trenching required - This information is not tracked by PG&E. j) Total life-cycle electric costs of the project (i.e., costs attributed to your electric facilities), including costs for planning, design, permitting, and construction - See column X k) Total life-cycle costs of the project, including costs attributed to non-electric utilities, including costs for planning, design, permitting, and construction - There is no non-electric utility work in the scope of System Hardening (undergrounding) I) Whether this was a Rule 20 project (yes/no) - See column F m) Whether this was a WMP project (yes/no) - See column G n) Whether this was a post-wildfire rebuild project (yes/no) - See column H o) PG&E did not share trenches for any projects identified in "WMP-Discovery2023_DR_CalAdvocates_006-Q011AaCh1CONF.xlsx" p) Whether you shared trenches for this project with gas facilities (yes/no) - No. For system hardening, we do not share trenches with gas. The data includes project information from 2021 where projects overlap with 2022. Because this question is associated with the System Hardening workplan only, this data does not include undergrounding mileage associated with the Butte Rebuild.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	1	N/A	2023 WMP 8.1.2.2	Grid Design and System Hardening	Undergrounding
Pre-Discovery 37	CalPA	Set WMP-06	CalPA_Set WMP-06	12	CalPA_Set WMP-06_012	Please provide a geodatabase file with a polyline feature for each undergrounding project completed during the period of January 1, 2022 through December 31, 2022. In addition to the spatial location, please provide the following attributes for each project: a) Project ID number or other identifier, matching part (a) of the previous question b) Circuit ID c) Project completion date.	See attached "WMP-Discovery2023_DR_CalAdvocates_006-Q012AaCh1CONF.zip." Please note that the data reflected in this GIS geodatabase will not match the data set from Q11 due to the process time lag between construction completion and being fully mapped in GIS.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	1	N/A	2023 WMP 8.1.2.2	Grid Design and System Hardening	Undergrounding
Pre-Discovery 38	CalPA	Set WMP-06	CalPA_Set WMP-06	13	CalPA_Set WMP-06_013	Identify any ignitions in 2022 associated with assets where you had an existing corrective notification at the time of the ignition. Please provide a spreadsheet listing each such ignition (as rows) with the following information in separate columns: a) Unique Ignition ID b) Date of ignition c) Cause of ignition d) Type of asset associated with the ignition e) Acres burned f) Number of structures burned, if any g) Number of injuries associated with ignition, if any h) Asset ID of asset associated with ignition i) Circuit ID number of circuit associated with ignition j) Notification number(s) for the existing maintenance tag on the asset in question.	Please see the table below identifying 2022 CPUC reportable ignitions where the asset involved in the ignition was associated with an existing open corrective maintenance notification at the time of the event. Cause Suspected Equipment Type Associated With Ignition Fire Size Structures Destroyed Injuries Asset ID Circuit ID Existing Maintenance Notifications 20220374 46/2022 Equipment Failure Conductor - Primary 0.26 9.90 Acres 0 0 101804229 MESA 1103 121931783 20220613 5/17/2022 Equipment Failure Splice Clamp Connector 1 meter -3 meters 0 0 102242348 SAN RAFAEL 1104	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	0	N/A	2022 WMP Section 7.3.4	Asset Management and Inspections	N/A
Pre-Discovery 39	CalPA	Set WMP-06	CalPA_Set WMP-06	14	CalPA_Set WMP-06_014	a) Has PG&E's Asset Failure Analysis Team causally connected any ignitions that occurred in 2022 to assets with existing asset or vegetation corrective notifications at the time of ignition? b) If the answer to part (a) is yes, please provide the following information on each such ignition: i. Unique Ignition ID (matching the previous question) ii. Date of ignition iii. Cause(s) identified by the Asset Failure Analysis Team iv. The type of corrective notification that was linked to the ignition (i.e., the priority level and whether it related to asset management or vegetation management). v. Copies of associated reports or investigations performed by the Asset Failure Analysis Team.	a) Yes, please see below. b) Two ignitions have been identified that meet these criteria: Ignition ID Date of Ignition Cause Type of Corrective Notification Copies of Associated Reports 20221278 7/28/2022 The cause of this ignition is still being finalized. EC Notification 118429275 - Pole Replacement The report in question is still being finalized and can be provided upon completion. 20220311 11/16/2022 Broken crossarm EC Notification 123866774 - Crossarm replacement (later updated to pole replacement) The report in question is still being finalized and can be provided upon completion.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	0	N/A	2022 WMP 7.3.7	Data Governance	Asset Failure Analysis
Pre-Discovery 40	CalPA	Set WMP-06	CalPA_Set WMP-06	15	CalPA_Set WMP-06_015	Per PG&E's response to Data Request CalAdvocates-PGE-2022WMP-17, Question 13, March 24, 2022, PG&E's inspection strategy in 2022 was to complete detailed inspections on all assets in HFD Tier 3 and Zone 1, and approximately one-third of assets in HFD Tier 2. a) Please describe any changes to the above strategy for PG&E's detailed distribution inspections in 2023. b) Please describe any changes to the above strategy for PG&E's detailed transmission inspections in 2023. c) Please describe any changes to the above strategy for PG&E's detailed distribution inspections in 2024. d) Please describe any changes to the above strategy for PG&E's detailed transmission inspections in 2024.	a) Beginning in 2023, PG&E's detailed inspections of distribution structures in high fire areas will be informed by wildfire consequence as provided PG&E's Wildfire Distribution Risk Model v3. PG&E will complete a detailed inspection on each structure every one to three years. For additional details on this strategy, please refer to Section 8.1.3.2 of our 2023 WMP. This differs from our 2022 strategy where we inspected all of Tier 3 and one-third of Tier 2. b) There are no major changes in our strategy compared to last year. Transmission detailed inspections in 2023 are informed by predictive models of asset health and wildfire consequence. HFD1 (Tier 3, Tier 2, and Zone 1) and IFPA structures have a baseline inspection frequency of once every three years. In addition to this baseline frequency, structures may be added to the detailed inspection scope annually based on the following considerations: • Wildfire Risk, which is informed by the asset health Transmission Composite Model V1 (TCM) annualized probability of failure and the Wildfire Consequence Model V3. • Other factors involving data not currently integrated into the Wildfire Transmission Risk Model V1 (see inspection result trends, historic fire locations etc.) For additional details on this strategy, please refer to Section 8.1.3.1 of our 2023 WMP. c) No major changes are anticipated to the detailed distribution ground inspections strategy in 2024. However, as PG&E's risk models and understanding of the distribution system continues to mature, we may adjust the strategy described above or establish additional criteria to define the structures for inspection each year. d) There is no major anticipated change to detailed inspection scoping strategy in 2024. However, the considerations or thresholds used to define the additional structures may vary each year as the risk models mature and the overall risk of the transmission system evolves.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	0	N/A	2022 WMP 7.3.4.1 and 7.3.4.14	Asset Management and Inspections	N/A
Pre-Discovery 41	CalPA	Set WMP-06	CalPA_Set WMP-06	16	CalPA_Set WMP-06_016	Regarding your PSPS circuit modeling capabilities: a) Please describe your present circuit modeling capabilities with regard to PSPS decision making (PSPS circuit modeling capabilities), including what level of granularity they are able to determine how circuit hardening efforts or other changes to a line segment will affect PSPS thresholds. b) Please describe any improvements to the present PSPS circuit modeling capabilities that you expect to implement in 2023. c) Please describe any improvements to the present PSPS circuit modeling capabilities that you expect to implement in 2024. d) Please describe the expected state of your PSPS circuit modeling capabilities at the conclusion of the 2023-2025 WMP cycle.	a) For all questions below, PG&E understands circuit modeling to mean the level of granularity at which an utility can model the configuration of its electrical assets and de-energize them as such. PG&E models and de-energizes circuits utilizing all switching devices on the system that do not pose ignition risk. The effects of hardening and other changes to lines will be accounted for by our FIV model which uses machine learning to quantify past outages and ignitions and uses those as a basis for ignition and outage potential going forward which feeds into our PSPS decision making. This improves results as the model is re-trained and incorporated as its historical performance changes. b) As mentioned, PG&E models circuits at the most granular level for de-energization taking into account all devices on the system that do not pose an ignition risk. c) As mentioned, PG&E models circuits at the most granular level for de-energization taking into account all devices on the system that do not pose an ignition risk. d) As mentioned, PG&E models circuits at the most granular level for de-energization taking into account all devices on the system that do not pose an ignition risk.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	0	N/A	PSPS	N/A	N/A

Pre-Discovery 42	CaPA	Set WMP-06	CaPA_Set WMP-06	17	CaPA_Set WMP-06_017	<p>a) Have you developed Public Safety Power Shutoff (PSPS) risk scores at the circuit-segment level? b) Have you developed Enhanced Powerline Safety Settings (EPSS) risk scores at the circuit-segment level? c) If the answer to either parts (a) or (b) is yes, please provide a geodatabase file containing, as file features, the most recent spatial data for all circuit segments for which you have modeled PSPS or EPSS risk scores. Include the following attributes for each circuit segment: i. Circuit Identification Number ii. Circuit Name iii. Circuit Segment Identification Number iv. Circuit segment-level PSPS Risk Score (if applicable) v. Circuit segment-level EPSS Risk Score (if applicable). d) If the answer to either parts (a) or (b) is yes, please provide a spreadsheet that lists (as rows) each circuit-segment for which you have modeled PSPS or EPSS risk scores. Include the following attributes for each circuit segment: i. Circuit Identification Number ii. Circuit Name iii. Circuit Segment Identification Number iv. Circuit segment-level PSPS Risk Score (if applicable) v. Circuit segment-level EPSS Risk Score (if applicable) e) If the answer to part (a) is no, does PG&E intend to develop PSPS risk scores for circuit segments? f) If the answer to part (b) is no, does PG&E intend to develop EPSS risk scores for circuit segments?</p>	<p>a) Yes. This is cited in Section 6.2.1, figure 6.2.1.3. b) Yes. This is cited in Section 6.2.1, figure 6.2.1.3. c) Please see "WMP-Discovery2023_DR_CaAdvocates_006-Q017Ach01CONF.zip" which is a geodatabase file containing the circuit segments along with PSPS risk values and Circuit Segment names. Due to the different circuit segment voltages approximately 400 of the circuit segments are not mapped. d) Yes please see "WMP-Discovery2023_DR_CaAdvocates_006-Q017Ach02CONF.xlsx" which provides the circuit segment PSPS risk values. e) Not applicable. f) PG&E produces an annual reliability study of EPSS outage activity, which informs reliability mitigation actions. Furthermore, PG&E is exploring incorporating this data into an "EPSS reliability risk" score for circuit segments.</p>	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/pge_global/common/pdf/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/SPN_001.zip	2	N/A	PSPS/EPSS	N/A	N/A
Pre-Discovery 43	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_01	1	CPUC - SPD (Safety Policy Division)_001_01	<p>REFCL Inquiries: REFCL Pilot at Calatoga Circuit Segment ID 1102131531 Describe various active settings profiles. Describe how staged fault testing is planned to be conducted. Explain how REFCL rides through momentary faults & when REFCL deenergizes line for permanent faults. Substation Configuration - Describe any substation and/or circuit configuration issues to deploy REFCL. Availability of REFCL - Describe any known barriers to increasing deployment in CA Explain which risk drivers per Table PG&E 7.1.4.1 REFCL mitigates. Explain why REFCL is not preferred mitigation for broader deployment and confirm PG&E no longer plans to install REFCL at substations per year per GRC filing.</p>	<p>i. The REFCL equipment installed in the substation protects all the primary lines on both Calatoga circuits. Three settings profiles allow for changing fault sensitivity and tripping behavior on the fly based on field conditions. Setting 1 is for low risk with a three second delay before switching the neutral to solid grounding to clear the fault. Setting 2 is for medium risk with a three second fault ride through before directly tripping the faulted feeder circuit breaker for a sustained fault. Setting 3 is for high risk with no time delay and greatest fault sensitivity and tripping the faulted feeder circuit breaker. ii. Staged fault testing was performed in 2022 with preliminary data collected. A mobile high voltage resistor bank is momentarily connected to stage a fault on the circuit. Normally the system rides through the neutral shift with no service outage from the test. Due to greater line to ground voltages during the testing, the possibility of unplanned outage of line equipment during testing is slightly increased. iii. All service transformers on REFCL circuits are connected line to line, so service voltage is maintained during the ground fault. If setting 1 or 2 is active, once a ground fault is detected, a three second time delay elapses before the fault confirmation is performed. If the fault confirmation determines that the fault vanished (momentary fault), then the neutral voltage is returned to normal with no service interruption. If the fault confirmation determines that it is a sustained fault, then the tripping is handled based on the active setting group described in table 2. Due to equipment failures in the substation and on the line in the REFCL demonstration project, PG&E is still evaluating the technology and gaining operational experience with it. In order to deploy REFCL, the primary considerations for deployment are: • Substation voltage regulators: Replace wire-ground connected regulators with line-line connected regulators • Substation feeder breakers: High accuracy current transformers retrofitted • Substation secondary neutral: clearance of substation transformer bank and installation of grounding switch and cable connections to an suppression coil • Substation physical space: Enough room within the substation for an 16 ft x 28 ft footprint per Ground Fault Neutralizer (GFN). Some substations may require 2 GFNs right away for deploying REFCL. • Distribution circuits: 3-wire uni-grounded neutral only • Distribution circuits: Maximum of approximately 50 circuit miles of underground cable per transformer bank</p>	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/pge_global/common/pdf/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/SPN_001.zip	0	N/A	8.1.8.1.3	Grid Operations and Procedures	Settings of Other Emerging Technologies (e.g., Rapid Earth Fault Current Limiters)
Pre-Discovery 44	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_01	2	CPUC - SPD (Safety Policy Division)_001_02	<p>EPSS & Supporting Technologies (DCD & Partial Voltage Detection) Inquiries: Explain all activities planned to mitigate EPSS reliability impacts. Are customer support programs (e.g., battery backup) distinct from or linked to those in place for PSPS implementation? Explain Sensitive Ground Fault settings for EPSS enabled circuit segments. Explain Downed Conductor Detection (DCD) technology and how it isolates high impedance faults with EPSS. Explain DCD 2023-2025 Targets (i.e. 500, 400 & 250 protective device controllers or relays) and whether they will cover all HFTD and buffer EPSS circuits. Explain why says To Be Updated. Explain how many DCD are currently installed including on top 5% risk circuit segments. Explain Partial Voltage Detection using SmartMeters and how supplements DCD and EPSS.</p>	<p>a. The following includes activities on-going and planned to mitigate EPSS reliability impacts: Enhanced Outage Review Team (ORT) process that includes additional review of circuit/Circuit Protection Zone (CPZ) performance that when multiple outages occur triggers a Multiple Outage Review (MOR) to drive additional actions if needed to reduce repeat outages going forward. • Continuing Proactive Vegetation Trimming on the Top 12 circuit segments that were identified last year based on number of outages experienced and a projected escalation of over 50% for the fire season. For 2023 we looked at CEM (customers experiencing multiple outages) impacted customers and evaluated vegetation outages and identified 9 additional circuit protection zones to be added to this approach. • Continuing Extent of Condition assessment and trimming. When a vegetation related EPSS outage occurs the incident location and 5' radius in all directions is inspected by our vegetation management team to identify trimming opportunities to prevent an outage from occurring near the previous location reducing risk and improving reliability. b. EPSS CEM by Targeted outages 1. Vegetation clearing for CPZs with multiple veg caused outages as covered above 2. Development of an aerial mitigation strategy for aerial intervention reduction due to high annual caused outages when EPSS is enabled. c. Fault Indicator Installations Proactively installing 1800 Fault Indicators on EPSS Circuits to expedite outage restoration and assist in finding the cause of outages to be addressed to prevent future unknown outages i. In general, customer support programs for EPSS are linked to those in place for PSPS implementation. In most cases, such as with PG&E's Portable Battery Program (PBP), Disability and Disaster Access and Resource Program (DDAR), and Generator and Battery Rebate Program (GBRP), the programs are the same. PG&E simply expanded eligibility criteria such that programs initially targeting PSPS customer outages now also include the most impacted EPSS customers. One notable exception is the new residential Fixed Power Solutions offering (aka, the Residential Storage Initiative or RSI), which was launched in late 2022. As a new offering, RSI was targeted at EPSS-impacted customers, which happen to overlap with areas historically impacted by PSPS events. b. The Sensitive Ground Fault (SGF) protective element, which was expanded to systemwide use in 2021 and 2022 on 3-wire circuits as a part of EPSS, is a low set non-directional ground overcurrent element typically set at 15A with a 15-20 second delay. Prior to 2021, SGF was in a concept. EPSS and REFCL are two very different approaches that share a common goal of attempting to reduce risk associated with ignitions on primary electric distribution systems. i. EPSS - advantages: • Can be implemented on mostly existing equipment and relays • Reduces incident fault energy across all types of faults (Three-phase, line-to-line, line-to-ground, etc.) • Reduces incident fault energy through fault clearing time reduction • Helps to reduce backfeed issues associated with 3-wire distribution system by prioritizing gang trip behavior versus single phase fuse operation • Incorporates various technologies for high impedance fault detection (Sensitive Ground Fault (SGF), Downed Conductor Detection (DCD), etc.) • Does not require extensive field high speed measurements or communication beyond traditional SCADA and remote access. (i.e. does not rely on synchrophasor technology) • Does not require changes to system grounding configuration or load connections to implement REFCL - advantages: • Potential for 80% ignition probability reduction for single line to ground faults (Victorian ignition testing). Considering all fault types, an overall ignition probability reduction can be calculated to approximately a 50% reduction. • Fault current limited to 1 Amp for single line to ground faults based on 2022 field testing • Greater sensitivity to high impedance faults (> 5k ohm fault resistance) • Cover short circuit forces for line equipment for ground faults EPSS - disadvantages: • Less capability to desensitize the system during fault events as compared to traditional protective settings due to the minimal coordination time provided in which can result in lower reliability performance • Fault current is not limited - fault energy is reduced by faster clearing times - and remains a function of existing system configuration. Re-energization after a fault event requires disabling of EPSS to avoid inrush trips • Susceptible to trips associated with customer load inrush, CT error, capacitor bank switching, and other non-fault grid disturbances. REFCL - disadvantages: • No risk reduction for line-line faults or three-phase ground faults PG&E's long term goal is to minimize risk reduction by undergrounding high wildfire risk locations. For locations that will not be undergrounded, we will continue to deploy our suite of Operational Mitigations and other System Resilience Mitigations. Operational Mitigations include programs such as EPSS, equipment maintenance and repair, vegetation management for operational mitigations, and PSPS. System Resilience Mitigations include programs such as covered conductor installation, transmission conductor replacement, line removal, and distribution and transmission HFTD and HFRAs open tag reduction. We will also manage system risk through our Comprehensive Monitoring and Data Collection programs include detailed distribution and transmission asset inspection programs, vegetation inspection programs, and monitoring programs such as Distribution Fault Anticipation Installations, Early Fault Detection Sensors and our network of wildfire cameras and weather stations. A complete listing of PG&E's mitigation programs is included in Section 7.2.1.1 of PG&E's WMP. Table 7.4 in PG&E's WMP shows how we layer different mitigation programs at the circuit segment level to provide system protection and reduce risk. While Table 7.4 shows only PG&E's top risk circuit segments, we apply this approach across all the circuits in the HFTD and HFRAs. PG&E will continue to explore new technologies to reduce the risk of ignitions and the consequences of wildfires and may incorporate new technologies into our mitigation portfolio.</p>	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/pge_global/common/pdf/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/SPN_001.zip	0	N/A	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
Pre-Discovery 45	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_01	3	CPUC - SPD (Safety Policy Division)_001_03	<p>EPSS & REFCL Inquiries: EPSS vs REFCL - Describe the major similarities and differences. What are advantages and disadvantages? • In terms of capability, seasonization, safety, and reliability? • Phase-to-Ground Faults vs Complex (Multiphase) Faults - What is the risk profile of existing ignitions on PG&E's system and how does REFCL & EPSS mitigate these risks? • Combination of REFCL with EPSS & Other Mitigations - Explain how these could work together, and if PG&E has quantified combined risk-reduction benefits. Explain the differences in fault energy for EPSS vs REFCL including for low and high impedance faults. Explain why EPSS is preferred if REFCL fault energy is less than 10% of EPSS fault energy for low impedance faults. Explain the effectiveness of DCD vs REFCL on high impedance faults</p>	<p>a. In concept, EPSS and REFCL are two very different approaches that share a common goal of attempting to reduce risk associated with ignitions on primary electric distribution systems. i. EPSS - advantages: • Can be implemented on mostly existing equipment and relays • Reduces incident fault energy across all types of faults (Three-phase, line-to-line, line-to-ground, etc.) • Reduces incident fault energy through fault clearing time reduction • Helps to reduce backfeed issues associated with 3-wire distribution system by prioritizing gang trip behavior versus single phase fuse operation • Incorporates various technologies for high impedance fault detection (Sensitive Ground Fault (SGF), Downed Conductor Detection (DCD), etc.) • Does not require extensive field high speed measurements or communication beyond traditional SCADA and remote access. (i.e. does not rely on synchrophasor technology) • Does not require changes to system grounding configuration or load connections to implement REFCL - advantages: • Potential for 80% ignition probability reduction for single line to ground faults (Victorian ignition testing). Considering all fault types, an overall ignition probability reduction can be calculated to approximately a 50% reduction. • Fault current limited to 1 Amp for single line to ground faults based on 2022 field testing • Greater sensitivity to high impedance faults (> 5k ohm fault resistance) • Cover short circuit forces for line equipment for ground faults EPSS - disadvantages: • Less capability to desensitize the system during fault events as compared to traditional protective settings due to the minimal coordination time provided in which can result in lower reliability performance • Fault current is not limited - fault energy is reduced by faster clearing times - and remains a function of existing system configuration. Re-energization after a fault event requires disabling of EPSS to avoid inrush trips • Susceptible to trips associated with customer load inrush, CT error, capacitor bank switching, and other non-fault grid disturbances. REFCL - disadvantages: • No risk reduction for line-line faults or three-phase ground faults PG&E's long term goal is to minimize risk reduction by undergrounding high wildfire risk locations. For locations that will not be undergrounded, we will continue to deploy our suite of Operational Mitigations and other System Resilience Mitigations. Operational Mitigations include programs such as EPSS, equipment maintenance and repair, vegetation management for operational mitigations, and PSPS. System Resilience Mitigations include programs such as covered conductor installation, transmission conductor replacement, line removal, and distribution and transmission HFTD and HFRAs open tag reduction. We will also manage system risk through our Comprehensive Monitoring and Data Collection programs include detailed distribution and transmission asset inspection programs, vegetation inspection programs, and monitoring programs such as Distribution Fault Anticipation Installations, Early Fault Detection Sensors and our network of wildfire cameras and weather stations. A complete listing of PG&E's mitigation programs is included in Section 7.2.1.1 of PG&E's WMP. Table 7.4 in PG&E's WMP shows how we layer different mitigation programs at the circuit segment level to provide system protection and reduce risk. While Table 7.4 shows only PG&E's top risk circuit segments, we apply this approach across all the circuits in the HFTD and HFRAs. PG&E will continue to explore new technologies to reduce the risk of ignitions and the consequences of wildfires and may incorporate new technologies into our mitigation portfolio.</p>	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/pge_global/common/pdf/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/SPN_001.zip	0	N/A	8.1.8.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
Pre-Discovery 46	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_01	4	CPUC - SPD (Safety Policy Division)_001_04	<p>General risk reduction inquiry: What's PG&E's goal for long-term risk reduction, particularly reduction of likelihood of ignition and also reduction of consequences, for circuits in HFTDs that are not undergrounded?</p>	<p>PG&E's long term goal is to minimize risk reduction by undergrounding high wildfire risk locations. For locations that will not be undergrounded, we will continue to deploy our suite of Operational Mitigations and other System Resilience Mitigations. Operational Mitigations include programs such as EPSS, equipment maintenance and repair, vegetation management for operational mitigations, and PSPS. System Resilience Mitigations include programs such as covered conductor installation, transmission conductor replacement, line removal, and distribution and transmission HFTD and HFRAs open tag reduction. We will also manage system risk through our Comprehensive Monitoring and Data Collection programs include detailed distribution and transmission asset inspection programs, vegetation inspection programs, and monitoring programs such as Distribution Fault Anticipation Installations, Early Fault Detection Sensors and our network of wildfire cameras and weather stations. A complete listing of PG&E's mitigation programs is included in Section 7.2.1.1 of PG&E's WMP. Table 7.4 in PG&E's WMP shows how we layer different mitigation programs at the circuit segment level to provide system protection and reduce risk. While Table 7.4 shows only PG&E's top risk circuit segments, we apply this approach across all the circuits in the HFTD and HFRAs. PG&E will continue to explore new technologies to reduce the risk of ignitions and the consequences of wildfires and may incorporate new technologies into our mitigation portfolio.</p>	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/pge_global/common/pdf/afity/emergency-preparedness/natural-disaster/wildfires/wildfire-mitigation-plan/reference-docs/SPN_001.zip	0	N/A	7.2.1	Mitigation Strategy Devic	Overview of Mitigation Initiatives and Activities

Pre-Discovery 47	Green Power Institute (GPI)	001	Green Power Institute (GPI)_001	1	Green Power Institute (GPI)_001_01	<p>Please provide PG&E's Pre-submission 2023-2025 WMP Base Plan filed on February 13, 2023, with the OES per the 2023 WMP Guidelines and Schedule document. Including all attachments and associated supporting documents required for the Pre-submission 2023-2025 WMP Base Plan filing.</p>	<p>PG&E has designated the entire pre-submission as confidential to align with Energy Safety's pre-submission process and guidelines which stipulate that the pre-submission documents are not to be made public. In addition, the pre-submission contains contact information for individuals that is considered confidential.</p> <p>As noted in our correspondences to you on March 8th and March 10th, we can provide you with a copy of the pre-submission documents that were submitted upon execution of a non-disclosure agreement. Alternatively, we will be submitting our final 2023-2025 Wildlife Mitigation Plan (WMP) for public review on March 27, 2023 if you would prefer to wait for a copy of the completed WMP following Energy Safety's completeness check. Please feel free to reach out to us to discuss how you would prefer to move forward with this request.</p>	Zoe Harrold	3/1/2023	3/14/2023	3/14/2023	https://www.pge.com/pge_global/common/pdfs/3/14/2023/energy-safety-2023-2025-wildlife-mitigation-plan/reference-docs/GPI_001.zip	0	N/A	All	All	All