











|     |      |            |                     |    |                     |  |              |          |           |           |   |   |     |            |                                       |   |
|-----|------|------------|---------------------|----|---------------------|--|--------------|----------|-----------|-----------|---|---|-----|------------|---------------------------------------|---|
| 131 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 8  | CaPA_Set WMP-14_Q8  | <p>P. 369 of PG&amp;E's WMP states, "For 2022, we have planned to install devices that will provide significant reliability benefits in areas that are in the scope of EPSS." Please describe the "significant reliability benefits" that will be provided from devices installed in 2022.</p> <p>a) Please quantify the "significant reliability benefits" that will be provided from devices installed in 2022.</p> <p>b) Please describe any available available resources or studies to support your response to part (a).</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.2.8.1  | Grid Design and System Hardening      | Installation of System Automation Equipment - Distribution Protective Devices |
| 132 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 9  | CaPA_Set WMP-14_Q9  | <p>P. 385 of PG&amp;E's WMP states that it will perform a "Substation Annual Effectiveness Study" in 2022. Please describe the study.</p> <p>a) When does PG&amp;E expect to begin the Substation Annual Effectiveness Study?</p> <p>b) When does PG&amp;E expect to complete the Substation Annual Effectiveness Study?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.2.12.2 | Grid Design and System Hardening      | Other Technologies and Systems - Substation Annual Assessment                 |
| 133 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 10 | CaPA_Set WMP-14_Q10 | <p>P. 393 of PG&amp;E's WMP states, "In 2022 PGE implemented revisions to TD-3235, which includes as well as adjusted the pole rejection criteria." Please list the adjustments that PG&amp;E made to the pole rejection criteria.</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.3.1.5  | Asset Inspections                     | Intensive Pole Inspection   |
| 134 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 11 | CaPA_Set WMP-14_Q11 | <p>P. 400 of PG&amp;E's WMP states, "PGE designed pilot areas in extreme, severe, high medium, or low based on the average wildfire frequency of the structures within that pilot map." Please describe the pilot areas.</p> <p>a) How were the pilot areas designed?</p> <p>b) How were the pilot areas designed?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.3.2.1  | Asset Inspections                     | Detailed Ground Inspection  |
| 135 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 12 | CaPA_Set WMP-14_Q12 | <p>Table PG&amp;E-8.1.7.6 on p. 458 of PG&amp;E's WMP shows that PG&amp;E added 41,869 distribution work orders in an HTD/HFD area in 2022.</p> <p>a) What measures has PG&amp;E implemented to ensure that it will be able to restore its backlog in 2023 by closing more tags than it opens?</p> <p>b) What factors may prevent PG&amp;E from reaching its backlog reduction goal?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.7.2    | Open Work Orders                      | Open Work Orders - Distribution Tags  |
| 136 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 13 | CaPA_Set WMP-14_Q13 | <p>P. 463 of PG&amp;E's WMP states, "EPSS does not cause a power outage." Given that EPSS settings can de-energize a line without prior warning, and without an apparent cause, please explain what is meant by the above quote.</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.8.1.1  | Grid Operations and Procedures        | Protective Equipment and Device Settings                                      |
| 137 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 14 | CaPA_Set WMP-14_Q14 | <p>The PG&amp;E's January 2023 EPSS monthly report, PG&amp;E experienced 2,315 EPSS outages in 2022.</p> <p>a) Of the EPSS-triggered outages in 2022, in how many of these outages did PG&amp;E find that no corrective actions were required prior to re-energizing (i.e., there was no persistent condition that PG&amp;E needed to resolve upon re-energizing the location of the outage)?</p> <p>b) Of the EPSS-triggered outages in 2022, in how many of these outages did PG&amp;E find that corrective actions were required prior to re-energizing (i.e., there was a persistent condition that PG&amp;E needed to resolve upon re-energizing the location of the outage)?</p> | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.8.1.1  | Grid Operations and Procedures        | Protective Equipment and Device Settings                                      |
| 138 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 15 | CaPA_Set WMP-14_Q15 | <p>465 of PG&amp;E's WMP states, "In 2022, we expanded the scope of our HTD/HFD work on our service territory and select adjacent EPSS buffer areas."</p> <p>a) In 2022, what was the scope of our HTD/HFD work on our service territory and select adjacent EPSS buffer areas?</p> <p>b) In 2022, how many HTD/HFD work orders did PG&amp;E perform on our service territory and select adjacent EPSS buffer areas?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.8.1.1  | Grid Operations and Procedures        | Protective Equipment and Device Settings                                      |
| 139 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 16 | CaPA_Set WMP-14_Q16 | <p>Cal Advocates understands that a grant segment that has been undergrounded may still experience PSPS outages if a segment upstream or downstream of the undergrounded circuit segment is subject to PSPS.</p> <p>a) Is the above understanding correct? If yes, please correct the above.</p> <p>b) If the answer to part (a) is no, please describe the circumstances, microclimate, or other factors that may cause a grant segment to experience PSPS outages.</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 9.1.5      | Public Safety Power Shutoff           | Performance Metrics Identified by the Electrical Corporation                  |
| 140 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 17 | CaPA_Set WMP-14_Q17 | <p>Has PG&amp;E performed a study or back cast to predict the likelihood that an undergrounded segment will be subject to PSPS due to re-energizations due to upstream or downstream segments becoming subject to PSPS?</p> <p>a) If yes, please provide the results of any such studies.</p> <p>b) If the answer to part (a) is no, please describe why not.</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 9.1.5      | Public Safety Power Shutoff           | Performance Metrics Identified by the Electrical Corporation                  |
| 141 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 18 | CaPA_Set WMP-14_Q18 | <p>Has PG&amp;E performed a study or back cast to predict the likelihood that an undergrounded segment will be subject to PSPS due to re-energizations due to upstream or downstream segments becoming subject to PSPS?</p> <p>a) If yes, please provide the results of any such studies.</p> <p>b) If the answer to part (a) is no, please describe why not.</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.8.1.1  | Grid Operations and Procedures        | Protective Equipment and Device Settings                                      |
| 142 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 19 | CaPA_Set WMP-14_Q19 | <p>Please provide a list of all dip-in incidents that occurred from 2020-2022 and involved an underground electric distribution line. For each incident, please provide:</p> <p>a) Date of the dip-in</p> <p>b) Whether the dip-in was caused by PG&amp;E equipment, PG&amp;E contractors, or a third party</p>  | Holly Wetman | 4/1/2023 | 4/28/2023 | 4/28/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 1 | N/A | 8.4.2.1    | Emergency Preparedness                | Overview of Wildfire and PSPS Emergency Procedures                            |
| 143 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 20 | CaPA_Set WMP-14_Q20 | <p>a) During the period from 2020-2022, did PG&amp;E replace any distribution poles as part of its WMP activities for which PG&amp;E has not fully recovered the original cost of the pole?</p> <p>b) If the answer to part (a) is yes, what was PG&amp;E's practice regarding cost recovery on the unrecovered portion of the value associated with the replaced pole?</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.2.3    | Grid Design and System Hardening      | Distribution Pole Replacements and Reinforcements                             |
| 144 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 21 | CaPA_Set WMP-14_Q21 | <p>a) During the period from 2020-2022, did PG&amp;E replace any distribution conductors as part of its WMP activities for which PG&amp;E has not fully recovered the original cost of the conductor?</p> <p>b) If the answer to part (a) is yes, what was PG&amp;E's practice regarding cost recovery on the unrecovered portion of the value associated with the replaced conductor?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.2.3    | Grid Design and System Hardening      | Distribution Pole Replacements and Reinforcements                             |
| 145 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 22 | CaPA_Set WMP-14_Q22 | <p>a) During the period from 2020-2022, did PG&amp;E replace any distribution conductors as part of its WMP activities for which PG&amp;E has not fully recovered the original cost of the conductor?</p> <p>b) If the answer to part (a) is yes, what was PG&amp;E's practice regarding cost recovery on the unrecovered portion of the value associated with the replaced conductor?</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | 8.1.4.1.1  | Equipment Maintenance and Repair      | Transformers  |
| 146 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 23 | CaPA_Set WMP-14_Q23 | <p>How many ignitions did PG&amp;E experience related to overhead covered conductor distribution lines?</p> <p>a) In 2022, how many ignitions did PG&amp;E experience related to overhead covered conductor distribution lines?</p> <p>b) In 2022, how many ignitions did PG&amp;E experience related to overhead secondary distribution lines?</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | Appendix D | Areas for Continued Improvement       | AOI PG&E-22-06 - Addressing Increase in Risk Events                           |
| 147 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 24 | CaPA_Set WMP-14_Q24 | <p>a) In 2022, how many ignitions did PG&amp;E experience related to overhead secondary distribution lines?</p> <p>b) In 2022, how many ignitions did PG&amp;E experience related to overhead secondary distribution lines?</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 0 | N/A | Appendix D | Areas for Continued Improvement       | AOI PG&E-22-06 - Addressing Increase in Risk Events                           |
| 148 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 25 | CaPA_Set WMP-14_Q25 | <p>P. 89 of PG&amp;E's 2022 Joint Annual Report to Shareholders states:</p> <p>"On October 26, 2022, the Utility notified the CPUC that the Utility's procedure for wood pole replacements did not comply with CPUC requirements for replacement of poles under certain conditions and, accordingly, in some instances, the Utility failed to replace wood poles with safety factors below the relevant minimum."</p>  | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 1 | N/A | 8.1.2.3    | Grid Design and System Hardening      | Distribution Pole Replacements and Reinforcements                             |
| 149 | CaPA | Set WMP-14 | CaPA_Set WMP-14     | 26 | CaPA_Set WMP-14_Q26 | <p>P. 90 of PG&amp;E's 2022 Joint Annual Report to Shareholders states:</p> <p>"On December 22, 2022, the Utility submitted an update to the CPUC explaining the Utility had identified a population of wood poles that had not received intensive inspections in accordance with GO 95 standards due to legacy issues, which should no longer be in service."</p>   | Holly Wetman | 4/1/2023 | 4/17/2023 | 4/17/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_014.zip</a> | 1 | N/A | 8.1.2.3    | Grid Design and System Hardening      | Distribution Pole Replacements and Reinforcements                             |
| 150 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q1  | 1  | CaPA_Set WMP-15_Q1  | <p>PG&amp;E will maintain clearances where EIM work occurred. PG&amp;E will also be prescribing a minimum radial clearance of 12 feet throughout the system within HTD and HFD. The two new programs, Vegetation for Operational Mitigation (VOM) and Focus Tree Inspections (FTI) will identify new trees for the sort of work identified in (b) (re) inventory. Additionally, if any priority trees are discovered while completing the FTI sort of work, they will be added to the VOM program.</p>   | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.6  | Vegetation Management and Inspections | Discontinued Programs   |
| 151 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q2  | 2  | CaPA_Set WMP-15_Q2  | <p>PG&amp;E states in its response to Question 2 (b) of CalAdvocates-PGE-2023WMP-08 that its strategy for determining desired clearance distances going forward will be "Minimum of 12 feet of clearance, the overall impact of pruning to tree health or corrected tree work, which can be interpreted as enhanced clearance. As a methodology, the goal is to mitigate identified problematic tree conditions between inspection cycles and between 23 years of clearance."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.6  | Vegetation Management and Inspections | Discontinued Programs   |
| 152 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q3  | 3  | CaPA_Set WMP-15_Q3  | <p>PG&amp;E intends to track trees identified for work under VOM and FTI using the OneM tool.</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.4  | Vegetation Management and Inspections | Tree Removal Inventory  |
| 153 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q4  | 4  | CaPA_Set WMP-15_Q4  | <p>PG&amp;E states in its response to Question 1 (c)(ii) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on a review of outage data and trends by AOC. Additionally, any tree which is within MCR, will be within the MDR before next work completion cycle or a tree which is not in MCR, will be within the MDR before next work completion cycle."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.6  | Vegetation Management and Inspections | Discontinued Programs   |
| 154 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q5  | 5  | CaPA_Set WMP-15_Q5  | <p>PG&amp;E states in its response to Question 1 (c) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on a review of outage data and trends by AOC. Additionally, any tree which is within MCR, will be within the MDR before next work completion cycle or a tree which is not in MCR, will be within the MDR before next work completion cycle."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.4  | Vegetation Management and Inspections | Tree Removal Inventory  |
| 155 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q6  | 6  | CaPA_Set WMP-15_Q6  | <p>PG&amp;E states in its response to Question 2 (c) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on a review of outage data and trends by AOC. Additionally, any tree which is within MCR, will be within the MDR before next work completion cycle or a tree which is not in MCR, will be within the MDR before next work completion cycle."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.4  | Vegetation Management and Inspections | Tree Removal Inventory  |
| 156 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q7  | 7  | CaPA_Set WMP-15_Q7  | <p>PG&amp;E states in its response to Question 2 (b) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on a review of outage data and trends by AOC. Additionally, any tree which is within MCR, will be within the MDR before next work completion cycle or a tree which is not in MCR, will be within the MDR before next work completion cycle."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.4  | Vegetation Management and Inspections | Tree Removal Inventory  |
| 157 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q8  | 8  | CaPA_Set WMP-15_Q8  | <p>PG&amp;E states in its response to Question 4 (c) of CalAdvocates-PGE-2023WMP-08 that "The Wildfire Data Risk Model (WDRM) is used to prioritize the CPZs for the VOM program."</p>   | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.3  | Vegetation Management and Inspections | VM for Operational Mitigations  |
| 158 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q9  | 9  | CaPA_Set WMP-15_Q9  | <p>PG&amp;E states in its response to Question 2 (b) of CalAdvocates-PGE-2023WMP-08 that it will decide desired clearance distances "Based on a review of outage data and trends by AOC. Additionally, any tree which is within MCR, will be within the MDR before next work completion cycle or a tree which is not in MCR, will be within the MDR before next work completion cycle."</p>  | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.3  | Vegetation Management and Inspections | VM for Operational Mitigations  |
| 159 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q10 | 10 | CaPA_Set WMP-15_Q10 | <p>PG&amp;E states in its response to Question 4 (c) of CalAdvocates-PGE-2023WMP-08 that "The Wildfire Data Risk Model (WDRM) is used to prioritize the CPZs for the VOM program."</p>   | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.3  | Vegetation Management and Inspections | VM for Operational Mitigations  |
| 160 | CaPA | Set WMP-15 | CaPA_Set WMP-15_Q11 | 11 | CaPA_Set WMP-15_Q11 | <p>PG&amp;E states in its response to Question 4 (c) of CalAdvocates-PGE-2023WMP-08 that "The Wildfire Data Risk Model (WDRM) is used to prioritize the CPZs for the VOM program."</p>   | Holly Wetman | 4/1/2023 | 4/14/2023 | 4/14/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-dispatch/reference-docs/2023/caladvocates_015.zip</a> | 0 | N/A | 8.2.2.2.3  | Vegetation Management and Inspections | VM for Operational Mitigations  |

















|     |                                     |                    |  |   |  |  |   |                 |           |           |           |   |   |     |           |                                       |  |
|-----|-------------------------------------|--------------------|--|---|--|--|---|-----------------|-----------|-----------|-----------|---|---|-----|-----------|---------------------------------------|--|
| 367 | Green Power Institute (GPI)         | 002                | Green Power Institute (GPI)_002            | 5 | Green Power Institute (GPI)_002_05         | Please describe current agreements and any recent (2021-Present) communications with state and federal agencies regarding fuels and slash management practices on state and federal lands, respectively.   | The U.S. Forest Service (USFS), Bureau of Land Management (BLM), National Park Service (NPS), and California State Parks (CASP) have the authority to require specific wood and debris management (e.g. wood or log removal, docking, chipping up to a certain diameter, piling) be incorporated into proposals for Vegetation Management work on their lands. Several public agencies, including USFS, have established FG&E with their respective agencies. | Zoe Harold      | 5/1/2023  | 5/16/2023 | 5/16/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/GPI_002.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/GPI_002.zip</a>   | 0 | N/A | 8.2.3.2   | Vegetation Management and Inspections | Wood and Slash Management  |
| 368 | MGRA                                | Data Request No. 6 | MGRA_Data_Request_No.6                     | 1 | MGRA_Data_Request_No.6_01                  | PG&E was requested to provide an Excel spreadsheet containing outage IDs. These were delivered as a "Dated" ID initially created by the O&A group and it lists in its outage data provided as a result of DRI. Please provide the file sent in response to DR4-08 as soon as possible.   | "WMP-Discovery2023_DR_MGRA_006-0001A01.xlsx" contains a new column called "DatedID" that will align with the same outage identifier (ID) from DRI.  | Joseph Mitchell | 5/1/2023  | 5/16/2023 | 5/16/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip</a> | 1 | N/A | 8.1.8.1.1 | Grid Operations and Procedures        | Protective Equipment and Device Settings                         |
| 369 | MGRA                                | Data Request No. 6 | MGRA_Data_Request_No.6                     | 2 | MGRA_Data_Request_No.6_02                  | Please add (or re-add) a simple "cause" attribute to this outage file.   | "WMP-Discovery2023_DR_MGRA_006-0001A01.xlsx" contains a new column called "basic_cause" as requested.   | Joseph Mitchell | 5/1/2023  | 5/16/2023 | 5/16/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip</a> | 0 | N/A | 8.1.8.1.1 | Grid Operations and Procedures        | Protective Equipment and Device Settings                         |
| 370 | MGRA                                | Data Request No. 6 | MGRA_Data_Request_No.6                     | 3 | MGRA_Data_Request_No.6_03                  | Likewise, please add a "cause" attribute to the outage data in the GIS files used in response to MGRA DRI. Alternatively, provide an Excel file in which cause is cross-referenced to DatedID.   | "WMP-Discovery2023_DR_MGRA_006-0001A01.xlsx" includes both "basic_cause" and "DatedID" for cross-referencing.   | Joseph Mitchell | 5/1/2023  | 5/16/2023 | 5/16/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip</a> | 0 | N/A | 8.1.8.1.1 | Grid Operations and Procedures        | Protective Equipment and Device Settings                         |
| 371 | MGRA                                | Data Request No. 6 | MGRA_Data_Request_No.6                     | 4 | MGRA_Data_Request_No.6_04                  | If there are refusals or delays to the above please provide the EPSS data in a format similar to that provided in response to MGRA DRI section 8.  | Not applicable.   | Joseph Mitchell | 5/1/2023  | 5/16/2023 | 5/16/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/MGRA_006.zip</a> | 0 | N/A | 8.1.8.1.1 | Grid Operations and Procedures        | Protective Equipment and Device Settings                         |
| 372 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_01 | 1 | CPUC - SPD (Safety Policy Division)_005_01 | 1.Regarding costs inherent in PG&E's undergrounding grid hardening mitigation initiative projects, used in calculating cost efficiency and project feasibility as described in the 2022-2023 WMP (p. 340 and p. 968), to date and looking forward:<br>a.What was the average cost per circuit mile for undergrounding in 2022, 2021, and 2020, in the METN, non-METN, and non-both? b.   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 373 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_02 | 2 | CPUC - SPD (Safety Policy Division)_005_02 | 2.Provide the utility's cost estimate breakdown for undergrounding per mile. Provide the cost estimate in a commonly used cost-estimating format (e.g., Uniform). If the utility uses a different format, please provide documentation on that format so SPD can understand the cost estimate.   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 374 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_03 | 3 | CPUC - SPD (Safety Policy Division)_005_03 | 3.How is PG&E incorporating subsurface variability (e.g., encountering hard rock, slope, or other conditions presenting significant physical obstacles) into undergrounding cost calculations? Provide an example.   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 375 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_04 | 4 | CPUC - SPD (Safety Policy Division)_005_04 | 4.PG&E has stated that CalTrans trench depth requirements exceeded PG&E trench depth requirements. How has this impacted costs and planning? For planning purposes, what percentage of anticipated ground circuit miles will be impacted by the CalTrans trench depth requirements for 2023-2025?  |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 376 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_05 | 5 | CPUC - SPD (Safety Policy Division)_005_05 | 5.How does service life impact cost calculation?   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 377 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_06 | 6 | CPUC - SPD (Safety Policy Division)_005_06 | 6.What is the estimated multiplier for conversion from overhead (OH) line to underground (UG) line, 1.25 MIE OH converts to 1.00 MIE UG?<br>a.How was this conversion rate derived?<br>b.How was established or the accepted/operating average for project planning purposes?<br>7.On pilot projects completed to date:<br>a.What is the total all-in cost per mile?<br>b.What is the break even project size per mile? SPD expects to see the following components inside of the costs, although SPD understands they may not be broken down in this report format:<br>1. What types of covered conductor (size of conductor, material of conductor, voltage rating of conductor - if PG&E can point to product data from a manufacturer, this would be preferred) does PG&E use and does PG&E choose different types of covered conductor types near coastal areas?  |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 378 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_07 | 7 | CPUC - SPD (Safety Policy Division)_005_07 | Regarding PG&E's response to OEIS DR 1 Question 10, Attachment 1:<br>a. Explain the difference between a Field Safety Reassessment and a Planned Field Safety Reassessment.<br>b. In what instances would PG&E extend a work order due date through a Field Safety Reassessment? Provide all supporting documentation and criteria, including any procedures and inspection protocols demonstrating decision-making.<br>c. In what instances would a Standard Change lead to extending a work order due date? Provide all supporting documentation and criteria, including any procedures and inspection protocols demonstrating decision-making. Additionally, provide examples in which this has occurred, including any swaging changes.<br>d. Include any criteria that would fall under "Other Reassessment" as seen in Column 1 Reason for interruption (if applicable).<br>e. PG&E included three Priority 1 level work orders within the tab labeled "Table 13 - Open".<br>f. Provide the work order documentation associated with each of these tags (i.e. Electric Corrective notification).<br>g. Are these tags still open? If not, provide the respective completion date for when each tag was closed, as applicable.<br>h. Within non-HTD, PG&E included 13 Priority 1 level work orders that were closed in 2022 and 52 that are still open.<br>i. Explain what circumstances would lead to a Priority 1 tag within non-HTD.<br>j. Provide a list of the projects in which the 13 closed work orders were associated with, including details on the associated mitigation being used.<br>k. Provide a list of the projects in which the 52 work orders were associated with, including details on the associated mitigation being used.<br>l. Regarding PG&E's ignition risk notifications:<br>1. Provide documentation and/or procedures PG&E uses to determine whether or not a work order meets ignition risk criteria, including any relevant thresholds (e.g., equipment type, risk code, etc.). This should also include an explanation as to how PG&E prioritizes within the categorization of ignition risk tags (i.e. planning for timing of correction based on know risk).<br>2. Provide PG&E's list of Facility Damage Action (FDA) codes for determining which ones present an ignition risk, as discussed in response to CalAdvocates Data Request 19 Question 8.  |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_007.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_007.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Covered Conductor Installation - Distribution                    |
| 379 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_08 | 8 | CPUC - SPD (Safety Policy Division)_005_08 | 8. Please provide WMP-Discovery2023_DR_TURN_007-Q001A01CONC.xlsx, used to address TURN Data Request 7, Question 1, discussing RSE calculation for system hardening.  |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_005.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 380 | CPUC - SPD (Safety Policy Division) | 005                | CPUC - SPD (Safety Policy Division)_005_09 | 9 | CPUC - SPD (Safety Policy Division)_005_09 | 9. On page 15 of the 2022-2023 WMP, PG&E states that the WDRM v3 ignition source is PG&E's Historical Ignition Data, 2015-2021 (approximately 2,000 CPUC-reportable ignitions and approximately 1,900 non-reportable ignitions).<br>a. Describe how PG&E is using the ~3,000 CPUC-reportable ignitions in its risk modeling.<br>b. Provide this ~3,000 non-CPUC-reportable ignitions data, as announced in format similar to that in the WDRM v3 report.<br>c. After it was pointed out by SPD that there appeared to be a discrepancy in the methodologies used to calculate the risk mitigation effectiveness of EPSS, Undergrounding and Covered Conductor (CC), PG&E stated that CC is probably the most "natural" mitigation effectiveness as the effectiveness is based on empirical data and close utility collaboration. EPSS is the second most as it is based on general data, and that it is the least mature mitigation effectiveness as it is PG&E's assertion that PG&E is addressing the risk from secondary lines and service drops in part by replacing the secondary with covered aerial conductor and breakaway connectors at all locations (see PG&E's response to Question 4 of SPD, PG&E_2023_003 for additional description). PG&E also stated that there may need to be a messaging update because the 99% risk reduction reflects the cases, not the actual conditions, actually done.<br>The CONFIDENTIAL attachments are being provided pursuant to the accompanying confidentiality declaration.<br>a. There is no difference between the terms "Field Safety Reassessment" and "Planned Field Safety Reassessment". The transmission team used the term "Planned Field Safety Reassessment" in their QDR reporting while the distribution team used the term "Field Safety Reassessment". We will align our terminology for future reporting by using the term "Field Safety Reassessment".<br>b. Due to the current tag backlog, PG&E's execution of some notifications may not meet GO 95, Rule 18 compliance 100% of the time. As a result, we have focused our efforts on risk marking the outstanding tags and working the riskiest tags first. FSRs are an internal containment activity we perform to mitigate potential safety and wildfire impacts by conducting an additional field visit (FSR) to check the identified condition requires escalation. Additionally, as part of our 2023 WMP, we committed to closing all newly identified ignition tags in HFTD/SRA in accordance with GO 95, Rule 18 timelines (steady-state).<br>For distribution tags, if the condition in the field has deteriorated, the priority of the tag can be escalated to complete the work as a Level 1 Emergency (A tag) or set a revised due date to complete the work within 90 days as a B tag. When a condition is determined not to require escalation, the work order date is not extended, and the tag is then worked according to the tag's risk ranking. We have committed to reduce the wildfire risk associated with our distribution tag backlog by 48% in 2023 and by 68% by the end of 2024. Please also note that the work order date change is used for internal tag escalation planning. The FSR does not extend the GO 95, Rule 18 due date of a tag, which can only be changed by a recognized exemption to GO 95, Rule 18. For more information, please see procedure TD-8123P-001 WMP-Discovery2023_DR_OEIS_006-Q001A01CONC.pdf.<br>The CONFIDENTIAL attachments are being provided pursuant to the accompanying confidentiality declaration.<br>a. Please see "WMP-Discovery_2023_DR_OEIS_006-Q001A01CONC.zip" for the requested confidential attachments previously provided to Cal Advocates.<br>b. Please see "WMP-Discovery_DR_OEIS_006-Q001A01CONC.zip" for the requested confidential attachments.<br>c. Please see attachment "WMP-Discovery2023_DR_OEIS_006-Q001A01CONC.xlsx" for the requested circuit segment detail. Please note the following:<br>- There are differences between the WDRM v2 and the WDRM v3 and, as a result, there are five circuit segments that have a V3 risk score but do not have a V2 risk score. |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_009.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_009.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 381 | CPUC - SPD (Safety Policy Division) | 006                | CPUC - SPD (Safety Policy Division)_006_01 | 1 | CPUC - SPD (Safety Policy Division)_006_01 | 1. The CPUC issued (D) 19-07-015, adopting an emergency disaster relief program for utility customers. The trigger to implement the program is an emergency or disaster as defined by the United States, the State of California, or the County of the United States. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program.   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_006.zip</a>   | 0 | N/A | 8.1.8.1.1 | Grid Design and System Hardening      | Protective Equipment and Device Settings                         |
| 382 | CPUC - SPD (Safety Policy Division) | 006                | CPUC - SPD (Safety Policy Division)_006_02 | 2 | CPUC - SPD (Safety Policy Division)_006_02 | 2. Provide PG&E's list of Facility Damage Action (FDA) codes for determining which ones present an ignition risk, as discussed in response to CalAdvocates Data Request 19 Question 8.   |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_006.zip</a>   | 0 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 383 | CPUC - SPD (Safety Policy Division) | 007                | CPUC - SPD (Safety Policy Division)_007_01 | 1 | CPUC - SPD (Safety Policy Division)_007_01 | 1. Provide the following confidential attachments from CalAdvocates Data Request:<br>a. Attachment 1 in response to Data Request 19 Question 13.<br>b. Attachment 1 in response to Data Request 21 Question 3.<br>c. Attachment 1 in response to Data Request 21 Question 7.<br>d. Attachment 1 in response to Data Request 7, Question 3.<br>e. For each of the circuit segments listed in part (d), provide by Excel:<br>1. VFE score<br>2. FFE score<br>3. FFE score<br>4. FFE score<br>5. FFE score<br>6. FFE score<br>7. FFE score<br>8. FFE score<br>9. FFE score<br>10. FFE score<br>11. FFE score<br>12. FFE score<br>13. FFE score<br>14. FFE score<br>15. FFE score<br>16. FFE score<br>17. FFE score<br>18. FFE score<br>19. FFE score<br>20. FFE score<br>21. FFE score<br>22. FFE score<br>23. FFE score<br>24. FFE score<br>25. FFE score<br>26. FFE score<br>27. FFE score<br>28. FFE score<br>29. FFE score<br>30. FFE score<br>31. FFE score<br>32. FFE score<br>33. FFE score<br>34. FFE score<br>35. FFE score<br>36. FFE score<br>37. FFE score<br>38. FFE score<br>39. FFE score<br>40. FFE score<br>41. FFE score<br>42. FFE score<br>43. FFE score<br>44. FFE score<br>45. FFE score<br>46. FFE score<br>47. FFE score<br>48. FFE score<br>49. FFE score<br>50. FFE score<br>51. FFE score<br>52. FFE score<br>53. FFE score<br>54. FFE score<br>55. FFE score<br>56. FFE score<br>57. FFE score<br>58. FFE score<br>59. FFE score<br>60. FFE score<br>61. FFE score<br>62. FFE score<br>63. FFE score<br>64. FFE score<br>65. FFE score<br>66. FFE score<br>67. FFE score<br>68. FFE score<br>69. FFE score<br>70. FFE score<br>71. FFE score<br>72. FFE score<br>73. FFE score<br>74. FFE score<br>75. FFE score<br>76. FFE score<br>77. FFE score<br>78. FFE score<br>79. FFE score<br>80. FFE score<br>81. FFE score<br>82. FFE score<br>83. FFE score<br>84. FFE score<br>85. FFE score<br>86. FFE score<br>87. FFE score<br>88. FFE score<br>89. FFE score<br>90. FFE score<br>91. FFE score<br>92. FFE score<br>93. FFE score<br>94. FFE score<br>95. FFE score<br>96. FFE score<br>97. FFE score<br>98. FFE score<br>99. FFE score<br>100. FFE score  |   | Kevin Miller    | 5/1/2023  | 6/12/2023 | 6/12/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_007.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/SPD_007.zip</a>   | 3 | N/A | 8.1.2.1   | Grid Design and System Hardening      | Covered Conductor Installation - Distribution                    |
| 384 | OEIS                                | 006                | OEIS_006                                   | 1 | OEIS_006_01                                | 1. Explain what circumstances would lead to a Priority 1 tag within non-HTD.<br>2. Provide a list of the projects in which the 13 closed work orders were associated with, including details on the associated mitigation being used.<br>3. Provide a list of the projects in which the 52 work orders were associated with, including details on the associated mitigation being used.<br>4. Regarding PG&E's ignition risk notifications:<br>a. Provide documentation and/or procedures PG&E uses to determine whether or not a work order meets ignition risk criteria, including any relevant thresholds (e.g., equipment type, risk code, etc.). This should also include an explanation as to how PG&E prioritizes within the categorization of ignition risk tags (i.e. planning for timing of correction based on know risk).<br>b. Provide PG&E's list of Facility Damage Action (FDA) codes for determining which ones present an ignition risk, as discussed in response to CalAdvocates Data Request 19 Question 8.  |   | Dakota Smith    | 5/1/2023  | 5/23/2023 | 5/23/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip</a> | 8 | N/A | 8.1.7     | Open Work Orders                      | N/A  |
| 385 | OEIS                                | 006                | OEIS_006                                   | 2 | OEIS_006_02                                | 2. Provide the following confidential attachments from CalAdvocates Data Request:<br>a. Attachment 1 in response to Data Request 19 Question 13.<br>b. Attachment 1 in response to Data Request 21 Question 3.<br>c. Attachment 1 in response to Data Request 21 Question 7.<br>d. Attachment 1 in response to Data Request 7, Question 3.<br>e. For each of the circuit segments listed in part (d), provide by Excel:<br>1. VFE score<br>2. FFE score<br>3. FFE score<br>4. FFE score<br>5. FFE score<br>6. FFE score<br>7. FFE score<br>8. FFE score<br>9. FFE score<br>10. FFE score<br>11. FFE score<br>12. FFE score<br>13. FFE score<br>14. FFE score<br>15. FFE score<br>16. FFE score<br>17. FFE score<br>18. FFE score<br>19. FFE score<br>20. FFE score<br>21. FFE score<br>22. FFE score<br>23. FFE score<br>24. FFE score<br>25. FFE score<br>26. FFE score<br>27. FFE score<br>28. FFE score<br>29. FFE score<br>30. FFE score<br>31. FFE score<br>32. FFE score<br>33. FFE score<br>34. FFE score<br>35. FFE score<br>36. FFE score<br>37. FFE score<br>38. FFE score<br>39. FFE score<br>40. FFE score<br>41. FFE score<br>42. FFE score<br>43. FFE score<br>44. FFE score<br>45. FFE score<br>46. FFE score<br>47. FFE score<br>48. FFE score<br>49. FFE score<br>50. FFE score<br>51. FFE score<br>52. FFE score<br>53. FFE score<br>54. FFE score<br>55. FFE score<br>56. FFE score<br>57. FFE score<br>58. FFE score<br>59. FFE score<br>60. FFE score<br>61. FFE score<br>62. FFE score<br>63. FFE score<br>64. FFE score<br>65. FFE score<br>66. FFE score<br>67. FFE score<br>68. FFE score<br>69. FFE score<br>70. FFE score<br>71. FFE score<br>72. FFE score<br>73. FFE score<br>74. FFE score<br>75. FFE score<br>76. FFE score<br>77. FFE score<br>78. FFE score<br>79. FFE score<br>80. FFE score<br>81. FFE score<br>82. FFE score<br>83. FFE score<br>84. FFE score<br>85. FFE score<br>86. FFE score<br>87. FFE score<br>88. FFE score<br>89. FFE score<br>90. FFE score<br>91. FFE score<br>92. FFE score<br>93. FFE score<br>94. FFE score<br>95. FFE score<br>96. FFE score<br>97. FFE score<br>98. FFE score<br>99. FFE score<br>100. FFE score  |   | Dakota Smith    | 5/1/2023  | 5/23/2023 | 5/23/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip</a> | 2 | N/A | N/A       | N/A                                   | N/A  |
| 386 | OEIS                                | 006                | OEIS_006                                   | 3 | OEIS_006_03                                | 3. Provide the following confidential attachments from CalAdvocates Data Request:<br>a. Attachment 1 in response to Data Request 19 Question 13.<br>b. Attachment 1 in response to Data Request 21 Question 3.<br>c. Attachment 1 in response to Data Request 21 Question 7.<br>d. Attachment 1 in response to Data Request 7, Question 3.<br>e. For each of the circuit segments listed in part (d), provide by Excel:<br>1. VFE score<br>2. FFE score<br>3. FFE score<br>4. FFE score<br>5. FFE score<br>6. FFE score<br>7. FFE score<br>8. FFE score<br>9. FFE score<br>10. FFE score<br>11. FFE score<br>12. FFE score<br>13. FFE score<br>14. FFE score<br>15. FFE score<br>16. FFE score<br>17. FFE score<br>18. FFE score<br>19. FFE score<br>20. FFE score<br>21. FFE score<br>22. FFE score<br>23. FFE score<br>24. FFE score<br>25. FFE score<br>26. FFE score<br>27. FFE score<br>28. FFE score<br>29. FFE score<br>30. FFE score<br>31. FFE score<br>32. FFE score<br>33. FFE score<br>34. FFE score<br>35. FFE score<br>36. FFE score<br>37. FFE score<br>38. FFE score<br>39. FFE score<br>40. FFE score<br>41. FFE score<br>42. FFE score<br>43. FFE score<br>44. FFE score<br>45. FFE score<br>46. FFE score<br>47. FFE score<br>48. FFE score<br>49. FFE score<br>50. FFE score<br>51. FFE score<br>52. FFE score<br>53. FFE score<br>54. FFE score<br>55. FFE score<br>56. FFE score<br>57. FFE score<br>58. FFE score<br>59. FFE score<br>60. FFE score<br>61. FFE score<br>62. FFE score<br>63. FFE score<br>64. FFE score<br>65. FFE score<br>66. FFE score<br>67. FFE score<br>68. FFE score<br>69. FFE score<br>70. FFE score<br>71. FFE score<br>72. FFE score<br>73. FFE score<br>74. FFE score<br>75. FFE score<br>76. FFE score<br>77. FFE score<br>78. FFE score<br>79. FFE score<br>80. FFE score<br>81. FFE score<br>82. FFE score<br>83. FFE score<br>84. FFE score<br>85. FFE score<br>86. FFE score<br>87. FFE score<br>88. FFE score<br>89. FFE score<br>90. FFE score<br>91. FFE score<br>92. FFE score<br>93. FFE score<br>94. FFE score<br>95. FFE score<br>96. FFE score<br>97. FFE score<br>98. FFE score<br>99. FFE score<br>100. FFE score  |   | Dakota Smith    | 5/1/2023  | 5/23/2023 | 5/23/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_006.zip</a> | 1 | N/A | 8.1.2.2   | Grid Design and System Hardening      | Undergrounding of Electric Lines and/or Equipment - Distribution |
| 387 | OEIS                                | 007                | OEIS_007                                   | 1 | OEIS_007_01                                | 1. The CPUC issued (D) 19-07-015, adopting an emergency disaster relief program for utility customers. The trigger to implement the program is an emergency or disaster as defined by the United States, the State of California, or the County of the United States. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program. The program is intended to provide relief to utility customers who are impacted by a disaster as described in the program.   |   | Alan Solomon    | 5/24/2023 | 5/30/2023 | 5/30/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_007.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_007.zip</a> | 0 | N/A | 8.4.6     | Emergency Preparedness                | Customer Support in Wildfire and PSPS Emergencies                |
| 388 | OEIS                                | 008                | OEIS_008                                   | 1 | OEIS_008_01                                | 1. Provide PG&E's list of Facility Damage Action (FDA) codes for determining which ones present an ignition risk, as discussed in response to CalAdvocates Data Request 19 Question 8.   |   | Dakota Smith    | 5/25/2023 | 5/31/2023 | 5/31/2023 | <a href="https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_008.zip">https://www.pge.com/page_global/common/pdf/safety/emergency-preparedness/natural-disaster/wildfire/wildfire-mitigation-plan/reference-docs/2023/OEIS_008.zip</a> | 0 | N/A | 8.2.2.2.5 |                                       |  |



