

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 3 - S C E - 0 0 7

To: Energy Safety
Prepared by: June Bote
Job Title: Senior Advisor
Received Date: 6/13/2023

Response Date: 6/16/2023

Question 01:

Regarding 3- and 10-Year Emergency Preparedness Objectives

a. For SCE’s 3- and 10-year Emergency Preparedness Objectives (Tables 8-33 and 8-34), for the four (4) Objectives listed below, the Methods of Verification are unclear. Please specify what documentation or reporting is available to verify progress toward each objective.

Objectives	ID	Applicable Reg. Codes, Standards, and Best Practices	Method of Verification	Completion Date
3-year Maintain a comprehensive all-hazards planning and preparedness program to provide effective emergency response and to safely and expeditiously restore service during and after a major event.	Emergency Preparedness Plan (8.4.2)	<ul style="list-style-type: none"> • GD 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	Annual Filing	Yearly
3-year Provide effective and accurate communications to the public before, during and immediately following major outages and emergencies.	Public Emergency Communication Strategy (8.4.4)	<ul style="list-style-type: none"> • GD 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	Activity Reporting	On-going
10-year Refined emergency planning and preparedness practices and programs to support customers before, during, and following emergency events.	Customer Support In Wildfire and PSPS Emergencies (8.4.6)	<ul style="list-style-type: none"> • GD 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	Activity Reporting	On-going
10-year Ongoing implementation of lessons learned and findings from After Action Reports (AARs) and other external sources to continuously improve emergency response capabilities.	Emergency Preparedness Plan (8.4.2) External Collaboration and Coordination (8.4.3) Public Emergency Communication Strategy (8.4.4)	<ul style="list-style-type: none"> • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 	Activity Reporting	On-going

Response to Question 01:

Please see the attachment titled *Tables 8-33 and 8-34.pdf* for additional details on methods of verification.

Table 8-33 -Emergency Preparedness Initiative Objectives (3-year plan)

Objectives for Three Years (2023–2025)	Applicable Initiative(s), Tracking ID(s)	Applicable Regulations, Codes, Standards, and Best Practices (See Note)	Method of Verification (i.e., program)	Completion Date	Reference (section & page #)
<p>Maintain a comprehensive all-hazards planning and preparedness program to provide effective emergency response and to safely and expeditiously restore service during and after a major event.</p>	<p>Emergency Preparedness Plan (8.4.2)</p>	<ul style="list-style-type: none"> • GO 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	<p>Annual Filing</p> <p>SCE maintains an annual schedule for completion of updates to both the All-Hazards Emergency Plan and associated hazard specific plans to provide for response and meet regulatory requirements. SCE also files these emergency plans annually to meet regulatory requirements (GO166, EEAP, etc.) with the Safety Enforcement Division of the CPUC. A publicly available version of the All Hazards Emergency Plan was also posted on the Energy Safety website in 2023 and can be found at https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=53525&shareable=true</p>	<p>Yearly</p>	<p>Section 8.4.2 Emergency Preparedness Plan, pp. 529-551</p>

<p>Provide effective and accurate communications to the public before, during and immediately following major outages and emergencies.</p>	<p>Public Emergency Communication Strategy (8.4.4)</p>	<ul style="list-style-type: none"> • GO 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	<p>Activity Reporting</p> <p>Communication to customers occurs on our website, including banners and macro messaging on our home page, and updated information on our outage page and map; through Energized, our news channel; and on social media. During emergencies, all these channels are publicly available for review. News stories on Energized are posted in advance of flex alerts, and when there is a potential for significant customer impacts, with follow-up reporting as required. These articles are archived and publicly available indefinitely (going back to 2013) at energized.com. For PSPS, notifications are sent pursuant to PSPS guidelines and results are available in SCE post-event reports, 10 days after the conclusion of each event, which can be found on SCE's website at: https://www.sce.com/wildfire/wildfire-safety.</p>	<p>On-going</p>	<p>Section 8.4.4 Public Emergency Communication Strategy, pp. 558-566</p>
--	--	--	---	-----------------	---

Note: An asterisk indicates that the electrical corporation exceeds a particular code, regulation, standard, or best practice. The electrical corporation must provide a reference to the appendix section and page providing further documentation,

justification, and substantiation.

Table 8-34 - Emergency Preparedness Initiative Objectives (10-year plan)

Objectives for Ten Years (2026–2032)	Applicable Initiative(s), Tracking ID(s)	Applicable Regulations, Codes, Standards, and Best Practices (See Note)	Method of Verification (i.e., program)	Completion Date	Reference (section & page #)
Refined emergency planning and preparedness practices and programs to support customers before, during, and following emergency events.	Customer Support in Wildfire and PSPS Emergencies (8.4.6)	<ul style="list-style-type: none"> • GO 95 • GO128 • GO 166 • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 • SEMS • NIMS 	<p>Activity Reporting</p> <p>All planning and preparedness programs to support customers before, during and following emergency events are described on SCE’s website at: https://www.sce.com/outage-center/customer-resources-and-support</p> <p>Information is updated to be current with any program updates or changes.</p>	On-going	Section 8.4.6 Customer Support in Wildfire and PSPS Emergencies, pp. 570-576
Ongoing implementation of lessons learned and findings from After Action Reports (AARs) and other external sources to continuously improve emergency response capabilities.	<p>Emergency Preparedness Plan (8.4.2)</p> <p>External Collaboration and Coordination (8.4.3)</p> <p>Public Emergency Communication Strategy (8.4.4)</p>	<ul style="list-style-type: none"> • ESRB-8 • PSPS OIR Phase 1 D.19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 • PSPS OII D.21-06-014 	<p>Activity Reporting</p> <p>AARs – completed after each exercise and real-world event. AARs include corrective action items for resolution that are managed to completion.</p>	On-going	Section 8.4.2 (Emergency Preparedness Plan), pp. 529-551; Section 8.4.3 (External Collaboration and Coordination) pp. 550-560; Section 8.4.4 (Public Emergency Communication Strategy), pp. 558-566

Note: An asterisk indicates that the electrical corporation exceeds a particular code, regulation, standard, or best practice. The electrical corporation must provide a reference to the appendix section and page providing further documentation, justification, and substantiation.

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 3 - S C E - 0 0 7

To: Energy Safety
Prepared by: Bryan Landry
Job Title: Senior Advisor
Received Date: 6/13/2023

Response Date: 6/16/2023

Question 02:

Regarding the Use of Landfire Versions

In its response to Data Request OEIS-P-WMP-2023-SCE-002 SCE states that it did not utilize Landfire 2020 due to its late release date in June of 2022, but utilized the older version Landfire 2016 with an additional 19 edits to fuels and fire areas developed by Technosylva.

a. Will SCE be utilizing Landfire 2020 when it completes its next WMP submittal in 2024? If not, please explain why SCE will not be utilizing the most up-to-date version of Landfire. PG&E and SDG&E both use Landfire 2020.

Response to Question 02:

A schedule has not been issued that states the submittal date of the next WMP Update in 2024. However, at this time, SCE does not plan to use the LandFire 2020 fuel model as the basis of wildfire consequence modeling in its 2024 WMP update.

Instead, SCE plans to use a Technosylva-developed fuel model for our next WMP Update as this layer incorporates the remote-sensed data with the most up-to-date information about land disturbances and fuel types/amounts.

A preview of the sources and methods used to develop this fuel model can be found at

<https://gisportal.technosylva.com/portal/apps/storymaps/stories/cd2be1a093e14b0fa0101d6124c1b5c8>