

Row ID	Agency	Project Name	Task ID	Task Description	Start Date	End Date	Priority	Responsible Party	Status	Notes				
22	CaPA	Set WMP-08	CaPA_Set WMP-08	Table 9-12, Vegetation Management Implementation Objectives, PG&E's Focused Tree Inspection Program currently under development. By the end of 2023, PG&E plans to fully implement AOC's core functional teams to implement guidelines across all AOC's.	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections	
23	CaPA	Set WMP-08	CaPA_Set WMP-08_011	Table 14, PG&E's WMP Targets, states that PG&E will have a total of 18,111 circuit miles of overhead transmission lines.	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.1.1	Vegetation Management and Inspections	Routine Transmission NERC and Non-NERC	
24	CaPA	Set WMP-08	CaPA_Set WMP-08_012	a) Does PG&E have a plan to collect LDMR data on approximately 600 overhead circuit miles of transmission?	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.2.4	Vegetation Management and Inspections	Tree Removal Inventory	
25	CaPA	Set WMP-08	CaPA_Set WMP-08_013	Table 14, PG&E's WMP Targets, states that "Each of the 3 programs (Vegetation Distribution, Routine Transmission and Pole Clearing) must achieve a 95% quality verification audit results pass rate."	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.1	Vegetation Management and Inspections	Quality Assurance and Quality Verification	
26	CaPA	Set WMP-08	CaPA_Set WMP-08_014	Table 8-1.1, Vegetation Management QV 2023, lists the following audit pass rates for 2022 VM work.	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.2.2	Vegetation Management and Inspections	Distribution Second Patrol	
27	CaPA	Set WMP-08	CaPA_Set WMP-08_015	Regarding the "Defensible Space Inspection" described in section 8.2.2.1.1 of PG&E's WMP, PG&E states:	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.2.3.1	Vegetation Management and Inspections	Defensible Space Inspection	
28	CaPA	Set WMP-08	CaPA_Set WMP-08_016	Regarding "Wood and Slash Management" described in section 8.2.3 of PG&E's WMP, PG&E states:	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.3.2	Vegetation Management and Inspections	Wood and Slash Management	
29	CaPA	Set WMP-08	CaPA_Set WMP-08_017	Regarding "High-Risk Species" described in section 8.2.3.5 of PG&E's WMP, PG&E states:	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.3.6	Vegetation Management and Inspections	High-Risk Species	
30	CaPA	Set WMP-08	CaPA_Set WMP-08_018	PG&E's WMP states, in Tables 8-1B, 3-1M, VM Field QC Metrics Report, that pass rates are "not a WMP target for 2023-2025."	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	0	N/A	8.2.5.2	Vegetation Management and Inspections	Quality Control	
31	CaPA	Set WMP-08	CaPA_Set WMP-08_019	Table 8-1D, Priority 1 Priority 2 and Second Patrol Trees Categorized by Age, shows 28% priority 1 or 2 trees that are inspected more than 180 days prior to February 28, 2023.	3/30/2023	4/5/2023	4/5/2023	Holy Wehrman	1	N/A	8.2.6	Vegetation Management and Inspections	Open Work Orders	
32	CaPA	Set WMP-09	CaPA_Set WMP-09_01	P. 10 of PG&E's WMP states, "We have completed certain programs and removed some less impactful targets from the 2023 WMP."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	1	N/A	Executive Summary & Overview	N/A
33	CaPA	Set WMP-09	CaPA_Set WMP-09_02	P. 107 of PG&E's WMP states, "Increased temperatures can cause electronic equipment to become quickly which will increase the need for more frequent asset replacements. Higher temperatures may cause equipment to fail."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	5.1.4	Overview of the Service Territory	Climate Change Phenomena and Trends	
34	CaPA	Set WMP-09	CaPA_Set WMP-09_03	P. 174 of PG&E's WMP states, "The results of the PSPS Consequence Model are then calibrated to PG&E's Enterprise Risk Model (ERM) to determine the ERM Risk Score for PSPS."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	1	N/A	8.3.4.2	Situational Awareness and Forecasting	Ignition Detection Systems	
35	CaPA	Set WMP-09	CaPA_Set WMP-09_04	P. 161 of PG&E's WMP discusses Group 1, Above-Grade Hardware, in the context of PG&E's WRM. Group 1 has two sub-groups: PG&E states, "Sub-Group 1 consists of components where the wire closely abuts or is in contact with the structure."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	3	N/A	6.2.2.3	Risk Methodology and Assessment	Risk and Risk Components Calculation	
36	CaPA	Set WMP-09	CaPA_Set WMP-09_05	P. 161 of PG&E's WMP discusses Group 1, Above-Grade Hardware, in the context of PG&E's WRM. Group 1 has two sub-groups: PG&E states, "Sub-Group 1 consists of components where the wire closely abuts or is in contact with the structure."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	6.2.2.1	Risk Methodology and Assessment	Risk and Risk Components Calculation	
37	CaPA	Set WMP-09	CaPA_Set WMP-09_06	P. 193 of PG&E's WMP states, "Top risk areas are defined as the areas corresponding to the roughly 100 m miles that intersect PG&E overhead electrical infrastructure locations that are in the upper 20th percentile based on WDRM v3 risk scores."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	6.1.1.2	Risk Methodology and Assessment	Top Risk Areas Within the HRA	
38	CaPA	Set WMP-09	CaPA_Set WMP-09_07	a) What is PG&E's species-specific stress index model for tree health and mortality?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	4.4	Overview of WMP	Risk-Informed Framework	
39	CaPA	Set WMP-09	CaPA_Set WMP-09_08	When conducting VM activities, PG&E employees and contractors must adhere to PG&E's Best Management Practices (BMP) where practicable. BMPs are considered practicable where physically possible and not conflicting with other regulatory requirements.	4/4/2023	4/12/2023	4/12/2023	Holy Wehrman	1	N/A	5.4.5	Overview of the Service Territory	Environmental Compliance and Permitting	
40	CaPA	Set WMP-09	CaPA_Set WMP-09_09	PG&E's Best Management Practices (BMP) where practicable. BMPs are considered practicable where physically possible and not conflicting with other regulatory requirements.	4/4/2023	4/12/2023	4/12/2023	Holy Wehrman	1	N/A	5.4.5	Overview of the Service Territory	Environmental Compliance and Permitting	
41	CaPA	Set WMP-09	CaPA_Set WMP-09_10	Section 8.2.3.5 of PG&E's WMP states, "The primary target for secondary patrolling is the 100 m miles of overhead electrical infrastructure that intersect PG&E's WDRM v3 risk scores."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	8.2.2.2.2	Vegetation Management and Inspections	Distribution Second Patrol	
42	CaPA	Set WMP-09	CaPA_Set WMP-09_011	Does PG&E's target of 10,000 miles of undergrounding refer to the number of OH circuit-miles to be moved underground, or the number of underground circuit-miles to be installed?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	Appendix D	Access for Continued Improvement	ACI PG&E-23-4 - Revise Process of Prioritizing Wildlife Mitigations	
43	CaPA	Set WMP-09	CaPA_Set WMP-09_012	a) What is PG&E's current forecast cost per circuit-mile for undergrounding projects completed in the second half of 2022?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution	
44	CaPA	Set WMP-09	CaPA_Set WMP-09_013	a) What is PG&E's forecast RSE for undergrounding completed in the second half of 2022?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	1	N/A	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution	
45	CaPA	Set WMP-09	CaPA_Set WMP-09_014	a) Does PG&E's current forecast cost per circuit-mile for covered conductor projects completed in the second half of 2022?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	8.1.2.5	Grid Design and System Hardening	Traditional Overhead Hardening - Transmission Conductor and Distribution	
46	CaPA	Set WMP-09	CaPA_Set WMP-09_015	a) What is PG&E's forecast RSE for covered conductor system hardening completed in the second half of 2022?	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	0	N/A	8.1.2.5	Grid Design and System Hardening	Traditional Overhead Hardening - Transmission Conductor and Distribution	
47	CaPA	Set WMP-09	CaPA_Set WMP-09_016	In response to data request CaPA/CALCAC/2023-02-WMP-0D, question 7C, PG&E states, "The primary basis for site metrics used for low risk prioritization methodology based on the 2021 WDRM v3 and (2) the (Wildfire Forecast) ERM reports based on the 2022 WDRM v3 and considering undergrounding feasibility."	4/4/2023	4/7/2023	4/7/2023	Holy Wehrman	1	N/A	7.2	Wildfire Mitigation Strategy Development	Wildfire Mitigation Strategy	
48	CaPA	Set WMP-10	CaPA_Set WMP-10_01	a) Does PG&E's forecast for the number of overhead circuit miles to be moved underground in 2024 and 2025?	4/4/2023	4/10/2023	4/10/2023	Holy Wehrman	0	N/A	8.1.1.2	Grid Design, Operations, and Maintenance	Targets	
49	CaPA	Set WMP-10	CaPA_Set WMP-10_02	a) What factors contribute to the reduction in the number of EPPS events discussed above?	4/4/2023	4/10/2023	4/10/2023	Holy Wehrman	0	N/A	8.1.1.3	Grid Design, Operations, and Maintenance	Performance Metrics Identified by the Electrical Corporation	
50	CaPA	Set WMP-10	CaPA_Set WMP-10_03	a) Does PG&E forecast a change in the average duration of EPPS events during the 2023-2025 period?	4/4/2023	4/10/2023	4/10/2023	Holy Wehrman	0	N/A	8.1.1.3	Grid Design, Operations, and Maintenance	Performance Metrics Identified by the Electrical Corporation	
51	CaPA	Set WMP-10	CaPA_Set WMP-10_04	a) Does PG&E forecast a change in the average duration of EPPS events during the 2023-2025 period?	4/4/2023	4/10/2023	4/10/2023	Holy Wehrman	0	N/A	8.1.2.6.2	Grid Design and System Hardening	Emerging Grid Hardening Technology Installations and Pilots	

ID	Category	Item ID	Sub Item ID	Priority	Description	Lead	Start Date	End Date	Status	Progress	Dependencies	Impact
229	OEIS	003	OEIS_003	15	OEIS_003_Q15							
230	OEIS	003	OEIS_003	16	OEIS_003_Q16							
231	OEIS	003	OEIS_003	17	OEIS_003_Q17							
232	CaPA	Set WMP-17	CaPA_Set WMP-17_Q1	1	CaPA_Set WMP-17_Q1							
233	CaPA	Set WMP-17	CaPA_Set WMP-17_Q2	2	CaPA_Set WMP-17_Q2							
234	CaPA	Set WMP-17	CaPA_Set WMP-17_Q3	3	CaPA_Set WMP-17_Q3							
235	CaPA	Set WMP-17	CaPA_Set WMP-17_Q4	4	CaPA_Set WMP-17_Q4							
236	TURN	TURN_006	TURN_006_Q1	1	TURN_006_Q1							
237	TURN	TURN_006	TURN_006_Q2	2	TURN_006_Q2							
238	TURN	TURN_006	TURN_006_Q3	3	TURN_006_Q3							
239	TURN	TURN_006	TURN_006_Q4	4	TURN_006_Q4							
240	TURN	TURN_006	TURN_006_Q5	5	TURN_006_Q5							
241	TURN	TURN_006	TURN_006_Q6	6	TURN_006_Q6							
242	TURN	TURN_007	TURN_007_Q1	1	TURN_007_Q1							
243	TURN	TURN_007	TURN_007_Q2	2	TURN_007_Q2							
244	TURN	TURN_007	TURN_007_Q3	3	TURN_007_Q3							
245	TURN	TURN_007	TURN_007_Q4	4	TURN_007_Q4							
246	CaPA	Set WMP-18	CaPA_Set WMP-18_Q1	1	CaPA_Set WMP-18_Q1							
247	CaPA	Set WMP-18	CaPA_Set WMP-18_Q2	2	CaPA_Set WMP-18_Q2							
248	CaPA	Set WMP-18	CaPA_Set WMP-18_Q3	3	CaPA_Set WMP-18_Q3							
249	CaPA	Set WMP-18	CaPA_Set WMP-18_Q4	4	CaPA_Set WMP-18_Q4							
250	CaPA	Set WMP-18	CaPA_Set WMP-18_Q5	5	CaPA_Set WMP-18_Q5							
250	CaPA	Set WMP-18	CaPA_Set WMP-18_Q6	6	CaPA_Set WMP-18_Q6							
251	CaPA	Set WMP-18	CaPA_Set WMP-18_Q7	7	CaPA_Set WMP-18_Q7							
252	CaPA	Set WMP-18	CaPA_Set WMP-18_Q8	8	CaPA_Set WMP-18_Q8							
253	TURN	TURN_008	TURN_008_Q1	1	TURN_008_Q1							
254	TURN	TURN_008	TURN_008_Q2	2	TURN_008_Q2							
255	TURN	TURN_008	TURN_008_Q3	3	TURN_008_Q3							
256	TURN	TURN_008	TURN_008_Q4	4	TURN_008_Q4							
257	TURN	TURN_008	TURN_008_Q5	5	TURN_008_Q5							
258	TURN	TURN_008	TURN_008_Q6	6	TURN_008_Q6							

Pre-Discovery 36	CaPA	Set WMP-06	CaPA_Set WMP-06	11	CaPA_Set WMP-06_011	Please provide a spreadsheet listing (as rows) each undergrounding project completed during the period of January 1, 2022, through December 31, 2022. For each project, please provide the following information (as columns): a) Project ID number or other identifier b) Circuit ID c) Location of project d) Date of completion	See "WMP-Discovery2023_DR_CalAdvocates_006-Q011A2b12CONP.xlsx" a) Project ID number or other identifier – See column A (order Number) and B (Order Description) b) Circuit ID – See column C c) Location of project – See column D d) Date of completion – See column E	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	1	N/A	8.1.2.2	Grid Design, Operations, and Maintenance	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 37	CaPA	Set WMP-06	CaPA_Set WMP-06	12	CaPA_Set WMP-06_012	Please provide a geodatabase file with a polyline feature for each undergrounding project completed during the period of January 1, 2022 through December 31, 2022. In addition to the spatial location, please provide the following attributes for each project: a) Project ID number or other identifier, matching part (a) of the previous question b) Circuit ID	See attachment "WMP-Discovery2023_DR_CalAdvocates_006-Q012A2b12CONP.zip" Please note that the data reflected in this GIS geodatabase file will not match the data set from Q11 due to the process time lag between construction completion and being fully mapped in GIS.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	1	N/A	8.1.2.2	Grid Design, Operations, and Maintenance	Undergrounding of Electric Lines and/or Equipment
Pre-Discovery 38	CaPA	Set WMP-06	CaPA_Set WMP-06	13	CaPA_Set WMP-06_013	Identify any ignitions in 2022 associated with assets where you had an existing corrective notification at the time of the ignition. Please provide a spreadsheet listing each such ignition (as rows) with the following information in separate columns: a) Unique ignition ID b) Date of ignition	Please see the table below identifying 2022 CPUC reportable ignitions where the asset involved in the ignition was associated with an existing open corrective maintenance notification at the time of the event. Ignition ID Date of Ignition	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	0	N/A	2022 WMP Section 7.3.4	Asset Management and Inspections	N/A
Pre-Discovery 39	CaPA	Set WMP-06	CaPA_Set WMP-06	14	CaPA_Set WMP-06_014	a) Has PG&E's Asset Failure Analysis Team causally connected any ignitions that occurred in 2022 to assets with existing asset or vegetation corrective notifications at the time of ignition? b) If the answer to part (a) is yes, please provide the following information on each such ignition: 1) Unique Ignition ID (matching the previous question) 2) Date of ignition	a) Yes, please see below b) The ignitions have been identified that meet these criteria: Ignition ID Date of Ignition Cause Type of Corrective Notification c) For all questions below, PG&E understands circuit modeling to mean the level of granularity at which a utility can model the configuration of its electrical assets and de-energize them as such. PG&E models and de-energizes circuits utilizing all switching devices on the system that do not have an action risk. The effects of hardware and other changes in lines will be accounted for in the model.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	0	N/A	2022 WMP 7.3.7	Data Governance	Asset Failure Analysis
Pre-Discovery 40	CaPA	Set WMP-06	CaPA_Set WMP-06	15	CaPA_Set WMP-06_015	PG&E's response to Data Request CalAdvocates-P06-2022WMP-17, Question 13, March 24, 2022. PG&E's inspection strategy in 2022 aims to complete detailed inspections on all assets in HTD Tier 3 and Zone 1, and approximately one-third of assets in HTD Tier 2. a) Please describe any changes to the above strategy for PG&E's detailed transmission inspections in 2023. b) Please describe any changes to the above strategy for PG&E's detailed distribution inspections in 2023.	a) Beginning in 2023, PG&E's detailed inspections of distribution structures in high fire areas will be informed by wildfire consequence as provided PG&E's Wildfire Distribution Risk Model (WD). PG&E will complete a detailed inspection on each structure every one to three years. For additional details on this strategy, please refer to Section 8.1.2.1 of our 2023 WMP. This applies from our 2022 strategy where an inspection of Tier 3 and non-Tier 2 Tier 3.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	0	N/A	2022 WMP 7.3.4.1 and 7.3.4.14	Asset Management and Inspections	N/A
Pre-Discovery 41	CaPA	Set WMP-06	CaPA_Set WMP-06	16	CaPA_Set WMP-06_016	Regarding your PSPS circuit modeling capabilities: a) Please describe your present circuit modeling capabilities with regard to PSPS decision making ("PSPS circuit modeling capabilities") including what level of granularity you are able to determine how circuit handling efforts or other changes to a line segment will affect PSPS thresholds. b) Please describe any improvements to the present PSPS circuit modeling capabilities that you expect to have by developing Public Safety Power Shutoff (PSPS) risk scores at the circuit segment level? c) If the answer to either parts (a) or (b) is yes, please provide a geodatabase file containing, as line features, the most recent spatial data for all circuit segments for which you have modeled PSPS or EPSS risk scores. Include the following information for each circuit segment:	a) Yes. This is cited in Section 6.2.1, figure 6.2.1-3. b) No. c) Please see "WMP-Discovery2023_DR_CalAdvocates_006-Q017A10CONP.zip" which is a geodatabase file containing the circuit segments along with PSPS risk values and Circuit Segment names. This is the affected circuit segment information associated with #2 of the circuit.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	0	N/A	PSPS	N/A	N/A
Pre-Discovery 42	CaPA	Set WMP-06	CaPA_Set WMP-06	17	CaPA_Set WMP-06_017	REFLC and REFCAL: a) Have you developed Public Safety Power Shutoff (PSPS) risk scores at the circuit segment level? b) If the answer to either parts (a) or (b) is yes, please provide a geodatabase file containing, as line features, the most recent spatial data for all circuit segments for which you have modeled PSPS or EPSS risk scores. Include the following information for each circuit segment:	a) Yes. This is cited in Section 6.2.1, figure 6.2.1-3. b) No. c) Please see "WMP-Discovery2023_DR_CalAdvocates_006-Q017A10CONP.zip" which is a geodatabase file containing the circuit segments along with PSPS risk values and Circuit Segment names. This is the affected circuit segment information associated with #2 of the circuit.	Holly Wehman	2/10/2023	3/29/2023	3/29/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/CalAdvocates_006.sip	2	N/A	PSPS/EPSS	N/A	N/A
Pre-Discovery 43	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_001_01	1	CPUC - SPD (Safety Policy Division)_001_01	REFLC Plot at Calistoga Circuit Segment ID 1102131531 Describe various active settings profiles. Describe how staged fault testing is planned to be conducted. a) Have you identified any other systems or equipment that may be impacted by the REFLC plot? b) Have you identified any other systems or equipment that may be impacted by the REFLC plot? c) Have you identified any other systems or equipment that may be impacted by the REFLC plot?	a) In concept, EPSS and REFLC are two very different approaches that share a common goal of attempting to reduce risk associated with ignitions on primary electric distribution systems. i. EPSS – advantages: - Can be implemented on newly existing equipment and relay. ii. REFLC – advantages: - Can be implemented on existing equipment and relay. iii. REFLC – disadvantages: - Requires a large number of resources across all types of faults. iv. REFLC – disadvantages: - Requires a large number of resources across all types of faults. v. REFLC – disadvantages: - Requires a large number of resources across all types of faults. vi. REFLC – disadvantages: - Requires a large number of resources across all types of faults.	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/SPD_001.sip	0	N/A	8.1.8.13	Grid Operations and Procedures	Settings of Other Emerging Technologies (e.g. Rapid Earth Fault Current Limiter)
Pre-Discovery 44	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_001_02	2	CPUC - SPD (Safety Policy Division)_001_02	EPSS & REFLC: a) Have you identified any other systems or equipment that may be impacted by the REFLC plot? b) Have you identified any other systems or equipment that may be impacted by the REFLC plot? c) Have you identified any other systems or equipment that may be impacted by the REFLC plot?	a) The following includes activities on-going and planned to mitigate EPSS reliability impacts: Enhanced Outage Review Team (ORT) process that includes additional review of circuit/Circuit Protection Zone (CPZ) performance that when multiple outages occur triggers a Multiple Outage Review (MOR) to drive additional actions if needed to reduce repeat outages on the system.	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/SPD_001.sip	0	N/A	8.1.8.11	Grid Operations and Procedures	Protective Equipment and Device Settings
Pre-Discovery 45	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_001_03	3	CPUC - SPD (Safety Policy Division)_001_03	EPSS & REFLC: a) Have you identified any other systems or equipment that may be impacted by the REFLC plot? b) Have you identified any other systems or equipment that may be impacted by the REFLC plot? c) Have you identified any other systems or equipment that may be impacted by the REFLC plot?	a) In concept, EPSS and REFLC are two very different approaches that share a common goal of attempting to reduce risk associated with ignitions on primary electric distribution systems. i. EPSS – advantages: - Can be implemented on newly existing equipment and relay. ii. REFLC – advantages: - Can be implemented on existing equipment and relay. iii. REFLC – disadvantages: - Requires a large number of resources across all types of faults. iv. REFLC – disadvantages: - Requires a large number of resources across all types of faults. v. REFLC – disadvantages: - Requires a large number of resources across all types of faults. vi. REFLC – disadvantages: - Requires a large number of resources across all types of faults.	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/SPD_001.sip	0	N/A	8.1.8.1	Grid Operations and Procedures	Equipment Settings to Reduce Wildfire Risk
Pre-Discovery 46	CPUC - SPD (Safety Policy Division)	001	CPUC - SPD (Safety Policy Division)_001_04	4	CPUC - SPD (Safety Policy Division)_001_04	General risk reduction inquiry: What is PG&E's goal for long-term risk reduction, particularly reduction of likelihood of ignition and also reduction of consequences, for circuits in HTDs that are not undergrounded?	For locations that will not be undergrounded, we will continue to deploy our suite of Operational Mitigations and other System Resilience Mitigations. Operational Mitigations include programs such as: - EPSS, equipment maintenance and repair, vegetation management, controlled burning, etc. - We have designated the entire pre-submission as confidential to align with Energy Safety's pre-submission process and guidelines which stipulate that the pre-submission documents are not to be made public. In addition, the pre-submission contains contact information for individuals that is considered confidential. As noted in our correspondence to you on March 8th and March 10th, we can provide you with	Wendy Al-Mukdad	2/23/2023	3/9/2023	3/9/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/SPD_001.sip	0	N/A	7.2.1	Wildfire Mitigation Strategy Development	Overview of Mitigation Initiatives and Activities
Pre-Discovery 47	Green Power Institute (GPI)	001	Green Power Institute (GPI)_001_01	1	Green Power Institute (GPI)_001_01	Please provide PG&E's Pre-submission 2023-2025 WMP Base Plan filed on February 13, 2023, with the OES per the 2023 WMP Guidelines and Schedule document, including all attachments and associated supporting documents required for the Pre-submission 2023-2025 WMP Base Plan filing.		Zoe Harold	3/1/2023	3/14/2023	3/14/2023	https://www.pge.com/page_global/common/pdf/vr/plant/wireless/wireless_mitigation_plan/reference_doc/2023/SPD_001.sip	0	N/A	All	All	All