

SDG&E 2021 ARC Defect List

Report	Item #	Utility	Inspection Date	Report Date	County	Circuit	Structure Number	Coordinates	HFTD Tier	Defect Code	Defect Description	Defect Severity	Defect Category	Required Remediation Date	Responsible	Status	Completion Date	Closure Date
GCA-SDGE-010	3	SDG&E	3/4/2021	3/5/2021	San Diego	449	P45363	32.6859864,-116.5127979	3	424.1	Anchors supporting wooden pole not visible or buried under vegetation	Minor	WMP4	2/25/2022	CMP	Closed	10/20/2021	11/9/2021
GCA-SDGE-009	10	SDG&E	3/3/2021	3/5/2021	San Diego	356	P476909	32.8643252,-116.8329636	3	428.1	Down guy in contact with communication service drop	Minor	WMP4	2/25/2022	CMP	Closed	3/9/2021	11/8/2021
GC-SDGE-002	3	SDG&E	2/2/2021	2/4/2021	San Diego	246	P75347	32.85580794,-116.83974081	3		Data provided by utility is inaccurate	Minor	WMP5	1/28/2022	VM	Closed	10/26/2021	10/26/2021
GC-SDGE-002	6	SDG&E	2/2/2021	2/4/2021	San Diego	246	P875538	32.86081008,-116.84408805	3		Data provided by utility is inaccurate	Minor	WMP5	1/28/2022	VM	Closed	10/26/2021	10/26/2021
IAG_SDGE_2021_11	5	SDG&E	4/8/2021	4/16/2021	San Diego	908	P118835	33.2554093,-117.0168169	2	426.1	426.1 Failure to follow utility standards, manual, or best practices (GO95 Rule 31.1) in HFTD.	Moderate	WMP4	10/8/2021	CMP	Closed	5/20/2021	9/10/2021
IAG_SDGE_2021_10	1	SDG&E	4/7/2021	4/16/2021	San Diego	222	P312305	33.0319901,-116.581085	3	423.1	Guy wire loose in HFTD	Moderate	WMP4	6/11/2021	CMP	Closed	5/11/2021	6/2/2021
IAG_SDGE_2021_10	8	SDG&E	4/7/2021	4/16/2021	San Diego	79	P273550	32.973456,-116.583372	3	426.1	426.1 Failure to follow utility standards, manual, or best practices (GO95 Rule 31.1) in HFTD.	Moderate	WMP4	6/11/2021	CMP	Closed	4/21/2021	6/2/2021
ATJ_SDGE_2021_003	9	SDG&E	4/7/2021	4/14/2021	San Diego	OK1	P617671	33.06832288,-116.5763464	3	423	Guy wire loose in HFTD. – Small unbalanced load (minor)	Minor	WMP4	4/8/2022	CMP	Closed	5/11/2021	6/2/2021
ATJ_SDGE_2021_003	9	SDG&E	4/7/2021	4/14/2021	San Diego	OK1	P617671	33.06832288,-116.5763464	3	424.1	Anchors supporting wooden pole not visible or buried under vegetation in HFTD	Minor	WMP4	4/8/2022	CMP	Closed	5/11/2021	6/2/2021
GCA-SDGE-010	1	SDG&E	3/4/2021	3/5/2021	San Diego	449	P45365	32.6865104,-116.5138177	3	GO95 56.1	High voltage sign faded	Minor	WMP4	4/30/2021	CMP	Closed	3/9/2021	4/15/2021
GCA-SDGE-010	1	SDG&E	3/4/2021	3/5/2021	San Diego	449	P45365	32.6865104,-116.5138177	3	419.1	Ground wire broken or uncovered	Moderate	WMP4	4/30/2021	CMP	Closed	3/9/2021	4/15/2021
EW-SDGE-041	4	SDG&E	4/7/2021	4/12/2021	San Diego	351	P115787	33.2055413,-117.0894495	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	1/28/2022	2/17/2022
EW-SDGE-041	5	SDG&E	4/7/2021	4/12/2021	San Diego	351	P115769	33.19535601,-117.0889231	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	1/28/2022	2/17/2022
EW-SDGE-041	10	SDG&E	4/7/2021	4/12/2021	San Diego	1039	P515009	33.17923244,-117.093874	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	1/28/2022	2/17/2022
EW-SDGE-041	11	SDG&E	4/7/2021	4/12/2021	San Diego	1039	P515008	33.17849552,-117.0938186	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	1/28/2022	2/17/2022
EW-SDGE-042	6	SDG&E	4/8/2021	4/12/2021	San Diego	1001	P614332	33.04475751,-117.2123439	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	2/1/2022	2/17/2022
EW-SDGE-042	8	SDG&E	4/8/2021	4/12/2021	San Diego	1001	P119459	33.0465410,-117.2200509	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/8/2022	VM	Closed	2/1/2022	2/17/2022
GCA-SDGE-010	9	SDG&E	3/4/2021	3/5/2021	San Diego	449	P42498	32.6830855,-116.5136189	3	423.1	Guy wire loose/frayed	Moderate	WMP4	4/30/2021	CMP	Closed	3/9/2021	4/15/2021
GCA-SDGE-009	12	SDG&E	3/3/2021	3/5/2021	San Diego	356	P75363	32.8595643,-116.8316016	3	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	2/25/2022	VM	Closed	3/14/2021	4/15/2021
GCA-SDGE-025	11	SDG&E	4/26/2021	4/30/2021	San Diego	520	P515533	33.3881350,-117.21446	2	524.1	Veg. contact with guy wire above insulator	Minor	WMP5	4/22/2022	VM	Closed	2/1/2022	2/17/2022