

# UTILITY WILDFIRE MITIGATION PLAN

(REVISED FOR CALENDAR YEAR 2023)



Healdsburg Electric Department

Table of Contents

Executive Summary..... 3

Wildfire Policy Statement ..... 4

Purpose of Wildfire Mitigation Plan ..... 4

Wildfire Mitigation Plan Components (PUC Section 8387) ..... 5

    Wildfire Mitigation Plan Areas of responsibility [PUC-8387 (b)(2)(A)] ..... 5

    Objective of the Wildfire Mitigation Plan [PUC-8387 (b)(2)(B)] ..... 5

    Overview of Preventative Strategies and Programs [PRC-8387 (b)(2)(C)]..... 6

    Key Performance Metrics [PRC-8387 (b)(2)(D)] ..... 8

    Previous metrics related to wildfire [PRC-8387 (b)(2)(E)] ..... 10

    Disabling Reclosers & De-Energization ..... 12

    Customer Notification Procedures [PRC-8387 (b)(2)(G)]..... 12

    Vegetation Management Program [PRC-8387 (b)(2)(H)] ..... 13

    Wildfire Inspection Program [PRC-8387 (b)(2)(I)]..... 14

    Wildfire Risks [PRC-8387 (b)(2)(J)] ..... 14

    Identification of Areas of Higher Risk [PRC-8387 (b)(2)(K)] ..... 16

    Methodology for Identifying Enterprise-Wide Safety and Wildfire Risks [PRC-8387 (b)(2)(L)]..... 16

    Process for restoring power after de-energization [PRC-8387 (b)(2)(M)] ..... 17

    Wildfire Process & Procedure [PRC-8387 (b)(2)(N)] ..... 17

APPENDIX A – HIGHER FIRE THREAT AREAS WITHIN HEALDSBURG’S SERVICE TERRITORY (CPUC APPROVED 8/19/2021) ..... 19

APPENDIX B – LOCAL WILDFIRE HISTORY ..... 20

APPENDIX C – DISTRIBUTION LINES WITHIN FIRE THREAT AREAS ..... 21

## Executive Summary

Established in 1899, Healdsburg's electric department continues its historical trend of providing safe, reliable, and affordable electric service to Healdsburg's residents and businesses. Healdsburg's Electric Department is owned by the community and governed by Healdsburg's City Council. This arrangement provides direct local control in the operation and management of the City's electric utility.

Wildfires and changes in climate patterns continue concern the community of Healdsburg. These changes in our climate coupled with increased housing in and adjacent to wildland urban interfaces (WUI) requires the City's electric utility to rethink past operational procedures, construction standards, and develop new ways to improve upon our record of safe and reliable electric service.

In response to statewide wildfires, Senate Bill 901 (SB901) electric utilities continue to prepare annual wildfire mitigation plan (WMP). Through the WMP, publicly owned utility can track and monitor construct, maintain, and operate practices and how those practices can reduce the risk of utility caused wildfires. Each WMP includes several key components that are foundational to reducing the risk of utility caused wildfires including developing plans to contact critical customers such as police, fire, hospitals, and communication service providers. The WMP also measures past performance through key indicators to identify and correct deficiencies of the WMP or construction and operating procedures.

This document is the City of Healdsburg's wildfire mitigation plan and provides City staff with a guideline to implement and track efforts to reduce utility caused wildfires. The WMP is not a comprehensive study of the mitigation of wildfires in general, study of climate change, nor is this plan intended to provide a guide to mitigate impacts of wildfires upon electric infrastructures.

## Wildfire Policy Statement

It shall be the policy of the City of Healdsburg's Electric Department to construct, maintain, and operate electrical lines and equipment within high fire threat areas in a manner that reduces the risk of utility caused wildfires.

## Purpose of Wildfire Mitigation Plan

The City of Healdsburg's electric service area includes areas considered to be of a higher fire threat. In general, these areas include the City's Wildland Urban Interface (WUI) and are generally described as the areas on and around Fitch Mountain, the Healdsburg Ridge, and the northern most portions of the City's service territory. These areas were identified by staff and later confirmed by the City Council in 2017. The fire threat area covers roughly one-third of the City's entire service territory. Within this area, the City owns and operates roughly 14.5 miles of underground primary conductor and 7.5 miles of overhead primary conductor. Line protection devices (devices that interrupt power should a fault occur) in this area include two feeder breakers, three reclosers and numerous fuses.

The City's Electric Department takes appropriate actions to help city electric customers prevent and respond to the increasing risk of wildfires. In its role as a public agency, Healdsburg closely coordinates with other local safety and emergency officials to help protect against fires and respond to emergencies. In its role as a utility, Healdsburg follows applicable design, construction, operation, and maintenance requirements to reduce risks associated with its electric system. This Wildfire Mitigation Plan describes the safety-related measures Healdsburg follows to reduce risk of wildfires. The WMP is not intended to be a final set of directions for the City's Utility Department staff. The intent of this document is to create an ever-improving framework for policies, procedures, and metrics that mitigate the risk of utility caused wildfires. Over time, and as warranted utility practices, the WMP's policies and procedures will be reviewed, updated, and incorporated into this document with the goal of implementing effective and responsible wildfire mitigation measures.

## Wildfire Mitigation Plan Components (PUC Section 8387)

The City's WMP is organized similar to the listed consideration of the California Public Utility Code (PUC) Section 8387. Areas of consideration are listed below and are used to develop key elements that frame the City's wildfire mitigation plan.

### Wildfire Mitigation Plan Areas of responsibility [PUC-8387 (b)(2)(A)]

The City's Electric Department is governed by Healdsburg's City Council, managed by the City Manager and Utility Director with day-to-day operations handled by the City's Electric Operations Superintendent.



The City Council is the governing body for Healdsburg's Electric Department and approves utility policies and utility expenditures such as wildfire mitigation efforts. The wildfire mitigation plan is implemented by the City's Electric Operations Superintendent with oversight provided by the Utility Director and City Manager. Due to the small size of Healdsburg's electric department, the Electric Operations Superintendent is responsible for the implementation of many aspects of the plan (inspections, tree trimming, SOPs, etc.). To implement the WMP the superintendent relies on his experience and knowledge of the system and the qualified electrical workers that report directly to him.

### Objective of the Wildfire Mitigation Plan [PUC-8387 (b)(2)(B)]

The main objective of the Plan is to reduce the risk of utility caused wildfires. To achieve this objective, various industry best practices, policies, procedures, and system improvements will be studied and implemented should they be applicable to the Healdsburg community and Healdsburg's electric distribution system. Additionally, the WMP is intended to track the progress and effectiveness of past practices implemented by previous versions of the WMP. This self-assessment is critical to ensuring that the actions of the WMP effect the intended goal of reducing

utility caused wildfires. Healdsburg's Electric Department staff will assess the merits of the WMP and modifications based upon new information and applicable utility best practices. A key objective of the WMP is to annually identify cost-effective measures that produce the same or improved results in reducing wildfire risk.

#### Overview of Preventative Strategies and Programs [PRC-8387 (b)(2)(C)]

New and existing strategies and programs will be used to mitigate the risk and impact of utility caused wildfires. Primarily these programs rely on adequate staffing levels to perform prudent and timely maintenance or the pro-active replacement of high-risk utility equipment. Strategies and programs are listed below and are discussed further throughout this document.

**Vegetation Management** – The City's existing vegetation management program (tree trimming) exceeds the CPUC's requirements for vegetation clearance from electric powerlines. Through the WMP, the existing vegetation management program will be reassessed and enhanced where needed to further mitigate wildfire risk. The City's vegetation management program is discussed further within this document.

**Public Education and Notification** – Public education and notification are key components of the Plan. The Plan will identify how the City will inform and notify the public on the wildfire plan and prepare the public for potential de-energizations of portions of or the entirety of the City's electric system.

**Situational Awareness** – Situational awareness allows City staff to be informed of the status of the City's electric infrastructure and weather conditions conducive to wildfires. City Staff will rely heavily on internet weather services and technology but not forego the value of field observation from the Electric Operations Superintendent, Qualified Electrical Workers (QEW), and other City staff. Starting in 2022, City staff enhanced recloser controls with remote indication and control to monitor system status.

**Routine Inspections** – To ensure the City's electric system remains in good condition the City follows CPUC General Order 165. These routine inspections help assure that necessary repairs or replacements are identified and corrected in a timely manner. Needed repairs within the fire area will be prioritized and moved up in the Electric Department's work schedule. The Electric Department's Preventative Maintenance and Inspection Program guides in the assessment of City electric facilities and will be continually reviewed and revised to incorporate utility best practices.

**System Hardening** - At the time of reconstruction, the City constructs overhead facilities to meet or exceed CPUC General Order No. 95 (GO 95). Following or exceeding current GO 95 standards helps to assure that the City's facilities are safe and reliable. Specifically, the City

increases pole strength requirements beyond those required by CPUC's GO 95 safety factors. In addition to the increased pole strength, the City has pro-actively replaced weaker copper conductors to lessen the risk of overhead conductors falling during wind events.

**Increased Overhead Conductor Spacing** - Overhead conductors can increase the risk of utility caused wildfire. To mitigate that risk, in 2018 Healdsburg staff spoke with a provider supplying covered overhead conductor to assess the value of installing covered conductor in areas of higher fire risk. In that review, the City found that covered conductors are heavier requiring stronger and larger diameter wood utility poles, are subject to the same preventative tree trimming/removal requirements, and that if tree wire falls to the ground line-protection devices may not trip (de-energize) the line in an expedient manner. As such, the City will continue its policy of increasing conductor spacing and increased tree trimming requirements beyond those required of GO95. Increased tree clearance and increasing the spacing between overhead wires is a best practice to reduce tree caused power outages. To further prevent wildfire and power outages the City uses covered jumpers, wildlife guards, and other protective coverings at equipment locations. These coverings minimize wildlife and tree caused outages at equipment locations.

**Use of Non-Expulsion Fuses** – The use of non-expulsion fuses can reduce the risk of utility caused wildfire by significantly reducing sparks created when a fuse operates (blows). City staff have replaced legacy expulsion fuses within the fire threat area with non-expulsion fuses. New construction within the fire threat area will use non-expulsion fuses.

**Elimination of Split Bolt Connectors** – The use of split bolt connectors creates system reliability issues and can be an ignition source for wildfires. To mitigate this risk, the City has prohibited the use of split bolt connectors throughout the City's electric system and actively removed split bolt connectors found within high fire threat areas.

**CAL FIRE Approved Lightning Arrestors** – Lightning arrestors are used to limit the damage caused by lightning strikes to or near utility equipment. While a lightning arrestor can protect a line many times over, in some cases a lightning arrestor will catastrophically fail emitting sparks. To limit the risk of these sparks igniting a wildfire, in 2021 the City replaced existing lightning arrestors with CAL FIRE approved lightning arrestor within high fire treat areas. Future installations and replacements will be CAL FIRE approved lightning arrestors.

**Operational Procedures** - The safe operation of the City's electric system helps lessen the risk of utility caused wildfires. As a standard practice, the City adjusts system protection settings during red-flag warnings (periods of forecasted high winds and low humidity) and is researching additional field practices (vegetation management, disabling of recloser, patrols, staffing) to lessen the risk of wildfire. During red-flag warnings the City will revise existing work practices and work locations to further reduce the risk of wildfire. These practices are center on limitations of work during weather conditions conducive to wildfire but include other preventive measures such as increased inspections.

**Capital Improvements** – As identified by the Utility Director and department staff, Capital improvements will be recommended through the City’s 5-year Capital Improvement Program (CIP) and other budgeting processes. This budgeting process occurs at least once every two years, but new projects can be presented to the City Council sooner if required. Recommendations for system wildfire mitigation measures will be based upon their ability to reduce wildfire risk in a cost-effective manner. Past projects have included the reconductoring, pole replacements, replacement of expulsion fuses and lightning arrestors, replacement of field recloser controls to provide SCADA and improved wildfire protection, replacement of feeder breakers to improve wildfire protection and provide SCADA. Staff will continue to identify projects, such as undergrounding powerlines in key areas, to be constructed when funding is available. Additionally, electric department staff will develop construction standards and City policies that reduce the risk of utility caused wildfire through the acceleration of undergrounding.

**Staffing & Staff Training** – The City will not be able to reduce the risk of wildfire without staff. Further, electric department staffing must be maintained at appropriate levels with adequate training to maintain staff knowledge and preparedness. This may include cross training to build redundancies within the department and from time-to-time succession planning for known and pending retirements. Additionally, short briefings (tailboards) will be had with staff ahead of weather events with a combination of conditions that favor the rapid spread of wildfire. With a recent rate increase, staff included funding to allow for succession planning for staff nearing retirement. In most cases this succession planning will require the early and successful recruitment and placement of new staff to allow a reasonable transition period.

**Wildfire Preparedness, Response, and Recovery** – To minimize the chaotic nature typical of any emergency, this plan outlines necessary steps to prepare, respond, and recover from weather events conducive to wildfire. Throughout the year these procedures will be reviewed and revised as needed to improve the City’s ability to reduce the risk of utility caused wildfires.

#### Key Performance Metrics [PRC-8387 (b)(2)(D)]

The purpose of the Plan is to reduce wildfire caused by utility equipment and the incident rate of utility caused wildfires as a primary metric. However other metrics exists to determine if the risk of wildfire mitigation is being reduced. Five primary metrics are identified below and will be used to measure the effectiveness of the City’s wildfire mitigation efforts.

##### **Metric 1: Ignitions caused by Utility Equipment**

This metric will be tracked by City staff and reported annually. For the purposes of this plan and the annual reporting, an ignition caused by City owned utility equipment and includes a sustained ground fire of combustible vegetation. To be tracked by the City, staff must have



knowledge of the ignition and will track (at a minimum) the date, time, location, and equipment involved for each ignition.

### **Metric 2: Inspection Records & Maintenance**

System inspections and timely maintenance is one of the leading methods to improve safety and system reliability. Inspections of overhead lines in the fire threat areas will begin in the spring of each year. Needed maintenance or repairs identified during these inspections will be tracked and given priority in the work schedule with higher priority repairs moved up in the Electric Department's work schedule. Each identified maintenance task or repair will be reported annually.

### **Metric 3: Vegetation Maintenance**

Throughout the year, the City maintains proper vegetation clearance from utility lines by contract with a qualified high-voltage tree trimmer and at times augments this work with City staff. Under the terms of the contract, the contractor is required to report their work plan to the City and ensure that proper vegetation clearance from powerlines is always met. Vegetation management performed within the high fire threat areas will be tracked throughout the year and reported annually.

### **Metric 4: Overhead Equipment Failures**

Failure of overhead electric utility equipment can be a source of wildfire ignitions. Therefore, the rate of failures of overhead electric equipment, within the high fire threat areas, will be tracked and reported on an annual basis. Any patterns that emerge will be used to proactively replace utility owned equipment.

### **Metric 5: Outage Response Time**

Utility response time to power-outages and other service-calls is a measurable metric that indicates the City's ability to mitigating unsafe conditions related to electric utility equipment. To track and gauge response time, staff's after-hours response time to power-outages or City owned equipment failures will be recorded throughout the year. Staff response time, from first call to the time they arrive on site, will be tracked for every confirmed power-outage, and reported annually.

### **Metric 6: System Reliability**

New for the 2023 WMP is the inclusion of systemwide reliability indices. This metric will track the total number of unplanned primary outages per year, the System Average Interruption Duration Index (SAIDI), and the System Average Interruption Frequency Index (SAIFI). With each outage, there is a chance for arcing that may result in ignition of vegetation. Tracking these reliability indices will help to understand trends in the occurrence of outages.

Previous metrics related to wildfire [PRC-8387 (b)(2)(E)]

SB901 requires consideration of how previous versions of the WMP’s metric have informed the current WMP. Metrics are compared below.

**Metric 1 Ignition Caused by Utility Equipment:** During the 2022 calendar year there was one known vegetation ignition. The ignition was at the base of field recloser (R-03) and was due to a bird placing acorns within the recloser’s wildlife covers. The burn area was limited to less than 10 square-feet. More details are listed below.

WMP Year	Date	Equipment & Location	Description of Cause
2020	no utility related wildfires		
2021	no utility related wildfires		
2022	9/26/2022	R-03 S. Fitch Mtn Rd	Bird stored acorns within wildlife bushing covers. This caused tracking across the bushings and eventually melted the covers. Melted covers caused a pole fire which started a small vegetation fire.

**Metric 2 Inspection Records & Maintenance:** To prepare for the wildfire season Electric Department staff completed several different inspections in 2022. These inspections include visual and intrusive inspections of existing facilities as well as inspections of vegetation clearance from overhead powerlines. The table below provides a summary of the inspections completed since 2020.

Type of Inspection (Fire Area)	2020 Grids Due	2020 Grids Complete	2021 Grids Due	2021 Grids Complete	2022 Grids Due	2022 Grids Complete
Overhead Visual Inspections	56	56	54	54	54	54
Overhead Detailed Inspections	8	8	3	3	38	38
Vegetation Clearance	56	56	54	54	54	54
Wood Pole Intrusive Inspections	3	3	0	0	30	30

From the inspections, maintenance tags were created for any issues found. Tags are prioritized based upon asset condition and whether the asset is located within the high fire-threat area.

**Metric 3: Vegetation Maintenance:** The City’s standard is to maintain vegetation clearance throughout the year, trimming within the fire area happens continuously. Therefore, inspections are also performed on a frequent basis throughout the year. This year’s contract period ended June 30, 2022. At that time vegetation was confirmed to have the required clearance. One vegetation

related outages occurred within calendar year 2022, versus no outages in the previous year. On April 16 a tree limb broke-off and blew into the line causing a sustained outage. All vegetation clearance was in compliance with the City’s standards.

Year	Date	Equipment & Location	Cause Detail
2020	no vegetation related outages		
2021	12/15/2021	Fuse 144 – Hasset Lane	Tree fell through line during December wind event
2022	4/16/2022	Fuse 54 – S. Fitch Mtn	tree limb broke-off and blew into the line

**Metric 4: Overhead Equipment Failures:** Three equipment failures occurred during calendar year 2022 with none of the failures occurring within the fire area. 2022 equipment failures included underground cable, a capacitor bank, and overhead fused cutout.

Calendar Year	Equipment Failures Systemwide	Failures within Fire Area
2020	3	0
2021	5	0
2022	3	0

**Metric 5: Outage Response Time:** Response time (time to first switching operation) for outages ranged from 6-minutes to 98-minutes with an average response time of 46-minutes. The range of response time is due to mix of outage occurring during the daytime when electric crews are within the City and outages that occur afterhours when electric crews must respond from home. This is faster than previous years and may be due to more outages occurring during the normal working hours. Consideration of pre-staging qualified electrical workers during significant fire-weather in the 2023 calendar year may be warranted.

Calendar Year	Response Time Range (min)	Average Response Time (min)
2020	17-60	41
2021	30-75	52
2022	6-98	46

**Metric 6: System Reliability:** New for the 2023 WMP is the inclusion of systemwide reliability indices. This metric will track the total number of unplanned primary outages per year, the System Average Interruption Duration Index (SAIDI), and the System Average Interruption Frequency Index (SAIFI). The data below is for unplanned primary level outages throughout the City’s distribution system including major events; transmission and secondary outages are excluded from this data. For calendar year the number of outages increased and included one underground cable failures, two equipment failures, one tree caused outage, one operator error, one weather caused

outage (heat), and two unknown outages. Staff will continue to monitor outages to assess if the number of outages continues to increase.

<b>Year</b>	<b>Total Customers</b>	<b>No. of Outages</b>	<b>SAIDI</b>	<b>SAIFI</b>
2020	5971	5	13.76	0.05
2021	6020	7	42.67	0.36
2022	6047	8	8.46	0.10

#### Disabling Reclosers & De-Energization [PRC-8387 (b)(2)(F)]

As a key component of the WMP, reclosing of circuit breakers and line reclosers serving high fire threat areas will be disabled when the National Weather Service issues red-flag warnings affecting any portion of the City electric service territory. Additionally, during Red-Flag warnings the City will implement recloser settings that shorten the time a fault will exist (faster tripping). In general, these settings include lowering instantaneous trip settings and improving the detection of ground faults. These settings were implemented in the first half of 2021. For calendar year 2022, City staff implementation of addition recloser protection settings that may speed fault detection during weather conditions conducive to wildfires. For 2023, staff will continue to monitor these settings and look for additional utility best practices to implement.

For public safety, City staff may pro-actively de-energize all or portions of the City’s electric distribution system. De-energization of City facilities may occur due to one or more of the following conditions.

- 1) Upon the request of Healdsburg’s Fire Department, Healdsburg’s Police Department, CAL-FIRE or other State or local public safety agencies.
- 2) When energized powerlines subject to high winds or other weather or atmospheric conditions may create a substantial public safety risk.
- 3) When real-time information from qualified City field staff indicates that wind driven vegetation or other combustible debris are threatening City owned electric utility equipment.
- 4) When PG&E de-energizes the City’s transmission source. The City has no control over PG&E’s decision to de-energize the Healdsburg’s transmission source.

As time permits, de-energization of City operated high-voltage powerlines will be coordinated between the City Manager’s Office, Electric Department, and City Public Safety Departments. The decision to de-energize City owned powerlines will be communicated to the City Manager’s office as soon as practical.

#### Customer Notification Procedures [PRC-8387 (b)(2)(G)]

Customer notification is an important component and consideration of the Wildfire Mitigation Plan. The City’s customer notification procedures start with customer education and continue with

relevant updates when weather conditions are conducive to wildfires. Customer education will be predominantly through printed material, social media, and the City's webpage. Real-time communications leading up to and during a potential de-energization event will be predominately through social media and other technology resources immediately available to City staff.

Leading up to and during an event, City staff will coordinate customer notifications through the City Manager's office, City Emergency Operations Center (EOC), or other means available to City staff at the time of the event. The City Manager, as EOC Director, or the EOC Coordinator (Fire or Police Chief) may activate the City's Emergency Operations Plan. To provide the fastest means of notifying electric customers the City will rely on automated phone calls and social media. Social media and automated alerts may include reverse phone calls, Facebook, and/or Nextdoor.

The City will make efforts to communicate with critical facility operators, such as hospitals, emergency centers, fire departments, public utilities/agencies, schools, and telecommunications providers before, during, and after any PSPS effecting their City supplied electric service. Communication with critical facilities will be primarily through automated phone call but operators of these critical facilities will also be encouraged to monitor the City's Facebook page and signup for automated emergency alerts from the City.

City staff will continue to reach out to the community on an ongoing basis regarding the risks of wildfire. This will include the encouragement of City electric customers, first responders, and operators of critical facilities to updating their contact information such that the City can reach them should a de-energization need to occur.

#### [Vegetation Management Program \[PRC-8387 \(b\)\(2\)\(H\)\]](#)

To reduce power outages, promote safety and comply with required clearance the City contracts with a qualified vegetation management contractor to maintain tree and vegetation clearance from energized overhead conductors. The City's clearance requirements, which exceed the requirements of GO-95, apply throughout the City, not just within the high-fire risk areas. Contractors are, in general, required to meet the City's tree clearance requirements as summarized below. Appendix D includes the City's specification for electric line clearance services (tree trimming).

- Primary (12,000 volts) - trim to 7-feet and maintain no less than 4-feet of clearance during the contract period.
- Secondary (480 volts and below) - trim to 3-feet and maintain no less than 1 foot of clearance during the contract period. (pole to pole configuration).
- Service drop - maintain 6-inches during contract period (pole to customer weather head).
- Poles and Streetlights - trim a 3-foot radius around entire length of poles and streetlights during contract period (excluding customer poles).
- Guy Wires - trim to 3 feet and maintain no less than 1 foot of clearance during the contract period. (pole to pole configuration).
- Substation – 3-feet clearance from outside of wall from ground level to top of tree.
- When trimming, contractors must assume at least two-feet of line sag and at least one-foot of horizontal movement in both directions in addition to the clearances listed above.

Through the contract period, the City's contractor is to prune and remove vegetation hazards. This includes removal of dead branches overhanging primary conductors shall be removed. Portions of dead, old decadent, rotten trees, or portions of trees weakened by decay or disease that may contact the line from the side or fall on the line, must be trimmed to eliminate the hazard.

#### Wildfire Inspection Program [PRC-8387 (b)(2)(I)]

Starting each year in the month of May, a City qualified employee shall perform a visual patrol of all overhead supply wires within the high-fire threat areas (Tier 2 or 3). This patrol shall review specific items related to wildfire mitigation such as;

- Proper vegetation clearance from primary and secondary wires
- Condition of wood poles, cross-arms, and other support structures
- Review and prioritize pending maintenance tags within the high-fire threat areas.

Before and after a Red-Flag Warning covering a portion of the City's service territory, the City may perform a visual patrol of aerial primary and secondary conductors within the Tier 2 areas. This patrol is intended to identify vegetation clearance and/or equipment issues that can be quickly corrected. A patrol following the Red-Flag event will document, by photo, any fallen vegetation, damaged facilities, or other potential causes of power outages.

The findings of these patrols will be recorded and reviewed by the Utility Director and Electric Superintendent. The Utility Director and Superintendent will review the patrol results to determine the system's performance during an event (outages, vegetation, damaged facilities). The intent of these patrols and data collection is to better predict system performance under specific or known weather events.

#### Wildfire Risks [PRC-8387 (b)(2)(J)]

This section of the plan identifies, describes, and prioritizes wildfire risks and drivers found within the City's service territory. The identified risks are separated into two categories; i) risks associated with design, construction, operation, and maintenance of the City's electrical equipment and facilities and ii) risks associated with topographic and climatological factors within the City's service territory.

- i. Risk associated with the design, construction, operation, and maintenance of the City's electric system include the following (listed in order of priority).
  - 1) Vegetation near or adjacent to the City electric lines present the highest risk for utility caused wildfires. Mitigation of this risk is done through the routine and thorough performance of tree trimming to provide adequate clearance from power lines. As discussed above, the City's high-voltage vegetation management program exceeds the requirements of the CPUC's GO 95 by increasing vegetation clearance for both high-voltage and low-voltage utility

lines. The City will continue to evaluate the need to limit trimming within the fire area during the fire season or at times of elevated fire risk.

- 2) Overhead Utility Equipment presents a risk of utility wildfire but can be mitigated through design standards, alternate equipment, and adjusted work practices. To mitigate the risk of utility caused wildfire, the City will enact the strategies discussed early within the plan. These strategies will be reviewed annually for their effectiveness in reducing the risk of wildfire.
  - 3) Reclosing or the automatic testing of faulted powerlines can increase the risk of utility caused wildfires. To lessen this risk, the City initiated the practice of disabling reclosing during red-flag warnings affecting the City's service territory.
  - 4) Certain work practices or operations can increase the risk of utility caused wildfire. To reduce the risk of wildfire, Staff incorporates operational procedures to limit work activities during weather conducive to wildfire, to clarify inspection practices within the fire-threat areas and revise other work procedures, as necessary.
- ii. Topographic and climatological risks include the following (listed in order of priority).
- a) Volume of vegetation (fuels) present in high-fire threat areas increases the risk and speed of which wildfire can spread. Increasing vegetation clearance from overhead lines lowers the risk of wildfire. Additionally, the City's active and ongoing weed abatement program reduces the amount of fuels within the fire area and Urban Wildland Interface (WUI) further reducing the risk of wildfire.
  - b) Periods of significantly low humidity can dry vegetative fuels and create an increased risk of ignition. The City will monitor the National Weather Service alerts related to fire warnings and/or red-flag days affecting the City's service territory to remain aware of the elevated risks.
  - c) High sustained winds and strong wind gusts can down trees, break branches, or damage utility equipment. The City will monitor the National Weather Service for high-wind warnings, watches, and/or advisory affecting the City's service territory to remain aware of these events. Increasing vegetation clearance, weed abatement programs, and exceeding GO 95 design standards reduces the risk of wildfire caused by these events.
  - d) Extended droughts or continued periods of below average rainfall can increase dry vegetative fuel loads leading to the increase in wildfire risk. Prolonged droughts can also weaken or kill trees. The City's vegetation management program requires the identification and removal of diseased, dying, or hazard trees adjacent to the City's electrical lines. Routine visual inspections allow the City to remain aware of this risk factor. Steep terrain and areas difficult to access are present within the High Fire Threat Area in the City's service territory. Steep terrain can increase the speed and spread of wildfire and limit access delaying response times of local firefighting agencies. While the terrain and access cannot be changed by the Electric Department, prudent utility

operations within the fire area can reduce the likelihood of wildfires caused by utility equipment.

- e) Housing and community activities within wildland urban interfaces (WUI) can increase the risk of wildfire. The City has zoning and land use policies that help to mitigate the risk of wildfire associated with activities in the WUI. Additionally, the City manages an aggressive weed abatement program to reduce wildfire risks.
- f) Wildfire history within and adjacent to the City's electric service area, shown in Appendix B, are indicators of the risk of wildfire. In review of historical wildfires, the City can confirm that Tier 2 areas covering the City's service area are in fact at higher risk of wildfire.

#### Identification of Areas of Higher Risk [PRC-8387 (b)(2)(K)]

In 2017, Healdsburg's City Council directed City staff to submit to the CPUC updates to the City service territory that defined high-fire threat areas (Tier 2). The area defined closely aligned with the City's defined Wildland Urban Interface (WUI) and contain areas of improved property and structures adjacent to wildland vegetation (fuels) with potentially delayed or restricted fire response due to narrow and windy roads and steep terrain. These areas were defined as Tier 2 and provided to the CPUC's fire mapping process.

In working with the CPUC mapping team, the area was further refined and is shown in Appendix A. In accordance with this map, the City operates and maintains electric facilities within these area in a manner appropriate for high-fire threat areas.

In 2021, the CPUC finalized and approved the Tier 2 area that covers Healdsburg's service territory. The finalization and approval of this area aligns closely with City's WUI but does exclude some areas of developed lands. The City is monitoring updates to fire-threat maps by various state agencies. Should these maps be finalized and effect changes within the City's service territory, the City will consider any needed updates to our utility maps.

#### Methodology for Identifying Enterprise-Wide Safety and Wildfire Risks [PRC-8387 (b)(2)(L)]

To determine the level of risk to the City's electric system and service territory, City staff review historic outages within the wildland urban interface and their associated causes to assess wildfire risk. Outages that have the potential for causing wildfires are noted and reviewed for potential corrective actions. On a rolling five-year window, the number of sustained outages is tracked to establish trends. The City must use a five-year window due to the low number of outages on an annual basis.

To assess the risk of wildfire throughout the City's service territory and adjacent areas, City staff reviewed historical fires as well as vegetation and terrain surrounding the City. This annual review



helps to confirm the need for wildfire mitigation as well as identify areas of potential threat to the City's infrastructure.

#### Process for restoring power after de-energization [PRC-8387 (b)(2)(M)]

Should the City proactively de-energize powerlines, loses its transmission source due, or following the opening of a protective device, power lines will be re-energized in the following manner.


- 1) Overhead facilities in high fire threat areas must be patrolled and visually found to be clear of trouble, damage, or vegetation before re-energizing facilities by a qualified electrical worker.
- 2) If damaged facilities are found, those facilities will be isolated such that sections of overhead lines not damaged can be re-energized restoring power to customers. To the extent additional resources are needed to repair the damage, the City will leverage mutual aid agencies and contractors to obtain material and qualified personnel.
- 3) Any damaged facilities or vegetation issues will be documented and photographed before being repaired or cleared.
- 4) Repairs to damaged facilities will be performed consistent with City and utility design standards and then re-energized.

#### Wildfire Process & Procedure [PRC-8387 (b)(2)(N)]

- i) The Plan's oversight, monitoring, and auditing will occur at least annually with any lessons learned being prioritized for incorporation into the plan, related standards, and procedures. The City's Utility Director will collect the results of oversight and monitoring of the program. This may include the use of qualified external stakeholders and consultants. As required and necessary, City staff will present this plan to the City Council for their consideration and action.
- ii) The identification of deficiencies and areas of improvement will be noted through the annual auditing process or as issues are identified. City Staff may implement deficiency mitigation, remediation, and/or improvements at any time in a continued effort to mitigate wildfires.
- iii) Quality control of inspections (line, equipment, & tree), construction standards, and operating procedures will be the responsibility of the City's Electric Superintendent. Through the scheduling of inspections, review of inspections performed, and the completion of any maintenance work found, the Electric Superintendent shall track and record the effectiveness of operations and maintenance staff.
- iv) City staff will continue to review and consider new utility equipment meant to reduce the risk of wildfire. Equipment will be reviewed for the effectiveness and applicability to the City's electric system including the evaluation of non-expulsion fuses, tree-wire, the use of lightning arrestors, and other equipment.
- v) As needed, but at least every five-years, City staff will review system protection settings to ensure proper coordination and possible improvements to reduce the risk of

wildfire mitigation. Coordination of protection devices is necessary to ensure system faults are cleared in a proper and expedient manner.


APPENDIX A – HIGHER FIRE THREAT AREAS WITHIN HEALDSBURG’S SERVICE TERRITORY (CPUC APPROVED 8/19/2021)



*The above graphic shows the CPUC fire threat areas that affect the City of Healdsburg’s Service territory.*




## APPENDIX B – LOCAL WILDFIRE HISTORY



*The above graphic shows historical wildfires in and around the City of Healdsburg. These historical fires help inform the City of the risk of wildfire. This graphic does not include the recent Walbridge Fire and Glass Fire.*

## APPENDIX C – DISTRIBUTION LINES WITHIN FIRE THREAT AREAS



*The above image approximates the footage of over-head and underground high-voltage distribution line within the Tier 2 area. Of the City's roughly 60 miles of distribution line, 30 are overhead. Of the 30 miles of overhead only 7.5 miles or 25% are within the Tier 2 area.*