



825 NE Multnomah, Suite 2000
Portland, Oregon 97232

August 18, 2023

Jessica McHale
Wildfire Safety Analyst
jessica.mchale@energysafety.ca.gov

Nicole Dunlap nicole.dunlap@energysafety.ca.gov
Jolynne Flores jolynne.flores@energysafety.ca.gov
Ethan Campos ethan.campos@energysafety.ca.gov
Andie Biggs andie.biggs@energysafety.ca.gov
Alan Solomon alan.solomon@energysafety.ca.gov
Luis Medina luis@level4ventures.com

Re: CA 2023-WMPs
OEIS-P-WMP_2023-PC-005

Please find enclosed PacifiCorp's responses to OEIS data requests 5.1-5.2.

If you have any questions, please call me at (503) 813-7314.

Sincerely,

 /s/
Pooja Kishore
Manager, Regulation

OEIS Data Request 5.1

Regarding Vegetation Management and Inspection Performance Metrics:

On page 185 of its WMP, PacifiCorp states that it is unable to provide vegetation management performance metrics. As such, the performance metrics listed in Table 8-17 of its WMP (“vegetation-caused ignitions” and “vegetation-caused outages”) are missing actuals and projections. However, in its Q4 2022 Quarterly Data Report (Revision 2, submitted on June 29, 2023) and Q1 (Revision 1) and Q2 2023 Quarterly Data Reports (submitted June 21 and August 1, 2023, respectively), PacifiCorp does provide actual and projected performance metrics for vegetation-caused outages and ignitions.

i. From which QDR(s) are these performance metrics correct?

(1) Please populate and provide an updated version of PacifiCorp’s WMP Table 8-17 with this information, including actuals, projections, and applicable methods of verification.

Response to OEIS Data Request 5.1

i. PacifiCorp’s Q2 2023 Quarterly Data Report (QDR) is correct.

(1) Please refer to the table provided below:

Performance Metrics	2020	2021	2022	2023 Projected	2024 Projected	2025 Projected	Method of Verification (e.g., third-party evaluation, QDR)
Vegetation-caused ignitions	5	4	4	5	5	5	QDR
Vegetation-caused outages	119	181	157	170	170	170	QDR

OEIS Data Request 5.2

Regarding Grid Design, Operations, and Maintenance Performance Metrics:

On page 136 of its WMP, PacifiCorp states that it is unable to provide performance metrics for grid design, operations, and maintenance. As such, the performance metrics listed in Table 8-5 of its WMP (equipment-caused ignitions, equipment-caused outages, grid inspection findings, and open work orders [tags]) are missing actuals and projections. However, in its Q4 2022 Quarterly Data Report (Revision 2, submitted on June 29, 2023) and Q1 (Revision 1) and Q2 2023 Quarterly Data Reports (submitted June 21 and August 1, 2023, respectively), PacifiCorp does provide actual and projected performance metrics for grid design, operations, and maintenance.

i. From which QDR(s) are these performance metrics correct?

(1) Please populate and provide an updated version of PacifiCorp’s WMP Table 8-5 with this information, including actuals, projections, and applicable methods of verification.

Response to OEIS Data Request 5.2

i. PacifiCorp’s Q2 2023 Quarterly Data Report (QDR) is correct.

(1) Please refer to the table provided below:

Performance Metrics	2020	2021	2022	2023 Projected	2024 Projected	2025 Projected	Method of Verification (e.g., third-party evaluation, QDR)
Equipment-caused ignitions	5	3	4	4	4	4	QDR
Equipment-caused outages	317	361	349	359	359	359	QDR
Grid inspection findings	8,071	7,487	8,202	--	--	--	QDR
Open work orders (tags)	--	--	12,161	--	--	--	QDR

Despite PacifiCorp's diligent efforts, certain information protected from disclosure by the attorney-client privilege or other applicable privileges or law may have been included in its responses to these data requests. PacifiCorp did not intend to waive any applicable privileges or rights by the inadvertent disclosure of protected information, and PacifiCorp reserves its right to request the return or destruction of any privileged or protected materials that may have been inadvertently disclosed. Please inform PacifiCorp immediately if you become aware of any inadvertently disclosed information.