



Bear Valley Electric Service, Inc.
 P.O. Box 9028
 San Dimas, CA 91773-9028
 A Subsidiary of American States Water Company

August 22, 2023

Lucy Morgans
 Program Manager | Electric Safety Policy Division
 Electrical Infrastructure Directorate
 Office of Energy Infrastructure Safety
 715 P Street. 20th Floor
 Sacramento, CA 95814

RE: BVES Response to the Office of Energy Infrastructure Safety Issuance of Revision Notice for Bear Valley Electric Service Company’s 2023-2025 Wildfire Mitigation Plan

Dear Ms. Morgans,

Bear Valley Electric Service, Inc. (BVES) submits this response pursuant to Public Utilities Code Section 8389.3(a), and the August 8, 2023, Office of Energy Infrastructure Safety (“Energy Safety”) Issuance of Revision Notice (“Notice”).

In accordance with the direction issued by Energy Safety, BVES revised its 2023-2025 Wildfire Mitigation Plan in accordance with the Notice to address critical issues identified by Energy Safety.

The table below demonstrates the issues identified and the location where each revision was made in response to the Notice.

<u>Issue</u>	<u>Action Target</u>	<u>Applicable WMP Sections & Page Number</u>
Correct the WMP Table 8-35 “Emergency Preparedness Initiative Targets by Year,” identified in Data Request OEIS-P-WMP_2023-BVES-003, Question 2. BVES provided its response to this data request on July 10, 2023, which confirmed the table in the submitted WMP was an error.	BVES corrected Table 8-35 in line with its response to Data Request OEIS-P-WMP_2023-BVES-003 Question 2.	Section 8.4.1.2 pp. 259-260
BVES must provide a completion date for the “continue to conduct comprehensive outreach to identify households with AFN persons” objective in its list of three-year PSPS objectives (Table 9-3).	BVES added a completion date for “continue to conduct comprehensive outreach to identify households with AFN persons” objective in its list of three-year PSPS objectives (Table 9-3) in line with its response to Data Request OEIS-P-WMP_2023-BVES-001.	Section 9.1.3 p. 368

<p>BVES must update its WMP's Section 9, "Public Safety Power Shutoff," to bring its targets into alignment with its narrative (including historical number of PSPS events, number of customers impacted by PSPS events, and number of circuits de-energized in PSPS events).</p>	<p>BVES updated Table 9-5 and Section 9.1.4 to bring into alignment its targets for "Number of Customers Impacted," "Number of Circuits De-energized," and "Number of PSPS events" and the associated narrative.</p>	<p>Section 9.1.4 pp. 370-371</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------

Sincerely,

Paul Marconi President, Treasurer and Secretary
 Bear Valley Electric Service, Inc.
 P.O. Box 9028
 San Dimas, CA 91773-9028
 Email: Paul.Marconi@bvesinc.com
 (909) 202-9539