



## PACIFIC GAS AND ELECTRIC COMPANY

## ELECTRIC INCIDENT REPORT FORM

TO: CALIFORNIA PUBLIC UTILITIES COMMISSION

PG&E Reference Number: EI210606A	
CPUC Website	June 22, 2021 at 1730 hours
CPUC Recipient 1-800-235-1076	Date & Time CPUC Notified PG&E
Telephone Number	Reported by 415-973-2782
	Telephone Number

Report Type: Amended 20-Day Report

- INJURY/FATALITY:** An incident which results in a fatality or personal injury to an employee or 3rd party rising to the level of in-patient hospitalization and is attributable or allegedly attributable to utility owned electric facilities. Incidents involving motor vehicles are not reportable unless they result in death or injury attributable or allegedly attributable to electrical contact with the utility owned electric facilities.
- MEDIA:** An incident that is attributable or allegedly attributable to Pacific Gas and Electric owned electric facilities and is subject to significant public attention and/or media coverage.
- PROPERTY DAMAGE:** A single electric incident where property damage of the utility or a single 3rd party is estimated to exceed \$50,000 and is attributable or allegedly attributable to utility owned electric facilities.
- OPERATOR JUDGEMENT:** Any incident that is significant in the judgement of the operator, even though it may not meet the incident reporting criteria.

20-Day Report Sent to CPUC – Date: July 21, 2021  
 Amended 20 Day Report Sent to the CPUC – Date:  
 October 13, 2021

Initial Report Sent to CPUC – Date: June 22, 2021



## PACIFIC GAS AND ELECTRIC COMPANY

## ELECTRIC INCIDENT REPORT FORM

TO: CALIFORNIA PUBLIC UTILITIES COMMISSION

PG&amp;E Reference Number: EI210606A

Amended 20-Day Report

<b>Date and Time of Incident:</b>		June 6, 2021 at 1320 hours	
<b>Date and Time Incident Determined Reportable:</b>		June 22, 2021 at 1605 hours	
<b>Location of Incident:</b>			
<b>City:</b>	Los Olivos	<b>Division:</b>	Los Padres
<b>County:</b>	Santa Barbara	<b>County:</b>	Santa Barbara
<b>Circuit/Facility:</b>	Zaca 1101	<b>Voltage:</b>	12kV
<b>Service Interrupted (Date and Time):</b>	June 6, 2021 at 1315 hours	<b>Total Customers Affected:</b>	1
<b>Service Restored (Date and Time):</b>	Service not yet restored		

**Description of Incident:**

Please note, we have reviewed our records and are updating two Attachments - Attachment 4 and Attachment 8. No other changes were made to this report.

On June 6, 2021 at 1315 hours, a PG&E Electric SmartMeter, associated to a commercial structure at [REDACTED] in Los Olivos ("Incident Location"), detected an outage and powered down. The Incident Location is served by the Zaca 1101 12kV distribution circuit. At 1320 hours, the County of Santa Barbara Fire Department ("SBFD") received notification of a fire at the Incident Location and arrived at 1345 hours. At 1420 hours, a PG&E troubleman was dispatched to the Incident Location.

Upon arrival, the troubleman observed personnel from the SBFD were on scene and the fire had been extinguished. According to the SBFD, the fire had been controlled at 1410 hours, prior to the troubleman's arrival. The troubleman coordinated with SBFD personnel to determine the source of the ignition but neither could find an obvious cause. The troubleman observed the electric panel at the Incident Location and the conduit housing an electric underground service feeding the panel showed visible signs of damage. The troubleman inspected the meter and found only slight melting on the exterior surface and no visible damage to the associated prongs. At 1700 hours, the troubleman disconnected the associated underground electric service to the meter at the transformer and retained it as evidence. The troubleman did not observe any media on scene and there were no reported injuries/fatalities. Service has not yet been restored because of the fire damage at the Incident Location.

A weather station approximately 0.05 miles northeast of the Incident Location reported seasonably dry conditions with the highest temperature of the day reaching 69 F at 1310 hours; relative humidity between 56-99% throughout the day. Winds were out of the west with the strongest gust being 15 mph near the Incident Location.

On June 22, 2021, at 1515 hours, a Third Party Subrogation Attorney notified PG&E's Law Claims Department by email of the fire incident that occurred on June 6, 2021 at the Incident Location. The Third Party is alleging that PG&E electric facilities may have been a factor to the causation of the incident and property damages were estimated at greater than \$50,000. As a result, PG&E reported the incident to the CPUC on June 22, 2021 under the Property Damage criterion.

A fire report from the SBFD was obtained by PG&E and indicated that the first engine arrived to observe a fully involved fire inside a metal building with only light smoke from the exterior.

Please note, the last GO165 inspection took place in 2015, and PG&E is currently assessing if the last inspection dates are within compliance.

PG&E is continuing its investigation into this incident. This information is preliminary, and PG&E is fully cooperating and communicating with external agencies as required.



**PACIFIC GAS AND ELECTRIC COMPANY**

## **ELECTRIC INCIDENT REPORT FORM**

Attachments: (Amended on October 13, 2021; Incident Location on Attachment 04 and Map Location on Attachment 08)

- Attachment 01\_2020 GO165 patrol records\_CONF.pdf
- Attachment 02\_2021 GO165 patrol records\_CONF.pdf
- Attachment 03\_2010 GO165 inspection records\_CONF.pdf
- Attachment 04\_2015 GO165 inspection records\_Amended\_CONF.pdf
- Attachment 05\_OIS\_1366957\_CONF.pdf
- Attachment 06\_Photos\_CONF.pdf
- Attachment 07\_Fire Report\_CONF.pdf
- Attachment 08\_Incident Map-Diagram\_Amended\_CONF.pdf