



PACIFIC GAS AND ELECTRIC COMPANY

ELECTRIC INCIDENT REPORT FORM

TO: CALIFORNIA PUBLIC UTILITIES COMMISSION

PG&E Reference Number: EI170611A	
CPUC Website	6/11/2017 12:17:00 PM
CPUC recipient	Date & Time CPUC notified
1-800-235-1076	Angie Luz
Telephone Number	Reported by
	415-973-2782
	Telephone Number

Report Type: Final

- INJURY/FATALITY:** An incident which results in a fatality or personal injury to an employee or 3rd party rising to the level of in-patient hospitalization and is attributable or allegedly attributable to utility owned electric facilities. Incidents involving motor vehicles are not reportable unless they result in death or injury attributable or allegedly attributable to electrical contact with the utility owned electric facilities.
- MEDIA:** An incident that is attributable or allegedly attributable to Pacific Gas and Electric owned electric facilities, and is subject to significant public attention and/or media coverage.
- PROPERTY DAMAGE:** A single electric incident where property damage of the utility or a single 3rd party is estimated to exceed \$50,000 and is attributable or allegedly attributable to utility owned electric facilities.
- OPERATOR JUDGEMENT:** Any incident that is significant in the judgement of the operator, even though it may not meet the incident reporting criteria.
- AIRCRAFT STRIKE:** Any incident involving aircraft striking PGE facilities, even though it may not meet the incident reporting criteria.

Initial Report Sent to CPUC – Date: 6/13/2017

Final Report Sent to CPUC – Date: 7/5/2017


PACIFIC GAS AND ELECTRIC COMPANY
ELECTRIC INCIDENT REPORT FORM
PG&E Reference Number: EI170611A
Final

Date and Time of Incident:		6/11/2017 12:58:00 AM	
Date and Time Incident Determined Reportable:		6/11/2017 11:58:00 AM	
Location of Incident:		Broadway St	
City:	Chico	Area:	6
County:	Butte	Voltage:	12 kV
Circuit/Facility:	CHICO STATION B 1106	Total Customers affected:	129
Service interrupted (time and date):	6/11/2017 12:58:00 AM	Major Customers affected:	TBD
Service restored (time and date):	6/12/2017 1:10:00 PM		

Description of Incident:

On Sunday, June 11, 2017 at approximately 0058 hours, an underground 12KV cable failure occurred in Vault 31 located on West 3rd and Broadway in Chico resulting in a fire contained within the vault and power outage.

The incident caused a sustained interruption affecting 129 commercial customers on the Chico B-1106 12kV circuit. PG&E implemented switching procedures and restored electric service to 85 customers by 0938 hours. The remaining 44 customers were restored by Wednesday, June 12, 2017 at 1310 hours.

PG&E replaced conductor and conduit needed due to the incident per the attached EC Notification #112952227 (Attachment 5).

This incident was reported under the Media criterion as there were reports of News Media on site. There were no reports of any injuries or property damage.

CPUC performed a site visit on Tuesday, June 13, 2017 with PG&E.

Attached with this incident report are the following records:

- 2016 and 2013 inspection records (Attachments 1 and 2)
- 2015 and 2014 patrol records (Attachments 3 and 4)
- EC Notification (Attachment 5)

Facility Type: UG Primary

Injured Party Infomation: No injuries reported.

Property Damage Description: No property damage reported.