



PACIFIC GAS AND ELECTRIC COMPANY

ELECTRIC INCIDENT REPORT FORM

TO: CALIFORNIA PUBLIC UTILITIES COMMISSION

PG&E Reference Number: EI170129A

CPUC Website

1/29/2017 3:06:00 PM

CPUC recipient

Date & Time CPUC notified

1-800-235-1076

Raquel Rojas

Telephone Number

Reported by

415-973-2782

Telephone Number

Report Type: Final

- INJURY/FATALITY:** An incident which results in a fatality or personal injury to an employee or 3rd party rising to the level of in-patient hospitalization and is attributable or allegedly attributable to utility owned electric facilities. Incidents involving motor vehicles are not reportable unless they result in death or injury attributable or allegedly attributable to electrical contact with the utility owned electric facilities.
- MEDIA:** An incident that is attributable or allegedly attributable to Pacific Gas and Electric owned electric facilities, and is subject to significant public attention and/or media coverage.
- PROPERTY DAMAGE:** A single electric incident where property damage of the utility or a single 3rd party is estimated to exceed \$50,000 and is attributable or allegedly attributable to utility owned electric facilities.
- OPERATOR JUDGEMENT:** Any incident that is significant in the judgement of the operator, even though it may not meet the incident reporting criteria.
- AIRCRAFT STRIKE:** Any incident involving aircraft striking PGE facilities, even though it may not meet the incident reporting criteria.

Initial Report Sent to CPUC – Date: 1/30/2017

Final Report Sent to CPUC – Date: 2/24/2017



PACIFIC GAS AND ELECTRIC COMPANY

ELECTRIC INCIDENT REPORT FORM

PG&E Reference Number: EI170129A

Final

Date and Time of Incident:		1/29/2017 10:43:00 AM	
Date and Time Incident Determined Reportable:		1/29/2017 2:14:00 PM	
Location of Incident:		200 Rosita Court	
City:	Vacaville	Area:	6
County:	Solano	Voltage:	12 kV
Circuit/Facility:	VACA DIXON 1104	Total Customers affected:	56
Service interrupted (time and date):	1/29/2017 10:43:00 AM	Major Customers affected:	TBD
Service restored (time and date):	1/29/2017 6:34:00 PM		

Description of Incident:

On January 29, 2017, at approximately 1043 hours, PG&E's subsurface transformer T-8550 failed on the Vaca Dixon – 1104 12kV circuit, near 200 Rosita Court in the City of Vacaville. The resulting voltage fluctuation that occurred before the transformer was manually shut off caused damage to appliances in about 14 homes, as well as a fire in one home (██████████). The property damage resulting from this incident is greater than \$50,000.

The incident also caused a sustained outage to 56 customers on the Vaca Dixon – 1104 circuit. PG&E implemented switching procedures and restored service to all of the affected customers by 1834 hours, the same day.

PG&E replaced the failed transformer per the attached EC notification 112544464 (Attachment 1).

Attached with this incident report are the following:

- 2014 and 2015 patrol records (Attachments 2 and 3)
- 2013 and 2016 inspection records (Attachments 4 and 5)
- Pictures taken January 31 during CPUC site visit (Attachment 6)
- Pictures of failed transformer taken at PG&E's Vacaville Service Center (Attachment 7)

CPUC conducted site visit with PG&E at the incident location on January 31, 2017.

PG&E reported this incident to the CPUC on January 29, 2017 under the Property Damage criterion.

Facility Type: OH Primary

Injured Party Information:

Property Damage Description: >\$50,000