

62	CaPA	Set WMP-10	CaPA_Set WMP-10_D15	15	CaPA_Set WMP-10_D15	In response to data request CALM/Resource-PGE-2023WMP-02, question 3. PGEAE states, "There is an inherent OC process that is part of the storm inspection, but there is no process that is solely an OC." a) Please describe the inherent OC process for the storm inspections. What are the main features of the inherent OC process? b) What types of problems or flaws in storm inspections can the inherent OC process identify? c) Please describe the most common problems or flaws in storm inspections that the inherent OC process identifies in 2023. d) What are the limitations of this inherent OC process?	There is a 100% review of all inspections that are part of the inspection process. The inspector completes the inspection and a spot check is performed for commonly reviewed items. The inspection is performed as follows: 1) The five most common problems of all OC processes are C-locks, Wadlock, roller pins, shoe losses, and structural flaws. 2) We have not identified any limitations of the OC process at this time.	Holly Wehman	4/4/2023	4/19/2023	4/19/2023	0	NA	8.1.3	Asset Inspections	N/A
4	MGRA	Data Request No. 1	MGRA_Data Request No. 1	1	MGRA_Data Request No. 1_O1	Please provide for Asset Point data for Camera, Faint, Support Structure, and Weather Station.	In response to this request, PGEAE is providing Camera and Weather Station data, as delivered in the 04 2022 OESB Grid Data Standard Submission. PGEAE is also providing non-confidential data from the Support Structure feature class. PGEAE is not providing for the Faint feature class as this data is confidential critical energy infrastructure information (CEII).	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	1	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
5	MGRA	Data Request No. 1	MGRA_Data Request No. 1	2	MGRA_Data Request No. 1_O2	Please provide Asset Line data for Transmission Line (as permitted as non-confidential), Primary Distribution Line, and Secondary Distribution Line.	In response to this request, PGEAE is providing non-confidential data for the Primary and Secondary Distribution Line Feature Classes. PGEAE is not providing the Transmission Line feature class because it is confidential CEII.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
6	MGRA	Data Request No. 1	MGRA_Data Request No. 1	3	MGRA_Data Request No. 1_O3	Please provide PSEPS Event data, Include Event Log, Event Line, Event Polygon data, Please include customer meter data. Provide all PSEPS Event Asset Damage data including photos.	In response to this request, PGEAE is unable to provide PSEPS Event data, PSEPS Event Damage data, and PSEPS Damage photos since there were no PSEPS Events that took place throughout 2022.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
7	MGRA	Data Request No. 1	MGRA_Data Request No. 1	4	MGRA_Data Request No. 1_O4	Please provide Risk Point data, including Wire Down, Ignition, Transmission Upstream Outage (as classified non-confidential), Distribution Upstream Outage data, Distribution Vegetation Causal Upstream Outage, Risk Event Asset Log.	In response to this request, PGEAE is providing non-confidential data for the Wire Down, Ignition, Transmission Upstream Outage, Distribution Upstream Outage, Distribution Vegetation Causal Upstream Outage, and Risk Event Asset Log feature classes and related tables.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
8	MGRA	Data Request No. 1	MGRA_Data Request No. 1	5	MGRA_Data Request No. 1_O5	Please provide photo data for Risk Events.	PGEAE does not have any non-confidential or non-published data to provide in response to this request. The photos provided in this feature class may be subject to attorney-client privilege or the work product doctrine and may be subject to an ongoing litigation. Additionally, PGEAE risk event photos are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
9	MGRA	Data Request No. 1	MGRA_Data Request No. 1	6	MGRA_Data Request No. 1_O6	User Inquiries, please provide Grid Hardening data, including Hardening Log, Hardening Point, and Hardening Line data. Inspection data is not requested of the line.	In response to this request, PGEAE is providing non-confidential data for the System Hardening, State County Related, and 108 Underpinning WMP initiative programs that were included in the Grid Hardening Log, Grid Hardening Point, and Grid Hardening Line feature classes and related tables. Additional initiative projects reported in these feature classes include data on where PGEAE has implemented, such as replacement, surge arrester replacement, and SCADA enabled work has been performed, and where future work is planned to take place. These are confidential CEII because they reveal physical facility and critical infrastructure locations. As such, they have been redacted from the response.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
10	MGRA	Data Request No. 1	MGRA_Data Request No. 1	7	MGRA_Data Request No. 1_O7	User Inquiries, please provide Other Initiative data per point, line, polygon features and the Other Initiative Log.	In response to this request, PGEAE is providing WMP initiative program data for the Weather Station Installation and Optimization and Camera Installation that were included in the Other Initiative Log and Other Initiative Point related table and feature class. Additional WMP initiative projects reported in this feature class and related table include data on where PGEAE has Line Sensor installations, Distribution Fault Anticipation, EPSP Reliability Improvements and Early Fault Detection Sensors work has been performed, and where future work is planned to take place. These are confidential CEII because they reveal physical facility and critical infrastructure locations.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
11	MGRA	Data Request No. 1	MGRA_Data Request No. 1	8	MGRA_Data Request No. 1_O8	User Other Required Data, please provide Red Flag Warning Day polygon data.	PGEAE is providing the Red Flag Warning Day polygon data, as requested by MGRA.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
12	MGRA	Data Request No. 1	MGRA_Data Request No. 1	9	MGRA_Data Request No. 1_O9	Please provide a layer including calculated circuit-level risk using the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	The method described in the 2023 WMP to aggregate model results is conducted to produce a circuit segment level risk value but it is not used to produce a circuit level risk. However, the geospatial representation of circuit segments that would be produced in response to this request requires the identification of CEII, which we are required by law to maintain as confidential and cannot produce without the necessary early agreement to protect the information through a non-disclosure agreement.	Joseph Mitchell	3/29/2023	4/19/2023	4/7/2023	0	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Presentation
103	CaPA	Set WMP-12	CaPA_Set WMP-12	1	CaPA_Set WMP-12_D1	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
104	CaPA	Set WMP-12	CaPA_Set WMP-12	2	CaPA_Set WMP-12_O2	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
105	CaPA	Set WMP-12	CaPA_Set WMP-12	3	CaPA_Set WMP-12_O3	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
106	CaPA	Set WMP-12	CaPA_Set WMP-12	4	CaPA_Set WMP-12_O4	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
107	CaPA	Set WMP-12	CaPA_Set WMP-12	5	CaPA_Set WMP-12_O5	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
108	CaPA	Set WMP-12	CaPA_Set WMP-12	6	CaPA_Set WMP-12_O6	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequently De-Energized Circuits
109	CaPA	Set WMP-12	CaPA_Set WMP-12	7	CaPA_Set WMP-12_O7	Regarding Table 9-2 (List of Frequently De-energized Circuits) in Appendix F of PGEAE's WMP, the column "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" is blank for the following distribution circuit Entry Numbers: 7, 8, 11, 15, 17, 18, 26, 30, 36, 37, 38, 39, 47, 55, 62, 63, 76, 77, 87, 105, 113, 125, 126, 142, 161, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 191. a) For each of the above Entry Numbers, please explain why "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" are being taken. b) For each of the above Entry Numbers, please explain why PSEPS plans to take any PSEPS on that circuit. c) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain why. d) For each item in part (b) where PGEAE does not plan to take any measures to reduce the need for and impact of future PSEPS on that circuit, please explain the basis for this decision.	a) We discovered an error in our 2023 WMP submission in the "Measures Taken, or Planned to Be Taken, to Reduce the Need for and Impact of Future PSEPS of Circuit" field. We will reach out to Energy Safety to provide the corrected information and discuss updating our WMP submission pursuant to Energy Safety's guidelines. We will provide an explanation of any remaining blanks. Please note, we expect to have the table revised by April 18, 2023. b) See response (a). c) See response (a). d) See response (a).	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	Appendix D	Areas for Continued Improvement	ACI PGEAE-23-35 - Quality Mitigation Benefits of Reducing PSEPS Scale, Scope, and Frequency
110	CaPA	Set WMP-12	CaPA_Set WMP-12	8	CaPA_Set WMP-12_O8	Regarding Section 9.2.3 (Outline of Textual and Strategic Decision-Making Protocol for Initiating a PSEPS/PSPS (Such as Decision Tree), Submission of Decision of De-Energize, the WMP, 780 states in part that "The OIC will determine whether alternatives to de-energization are reasonable." a) Please describe the alternatives to de-energization that are considered. b) Please state the basis of PGEAE's decision regarding which alternative to consider. c) Please describe the OIC process where such alternatives are analyzed or evaluated.	a) We consider if alternatives, such as additional vegetation management and disabling automatic reclosers, could adequately reduce the risk of catastrophic wildfire thus lowering the need for de-energization. When these measures alone cannot reduce the risk of catastrophic wildfire in areas within the PSEPS scope sufficiently to protect public safety, we will move forward with PSEPS. b) See response (a). c) After alternatives are considered the OIC further evaluates the forecasted high wind speeds and wind gust speeds, which can break and blow vegetation to debris into power lines and slow starts into dry vegetation, when it's determined these other measures are not adequate alternatives to mitigate the risk of catastrophic wildfire, and that de-energizing in the areas within the PSEPS scope is necessary to protect public safety. d) Furthermore, we implemented efforts to mitigate adverse impacts on the customers and communities in areas where power shutoffs were likely. These efforts include: - Employing greater resource processes to significantly reduce the public safety impacts of de-energization by de-energizing smaller segments of the grid within the areas critical of the fire-critical weather footprint, rather than de-energizing large amounts of customers in more populated areas. - Considering the public safety impacts of de-energizing by reviewing the total count of impacted customers and the impact of potential de-energization upon Medical Baseline customers, critical facilities, and the back-up generation capabilities of critical facilities that pose similar impact risks if de-energized (e.g., critical infrastructure). - Mitigating temporary generation to energize customers outside of the forecasted risk areas. - Using technicians to review the scope and number of customers affected. - Considering opportunities for assisting temporary generation, and alternate grid solutions, to reduce and mitigate the number of customers de-energized. - Reducing the public safety impacts of de-energization by using back-up generation to serve critical facilities and customers. - Providing local Community Resource Centers (CRCs) to support customers in their impacted communities. - Supporting vulnerable customers through California Foundation for Independent Living Centers (CILC) and Community Based Organizations (CBO) resource partners that offer various services to customers impacted by the event. - Making extensive use of Advance Notifications and outreach tools to notify impacted customers of the expected de-energization. - Using an extensive camera, weather station, and satellite weather monitoring network, and on-the-ground personnel to collect real-time observations to inform and support the identification of Weather "At-Clear" times in more precise, smaller areas, to get customers back to service faster. - Reading and increasing resources for restoration efforts, including use of helicopters and feed wire aircraft to conduct line safety patrols after the Weather "At-Clear", restoring service to safe levels as quickly as possible subject to operational safety and ability to access equipment to patrol any needed repairs.	Holly Wehman	4/6/2023	4/11/2023	4/11/2023	0	NA	9.2.3	Public Safety Power Shutoff	Outline of Textual and Strategic Decision-Making Protocol for Initiating a PSEPS/PSPS (Such as Decision Tree)

168	CaPA	Set WMP-15	CaPA_Set WMP-15	19	CaPA_Set WMP-15_Q19	<p>In response to Question 5 of Calhoun-PAGE-2023WMP-08, PAGE provides the following table of actual and forecasted costs for vegetation management programs. PAGE further states that "The EMV Transitional programs for VM are Focused Tree Inspections, VM for Operational Mitigations, and Tree Removal Inventory."</p> <p>Please update the table to include the actual and forecast costs for each EMV Transitional Program, including:</p> <p>a) VM for Operational Mitigations b) Tree Removal Inventory c) Focused Tree Inspections</p> <p>Please explain how PAGE plans to achieve the following cost reductions in vegetation management as demonstrated in the above table: - \$831,022.00 between 2022 and 2023 - \$4,841,000 between 2023 and 2024.</p>	<p>a) Please see the updated table which includes forecast costs for each EMV transitional program. These programs were not active in 2022 therefore actual costs are not available. ACT FCSFT 2022 2023 2024 Tree Inventory \$ 108,120 \$ 100,617 \$ 98,112 EMV \$ 500,071 N/A EMV Transitional Programs N/A \$ 160,357 \$ 156,396 VM for Operational Mitigations \$ 2,455 \$ 2,272 Tree Removal Inventory \$ 2,584 \$ 2,523 Focused Tree Inspections in ACC \$ 84,818 \$ 81,342 Tree Inventory \$ 75,171 \$ 71,844 \$ 69,225 VM Cleaning \$ 23,589 \$ 20,300 \$ 20,353 Totals \$ 1,354,625 \$ 1,168,119 \$ 1,144,627</p> <p>b) The difference of \$31,522.00 between 2022 and 2023 is achieved due to the completion of the EMV Program. These reductions are reflected in the Vegetation Management GRC Supplemental Testimony submitted in February 2022. c) The difference of \$4,841,000 between 2023 and 2024 is due to several factors, this is how PAGE will achieve this reduction: (1) Transitioning from EMV to tree program; (2) reducing the amount of routine VM work conducted each year commensurate with the amount of undergrounding miles completed; and (3) reducing unit costs through the use of more efficient equipment, programmatic adjustments that refine processes and improve resource efficiency.</p>	Holly Whitham	4/11/2023	4/14/2023	4/14/2023	0	NA	8.2.5.2	Vegetation Management and Inspections	Quality Control
169	CaPA	Set WMP-15	CaPA_Set WMP-15	20	CaPA_Set WMP-15_Q20	<p>In response to Question 19(a) of Calhoun-PAGE-2023WMP-08, PAGE says, "We do not have a source for tracking planned work data for individual trees and are unable to provide the data at this time."</p> <p>Does PAGE plan to develop a source for tracking planned work data for individual trees? If the answer to part (a) is yes, when does PAGE expect to have such a system implemented? If the answer to part (a) is no, please explain why not.</p>	<p>a) No, PAGE does not have a plan to develop a source for tracking planned work data for individual trees. b) Not applicable. c) When individual trees are identified as needing work, they are packaged into a work request that may contain multiple trees on the same circuit. The work identified is then sent out and completed as a project. Tracking individual trees and individual work dates would be a strain on our resources. PAGE tracks one project level based on a separate data set of the work work order and completed status.</p>	Holly Whitham	4/11/2023	4/14/2023	4/14/2023	0	NA	8.2.3.4	Vegetation Management and Inspections	Fabric Information
170	TURN	004	TURN_004	1	TURN_004_Q1	<p>Following up on the response to TURN Data Request 1, Question 2, please provide PAGE's data showing the "recorded reliability improvements at locations that have been undergrounded and/or have been hardened with covered conductors" that will be assessed in the study plan for completion on June 30, 2023.</p>	<p>Not applicable.</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	1	Yes	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
171	TURN	004	TURN_004	2	TURN_004_Q2	<p>Regarding Table PGME-22-35-1 (PPSP Events Lookback Analysis) on page 872 of PAGE's 2023-2025 WMP: For each column with numerical, provide a verbal description of the input data and how the numerical in each column were calculated. Provide the table in Excel format.</p>	<p>Please note that the attachment provided with this response contains confidential information. a) Input Data: The columns in Table PGME-22-35-1 used the following input data: 2022 PSPS Five-Year Lookback Analysis (2018-2022); this is an analysis which shows the hypothetical PSPS events created by applying 2022 PSPS guidance to the weather from 2018-2022. This is our most accurate method of estimating PSPS impacts based on our latest PSPS guidance, and results in a dataset identifying the list of customers impacted per hypothetical event. This list of customers is used in this WMP to calculate projected PSPS customer impacts. Customers whose PSPS impact is prevented due to existing mitigations (and the effect of 2022) are not included in this dataset. Some customers in this dataset may experience short-duration outages due to use of a downstream MSD device in the hypothetical PSPS events. When scoring PSPS events, we also add events to scope due to the presence of certain asset and vegetation tags. The number and location of these asset and vegetation tags on our system varies day-by-day and cannot be accurately forecasted in future PSPS events. The presence of certain asset and vegetation tags is incorporated as a 10.2% multiplier. The asset and vegetation tag multiplier was calculated using 2021 actual PSPS events, excluding the January 19, 2021 PSPS Event (which used the 2020 PSPS guidance and thus did not have a scope increase tag). b) Since we cannot determine which specific customers will be added to scope due to asset and vegetation tags, this 10.2% increase can only be applied to the aggregated customer count for each PSPS event. c) In the table specifically, this dataset is used in conjunction with the other input data to identify customers mitigated by MSD device replacements and undergrounding. This dataset also serves as the baseline or denominator for calculating the columns showing the percentage of customers mitigated. MSD Device Replacement (2023-2024): This dataset identifies the list of MSD devices that will be replaced with non-MSD devices in 2023 and 2024. This dataset was used in conjunction with the 2022 PSPS Five-Year Lookback Analysis described above to identify customers whose PSPS outages would be prevented by MSD device replacement. Isolated Undergrounding Projects: This dataset identifies the undergrounding projects scoped for future work. An analysis was performed using this dataset to determine the expected impact of undergrounding completed, assuming the success projects. The expected PSPS customer mitigation is calculated relative to hypothetical PSPS events in the 2022 PSPS Five-Year Lookback Analysis described above. Table Columns: Column: Incremental Customers Mitigated: This column indicates the number of incremental customer-events mitigated per category (year and type of mitigation), relative to the hypothetical PSPS events generated in the 2022 PSPS Five-Year Lookback Analysis. "Incremental" means that this column reports the additional customer-events mitigated (removed from PSPS impact) due specifically to this year and type of mitigation and indicates that these customers would otherwise have been de-energized for PSPS in this year and type of mitigation had not been implemented. "Other" mitigations (either already existing in 2022 or planned to be completed in later years) are assumed to be in place. For example, the value reported for "DISTRIBUTION HARDENING" is the comparison of customer counts from "the 2022 PSPS Five-Year Lookback Analysis with all 2023 allowed mitigation installed", not "the 2022 PSPS Five-Year Lookback Analysis with all 2023 allowed mitigation installed", not.</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	1	NA	Appendix D	Areas for Continued Improvement	ACI PGME-22-35 Quarterly Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency
172	TURN	004	TURN_004	3	TURN_004_Q3	<p>Regarding PAGE's response to ACI PGME 22-35, beginning on page 871 of its WMP: Please identify which mitigation discussed in PAGE's current WMP or its 2022 WMP has the potential to mitigate the scale, scope, frequency, or duration of PSPS events. Please explain why Table 22-35-1 only lists the impact of mitigation, undergrounding and MSD, and does not consider the other mitigations identified in response to subject (a). Please provide all PAGE analyses similar to what is presented in Table 22-35-1 regarding the impact on PSPS scale, scope, frequency, or duration of any one or all of the other mitigations identified in response to subject (a). Regarding the statement on page 871: "We concluded that none of the 2022 mitigation initiatives eliminated any event." Please identify any of the "2022 mitigation initiatives" that are referenced in this statement. Is the meaning of this statement that none of the 2022 mitigation initiatives reduced the scale, scope, frequency or duration of any event? If not, please explain what is meant by the statement and how it relates to the analysis presented in Table 22-35-1.</p>	<p>a) We currently do not have initiatives to add additional mitigation devices such as Sectioning devices and Temporary Mitrogrids as described in subject (a). In each of the 2022 and 2023 WMP, we examined the projected impact of future planned mitigation initiatives on PSPS events. Thus, Table 22-35-1 only lists the impact of the mitigation initiatives planned for future implementation of the 2022 WMP (undergrounding and MSD Replacements) and does not further examine the impact of past or pre-existing mitigations (including the additional mitigations discussed in the 2022 WMP). b) The analysis presented in Table 22-35-1 was only performed for the mitigation initiatives planned for implementation in the 2022 WMP. Undergrounding and MSD Replacements. c) The combined or total impacts of the 2022 WMP mitigations is reflected in the following tables: - Table PGME-22-35-2: Target Reductions as a Result of PAGE's WMP Mitigations - Table 7-2-5: PSPS WMP Targets - Table FCSFT - QOR Table 10 d) The impact of the remaining mitigations identified in the response to subject (a) on PSPS events were analyzed in the 2022 WMP, in the following tables: - Table PGME-8-1: Estimated Impact of 2022 WMP Planned Mitigations - Table PGME-8-1: PSPS Direct Impact Initiatives - Targets to be Completed by September 1, 2022 - Table PGME-8-2: PSPS Direct Initiative Targets to be Completed After September 1, 2022 and Prior to the Next WMP Update Furthermore, the combined or total impacts of the 2022 WMP mitigations is reflected in the following tables: - Table PGME-8-1-2: Estimated Total Impact of 2022 WMP Planned Mitigations - QOR Table 11 e) This was a mistake we made in the 2023 WMP. This statement was intended to say "We concluded that none of the mitigation initiatives described in this analysis will completely eliminate any event." The mitigation initiatives underlying to Undergrounding and MSD Replacement initiatives described in the 2022 WMP. This statement means that mitigation initiatives, Undergrounding or MSD Replacement, described in the 2023 WMP are not sufficient to completely eliminate or reduce the frequency of a PSPS event. However, they can reduce the scope and scale of a PSPS event in the lookback analysis for Table 22-35-1.</p>	Tom Long	4/12/2023	4/17/2023	4/17/2023	0	NA	Appendix D	Areas for Continued Improvement	ACI PGME-22-35 Quarterly Mitigation Benefits of Reducing PSPS Scale, Scope, and Frequency
124	CaPA	Set WMP-14	CaPA_Set WMP-14	1	CaPA_Set WMP-14_Q1	<p>P. 347 of PAGE's WMP states (regarding PAGE's undergrounding program), "Among other benefits, the reduced peak (as compared to prior practices) will decrease costs in the initial years of the program." Please list the "other benefits" referenced in the quote above.</p>	<p>There are also additional benefits to reducing the near-term undergrounding mileage targets, including providing more time to other process improvements that may reduce long term costs and drive long term efficiency of the program.</p>	Holly Whitham	4/11/2023	4/17/2023	4/17/2023	0	NA	8.1.3.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
125	CaPA	Set WMP-14	CaPA_Set WMP-14	2	CaPA_Set WMP-14_Q2	<p>P. 347 of PAGE's WMP states (regarding PAGE's undergrounding program), "Among other benefits, the reduced peak (as compared to prior practices) will decrease costs in the initial years of the program." Please list the "other benefits" referenced in the quote above.</p>	<p>a) No, DTFS-FAST does not have the capability to re-energize a line. Currently, DTFS-FAST is monitoring only, and is not automatically sending the trip (de-energize) signal to operations and the system has been tested to ensure accuracy. b) DTFS-FAST sensor data will report alarm conditions in real time. For example, if a vegetation has fallen into the alarm zone and remains (i.e., leaning on the conductor), the alarm will remain. However, if the vegetation falls away from the alarm zone, then the alarm will clear. Furthermore, we will use the alarm camera to validate the alarm and take appropriate actions. c) DTFS-FAST does not have the capability to re-energize a line, but will provide data to operations of sensor alarm patterns. In addition, DTFS-FAST cameras will provide remote visual awareness of the alarm location. d) We do not currently have enough field data to draw formal conclusions about reliability impacts, but our goal is to ensure the DTFS-FAST sensors report accurate PSPS data with no false alarms.</p>	Holly Whitham	4/11/2023	4/17/2023	4/17/2023	0	NA	8.1.2.6.1	Grid Design and System Hardening	Distribution, Transmission, and Substation: Fire Action Schemes and Technology
126	CaPA	Set WMP-14	CaPA_Set WMP-14	3	CaPA_Set WMP-14_Q3	<p>P. 359 of PAGE's WMP discusses Breakaway Connectors, and states, "The breakaway disconnect uses a weak link to provide a predictable point of separation and the service will fall to the ground de-energized." a) What's the maximum wind speed that Breakaway Connectors can handle without separating? b) Has PAGE studied whether conditions exist that could cause a temporary fault and minimal or no damage to a non-breakaway connector, but would cause a Breakaway Connector to separate? For example, a small branch falling on the line. c) If the answer to part (b) is yes, please provide any details of such studies. d) For each temporary distribution microgrid listed in part (a), state the number of times the temporary distribution microgrid was used in 2020, 2021, and 2022 to mitigate the effect of a possible PSPS event. e) For each temporary distribution microgrid listed in part (a), state the number of times the temporary distribution microgrid was used in 2020, 2021, and 2022 to mitigate the effects of a PSPS event. f) For each instance in part (b), list the number of customers that remained energized during a PSPS event. g) How does PAGE determine what locations would warrant deployment of a temporary distribution microgrid? h) How does PAGE determine when to deploy a temporary distribution microgrid? If how does PAGE determine when to remove a deployed temporary distribution microgrid?</p>	<p>a) Maximum wind speed is not easily defined. Span length, tension, conductor size and wind direction all influence the maximum wind speed. General Order 85: 14k-24k ft and 40-240 degree Supply service lines have a minimum strength of 90 psi or annealed copper. This is 470 lb pounds. The service breakaway has ten available weak links 500 lbs. for services 75' and shorter, 750 pounds for services longer than 75 feet and up to 150 feet. b) We do not currently have enough field data to draw formal conclusions about reliability impacts, but our goal is to ensure the DTFS-FAST sensors report accurate PSPS data with no false alarms. c) Yes, we have studied these cases: 1) Two 1800 amp breakers were observed with limbs weighing 125 lbs. and 200 lbs., respectively. No damage was found, and the weak links did not activate. 2) No applicable, please see the response to subject (b) above. 3) We do not expect any reliability impacts. 4) No applicable, please see the response to subject (b) above. 5) The conductor will fall before the breakaway. 6) EPRI is not affected by secondary conductors. It is primarily applied only. 7) Not applicable, please see the response to subject (g) above.</p>	Holly Whitham	4/11/2023	4/17/2023	4/17/2023	0	NA	8.1.2.6.2	Grid Design and System Hardening	Breakaway Connector
127	CaPA	Set WMP-14	CaPA_Set WMP-14	4	CaPA_Set WMP-14_Q4	<p>P. 359 of PAGE's WMP states, "Breakaway disconnect does not impact PSPS Risk." Please state the basis for the above quote.</p>	<p>Breakaway disconnects are used to prevent energized wires down to minimize ignition risk. At this point in time, of the presence of breakaway disconnects is not included in PSPS scoring decisions. Therefore, breakaway disconnects do not impact the PSPS risk.</p>	Holly Whitham	4/11/2023	4/17/2023	4/17/2023	0	NA	8.1.2.6.2	Grid Design and System Hardening	Breakaway Connector
128	CaPA	Set WMP-14	CaPA_Set WMP-14	5	CaPA_Set WMP-14_Q5	<p>P. 363 of PAGE's WMP states, "Temporary distribution microgrids are designed to support community resilience and reduce the number of customers impacted by PSPS by energizing 'near street corridors' with clusters of shared services and critical facilities so that those resources can continue serving surrounding residents during PSPS events." a) Please list the temporary distribution microgrids that PAGE had available in 2020, 2021, and 2022 to mitigate the effect of a possible PSPS event. b) For each temporary distribution microgrid listed in part (a), state the number of times the temporary distribution microgrid was used in 2020, 2021, and 2022 to mitigate the effects of a PSPS event. c) For each instance in part (b), list the number of customers that remained energized during a PSPS event. d) How does PAGE determine what locations would warrant deployment of a temporary distribution microgrid? e) How does PAGE determine when to deploy a temporary distribution microgrid? If how does PAGE determine when to remove a deployed temporary distribution microgrid?</p>	<p>a) Responses are summarized in the tables below, by year: 2020 Temporary Distribution Microgrid available to operate in 2020 Number of 2020 PSPS events supported Approx. % of service pts energized per 2020 PSPS event Birmingham 479 Cullman 11564 Placeville (temporary configuration without a pre-installed interconnection hub) 1487 Clawlake North (temporary configuration without a pre-installed interconnection hub) 1196 Clawlake South (temporary configuration without a pre-installed interconnection hub) 1196 2021 Temporary Distribution Microgrid available to operate in 2021 Number of 2021 PSPS events supported Approx. % of service pts energized per 2021 PSPS event Angren 14 Birmingham 183 Clawlake 1196 Magalia 183 Georgetown 0 n/a Pulaski Place 0 n/a Forsyth 0 n/a Midmore 0 n/a 2022 Temporary Distribution Microgrid available to operate in 2022 Number of 2022 PSPS events supported Approx. % of service pts energized per 2022 PSPS event Angren 0 n/a Birmingham 0 n/a Cullman 0 n/a</p>	Holly Whitham	4/11/2023	4/17/2023	4/17/2023	0	NA	8.1.2.7.2	Grid Design and System Hardening	Temporary Distribution Microgrids

177	CPUC - SPD (Safety Policy Division)	03	CPUC - SPD (Safety Policy Division)_03	5	CPUC - SPD (Safety Policy Division)_03	5	<p>5. Reporting the UC workshop table provided by PG&E 2023-03-27, PG&E_2023_WMP_R0_Appendix D ACI PG&E-22-16_Accord_CONF also a Why does Caltrans "V" Risk Rank (V2) begin at Rank 7 (as opposed to 1) for circuits?</p> <p>Why does it end at 332? </p> <p>Why are the gaps in rank 1-N exist? </p> <p>Why does Column "R" Risk Rank (V3) begin at Rank 6 (as opposed to 1) for circuits? </p> <p>Why does it end at 332? </p> <p>Why are the gaps in rank 1-N exist? </p>	<p>3. There are three primary reasons why the risk ranking does not begin at 1.</p> <p>1. If a circuit segment length is less than 1 mile then these smaller segments are bundled with other larger projects (e.g., the circuit segments that are risk ranked 1, 3, and 5 were all less than 1 mile and bundled with other larger groups of circuit segments)</p> <p>2. Some of the circuit segments are already owned by the owner remaining them of their responsibility to maintain the line but do not take action on these circuits (e.g., the circuit segment that is risk ranked 2 is privately owned)</p> <p>3. Some circuits are in the risk rated work but have been completed by the segment and therefore the circuit segment is not included in planned work in the 2023-2026 work plan (e.g., work on a circuit segment that is risk ranked 3 has already been completed)</p> <p>4. There have approximately 3,800 circuits in the 2023 WORM. The data provided is only for the circuit segments in the current worksheet which represents a subset of the overall 10,000 mile underground program (~2,700 miles) which is only a portion of the overall electric distribution lines in FTED. The Risk Rank (V2) ends at 3328 in the worksheet because not all circuit segments are represented in the 2023-2026 worksheet, including a number of circuit segments that are lower on the risk priority list (3,226-3,800).</p> <p>5. Some circuit segments are not yet included in the 2023-2026 worksheet due to the high efficiency of execution (e.g., circuit segment with risk rank 6 is bundled with three other segments with high execution difficulty such that they are not yet scored in the 2023-2026 worksheet).</p> <p>6. PG&E has approximately 1,600 circuits identified in the FTED as part of the 2023 WORM. The data provided is only for the circuit segments in the current worksheet which represents a subset of the overall 10,000 mile underground program (~2,700 miles) which is only a portion of the overall electric distribution lines in FTED. The Risk Rank (V3) ends at 3328 in the worksheet because not all circuit segments are represented in the 2023-2026 worksheet, including a number of circuit segments that are lower on the risk priority list (3,264-3,800).</p> <p>7. Please see responses to subpart a).</p>	Kevin Miller	4/12/2023	4/19/2023	4/19/2023	0	NA	Appendix D	Area for Continued Improvement	ACI PG&E-22-16 - Progress and Updates on Underground and Risk Prioritization
71	OEIS	001	OEIS_001	3	BUPP	OEIS_001_Q3 BUPP	<p>Regarding PG&E's Focused Tree Inspections plot:</p> <p>a. Describe the current state of development for the plot area, PG&E's Areas of Concern (AOC), and "yields" where focused vegetation inspection can be evaluated to determine appropriate courses to prioritize plots?" (page 22) and the expected timeline for implementation.</p> <p>b. Detail the criteria PG&E has and is using to develop the plot area, PG&E's Areas of Concern (AOC), and "yields" where focused vegetation inspection can be evaluated to determine appropriate courses to prioritize plots?" (page 22)</p> <p>c. What standards, processes, procedures, and tools are vegetation management personnel using/will use to perform tree risk assessments for the plot?</p> <p>d. Will PG&E be using the One 'M' Tool for recordkeeping for this plot? If not, what system will PG&E use for recording yields for this plot?</p> <p>e. When is PG&E conducting Focused Tree Inspections (FTI)? PG&E has not yet begun the plot, where will PG&E be conducting its Focused Tree Inspections plot?</p> <p>f. How many circuit miles are in scope for the plot?</p> <p>g. Will the plot area previously include or Enhance Vegetation Management (EVM)?</p> <p>h. For each Circuit Protection Zone (CPZ) area provide the:</p> <p>1. CPZ name.</p> <p>2. Tree Weighted Risk Score from PG&E's most recent version of its EVM Tree-Weighted Prioritization List.</p> <p>3. Tree Weighted Risk Score from PG&E's most recent version of its EVM Tree-Weighted Prioritization List.</p> <p>4. Risk Tier</p> <p>5. Does PG&E have a plan to continue its Focused Tree Inspections against the plot in success? If so, detail these plans, including how many circuit miles PG&E plans to inspect under the program in 2023 and 2024.</p> <p>6. Provide a GIS layer of the plot area, PG&E's Areas of Concern (AOC), and "yields" where focused vegetation inspection can be evaluated to determine appropriate courses to prioritize plots?" (page 22). As applicable, provide the following attributes for each project:</p> <p>Number of overhead circuit miles within the project.</p> <p>i. Overall Utility Risk</p> <p>ii. Ignition Risk</p> <p>iii. PSPS Risk</p> <p>iv. Contact from Vegetation Likelihood of Ignition</p>	<p>1) 2023 development of Areas of Concern (AOC) used WORM to fit priority CPZs to inform the plot areas selected. In the four ACZ selected for plots there are 31 CPZs. Total of 22 CPZs remain in WORM as of end of 2022 and end of 2023. WORMs are available to accurately show where CPZs do not have EVM Tree Weighted Risk Scores or Ranking. These WORMs are due to contact configuration and/or operating number changes that do not allow for available EVM Tree Weighted Risk Scores and EVM Tree Weighted Risk Scores are provided in the table below.</p>	Colin Lang	4/5/2023	4/19/2023	4/19/2023	0	NA	8.2.2.5	Vegetation Management and Inspections	Focused Tree Inspections
156	CalPA	Set WMP-16	CalPA_Set WMP-16	1	CalPA_Set WMP-16_Q1	<p>Regarding PG&E's SCADA Undergroup (UG) Switches:</p> <p>a) Please explain PG&E's operating procedure for operating a SCADA UG switch to energize and de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after opening a normally closed switch, the switch is returned to its normally closed position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a normally open switch, the switch is returned to its normal open position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>1) For distribution operations operating procedures, SCADA (UG) switches when energizing SCADA devices before RT SCADA with load read on SCADA devices before and after de-energizing. Energizing with a SCADA UG switch will have source side protective device releasing relay out, the ground relay will be checked to verify out and come back in with the ground relay, and then the load read will be taken closed. Releasing relay will be checked to verify out and come back in on source side protective device or RT EPPS installed.</p> <p>2) Please reference "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" and "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" for SCADA Undergroup Switching Terminations. Please also reference "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" for SCADA Undergroup Switching Terminations. A separate will be made by closing the normally closed switch and then opening the normally closed switch to separate parallel and return circuit to its normal source. When creating a parallel with releasing and ground relays are not on all protective devices in the parallel path and Bank 1-TCRDS are placed on source. All protective devices are out in following parallel separation. Load reads will be taken before, during, and after the parallel. It should be noted that releasing relays may or may not be read in devices in the parallel path are EPPS installed. EPPS installed devices have releasing relay read out.</p> <p>3) For distribution operations operating procedures, please see the answer to subpart (c). The normally closed switch will be opened to separate the parallel, setups, and load reads, which will be the same as subpart (c).</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	2	NA	8.1.2.2	Grid Design and System Hardware	Underground of Electric Lines and/or Equipment	
157	CalPA	Set WMP-16	CalPA_Set WMP-16	2	CalPA_Set WMP-16_Q2	<p>Regarding PG&E's Load Break Allowance:</p> <p>a) Please explain PG&E's operating procedure for operating a load break allow in a vault to energize or de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after opening a normally closed switch, the switch is returned to its normally closed position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a normally open switch, the switch is returned to its normal open position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>1) For distribution operations operating procedures, if de-energizing or energizing from Load Break allow that are not protected by fuses on the source side, then releasing a relay to first cut or verified out on the source side protective device as well as ground relay verified out. In following the source side protective setup (including relay control ground relay release), the work is then given to the field operators to then manually remove or place load break allow to de-energize/energize circuit segment. De-energizing allows will be placed on installed start off and protective equipment installed. To energize, relays, protective equipment is removed, and load break allow is returned to operating procedure. Once operation is complete, relays are then placed to their previous state.</p> <p>2) Please reference "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" and "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" for Load Break Allowance. Protection schemes for a parallel have ground and releasing relay cut out, as well as any fuses in the path bypassed. Before closing load break allow in a vault, while still in parallel, ground relays must be cut in, releasing relays verified out out, and then the work will be given to the field to perform the operation of closing the load break allow on the load. The normally closed device will then be opened to separate the loop. Relays will then be placed in their proper configuration to address the current parallel, and then parallel will be separated and relays and fuses placed into their beginning state, allowing the circuit normal. If a parallel is needed (i.e., only one circuit involved), isolated the source side protective device's releasing relay and verify the ground relay is out. System buses before closing on a loop, and then open the normally closed device to separate the loop. Protective schemes will be then placed in their previous state.</p> <p>3) For distribution operations operating procedures, please see the answer to subpart (c). The process is the same for opening a load break allow when placing circuit normal using a larger parallel path. More than one circuit involved, and creating a load loop to address load break allow on an already energized segment of the.</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.3	Grid Design and System Hardware	Motor Switch Operator Switch Replacement	
158	CalPA	Set WMP-16	CalPA_Set WMP-16	3	CalPA_Set WMP-16_Q3	<p>Regarding PG&E's Junction Boxes:</p> <p>a) Please explain in detail PG&E's operating procedure for operating a junction box in a vault to energize or de-energize a circuit or circuit segment.</p> <p>b) Please provide PG&E's written procedures or other documentation related to your response to part (a).</p> <p>c) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after opening a normally closed switch, the switch is returned to its normally closed position during switching.</p> <p>d) Please explain in detail PG&E's operating procedure, from start to finish, for the following operation: after closing a normally open switch, the switch is returned to its normal open position during switching.</p>	<p>The confidential attachments are being provided pursuant to the accompanying confidentiality declaration.</p> <p>1) For distribution operations operating procedures, junction boxes are contain either Load Break allow or de-energize circuit segments. For Load break operations, see the responses to question 2 of this data request set. Dead Break allow cannot be used to energize or de-energize circuit segments. Dead break allows are only to be opened or closed on a de-energized circuit segment after checking the cables are de-energized.</p> <p>2) Please reference "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" and "WMP_Discussion2023_DR_California_016-0001A48AC2CONF.pdf" for Junction Boxes. Protection schemes for a parallel have ground and releasing relay cut out, as well as any fuses in the path bypassed. Before closing load break allow in a vault, while still in parallel, ground relays must be cut in, releasing relays verified out out, and then the work will be given to the field to perform the operation of closing the load break allow on the load. The normally closed device will then be opened to separate the loop. Relays will then be placed in their proper configuration to address the current parallel, and then parallel will be separated and relays and fuses placed into their beginning state, allowing the circuit normal. If a parallel is needed (i.e., only one circuit involved), isolated the source side protective device's releasing relay and verify the ground relay is out. System buses before closing on a loop, and then open the normally closed device to separate the loop. Protective schemes will be then placed in their previous state.</p> <p>3) For distribution operations operating procedures, please see the answer to subpart (c). The process is the same for opening a load break allow when placing circuit normal using a larger parallel path. More than one circuit involved, and creating a load loop to address load break allow on an already energized segment of the.</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.10	Grid Design and System Hardware	Other Grid Topology Improvements to Mitigate Risk of Ignition	
159	CalPA	Set WMP-16	CalPA_Set WMP-16	4	CalPA_Set WMP-16_Q4	<p>Regarding PG&E's selection criteria for when to install the following equipment on underground circuits:</p> <p>a) SCADA UG switches</p> <p>b) Junction boxes</p> <p>c) Load break allow</p>	<p>SCADA Undergroup switches are typically only installed at metering interlocks. The SCADA switches will have up to 10 positions enabled with SCADA due to the space constraints on the top of the switch. Additionally, a communications signal to enable SCADA is not always available at the location where we would otherwise like to install a SCADA-enabled switch. While SCADA-enabled switches are preferred in these locations (metering interlocks where communication is available), it is the discretion of the Electric Distribution Planning Engineer to specify the appropriate device as part of the project design.</p> <p>1) A metering junction in the connection of multiple 600A separate conductors fed together in a surface enclosure and mounted on a wall of the enclosure. This connection could also include a 200A allow mounted on the wall to feed a nearby meter and the POSE typically designs the underground system with there is a switching device at every other enclosure, allowing the use of a single junction in between. (Technically speaking, this design approach is due to the 600A single junction (also called a "metering").</p> <p>2) Using a dead-break device requiring a clearance to open.</p> <p>3) A single junction is typically a dead-break allow installed as a bus mounted on the wall of a surface enclosure. These can be 3-way or 4-way connections. These junctions are typically designed to be back-to-back on 200A radial systems and are not a preferred connection for 200A taps, but they can be used to serve a single transformer on a loop system. If it is more cost efficient than tapping and are not a transformer. In some cases, the 200A junction can also be installed (installed inside a pad-mounted enclosure).</p> <p>4) The use of 200A Load-Break (LB) allow is required when terminating 200A cable (ending the cable run) generally into a piece of equipment like a transformer on all subsurface installations installed that are 200A. The use of 200A LB allows has been required for terminating 200A cables on most new pad-mounted installations since the early 1990s. To prevent the risk when performing work on existing underground installations that involve the replacement of existing 200A Dead Break (DB) allows, it may be feasible to convert 200A DBs to LBs. The overall height of the 200A-way LB allow is 10" taller than existing DB allows and the enclosure will be taller. The enclosure must be able to accurately closed when cables are placed on an insulated or grounded (LB) in the enclosure. In the cases where a LB allow cannot fit safely in the existing enclosure, DB allows are approved for use.</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2	Grid Design and System Hardware	Other Grid Topology Improvements to Mitigate Risk of Ignition	
200	CalPA	Set WMP-16	CalPA_Set WMP-16	5	CalPA_Set WMP-16_Q5	<p>Please explain PG&E's selection criteria for when to install the following equipment on underground circuits:</p> <p>a) Pad-mounted transformers</p> <p>b) Subsurface transformers</p>	<p>1) PG&E's standard is to install pad-mounted transformers on underground circuits where transformers are used. See the responses to subpart (a) for when a pad-mount may be used in lieu of a substation transformer, and prefer to install pad-mounted transformers in the street trenches, easements or the street frontage, easements or right-of-way areas for multiple customers or on the customer's property for a single service. For non-residential customers, the preference is to install pad-mounted transformers in the street trenches, easements or the street frontage, easements or the right-of-way areas for multiple customers or on the customer's property for a single service. For non-residential customers, the preference is to install pad-mounted transformers in the street trenches, easements or the street frontage, easements or the right-of-way areas for multiple customers or on the customer's property for a single service.</p> <p>2) Subsurface transformers are typically not installed unless it is required to support equipment, there is no space available for a pad-mounted transformer to be installed, or if a different transformer is required. Subsurface transformers are not preferred unless there is no space available for a pad-mounted transformer located in an enclosure where the air circulation is restricted such that the ambient temperature is high such as in the Central Valley or some of the FTED areas that see high temperatures. They may be used in a subsurface location where the ambient temperature is high such as in the Central Valley or some of the FTED areas that see high temperatures that influence the side of the transformer may limit the option of installing a surface transformer.</p> <p>3) On the customer's property back a sidewalk.</p> <p>4. In the street trench, easement or the street frontage, easements or the right-of-way areas for multiple customers or on the customer's property for a single service.</p> <p>5. In the sidewalk.</p> <p>6. In the street trench, easement or the street frontage, easements or the right-of-way areas for multiple customers or on the customer's property for a single service.</p> <p>7. In the parking / shoulder area of a street.</p> <p>8. In the right-of-way portion of the street.</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.2	Grid Design and System Hardware	Underground of Electric Lines and/or Equipment	
201	CalPA	Set WMP-16	CalPA_Set WMP-16	6	CalPA_Set WMP-16_Q6	<p>For each of the underground projects that PG&E has planned for 2023, please answer the following questions:</p> <p>a) How many SCADA underground switches will be installed?</p> <p>b) How many overhead switches will be removed?</p> <p>c) How many in switches to adjacent circuits currently exist?</p> <p>d) How many OH switches to adjacent circuits will be removed?</p> <p>e) How many in switches (OH or UG) will exist when the project is complete?</p> <p>f) How many SCADA overhead switches will be installed?</p> <p>g) How many SCADA underground switches will be installed as points to adjacent circuits?</p> <p>h) How many pad-mounted transformers will be installed?</p> <p>i) How many subsurface transformers will be installed?</p> <p>j) How many pad-mounted transformers will be removed?</p> <p>k) How many vaults will be installed?</p> <p>l) How many junction boxes will be installed?</p> <p>m) How many junction boxes will be installed for deadening?</p> <p>n) How many junction boxes will be installed for deadening?</p> <p>o) How many load break allow will be installed?</p> <p>p) How many load break allow will be installed for deadening?</p> <p>q) How many load break allow will be installed as points to adjacent circuits?</p> <p>r) How many vaults will be installed?</p> <p>s) How many vaults will be installed?</p>	<p>PG&E objects to this request as overbearing and unduly burdensome. We do not maintain the requested information in a manner that allows it to be aggregated without a manual review of each project's engineering and construction documentation. Manually collecting the data across thousands of projects would require significant time and resources and the development of multiple processes to ensure data accuracy. If you would like to discuss this request further, please feel free to reach out to us.</p>	Holly Whitham	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.2	Grid Design and System Hardware	Underground of Electric Lines and/or Equipment	

202	CaPA	Set WMP-16	CaPA_Set WMP-16	7	CaPA_Set WMP-16_Q7	<p>For each of the underground projects that PG&E has planned for 2024, please answer the following questions for each project:</p> <p>a) How many SCADA underground switches will be installed in each circuit? b) How many overhead switches will be removed? c) How many CHs will be installed to adjust circuit current? d) How many CHs will be installed to adjust circuit voltage? e) How many to switch (CH or UG) will exist when the project is complete? f) How many SCADA overhead switches will be removed? g) How many SCADA underground switches will be installed as tie points to adjacent circuits? h) How many SCADA underground switches will be installed for sectionalizing? i) How many substation transformers will be installed? j) How many overhead switches will be installed for sectionalizing? k) How many tie lines will be installed? l) How many junction boxes will be installed for sectionalizing? m) How many load break elbows will be installed as tie points to adjacent circuits? n) How many load break elbows will be installed? o) How many load break elbows will be installed for sectionalizing? p) How many load break elbows will be installed as tie points to adjacent circuits? q) How many load break elbows will be installed as tie points to adjacent circuits? r) How many load break elbows will be installed as tie points to adjacent circuits? s) How many load break elbows will be installed as tie points to adjacent circuits? t) How many load break elbows will be installed as tie points to adjacent circuits? u) How many load break elbows will be installed as tie points to adjacent circuits? v) How many load break elbows will be installed as tie points to adjacent circuits? w) How many load break elbows will be installed as tie points to adjacent circuits? x) How many load break elbows will be installed as tie points to adjacent circuits? y) How many load break elbows will be installed as tie points to adjacent circuits? z) How many load break elbows will be installed as tie points to adjacent circuits?</p>	Holly Whitman	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.2	Grid Design and System Planning	Undergrounding of Electric Lines and Voltage Equipment
204	CaPA	Set WMP-16	CaPA_Set WMP-16	9	CaPA_Set WMP-16_Q9	<p>8.1.2.10 - Other Grid Topology Improvements to Minimize Risk of Ignitions</p> <p>8.1.2.10.1 - Covered Conductor Detection Device</p> <p>PG 374.375 of PG&E's WMP states: "Installation of CDD on existing, new, and retrofitted recloser controllers is expected to reduce the number of ignitions due to high impedance in-ground faults by quickly detecting and de-energizing the fault, which is the primary existing gap in EPSS protection on primary overhead distribution conductors. Approximately half of the CDD-replaceable ignitions in HT/DT that occurred in 2022 while EPSS was enabled were the result of high-impedance faults."</p> <p>a) Explain how CDD technology can mitigate this gap to encompass all high impedance faults. b) List the advantages of having both programs working simultaneously. c) What percentage of high-impedance faults does PG&E anticipate could be mitigated by EPSS alone? d) What percentage of high-impedance faults does PG&E anticipate could be mitigated by CDD alone? e) What percentage of high-impedance faults does PG&E anticipate could be mitigated by the combination of EPSS and CDD? f) Based upon limited field experience and post-event data analysis, we estimate that incrementally approximately 25% of all 2022 EPSS high impedance line to ground fault incidents could have been avoided by CDD.</p>	Holly Whitman	4/18/2023	4/21/2023	4/21/2023	0	NA	8.1.2.10	Grid Design and System Planning	Other Grid Topology Improvements to Minimize Risk of Ignitions
205	CaPA	Set WMP-16	CaPA_Set WMP-16	10	CaPA_Set WMP-16_Q10	<p>Please provide an Excel sheet listing each circuit (in its own row) that next circuit outages that occurred from 2020 to 2022 in any HT or LV area. A circuit outage is when the Substation circuit breaker trips and de-energizes the entire circuit due to a fault. For each circuit with an outage, the Excel sheet should be updated as each Circuit Change as a row. Please provide the following additional information (in columns):</p> <p>a) ID number of the circuit affected. b) The size of the outage c) For all equipment failure outages, please state the specific type of failure (i.e., OH transformer failure, overhead wire issue, UG transformer failure, cable failure, splice failure, etc.) d) The outage duration in minutes e) The total number of customers impacted. f) If all or part of the circuit is currently undergrounded, provide the date that OH to UG conversion was completed (if all or part of the circuit is in scope of a planned undergrounding project, the forecast completion date of the OH to UG conversion project).</p>	Holly Whitman	4/18/2023	4/21/2023	4/21/2023	1	NA	QDR	NA	NA
12	MGRA	Data Request No. 1	MGRA_Data Request No. 1	9	SLPP	<p>MGRA_Data Request No. 1_Q9 SLPP</p> <p>Please provide a brief narrative identifying critical-risk level using the methodology provided in the WMP. a) Independent probability and consequence layers exist, please provide these independently as well. b) Regarding Comprehensive System Diagram for All Risk Models Used Provide comprehensive system diagrams in MS Visio or PPT for all risk models. 1. A comprehensive diagram for operational models 2. A comprehensive diagram for planning models Section 1.2 Summary of Risk Models, asks for a summary of risk models in table form with specific fields. Section 2.1 Risk and Risk Component Identification, asks for a chart that demonstrates the components of overall utility risk. The request is comprehensive of all models that work together in the Decision-Making Framework (DMF). The requested diagram should show: a. Interaction between the models presented graphically (e.g., inputs and outputs coming to and going from models to other models). b. Organization with the use of swimlanes where applicable. c. Starting and ending points. d. Decisions and process flows. e. Use of a legend and colors to clearly distinguish input types and model-to-model interactions, and f. The full scope of models, actions, swimmers, and complex feedbacks for model adjustments and the actions.</p>	Joseph Mitchell	3/9/2023	4/21/2023	4/21/2023	1	NA	6.4	Risk Methodology and Assessment	Risk Analysis Results and Prioritization
76	OEIS	001	OEIS_001	8	OEIS_001_Q8	<p>Request a comprehensive set of all models that work together in the Decision-Making Framework (DMF). The requested diagram should show: a. Interaction between the models presented graphically (e.g., inputs and outputs coming to and going from models to other models). b. Organization with the use of swimlanes where applicable. c. Starting and ending points. d. Decisions and process flows. e. Use of a legend and colors to clearly distinguish input types and model-to-model interactions, and f. The full scope of models, actions, swimmers, and complex feedbacks for model adjustments and the actions.</p>	Colin Lang	4/5/2023	4/24/2023	4/24/2023	1	NA	6.1.2	Risk Methodology and Assessment	Summary of Risk Models
207	MGRA	Data Request No. 2	MGRA_Data Request No. 2	1	MGRA_Data Request No. 2_Q1	<p>With regard to PG&E's response to CaPA_Set WMP-11_Q14, PG&E states that one of the significant changes to the grid required for REFL is "the replacement of all direct bury underground cable". Please explain the incompressibility of all direct bury underground cable with REFL.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Rapid Earth Fault Current Limit
208	MGRA	Data Request No. 2	MGRA_Data Request No. 2	2	MGRA_Data Request No. 2_Q2	<p>With regard to PG&E's response to CaPA_Set WMP-11_Q14, PG&E states that one of the significant changes to the grid required for REFL is "the replacement of all direct bury underground cable". Does PG&E have any recently undergrounded segments that are also "direct bury" if so would these be incompressible with REFL?</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Rapid Earth Fault Current Limit
209	MGRA	Data Request No. 2	MGRA_Data Request No. 2	3	MGRA_Data Request No. 2_Q3	<p>With regard to PG&E's response to CaPA_Set WMP-11_Q14, PG&E states that one of the significant changes to the grid required for REFL is "the replacement of all direct bury underground cable". Does PG&E have any recently undergrounded segments that are also "direct bury" if so would these be incompressible with REFL?</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Rapid Earth Fault Current Limit
210	MGRA	Data Request No. 2	MGRA_Data Request No. 2	4	MGRA_Data Request No. 2_Q4	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q07A04KCCDF.pdf</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	NA	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definition	Detailed Model Documentation
211	MGRA	Data Request No. 2	MGRA_Data Request No. 2	5	MGRA_Data Request No. 2_Q5	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q07A04KCCDF.pdf</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	NA	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definition	Detailed Model Documentation
212	MGRA	Data Request No. 2	MGRA_Data Request No. 2	6	MGRA_Data Request No. 2_Q6	<p>Please provide non-confidential versions of the following documents: WMP-Discovery2023_DR_OEIS_001-Q07A04KCCDF.pdf</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	NA	Appendix B	Supporting Documentation for Risk Methodology and Assessment Definition	Detailed Model Documentation
213	MGRA	Data Request No. 2	MGRA_Data Request No. 2	7	MGRA_Data Request No. 2_Q7	<p>Please provide a GIS file of 2022 outages occurring on circuits where EPSS was enabled.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
214	MGRA	Data Request No. 2	MGRA_Data Request No. 2	8	MGRA_Data Request No. 2_Q8	<p>Please provide a GIS file of 2022 ignitions occurring on circuits where EPSS was enabled.</p>	Joseph Mitchell	4/20/2023	4/25/2023	4/25/2023	1	NA	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
215	OEIS	003	OEIS_003	1	OEIS_003_Q1	<p>On page 624, PG&E states it "is currently working with internal and external stakeholders, including CalCES, to develop and implement activities that meet emergency response requirements to CRIC General Order (GO) 166. Standards for Operation, Reliability, and Safety During Emergencies and Disasters." a) List and describe the referenced activities. b) Explain how each listed activity exceeds GO 166.</p>	Colin Lang	4/21/2023	4/26/2023	4/26/2023	0	NA	8.4.1.1	Emergency Preparedness	Objectives

299	MGRA	Data Request No. 4	MGRA_Data Request No. 4	6	MGRA_Data Request No. 4_O6	If the risk score for each polygon represents an average risk in the polygon, please provide an additional version in which the maximum numerical value in the polygon is provided instead.	As described in section 8.2.3, pages 171 and 172 in PG&E's 2023-2025 WMP, the plant level risk value is the product of the cumulative probability of all risk drivers in that area and the wildfire consequence. As such, the value is not an average over a risk in a polygon.	Joseph Mitchell	4/28/2023	5/3/2023	5/9/2023	0	NA	Appendix C/E.4.1.1, E.4.1.2	Risk Methodology and Assessment	Geospatial Maps of Top Risk Areas Within the FRTD
301	MGRA	Data Request No. 4	MGRA_Data Request No. 4	8	MGRA_Data Request No. 4_O8	Please provide an excel spreadsheet giving the Distribution Diagram ID for each outage occurring while EPSS was enabled in 2022.	Please see "WMP-Discovery2023_DR_MGRA_04-0006A01.xlsx"	Joseph Mitchell	4/28/2023	5/3/2023	5/9/2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
302	TURN	010	TURN_010	1	TURN_010_Q1	PG&E's WMP (R1) at page 3 states PG&E undergrounded 180 miles in 2022 and 73 miles in 2021. In each of these years, separately, please provide the number of overhead miles that were converted to underground related to these mileage figures.	PG&E's WMP (R1) at page 4 states "Between 2023 and 2028, 87 percent of PG&E's undergrounding work is planned for the replacement of overhead circuit segments, as identified by our studies." a. Please provide workpapers and data in Excel that supports that 87 percent figure. b. Please explain what "top 20 percent of risk-ranked circuit segments" means, and reference the data and response in part (a) to show how this is calculated.	Tom Long	4/28/2023	5/3/2023	5/9/2023	0	NA	8.1.2.2	Grid Design, Operations, and Maintenance	Undergrounding
303	TURN	010	TURN_010	2	TURN_010_Q2	PG&E's WMP (R1) at page 4 states "Between 2023 and 2028, 87 percent of PG&E's undergrounding work is planned for the replacement of overhead circuit segments, as identified by our studies." a. Please provide workpapers and data in Excel that supports that 87 percent figure. b. Please explain what "top 20 percent of risk-ranked circuit segments" means, and reference the data and response in part (a) to show how this is calculated.	The contract attachment is being provided pursuant to a signed Non-Discretionary Agreement with PG&E. Please see attachment "WMP-Discovery2023_DR_TURN_010-0006A01CONC.pdf". The "Top 20 Risk-Ranked Circuit Segments" are those selected from the WORN V3 risk model with a V3 Risk Rank greater than 720. Any miles with a V3 Risk Rank greater than 720 that are contained as part of the program would be included inside the Top 20 percent of risk-ranked circuit segments. The "Top 20 Risk-Ranked Circuit Segments" are those selected from the WORN V3 risk model with a V2 Risk Rank of greater than 727. Any miles with a V2 Risk Rank greater than 727 that are contained as part of the program would be included inside the Top 20 percent of risk-ranked circuit segments.	Tom Long	4/28/2023	5/3/2023	5/9/2023	1	Yes	8.1.2.2	Grid Design, Operations, and Maintenance	Undergrounding
304	TURN	010	TURN_010	3	TURN_010_Q3	Following up on the response to TURN-DR-741c, in which TURN asked whether PG&E calculated circuit-segment level RSE for the past and future work shown in Attachment 2023-04-06_PGE_2023_WMP_R2_Section 8.4.2, A001, an earlier version of which is referenced on page 366, 6.77 of the WMP (R1), a "Whether or not CEIS required PG&E to present such circuit-segment level RSEs in the 2023-2025 WMP, has PG&E calculated them? If so, please provide the RSEs, preferably as additional columns in the workbooks provided as A001 to TURN DR 7.2. Please provide all supporting workpapers, calculations, inputs, data, and assumptions regarding these RSE calculations.	As described in our asset retirement responses to TURN Data Request 06, PG&E's Utility Reliability (URF) scores incorporate the elements of RSE calculations with the feasibility element used to modify the asset factor to account for operational and availability factors. Please see attachment "WMP-Discovery2023_DR_TURN_010-0006A01.xlsx" for a list of all circuit segments and their calculated URF scores. Circuit segments without a URF score are not in a FRTD and do not have a score calculated. a. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. b. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. c. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. d. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. e. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. f. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. g. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. h. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. i. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. j. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. k. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. l. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. m. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. n. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. o. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. p. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. q. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. r. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. s. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. t. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. u. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. v. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. w. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. x. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. y. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated. z. Please provide the RSEs for all circuit segments in the FRTD and do not have a score calculated.	Tom Long	4/28/2023	5/3/2023	5/9/2023	1	NA	6.4.2	Risk Methodology and Assessment	Top Risk Contributing Circuit Segments
306	TURN	010	TURN_010	5	TURN_010_Q5	Please provide the number of miles of secondary overhead distribution lines versus primary overhead distribution lines in PG&E's FRTD, and separate for PG&E's self-identified EPSS.	Please see "WMP-Discovery2023_DR_TURN_010-0006A01.xlsx"	Tom Long	4/28/2023	5/3/2023	5/9/2023	1	NA	8.1.2.5	Grid Design and System Hardening	Traditional Overhead Hardening
307	TURN	010	TURN_010	6	TURN_010_Q6	PG&E's WMP (R1) at page 4 states "Recent data and analysis demonstrate that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities." Please provide the recent data, including all supporting documents and quantitative analysis in Excel, that support this statement.	PG&E introduced the comparison of risk reduction and Risk Speed Efficiency (RSE) of EPSS vs EVM in the 2022 WMP and 2023 GRC Supplemental Fing in February 2022. The comparison is described in the 2023 GRC, Exhibit 3 Chapter 4 page 3-2 through 3-7. The updated wildfire mitigation strategy is summarized in Table 3-4 on page 3-10, as the risk reduction relative to spent between EVM and EPSS is substantially in EPSS's favor. a. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. b. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. c. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. d. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. e. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. f. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. g. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. h. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. i. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. j. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. k. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. l. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. m. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. n. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. o. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. p. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. q. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. r. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. s. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. t. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. u. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. v. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. w. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. x. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. y. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities. z. Please provide the recent data and analysis demonstrating that the Enhanced Vegetation Management (EVM) Program risk reduction is less than EPSS and additional Operational Mitigations such as Partial Voltage Detection capabilities.	Tom Long	4/28/2023	5/3/2023	5/9/2023	4	NA	8.2.3	Vegetation Management and Inspections	Vegetation and Fuels Management
308	TURN	010	TURN_010	7	TURN_010_Q7	PG&E WMP (R1) at page 251 states "The type of mitigation tradeoff and effectiveness analysis we conduct informed PG&E's decision to transition away from the Enhanced Vegetation Management (EVM) program." a. Please provide a description of the tradeoff and effectiveness analysis that informed PG&E's decision to transition away from the EVM program. b. Please provide the "effectiveness analysis" conducted by PG&E that informed its decision to discontinue the EVM program. c. Please provide annual total spending on the EVM program from 2018-2022.	As described in our asset retirement responses to TURN Data Request 06, PG&E's Utility Reliability (URF) scores incorporate the elements of RSE calculations with the feasibility element used to modify the asset factor to account for operational and availability factors. Please see attachment "WMP-Discovery2023_DR_TURN_010-0006A01CONC.pdf" sent by VM Program Communications on October 20, 2022 referencing end of EVM at the end of 2022. An A/E/C team called on October 20, 2022. PG&E informed staff that due to the end of the Enhanced Vegetation Management (EVM) Program by year's end, PG&E has eliminated EVM program's mandatory transfer and evaluations. a. Please see "WMP-Discovery2023_DR_TURN_010-0007A01.pdf" and "WMP-Discovery2023_DR_TURN_010-0007A02.pdf" that were performed by PG&E in response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. b. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. c. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. d. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. e. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. f. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. g. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. h. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. i. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. j. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. k. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. l. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. m. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. n. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. o. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. p. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. q. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. r. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. s. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. t. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. u. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. v. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. w. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. x. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. y. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. z. Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022.	Tom Long	4/28/2023	5/3/2023	5/9/2023	3	Yes	8.2.3	Vegetation Management and Inspections	Vegetation and Fuels Management
275	CaPA	Set WMP-20	CaPA_Set WMP-20	1	CaPA_Set WMP-20_Q1	a) Describe PG&E's standard process for retiring an asset from service. b) Describe how PG&E records the retirement of an asset from service.	i) Decision to retire an asset and "retire" it from service are driven by various factors such as asset risk, condition, design standards, and capacity needs, and are determined by the asset managers of each asset family. Different programs establish similar processes for making decisions on when to retire an asset from service. As an example, in our distribution system hardening and the undergrounding program, PG&E follows TD-000101 Chapter 15 requirements attached as "WMP-Discovery2023_DR_CaPA_CapEx_020-0001A01CONC.pdf". The overhead assets are therefore retired when they are replaced with new, hardened assets (either overhead or underground) based on PG&E's determination driven from the wildfire distribution risk model as described in the WMP. ii) To record the retirement of the assets removed from the field as described in response to subpart (a), the retired assets are administratively removed from the inventory portion of PG&E's asset registry and work management system and placed in an archive partition within the work management system where they can be accessed for reference only. iii) When an asset is retired from service due to replacement or removal, PG&E has an as-built process to document the work completed in the field, including removal of a pre-existing asset. As a part of this process, as-built may be work verified, retired (modified from the original project design), submitted for recording for certain asset types, and recorded in PG&E's system of record.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	1	NA	8.1.5	Asset Management and Inspection Enterprise Systems)	NA
276	CaPA	Set WMP-20	CaPA_Set WMP-20	2	CaPA_Set WMP-20_Q2	a) In 2022, as part of its WMP system hardening activities, did PG&E retire from service (i.e., replace, remove, destroy, or decommission) any assets that had not been fully depreciated at the time of retirement? b) Please describe how PG&E recorded the retirement of assets during 2022 system hardening activities.	i) Not applicable. The assets retired as part of WMP system hardening activities (electrical distribution overhead assets) follow group depreciation and retirement accounting. As such, there is no unrecorded value for the assets that were retired. Please refer to our response to Question 005, Subpart (a) for additional information on group depreciation and retirement accounting. ii) Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. iii) Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	0	NA	8.1.2	Grid Design and System Hardening	All
277	CaPA	Set WMP-20	CaPA_Set WMP-20	3	CaPA_Set WMP-20_Q3	a) In 2023, as part of its WMP system hardening activities, did PG&E retire from service (i.e., replace, remove, destroy, or decommission) any assets that had not been fully depreciated at the time of retirement? b) Please describe how PG&E recorded the retirement of assets during 2023 system hardening activities.	i) Not applicable. The assets retired as part of WMP system hardening activities in 2023 follow group depreciation and retirement accounting. As such, there is no unrecorded value of the assets that will be retired. Please refer to our response to Question 005, Subpart (a) for additional information on group depreciation and retirement accounting. ii) Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022. iii) Please see the response to Question 001, Subpart (a) - (i) of this Data Request for 2019-2022.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	0	NA	8.1.2	Grid Design and System Hardening	All
278	CaPA	Set WMP-20	CaPA_Set WMP-20	4	CaPA_Set WMP-20_Q4	a) What is PG&E's standard practice for tracking assets that are retired from service before they are fully depreciated?	Please see the response to Question 001, Subpart (a) for information regarding the tracking of PG&E's retired assets. Please see also Question 005, Subpart (a) for information on group depreciation and retirement accounting, as established by the CPUC, FERC, and the National Association of Regulatory Utility Commissioners (NARUC). b) The premise of this question is incorrect. PG&E follows group depreciation and retirement accounting, as established by the CPUC, FERC, and the National Association of Regulatory Utility Commissioners (NARUC). Group depreciation accounting refers to the well-established regulatory accounting method for large groups of homogeneous assets. The premise of group depreciation accounting principles (which may be referred to as "mass asset accounting" or "group depreciation") is that assets retired are deemed fully depreciated at the time of retirement, and hence their value in rate base goes forward to zero. As such, there is no unrecorded value of WMP assets retired. PG&E follows group depreciation practices, which are based on the average service life of elements of plant and equipment. The average life takes into account the ages of assets whenever they retire (are removed from service) and computes the average. The average itself is a recognition that some retirements occur before the average service life and others after. c) PG&E complies with the requirements of the FERC Code of Federal Regulations (CFR) Uniform System of Accounts when retiring assets. Title 18, Part 101 of the CFR states in its Electric Plan Instruction, section 105(b), that "the book cost of the unit retired is credited to the plant account and debited to the accumulated depreciation for depreciation. This then is an increase in rate base when plant is retired." d) The Commission's Standard Practice L14, Determination of Straight-Line Remaining Life Depreciation Accruals (SP L14), dated January 3, 1981, provides the same accounting treatment for retirements. (SP L14, 5, D, 1, 4.1) Authorized depreciation expense is calculated with the understanding that unrecorded depreciation expense due to earlier retirements is made up by depreciation expense on other units which outlive the average service life of an asset. As later explained in the Commission's SP L14, "group accounting" of units having like material characteristics or all units of an account are considered together. Accruals for the group are based on composite or weighted average values of salvage and service life expectancy. The resulting values are applied to the remaining plant balances each year or each accounting period. A deficiency due to early retirement of a unit is made up by the average service life of other units.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	0	NA	8.1.5	Asset Management and Inspection Enterprise Systems)	NA
279	CaPA	Set WMP-20	CaPA_Set WMP-20	5	CaPA_Set WMP-20_Q5	a) If PG&E retires from service an asset that has not been fully depreciated, does it remove the remaining unrecorded value of the asset from its rate base? b) How does PG&E determine the remaining unrecorded value of an asset that has not been fully depreciated? c) Please describe any scenario in which PG&E would retire from service an asset that has not been fully depreciated, but would keep the remaining unrecorded value of the asset in its rate base.	Please see the response to Question 001, Subpart (a) for information regarding the tracking of PG&E's retired assets. Please see also Question 005, Subpart (a) for information on group depreciation and retirement accounting, as established by the CPUC, FERC, and the National Association of Regulatory Utility Commissioners (NARUC). a) The premise of this question is incorrect. PG&E follows group depreciation and retirement accounting, as established by the CPUC, FERC, and the National Association of Regulatory Utility Commissioners (NARUC). Group depreciation accounting refers to the well-established regulatory accounting method for large groups of homogeneous assets. The premise of group depreciation accounting principles (which may be referred to as "mass asset accounting" or "group depreciation") is that assets retired are deemed fully depreciated at the time of retirement, and hence their value in rate base goes forward to zero. As such, there is no unrecorded value of WMP assets retired. PG&E follows group depreciation practices, which are based on the average service life of elements of plant and equipment. The average life takes into account the ages of assets whenever they retire (are removed from service) and computes the average. The average itself is a recognition that some retirements occur before the average service life and others after. b) PG&E complies with the requirements of the FERC Code of Federal Regulations (CFR) Uniform System of Accounts when retiring assets. Title 18, Part 101 of the CFR states in its Electric Plan Instruction, section 105(b), that "the book cost of the unit retired is credited to the plant account and debited to the accumulated depreciation for depreciation. This then is an increase in rate base when plant is retired." c) The Commission's Standard Practice L14, Determination of Straight-Line Remaining Life Depreciation Accruals (SP L14), dated January 3, 1981, provides the same accounting treatment for retirements. (SP L14, 5, D, 1, 4.1) Authorized depreciation expense is calculated with the understanding that unrecorded depreciation expense due to earlier retirements is made up by depreciation expense on other units which outlive the average service life of an asset. As later explained in the Commission's SP L14, "group accounting" of units having like material characteristics or all units of an account are considered together. Accruals for the group are based on composite or weighted average values of salvage and service life expectancy. The resulting values are applied to the remaining plant balances each year or each accounting period. A deficiency due to early retirement of a unit is made up by the average service life of other units.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	0	NA	8.1.5	Asset Management and Inspection Enterprise Systems)	NA
280	CaPA	Set WMP-20	CaPA_Set WMP-20	6	CaPA_Set WMP-20_Q6	a) As of the date of this data request, does PG&E's rate base currently include any portion of the value of any assets that are no longer in service? b) If the answer to part (a) is yes, please explain why. c) If the answer to part (a) is no, list the controls in place that ensure PG&E's rate base does not currently include any portion of the value of assets that are no longer in service.	i) Not applicable, as described in subpart (a) of this response. ii) PG&E follows group depreciation and retirement accounting established by the CPUC, FERC, and the National Association of Regulatory Utility Commissioners (NARUC). As such, there is no unrecorded value of WMP retired assets in the rate base of required controls. Please see the response to Question 005, Subpart (a), for additional information.	Holly Wehman	4/26/2023	5/3/2023	5/9/2023	0	NA	8.1.5	Asset Management and Inspection Enterprise Systems)	NA

395	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	2	CPUC - SPD (Safety Policy Division)_009	20) Page 646 of its 2023 WMP PG&E states there has been a "Redundant and non-essential" of PSPS events and "This is an indicator of increased operational maturity, flexibility, and system resilience." a) Is that claim directed toward PSPS? b) If yes, in what way is it not at least in part or perhaps implied, that PG&E's increased operational maturity, flexibility, and resilience is also relying on other processes such as EPSS (last year)?	<p>a. Yes, the statement is directed towards PSPS.</p> <p>b. No, EPSS operates independently of and is based on different criteria and thresholds designed to mitigate hazards and threats that can lead to risks of ignition and fire under non-PSPS conditions. See PG&E's 2023 WMP, Section 3.1.5 PSPS indicators of operational maturity, flexibility, and system resilience is based on but not limited to:</p> <ul style="list-style-type: none"> Operational Maturity Developed processes in the PSPS decision making process by reviewing information provided by our SMEs and determining when there is an imminent and significant risk of strong winds impacting PG&E assets and a significant risk of large, obstructive wildfires should ignition occur (see section 9.2.3 of PG&E's 2023 WMP). Improved our weather forecasting and scoping capabilities by utilizing Catastrophic Fire Probability models which employ granular scoping processes to significantly reduce the public safety impacts of de-energization by de-energizing smaller segments of the grid within the close confines of the fire critical weather window, rather than de-energizing larger geographic areas. More populated areas (see section 5.1 of PG&E's 2023 WMP). Maximized use of advanced technologies and outreach tools to notify impacted customers of the expected de-energization (see section 8.4.4.2 of PG&E's 2023 WMP). Using an extensive camera, weather station, and satellite weather monitoring network and on-the-ground personnel to collect real-time observations to inform and speed the identification of Weather "All-Clear" times in more precise, smaller areas, to get customers back in service faster (see section 7.3.2.1 of PG&E's 2023 WMP). Reaching and increasing resources for restoration efforts, including use of helicopters and fast wing aircraft to conduct line safety patrols after the Weather "All-Clear", restoring service to safe times as quickly as possible subject to operational safety and ability to access equipment for patrol and any needed repairs (see section 7.3.3.5 of PG&E's 2023 WMP). Supporting vulnerable customers through California Foundation for Independent Living Centers (CFILC) and Community Based Organizations (CBO) resource programs that assist vulnerable customers in obtaining assistance in the Emergency Operations Center (EOC). As such, we are at various stages of training completion. In addition, different problems within the EOC require different levels of training. Some of the courses at the more advanced level are instructor led and offered quarterly. PG&E is increasing the number of instructors this year to be able to increase these offerings in 2024. 	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	9.1.2	Public Safety Power Shutoff	Identification of Frequency De-Energized Circuits																
396	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	3	CPUC - SPD (Safety Policy Division)_009	3) PG&E has less than the required number of personnel with required training for several categories in Table 8-26 PG&E's Personnel Training Programs for Wildfire and PSPS Events. Other risks related to staffing include: for example, all staffing will complete training on time and reasons for not all being completed is the timing of table's required provision. Why are there less than required values of personnel not completing the training?	PG&E has a consistent effort and number of new personnel in its Emergency Operations Center (EOC). As such, we are at various stages of training completion. In addition, different problems within the EOC require different levels of training. Some of the courses at the more advanced level are instructor led and offered quarterly. PG&E is increasing the number of instructors this year to be able to increase these offerings in 2024.	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.18.3	Grid Operations and Procedures	Personnel Work Procedures and Training in Conditions of Elevated Fire Risk																
397	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	4	CPUC - SPD (Safety Policy Division)_009	4) PG&E provides means to verify message receipt in Table 8-49 PG&E's Protocols for Emergency Communication to Stakeholder Groups. How accurate is the receipt information with regard to verifying messages are reaching intended recipient/audience to aid in intended safety outcomes (e.g., including, but not limited to, messages not being sent to a new number or person no longer in the household)?	PG&E is able to verify that a message was delivered to the phone number and/or email address on file for the customer of record associated with the premises identified as requested by a potential PSPS, EPSS outage, and/or outage due to a wildfire. Phone number and/or email address are requested at the time an account is established and are verified when a customer logs into the Account Self Care portal or an email base and/or if a customer speaks with a Contact Center Customer Service Representative (CSR) and has not verified contact information in the past 60 days via CSR. To ensure we have the most updated contact information for customers of record, wildfire safety-related outreach material includes a standard call to action to update contact information. In addition, Business Energy Solutions Account Flaps engage with critical facilities and infrastructure, telecommunications and water providers' transmission level entities in high risk areas and likely to be impacted by PSPS and/or EPSS to verify contact information for the purpose of providing notice and notification. Contact information for CBOs and Paratransit agencies is maintained via a regulatory application used by the AEMV, Outreach Program. For customers that are MBL and/or SV, in addition to specific campaigns via mail and email to encourage contact information updates, we conduct a weekly review to identify customers with either missing or invalid contact information as documented in our Customer Care and Billing System (CCBS). Additionally, we cross-reference contact information submitted through our other program applications (e.g., CARE/FERRA and related) to our daily sync-up process with the CCBS system. These weekly and daily processes are conducted year-round to help ensure the MBL and SV contact information is current. Local and state agencies and first responders are engaged by Local Government Affairs and Public Safety Specialists annually to confirm contact information/identify new contacts for the purposes of public notification.	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.4.4.1	Emergency Preparedness	Protocols for Emergency Communications																
398	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	5	CPUC - SPD (Safety Policy Division)_009	5) PG&E issues notifications to AFNMB stakeholders. How does PG&E know that these notifications are received and that contact information is up to date? a) Does PG&E have a way to continuously/periodically verify that the contact information on file is current to help ensure such important notices are being received by the intended recipient(s)?	Our MBL and SV customers are sent annual communication either by email or a postcard (if an email address is not provided by the customer) between March and August, to reinforce the importance of having up-to-date contact information on file and encourage them to provide an alternative means of contact for PSPS notification. MBL and SV information is updated automatically and in real-time when a customer logs into their PG&E account and updates their information or when it is provided to a PG&E representative. Requests to change contact information can be submitted via multiple channels; therefore, there is no dedicated staffing member or department that represents changes. For example, contact information can be changed by customers via our website, which updates our systems of record directly. To Quality Assurance and Quality Control (QA/QC) the MBL and SV contact information, we conduct a weekly review to identify customers with either missing or invalid contact information as documented in our Customer Care and Billing System (CCBS). Additionally, we cross-reference contact information submitted through our other program applications (e.g., CARE/FERRA and related) to our daily sync-up process with the CCBS system. These weekly and daily processes are conducted year-round to help ensure the MBL and SV contact information is current. PG&E considers PSPS notification for medical baseline customer as "received" if one of the following occurs: Customer answers the phone, text confirmation is received back from the customer, e-mail is opened or a link within the e-mail is clicked, or the customer was successfully contacted during a door-to-door visit.	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.5.3	Community Outreach and Engagement	Engagement With Access and Functional Needs Populations																
399	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	6	CPUC - SPD (Safety Policy Division)_009	6) PG&E mentions pre-pandemic in-person engagement. Does PG&E have data comparing pre-pandemic engagement to pandemic (time/face engagement efforts) and among other things, attendance? For instance, are there metrics/tables regarding non-AFNMB and AFNMB?	For community events and gauging levels of customer attendance/interest, PG&E does not have specific or customer demographic data of the number of attendees at our webinars and town hall events. Registration is optional, and we first the eligibility of customers need to share their personal information (addresses) to receive an invitation. Prior to the pandemic (2019), all regional Safety Town-Halls were conducted in-person. Due to our COVID-19 safety protocols, during and post-pandemic (2020-2023), Regional Town Halls and Safety Webinars were conducted virtually. With that being said, we have been good attendance throughout the first half of 2023 as our attendees have been able to attend our events. The table below provides the attendance of our events by year and the year-over-year percentage change.	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.5.3	Community Outreach and Engagement	Engagement With Access and Functional Needs Populations																
400	CPUC - SPD (Safety Policy Division)	009	CPUC - SPD (Safety Policy Division)_009	7	CPUC - SPD (Safety Policy Division)_009	7) PG&E states that if an AFN customer does not answer the door, the notification is considered successful if a door hanger is left. What industry/professional or PG&E following that classifies a door hanger as a successful notification?	During a PSPS event, medical baseline customers receive automated calls, text and e-mails at the same intervals as the general customer notifications. In addition, these customers receive repeat automated calls and texts at hourly intervals until the customer confirms receipt of the notifications by either answering the phone, responding to the text or opening the email. If confirmation is not received, PG&E representative visits the customer's home to check on the customer in parallel to the continuation of hourly notification retries, related to the "door-hang procedure." If the customer does not answer, a door hanger is left at the home, when possible. PG&E's "door-hang" and "door hanger" process is above and beyond the guidelines set forth in CPUC's decisions under R. 18-12-005. While PG&E has not specifically benchmarked as an industry practice, the three best California CBOs have aligned on this process. The door hanger is considered Successful Notification Delivery but is not confirmed as notification received; other a door hanger is left, these customers will continue to receive hourly texts until they confirm receipt.	Kevin Miller	6/2/2023	6/6/2023	6/7/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.5.3	Community Outreach and Engagement	Engagement With Access and Functional Needs Populations																
372	CPUC - SPD (Safety Policy Division)	005	CPUC - SPD (Safety Policy Division)_005_02	1	CPUC - SPD (Safety Policy Division)_005_02	1) Regarding costs inherent in PG&E's undergrounding grid hardening mitigation initiative projects, used in calculating cost efficiency and project feasibility as described in the 2023-2025 WMP (p. 340 and p. 968), to date and looking forward: a) What was the average cost per circuit mile for undergrounding in 2022, 2021, and 2020, in the HTD, non-HTD, and non-HTD? b) What is the average cost per circuit mile expected in 2023, 2024, and 2025, in the HTD, non-HTD, and non-HTD? c) For inputs a & b, explain expected average year-over-year cost changes.	<p>a. PG&E has the following table for average cost per circuit mile for undergrounding:</p> <table border="1"> <tr> <td>Year</td> <td>Completed</td> </tr> <tr> <td>Base LG Total Cost (Average in \$M)</td> <td>2020 \$6.21 N/A \$6.21</td> </tr> <tr> <td>Fire Hazard LG Total LSC Cost (Average in \$M)</td> <td>2021 \$4.18 \$2.12 \$2.29</td> </tr> <tr> <td>2022 \$4.82 \$2.82 \$2.77</td> </tr> </table> <p>As shown above, the relative costs, particularly the rebuild footprints in the Cedar and North Complex, are more expensive per mile than the base system hardening undergrounding projects because of less administrative and operational constraints in these environments (e.g., expedited timelines, accelerated permitting, geographic targeting).</p> <p>b. The current forecasted average cost per circuit mile for undergrounding, including Fire Hazard and Base LG, is \$2.82 million in 2023, \$3.11 million in 2024, and \$2.96 million in 2025. All planned undergrounding projects are in HTDs or high risk risk areas (HFHA).</p> <p>c. As shown in the responses to subparts a & b, the year-over-year cost has generally decreased, and is expected to further decrease, due to multiple factors as we scale the program, including but not limited to: <ul style="list-style-type: none"> Economies of scale as the program knowledge and familiarity grows with our internal crews, contractors, materials suppliers, designers and many others. Undergrounding process efficiencies through historic learned. Updating standards for design and construction, such as revising the trench depth and width standards to accommodate larger conductors. </p>	Year	Completed	Base LG Total Cost (Average in \$M)	2020 \$6.21 N/A \$6.21	Fire Hazard LG Total LSC Cost (Average in \$M)	2021 \$4.18 \$2.12 \$2.29	2022 \$4.82 \$2.82 \$2.77	Kevin Miller	5/15/2023	6/12/2023	6/12/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	1	NA	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution									
Year	Completed																																
Base LG Total Cost (Average in \$M)	2020 \$6.21 N/A \$6.21																																
Fire Hazard LG Total LSC Cost (Average in \$M)	2021 \$4.18 \$2.12 \$2.29																																
2022 \$4.82 \$2.82 \$2.77																																	
373	CPUC - SPD (Safety Policy Division)	005	CPUC - SPD (Safety Policy Division)_005_02	2	CPUC - SPD (Safety Policy Division)_005_02	2) Provide the utility's cost estimate breakdown for undergrounding per mile. Provide the cost estimate in a commonly used cost-estimating format (e.g., Uniform). If the utility uses a different format, provide internal documentation on that format so SPD can understand the cost estimate.	<p>Please see the following table for each cost component's estimated contribution to the total cost. These estimates are based on actual costs for completed undergrounding projects in 2023 to date. This year's completed projects are PG&E's best currently available representation of the cost-estimating breakdown and is expected to be similar in future years.</p> <table border="1"> <tr> <td>Cost Component</td> <td>Contribution to Total Cost</td> </tr> <tr> <td>Labor (Internal)</td> <td>10%</td> </tr> <tr> <td>Materials</td> <td>15%</td> </tr> <tr> <td>Contractor</td> <td>61%</td> </tr> <tr> <td>Overhead</td> <td>10%</td> </tr> <tr> <td>Other</td> <td>2%</td> </tr> <tr> <td>Financing</td> <td>3%</td> </tr> <tr> <td>100%</td> <td></td> </tr> </table>	Cost Component	Contribution to Total Cost	Labor (Internal)	10%	Materials	15%	Contractor	61%	Overhead	10%	Other	2%	Financing	3%	100%		Kevin Miller	5/15/2023	6/12/2023	6/12/2023	https://www.pge.com/legal/affairs/common-law/affairs/communications/press-releases/2023/06/06/pges-2023-wmp-press-release	0	NA	8.1.2.2	Grid Design and System Hardening	Undergrounding of Electric Lines and/or Equipment - Distribution
Cost Component	Contribution to Total Cost																																
Labor (Internal)	10%																																
Materials	15%																																
Contractor	61%																																
Overhead	10%																																
Other	2%																																
Financing	3%																																
100%																																	

412	CaFA	Set WMP-26	CaFA_Set WMP-26	8	CaFA_Set WMP-26_Q8	Describe the challenges or advantages entailed in increasing load capacity on a circuit that has previously been reviewed with underground conductor.	<p>The challenges or advantages associated with increasing capacity on an underground electric distribution system will differ depending on whether the underground system was built recently or in the past under different engineering and design standards. Based on current design standards and practices, it is likely that several underground projects include physical capacity to support increased load growth in the sense that some conductors or larger cables may have already been installed. However, if load capacity above the design of a recently built underground system is required, then additional cable systems and enclosures would likely need to be installed. In these cases, digging near existing underground infrastructure can be more difficult than installing underground assets in the first place, and finding locations for additional enclosures may be challenging. Lastly, if some limited cases, a higher capacity conductor cannot be pulled through the existing conduit system due to additional load growth without having to do additional trenching or installing additional conduits. If load capacity needs to increase on an underground system that has not been recently engineered and design standards, then any potential challenges would depend on the health of the existing underground system. If the existing conductor is compromised that it may not be possible to pull new cables through the existing conduit, and a more extensive rebuild would be required involving installing new conduit and, potentially, new enclosures as well. If the existing conduit is generally intact, it may be possible to pull new cables through that conduit to replace some load growth without significant rebuild.</p> <p>OC is integrating with execution processes by completing OC on a shorter timeline than has been historically executed, allowing for smaller opportunities for re-training inspectors, sharing learnings, and making corrections, as necessary. By targeting shorter timelines to review and identify issues, PG&E can work with stakeholders who have been recently completed, enabling both more timely corrective actions and additional operational efficiencies (e.g., bringing the prior inspector back to a failed location before the inspector has departed the area).</p> <p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in section (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	7/27/2023	8/10/2023	8/10/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.2.2	Grid Design and System Planning	Underground of Electric Lines and/or Equipment – Distribution
422	CaFA	Set WMP-28	CaFA_Set WMP-28	1	CaFA_Set WMP-28_Q1	Describe the process from start to finish from an CA action that occur prior to a detection, continuing through the inspection, and ending when OC and CA are both complete.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
423	CaFA	Set WMP-28	CaFA_Set WMP-28	2	CaFA_Set WMP-28_Q2	Provide a breakdown of the 500 transmission locations by inspection type. For example, how many of these locations will audit detailed ground inspections, how many will audit aerial inspections, etc.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
424	CaFA	Set WMP-28	CaFA_Set WMP-28	3	CaFA_Set WMP-28_Q3	Provide a breakdown of the 1500 distribution locations by inspection type. For example, how many of these locations will audit detailed ground inspections, how many will audit aerial inspections, etc.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
425	CaFA	Set WMP-28	CaFA_Set WMP-28	4	CaFA_Set WMP-28_Q4	List all factors to which PG&E attributes the improved OC pass rates. This may include changes to inspection programs, changes to training, changes to the OC process, different preconstruction, etc.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
426	CaFA	Set WMP-28	CaFA_Set WMP-28	5	CaFA_Set WMP-28_Q5	State the basis for PG&E's estimate that its proposed OC process will achieve comparable quality performance results.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
427	CaFA	Set WMP-28	CaFA_Set WMP-28	6	CaFA_Set WMP-28_Q6	State the basis for PG&E's estimate that its proposed OC process will achieve comparable quality performance results.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.6	Quality Assurance and Quality Control	NA
428	CaFA	Set WMP-28	CaFA_Set WMP-28	7	CaFA_Set WMP-28_Q7	State the basis for PG&E's estimate that its proposed OC process will achieve comparable quality performance results.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	0	NA	8.1.8	Grid Operations and Procedures	NA
429	CaFA	Set WMP-28	CaFA_Set WMP-28	8	CaFA_Set WMP-28_Q8	State the basis for PG&E's estimate that its proposed OC process will achieve comparable quality performance results.	<p>OC is following the process that OC and CA follow in 2023:</p> <ol style="list-style-type: none"> System Inspections (SI) execution completes the scheduled distribution asset inspection. Completed inspection locations enter the queue of OC-eligible locations. OC completes their review of the OC-eligible locations through desktop and/or field review. OC shares any OC failures with the SI execution team. OC completed locations become eligible for CA sampling. WMP-Discovery2023_DR_CalAActivities_028-0001 Page 2 CA performs statistical sampling of OC completed locations per the 95% confidence and 5% margin of error criteria described in the WMP. CA auditors perform the field audits as identified during the sampling process. CA audits are reviewed by QA subject matter experts (SME) for accuracy and completeness. Once approved by a QA SME, a QA audit location is marked as complete. CA shares any findings data back to the SI OC and SI execution team. PG&E uses the responses to adjust (a) and (b) for a description of one OC and CA processes. The details further integrate OC with execution, as described in subject (a), during the second and third halves of the processes described in subject (b). PG&E is continuing to explore additional opportunities for further integration of the execution and OC functions. PG&E is tracking OC 20% of all System Inspections. Using the data identified under HFTD, having external factors. 	Holly Wehman	8/10/2023	8/15/2023	8/15/2023	https://www.pge.com/pge_global/common/global-locations/oc-completed-locations/ https://reference-docs/2023/CalAActivities_028_0001	1	NA	8.1.8.1	Grid Operations and Procedures	NA

456	CalPA	Set WMP-20	CalPA_Set_WMP-20	7	CalPA_Set_WMP-20_Q7	<p>Page 2 of PG&E's reply comments filed on September 1, 2023, state, "EPSS generally does not create outage events that would not have otherwise occurred. EPSS settings enable a line to trip more quickly than standard settings, but EPSS settings do not increase the number of outage events on their own."</p> <p>Please state the basis for the above claim that EPSS generally does not create outage events that would not have otherwise occurred.</p> <p>Please provide any supporting studies, analyses, reports, or other documentation to support your response to part (a).</p>	Holly Wehman	9/7/2023	9/27/2023	9/27/2023	https://www.pge.com/legal_global/communications/epss-reliability-revision-2023 https://www.pge.com/legal_global/communications/epss-reliability-revision-2023 https://www.pge.com/legal_global/communications/epss-reliability-revision-2023	0	NA	8.1.8.1.1	Grid Operations and Procedures	Protective Equipment and Device Settings
457	CalPA	Set WMP-20	CalPA_Set_WMP-20	8	CalPA_Set_WMP-20_Q8	<p>Page 3 of PG&E's reply comments filed on September 1, 2023, states, "The number of outages in the HFRA from May to October decreased significantly from 2021 to 2022. Additionally, the number of outages in the HFRA during the same time period was only slightly higher in 2022 (6,140 outage events) than in 2020 (6,128 outage events) before EPSS was enabled. Per PG&E's quarterly data reports, PG&E generally experienced lower RFW circuit mile days in 2022 than in 2020."</p> <p>2020: 2026 Q1: 202 Q2: 202 Q3: 202 Q4: Q1 Q2 Q3 Q4 Red Flag Warning overhead circuit mile days - HFTD tier 2 14,708 16,128 105,135 0.00 38,182 2,774.0 Red Flag Warning overhead circuit mile days - HFTD tier 3 0 1,640 20,214 16,124 0.00 1,539 741.0 4)</p> <p>Has PG&E performed a study to compare the weather-normalized number of outages in 2020, 2021, and 2022 to determine changes in the weather-normalized outage count across the three years? This may include, for example, normalizing the number of outages by RFW days, high wind days, high temperature days, or some other metric or set of metrics.</p> <p>If the answer to part (a) is yes, please explain how PG&E normalized the outage counts by weather.</p> <p>If the answer to part (a) is yes, please provide the results of any such study or analysis.</p> <p>If the answer to part (a) is no, please explain why not.</p>	Holly Wehman	9/7/2023	9/27/2023	9/27/2023	<p>a) No, PG&E has not performed a study regarding weather-normalized HFRA outage counts in 2020, 2021, and 2022 relative to our EPSS Reliability Mitigation program(s).</p> <p>b) Not applicable, please see the response to subject (a) above.</p> <p>c) Not applicable, please see the response to subject (a) above.</p> <p>d) PG&E has been using the method set out in the Institute of Electrical and Electronics Engineers standard 1366 (IEEE 1366) of excluding major event days. This has been PG&E's method in estimating outage the count on very extreme days, such as very high temperature days, significant storm days, etc. This methodology is the industry standard practice for identifying trends in reliability metrics.</p>	0	NA	7.2.1	Wildfire Mitigation Strategy Development	Overview of Mitigation Initiatives and Activities
458	OES	013	OES_013	1	OES_013_Q1	<p>Q01: Regarding Section 6.1.1, risk score calculations</p> <p>It is unclear from statements in its revised 2023-2025 WMP (revised 8/7) whether PG&E uses probability distributions or maximum values in its risk score calculations—likelihood (LRF) multiplied by consequence (CfR). On pages 173-174 (section 6) PG&E discusses how a classifier system is used to calculate mean (average) MWs by peak which are then aggregated to a risk score.</p> <p>These explanations of how consequences are calculated in section 6 appears inconsistent with Table 9.2.2.1 on page 908 (section 9), the table states maximum population impact from Technoeye simulation is used to calculate safety consequence and that maximum buildings impact from Technoeye simulation is used to calculate financial consequence.</p> <p>To address this data request:</p> <p>1. Please indicate whether the consequence component of PG&E's risk score calculations (CfR) uses averages or maximum values.</p> <p>2. If PG&E uses maximum values in the consequence component of its risk score calculations, please indicate which maximum values it uses and explain why maximum values are used instead of averages.</p>	Debra Smith	9/8/2023	9/13/2023	9/13/2023	https://www.pge.com/legal_global/communications/epss-reliability-revision-2023 https://www.pge.com/legal_global/communications/epss-reliability-revision-2023 https://www.pge.com/legal_global/communications/epss-reliability-revision-2023	0	NA	6.1.1.1	Risk Score Calculations	
459	TURN	014	TURN_014	1	TURN_014_Q1	<p>On September 11, 2023, PG&E submitted a request to supplement its 2023-2025 WMP submission, to which OES responded on September 13, 2023. PG&E's request indicated that PG&E wishes to include additional information responsive to items raised in the 2023-2025 Revision Notice.</p> <p>Please provide all documents (see the instructions above regarding interpreting "documents" broadly) in PG&E's possession that were created on or after August 7, 2023 (the date of PG&E's response to the Revision Notice) that reflect communication between an employee or other representative of PG&E and an employee or other representative of OES related to PG&E's 2023-2025 WMP. Please exclude from the response documents that are publicly available through the OES website, such as state responses from OES and PG&E's responses to such state requests.</p>	Tom Long	9/15/2023	9/20/2023	9/20/2023	<p>Please note the attachments to this response contain confidential material. PG&E objects to the request on the grounds that it is overbroad and overly burdensome. Additionally, PG&E objects to this request to the extent that it requests documents that are protected by attorney-client privilege. Subject to and without waiving these objections, PG&E responds as follows. In "WMP/Discovery2023_OR_TURN_014-0014001401CONF-ap", PG&E is producing the communications between PG&E and OES related to PG&E's 2023-2025 WMP that were created on or after August 7, 2023 and September 15, 2023, which is the day this data request was received. In this production, PG&E has attempted to avoid producing partial duplicates of the same message by producing longer message threads.</p>	1	NA	NA	NA	NA