

May 13, 2024

VIA ELECTRONIC FILING

Docket # 2022 NOV

Patrick Doherty
Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
715 P Street, 20th Floor
Sacramento, CA 95814

RE: PacifiCorp's Response to Notice of Violation – NOV_PC_CAC9_20230808_0929

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding(s) identified in the “Notice of Violation NOV_PC_CAC9_20230808_0929” (Notice of Violation or NOV) issued by the Office of Energy Infrastructure Safety (Energy Safety) on April 12, 2024. On August 8, 2023, Energy Safety conducted an inspection of PacifiCorp WMP initiatives in the vicinity of the city of Happy Camp, California.

Energy Safety found the following violation:

Violation 1. Energy Safety observed that in implementing 2022 WMP initiative 7.3.3.7 – Expulsion Fuse Replacement, PacifiCorp failed to adhere to a required protocol of replacing expulsion fuses with California Department of Forestry and Fire Protection (CAL FIRE)-approved power fuses on pole ID 07116007.0112804 at coordinates 41.7969133438358, -123.380378228127. Energy Safety considers this violation for failure of completeness to be in the Minor risk category.

PacifiCorp Response:

The company conducted a field inspection on April 26, 2024, and fuses were replaced that same day. No further corrective actions required. Please see images of the pole after the fuse replacement on April 26, 2024.



PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NOV_PC_CAC9_20230808_0929. Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or californiadockets@pacificorp.com.

Sincerely,

A handwritten signature in black ink that reads "Allen Berreth".

Allen Berreth
Vice President of Transmission & Distribution Operations
PacifiCorp
825 NE Multnomah Street, Suite 2000
Portland, OR 97232