

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2023-2025  
Data Response**

PG&E Data Request No.:	OEIS_022-Q001		
PG&E File Name:	WildfireMitigationPlansDiscovery2023_DR_OEIS_022-Q001		
Request Date:	June 11, 2024	Requester DR No.:	OEIS-P-WMP_2024-PG&E-007
Date Sent:	June 14, 2024	Requesting Party:	Office of Energy Infrastructure Safety
DRU Index #:		Requester:	Brad Hill

**SUBJECT: REGARDING MONITORING POTENTIAL HAZARD TREES**

**QUESTION 001**

- a. For Focused Tree Inspections, does One VM have the capability to document potential defects or issues found with "inventory only trees"1so that PG&E may monitor the condition of those trees?
- b. For all other VM inspection types, are inspectors able to document potential defects or issues found with trees not prescribed for work so that PG&E may monitor the condition of those trees?

**ANSWER 001**

- a. For the FTI program, the One VM application is not set up to document potential defects or issues with 'inventory only trees.'" Inspectors prescribe work based off potential defects or issues that would cause the tree to fail within 15 months. Vegetation is inspected twice a year in HFTD areas which allows PG&E to continually monitor the health of the vegetation along its lines.
- b. For other VM programs housed within One VM, the application is not set up to document potential defects or issues when a tree is not prescribed for work.