

NORTHERN CALIFORNIA POWER AGENCY WILDFIRE MITIGATION PLAN 2024

VERSION 3.0

CURRENT VERSION DESCRIPTION

Version 3.0 – A comprehensive review of NCPA's 2024 Wildfire Mitigation Plan. NCPA's Commission approved this WMP on June 27th, 2024. This WMP includes the Qualified Independent Evaluators (IE) Comprehensive Review Report describing revisions in Appendix 6.

TABLE OF CONTENTS

Executive Summary.....	iv
1. Overview.....	1
1.A. Policy Statement	1
1.B. Purpose of the Wildfire Mitigation Plan	1
1.B.1. Coordination with Local Agencies.....	2
1.C. Organization of the Wildfire Mitigation Plan.....	3
2. Goals	4
2.A. Minimizing Sources of Ignition	4
2.B. Resiliency of the Electric Grid.....	4
2.C. Identifying Unnecessary or Ineffective Actions.....	4
3. Roles and Responsibilities	5
3.A. Utility Governance Structure	5
3.B. Wildfire prevention organizational responsibilities	6
3.C. Wildfire Response, Communication, and Recovery.....	6
3.D. Coordination with Water Utilities/Department	7
3.E. Coordination With Communication Infrastructure Providers.....	7
3.F. Mutual Aid Agreements	8
4. Wildfire Risks and Drivers	9
4.A. Risks Associated With Topographic and Climatological Factors	10
4.B. Risks related to design, operation, and MAINTENANCE.....	11
4.C. Changes to CPUC Fire Threat Map	12
4.C.1. Map Comparisons and Updates	12
4.C.2. Fire Zone Review Process.....	13

5.	Wildfire Preventative Strategies	14
5.A.	Preventative Strategies and Programs	14
5.B.	Potential Climate Change Effects	16
5.C.	Potential Climate Change Risk Management Impacts	16
5.D.	Tree Mortality	17
5.E.	Vegetation Management.....	17
5.F.	Inspections	18
5.G.	Fire Prevention, Safety, Emergency Response training	19
5.H.	Reclosing Policy	20
5.I.	De-energization	20
5.J.1.	Impacts to Public Safety	20
5.J.2.	Customer Notification Protocols	21
6.	Left Blank.....	22
7.	Restoration of Service	23
7.A.	Metrics and Assumptions for Measuring Plan Performance	23
	Metric 1: Fire Ignitions.....	23
	Metric 2: Wires Down	23
	Metric 3: Fall in Hazard Trees Ignitions	24
7.B.	Impact of Metrics on Plan	24
7.C.	Monitoring and Auditing the Plan	24
7.D.	Identifying and Correcting Deficiencies in the Plan.....	25
7.E.	Monitoring the Effectiveness of Inspections	25
8.	Independent Auditor.....	26
9.	References	27
	APPENDIX 1 – FIRE RISK ASSESSMENT MAPS	28
	APPENDIX 2 – INDEPENDENT EVALUATOR REPORT 2020.....	30
	APPENDIX 3 – INDEPENDENT EVALUATOR REPORT 2021	33

APPENDIX 4 – INDEPENDENT EVALUATOR REPORT 2022..... 57

APPENDIX 5 – INDEPENDENT EVALUATOR REPORT 2023..... 75

APPENDIX 6 – INDEPENDENT EVALUATOR REPORT 2024..... 89

Revision History..... 99

ATTACHMENT A - PUC 8387 (B) REQUIREMENTS TABLE 100

ATTACHMENT B – WSAB RECOMMENDED ELEMENTS TABLE..... 102

ATTACHMENT C – WILDFIRE RISK ELEMENTS AND CONTROLS 104

ATTACHMENT D – PUBLIC SAFETY POWER SHUTOFF PROCEDURES..... 105

EXECUTIVE SUMMARY

Northern California Power Agency (NCPA) has prepared the following Wildfire Mitigation Plan (WMP) in accordance with California Public Utilities Commission (CPUC) regulation 8387 (Senate Bill 901). NCPA is a Joint Powers Agency, which owns and operates several electrical generation facilities to support its members' generation needs.

The objective of this WMP is to reduce the risk of wildfires that could be ignited or propagated by NCPA's electrical equipment or facilities in high fire threat locations. The plan describes the range of activities that NCPA is taking to mitigate the threat of power line-ignited wildfires, including its current programs, policies, and procedures as well as future plans to decrease risk and improve resiliency. The plan has prioritized the prevention of elements that create a wildfire event: 1) fuel or geographic conditions represented by the California Department of Forestry and Fire Protection and the CPUC risk maps, and 2) ignition represented by facilities subject to creating a fire. The facility types of highest interest are open-wire power lines (transmission and distribution) that are near heavy vegetation or forest.

NCPA has no retail customers. As such, this report focuses exclusively on NCPA's electrical facilities with minimal discussion regarding customer communication typical of other utility WMPs.

1. OVERVIEW

1.A. POLICY STATEMENT

The Northern California Power Agency (NCPA), a California Joint Action Agency, has an overarching goal to provide safe, reliable, and economic electric service to its public power members and associate members. To meet this goal, NCPA constructs, maintains, and operates its equipment in a manner that minimizes the risk of wildfire ignition and propagation caused by NCPA-owned and -operated electric utility equipment (generation, generation tie-lines, and distribution).

1.B. PURPOSE OF THE WILDFIRE MITIGATION PLAN

The objective of this Wildfire Mitigation Plan (WMP) is to reduce the risk of wildfires that could be ignited or propagated by NCPA's electrical equipment or facilities in high fire threat locations.

This WMP applies to NCPA's Geothermal Facility and Hydroelectric (Hydro) Facility located in two different geographical areas. These facilities contain electrical equipment in high fire threat locations. The Geothermal Plant is located near the Geysers in Lake County and the Hydro Facility is located in the North Fork Stanislaus River watershed.

The WMP describes the range of activities that NCPA is taking to mitigate the threat of power line-ignited wildfires, including: (1) current programs, policies, and procedures; and (2) future plans to decrease risk and improve resiliency. This WMP is subject to direct supervision by the NCPA Commission and is implemented by the NCPA General Manager. This WMP complies with the requirements of Public Utilities Code section 8387 (originally SB-901) for publicly owned electric utilities to prepare a wildfire mitigation plan by January 1, 2020, and to review and update it annually thereafter.

Historically, NCPA has continuously improved its practices to minimize wildfire risks. This includes:

- A transmission line vegetation management program that is compliant with North American Electric Reliability Corporation Standard FAC-003 and California Department of Forestry and Fire Protection (CAL FIRE) regulations
- Compliance with CAL FIRE and California Public Utilities Commission (CPUC) regulations and guidance for overhead distribution and transmission lines
- CAL FIRE emergency response plans
- Power management/dispatch response procedures
- Periodic equipment inspections and safe work practices
- Workforce training

This WMP complies with requirements of Public Utilities Code section 8387 (Senate Bill 901).

In November 2022, NCPA initiated the development of this current WMP (Version 2.0). NCPA hired Dudek to evaluate NCPA's electrical facilities, processes, and documentation based on the design, configuration, operations, maintenance, and condition of NCPA facilities in relation

to their potential to initiate a wildfire event. The comprehensive evaluation included consideration of NCPA system descriptions, record design/construction documents, typical facilities layouts, basic fire protection system features, data sheets, inspection practices and procedures, baseline vegetation conditions, potential climate change effects, vegetation management practices, fire threat and hazard maps, and other documentation.

In 2020, per Section 8 of this WMP, NCPA hired an outside consultant, Dudek, to review, assess the comprehensiveness, and provide recommendations to this plan. Subsequently, NCPA elected to modify its Draft WMP that incorporated Dudek's recommended modifications. The Revised WMP (version 1.1) was provided to Dudek on April 29, 2020. Dudek reviewed the Revised WMP and determined that it appropriately addressed all elements required under CPUC Section 8387(b)(2). In 2020, this WMP was presented at the NCPA commission meeting, a public meeting, and is posted on NCPA's public website domain. A similar process was followed with Dudek and NCPA's Commission in May of 2021 and 2022 for Versions 1.2 and 1.3.

In 2024, NCPA hired POWER Engineers, Inc. (POWER) to review and revise Version 2.0 of the Draft WMP. POWER reviewed the 2023 WMP and determined that it appropriately addressed all elements required under CPUC Section 8387(b)(2).

1.B.1. COORDINATION WITH LOCAL AGENCIES

NCPA's local wildfire mitigation coordination efforts include regular meetings for its Emergency Action Plan process. The NCPA Hydro Facility hosts an annual face-to-face meeting with local emergency management agencies, including: the United States Forest Service (USFS); CAL FIRE; sheriff departments for Calaveras, Tuolumne, and Alpine counties; California Highway Patrol; California Department of Parks and Recreation (Calaveras Big Trees State Park); and others. Since many NCPA Hydro facilities are located on USFS lands, a separate annual meeting is held with the USFS and wildfire mitigation is an agenda.

The NCPA Hydro and Geothermal facilities also coordinate vegetation management activities with CAL FIRE and routinely utilize CAL FIRE (in cooperation with California Department of Corrections Conservation Fire Camp labor) for vegetation management and wildfire mitigation around the facilities. Additionally, NCPA Geothermal Facility staff meet annually with Pacific Gas and Electric (PG&E), Calpine (operator of other geothermal facilities at the Geysers), CAL FIRE, the Bureau of Land Management, and Lake County Sanitation District.

Board (WSAB) developed template for review of Publicly Owned Utility WMPs

Utility Name:	Northern California Power Agency
Size:	<1.5 square miles (39 miles x 200 feet ground clearance)
Assets:	Yes - Generation, Yes - Transmission (Only a generator tie line), Yes - Distribution (Only for NCPA Utilities)
Number of Customers:	Zero Customers. Wholesale provider to PG&E electrical grid.
Customer Classes:	Zero Customers. Wholesale provider to PG&E electrical grid.
Location Topography:	No - Urban, Yes - Wildland Urban Interface, Yes - Rural/Forest, No - Rural/Desert, No - Rural/Agricultural
Percent Territory in CPUC High Fire Threat Maps:	Yes - Includes Maps, 61% in Tier 2, 7% in Tier 3
CAL Fire Frap Map Fire Threat Zones:	Yes - Includes Maps, 45% Very High, 27% High, 11% in Moderate
Existing Grid Hardening Measures	Yes - Describes hardened & non-hardened infrastructure
Utility Fire Threat Risk Level:	No - Hi, No - Low, Yes - Mixed
Impact by another utility's PSPS?	Yes - Impacted by PG&E PSPS
Mitigates impact of another utility's PSPS?	No - NCPA is a wholesaler of power feeding into PG&E electrical grid.
Expects to initiate its own PSPS?	No - NCPA is a wholesaler of power feeding into PG&E electrical grid.
Prevailing wind directions and speeds by season?	No - In Maps, Yes - Includes description in Section 4.A.

1.C. ORGANIZATION OF THE WILDFIRE MITIGATION PLAN

This WMP includes the following elements:

- Objectives of the plan
- Roles and responsibilities for carrying out the plan
- Identification of key wildfire risks and risk drivers
- Description of wildfire prevention, mitigation, and response strategies and programs
- Metrics for evaluating the performance of the plan and identifying areas for improvement
- Review and validation of the plan
- Timelines

2. GOALS

2.A. MINIMIZING SOURCES OF IGNITION

The primary goal of this WMP is to minimize the probability that NCPA's transmission and distribution system may be the origin or contributing fire ignition source. NCPA's priorities include facility improvement projects (Section 5A) as well as continued and improved inspection, maintenance, and vegetation management practices. NCPA evaluated, and continues to evaluate and implement, prudent and cost-effective improvements (Section 5A) to its physical assets, operations, and training to meet this objective.

2.B. RESILIENCY OF THE ELECTRIC GRID

The secondary goal of this WMP is to improve electrical grid resiliency. For this WMP, NCPA assessed, and will continue to assess, new industry practices and technologies that will reduce the likelihood of an interruption (frequency) in service and improve the restoration (duration) of service.

2.C. IDENTIFYING UNNECESSARY OR INEFFECTIVE ACTIONS

The final goal for this WMP is to measure the effectiveness of specific wildfire mitigation strategies. If a particular action, program component, or protocol is unnecessary or ineffective, NCPA will assess whether a modification or replacement is merited. This WMP will also help determine if more cost-effective measures would produce the same or improved results.


NCPA's current and planned wildfire risk mitigation activities are formally reviewed annually regarding effectiveness of ongoing practices, investigation of new technologies, and changing climate and ground conditions to prioritize the highest value activities for fire risk mitigation. These actions align with NCPA's Strategic Priorities of "Prepare" and "Value": *"Develop and maintain diverse generation resource portfolio in accordance with or exceeding renewable portfolio standard and capacity obligations"* and *"Develop and enhance strategies to control costs and minimize risks while optimizing the value of assets"*. These Priorities indicate the Agency's commitment to addressing the ongoing shift in service conditions for generation assets brought about by changing climate conditions and risks to energy deliverability brought about by increasing drought and aging transmission and distribution infrastructure.

3. ROLES AND RESPONSIBILITIES

3.A. UTILITY GOVERNANCE STRUCTURE

NCPA is governed by a Commission that maintains several committees, including an Executive Committee, a Nominating Committee, a Legal Committee, a Legislative & Regulatory Affairs Committee, a Facilities Committee, and a Finance Committee. The Executive Committee includes a Chair, Vice Chair, and seven at-large representatives.

Among its approximately 160 employees, NCPA has an internal management team, including a General Manager, an Assistant General Manager for Legislative & Regulatory Affairs, an Assistant General Manager for Power Management, an Assistant General Manager for Generation Services, an Assistant General Manager for Finance & Administrative Services, a General Counsel, and an Executive Assistant & Assistant Secretary to the Commission.



*The red box above indicates the responsible department of the North Fork Stanislaus Hydroelectric Project and Geysers Geothermal Projects. NCPA plant managers are responsible for executing the WMP and serve under the Generation Services Assistant General Manager.

3.B. WILDFIRE PREVENTION ORGANIZATIONAL RESPONSIBILITIES

NCPA is governed by a Commission comprised of one representative for each of its public power utility members. The Commission is responsible for the general management of the affairs, property, and business of the Agency. Under direction of the General Manager, Agency staff are responsible for providing various administrative, operating, and planning services for the Agency. This establishes all funding and is applied to all wildfire funding mechanisms in this WMP (i.e., 3.B., 3.C., 5.A., 5.F, 5.G., 5.H.).

NCPA's organizational responsibilities with respect to wildfire mitigation correspond to its two main facility locations that reside in high fire threat areas: The North Fork Stanislaus Hydro Project and Geysers' Geothermal Projects. Hydro and Geothermal plant managers have responsibility for operations at each respective generating facility. Plant supervisors at each location are responsible for workforce training and executing all policies and procedures related to fire risks, equipment design, maintenance, inspection, vegetation management, and operations.

Revisions to the NCPA WMP are presented to the NCPA Facilities Committee for review and comment before being routed for final approval to the NCPA Commission. The NCPA WMP and archived versions are available for public review on the NCPA website (Policy → Reports → Wildfire Mitigation Plan).

The NCPA Dispatch Center in Roseville, under the direction of the Assistant General Manager for Power Management, has jurisdictional and operational responsibilities for the generator tie lines, including procedures for Operating Instructions and Emergency Assistance (NCPA-PM-108) and Emergency Operating Guidelines for the Collierville-Bellota 230-kV Lines (NCPA-PM-201).

Under the Assistant General Manager's direction, plant managers are responsible for implementation and execution of the WMP with respect to their facilities (see notes in Section 3.A., Governance Structure Diagram). In coordination with the NCPA Dispatch Center, plant managers coordinate activities with internal and external entities necessary to operate and react to wildfire activity.

Additionally, all NCPA employees are responsible for:

- Performing good housekeeping practices
- Maintaining their work areas free of potentially flammable materials
- Participating in fire prevention and suppression training as required

3.C. WILDFIRE RESPONSE, COMMUNICATION, AND RECOVERY

The objective of crisis management is providing direction for rapid hazard assessment, prioritization, notification, and applicable actions. NCPA evaluated potential hazards in the work environment and surrounding areas and worked with local authorities to develop emergency response plans for each facility that address mitigation of hazards and effective response. The goals are to protect personnel, the public, the environment, and NCPA assets.

NCPA utilizes a number of resources to communicate emergency or hazardous conditions to

personnel (including non-NCPA personnel) at hydro and geothermal plants, powerhouses, and associated facilities and locations. These resources include two-way radio communications equipment, cell phones, satellite phones, telephone landlines, email, and the Internet.

The Agency maintains separate emergency response plans, due to different geographic locations, for Geothermal and Hydro generation projects. These plans provide guidance and emergency resources for: fire events; unplanned, sudden, or non-sudden hazardous materials/waste releases; air emissions exceedances; natural or manmade disasters (earthquakes, floods, bomb threats, or suspected terrorist or sabotage events, etc.); or emergency hazards.

Any accident or incident requiring emergency response and support from external agencies is reported to the appropriate NCPA plant supervisor. The event(s) type and severity determines the appropriate response and course of action.

The NCPA Dispatch Center is the main point of contact for PG&E on any public safety power shutoff (PSPS) notification affecting any of NCPA's or members' generation and member loads. NCPA does not have a defined service territory; however, the NCPA Dispatch Center's responsibility is to pass along relevant PG&E PSPS notification to affected members based on phone messages or emails received from PG&E through its Everbridge mass notification system. The NCPA Dispatch Center also follows up on the Everbridge PSPS notifications with information on any planned power shutoff events based on PG&E's PSPS websites or direct PG&E communication where current and real-time information is available.

NCPA provides wholesale power to cities and utilities, typically known as NCPA members, only via the utility grid. Since NCPA does not have retail customers, no customer notification protocols are in place.

3.D. COORDINATION WITH WATER UTILITIES/DEPARTMENT

Power from NCPA generation facilities is delivered to the California Independent System Operator (CAISO) grid. The NCPA Hydroelectric Project transports and delivers water owned by two water utilities through infrastructure (dams and tunnels) operated by NCPA. One of those entities, the Calaveras County Water District (CCWD), owns the NCPA-operated Hydro Facility that delivers this water. The Utica Water and Power Authority (UWPA) also receives some of the water through the same facilities. Neither curtailment of NCPA generation facilities nor de-energization of the NCPA powerlines has any impact on the abilities of CCWD or UWPA to obtain water. NCPA routinely communicates and coordinates with CCWD and UWPA, and both entities are included on communication flow charts for the relevant emergency plans.

3.E. COORDINATION WITH COMMUNICATION INFRASTRUCTURE PROVIDERS

NCPA does not provide power directly to any communication infrastructure providers, and therefore does not routinely coordinate with communication infrastructure providers related to wildfire mitigation or power outages.

3.F. MUTUAL AID AGREEMENTS

NCPA members are uniquely and ideally qualified to assist with the emergency replacement of poles and wires that are necessary to return electric distribution and communication facilities to normal operating condition. However, mutual aid agreements have also long been utilized by publicly owned utilities during times of need. These agreements are usually formed and exercised among neighboring utilities as proximity allows for quick response and fewer travel expenses. Additionally, mutual aid agreements that have a broader geographical reach, including across states or nations, can provide better protection from large regional events that impact neighboring utilities.

NCPA is a member of the California Utilities Emergency Association, which plays a key role in ensuring emergency communications between utilities and maintains a mutual aid agreement for its members. As a member of the American Public Power Association (APPA), NCPA and its members can also authorize APPA mutual aid agreements.

4. WILDFIRE RISKS AND DRIVERS

NCPA electrical infrastructure consists of the following facilities that are in CAL FIRE Moderate to Very High Fire Hazard Severity Zones (2023) and/or CPUC Tier 2/3 Fire Threat Zones (2021). See Appendix 1.

NCPA Project	NCPA Facility	Fire Hazard Severity Zone (Cal Fire 2023)			Fire Threat Zone (CPUC 2021)	
		Moderate	High	Very High	Tier 2	Tier 3
North Fork Stanislaus Hydroelectric Project (Hydro)	Collierville Powerhouse 11523 Camp 9 Rd., Murphys, CA 38.144944, -120.380022	-	-	-	X	-
	New Spicer Meadows Powerhouse 38.393735, -119.999489	-	-	-	-	-
	McKay's Point Diversion Dam 38°14'3.70"N, 120°17'31.70"W	-	-	-	-	X
	McKay's Point 17-kV Service Line	-	-	1.68 miles	-	0.36 mile
	Beaver Creek 38°14'02.94" N 120°16'43.50" W	-	-	-	-	X
	Collierville-Bellota 230-kV Gen-Tie Line	5 miles	12 miles	18 miles	27 miles	-
Geysers Geothermal (Geo)	Plant 1, Middletown, CA 38.751915, -122.719932	-	-	-	-	X
	Plant 2, Middletown, CA 38.748348, -122.710913	-	-	-	-	X
	230-kV Gen-Tie Line	-	-	0.17 mile	-	2.5 miles
	Effluent Pump System and 21-kV Service Line	-	-	3 miles	-	3 miles
	Steam Field and Delivery (includes 480vac power)	-	-	8 miles	-	8 miles

NCPA is also a 6.13 percent co-tenant of the Castle Rock Junction-Lakeville 230-kV Transmission Line, operated and maintained by PG&E, in the Geysers area. This line is in a Tier 3 CPUC Fire Threat Zone. This line is included within the scope of the PG&E Wildfire Mitigation Plan.

There are no new wildfire risks associated with design and construction of new assets. NCPA is currently operating and maintaining original generating facilities, and fire hardening is being performed on the McKay's Point 17-kV Service Line as a maintenance project. No new construction is planned in the immediate future.

Note that NCPA does not have “Enterprise-wide” Safety Risks (as addressed under Section 4.B of the CMUA template) as the Agency does not possess general responsibility over assets and geography except for locations tied to our specific generation assets, as outlined above.

4.A. RISKS ASSOCIATED WITH TOPOGRAPHIC AND CLIMATOLOGICAL FACTORS

Primary wildfire risk drivers are weather and climate. Weather and climate include extended drought periods, changing weather patterns, and high winds. These weather and climate factors affect vegetation conditions, including vegetation health, type, and density. Stressed vegetation is prone to disease, insect infestations, and increased mortality rates. Conversely, high levels of snow and rainfall also affect wildfire risk due to the potential for excessive vegetation growth and landslides, which could affect target trees or infrastructure. Vegetation and climate conditions are discussed in Section 5.

Physical conditions, such as terrain and high winds, affect fire risks. These factors influence fire movement and direction, and control migration rates. Generally, fires move upslope without strong winds, while high winds (e.g., Diablo winds) rapidly drive fires primarily in the same direction as the wind. Topographic features, such as steep canyons, create localized conditions that affect fire movement and rate of speed.

Several of the risk drivers are interrelated:

- **Extended drought:** Extended drought periods result in multiple stress factors for vegetation: dry trees and brush, higher susceptibility to disease and insects, easier ignition, faster burn rate, etc.
- **Excessive precipitation:** Excessive precipitation can affect vegetation density and susceptibility of trees to toppling in high winds.
- **Vegetation type:** Fire risk is partially dependent upon vegetation type. Some vegetation burns quickly (e.g., dry grass), while other types burn hotter (e.g., hardwood trees such as oak). Each vegetation type presents unique challenges for vegetation management and control.
- **Vegetation density:** Dense vegetation generally represents the highest hazard level, while sparse vegetation density is substantially lower risk. Vegetation density is often associated with weather conditions, local micro-climates, precipitation amount, and vegetation type.
- **Weather:** Weather conditions include precipitation, humidity, storms, and winds. Lightning strikes associated with thunderstorms or dry lightning are a natural cause of wildfires.
- **High winds:** High winds drive wildfires. They also down trees (a risk that rises with both drought and excessive rainfall) and sometimes down power lines. In turn, downed power lines are potential ignition sources and the documented cause of major wildfires in California.

- **Prevailing winds:** NCPA monitors prevailing wind directions and speeds differentiated by season, along with average weather conditions by season, using NCPA real-time observations noting disturbing local weather.
- **Terrain:** Fires generally burn uphill, especially within steep canyons typical of NCPA's Geothermal site. Wind-driven upslope and up-canyon fires spread rapidly and represent increased fire hazards.
- **Changing weather patterns (climate change):** Climate change alters vegetation habitat, causing species migration. It may result in increased or decreased precipitation, precipitation type changes (e.g., more rain than snow), higher maximum temperatures, extended heatwaves, or more frequent drought. In turn, these changes may cause increased tree mortality, increased stressed vegetation, and greater susceptibility to disease or insect infestation. See Section 5B for additional information.
- **Communities at risk:** The risk level around designated Communities at Risk may change from year to year based on overall weather conditions, as well as during the year, changing from the wet season through the dry summer and fall.
- **Fire Frequency:** Fire frequency is associated with vegetation changes. In addition to fires consuming existing vegetation, the new landscape is open to different vegetation types, both native and invasive. Since different vegetation types represent varied fire hazards, the risk level also evolves over time in conjunction with vegetation changes.

Wildfires have occurred in the general region of NCPA's Hydro and Geothermal facilities; however, NCPA facilities have not been associated with any ignition source. The 2017 Tubbs and 2019 Kincadee Fires affected areas nearby and immediately adjacent to the Geothermal Facility. The 2015 Valley Fire destroyed much of the 2-kV Service Line for the Effluent Pump System. Risks specific to NCPA's generation facilities are tied to both residual fuel load (snags) from previous fires and potential soil instability caused by previous damage to area vegetation. These hazards are addressed by enhanced inspection techniques described in Section 5.F

4.B. RISKS RELATED TO DESIGN, OPERATION, AND MAINTENANCE

Risks and risk drivers related to design, construction, operation and maintenance that could create fire ignition sources are listed below. The methodology for identifying, monitoring, analyzing, planning, and evaluating safety-wide risks are defined in NCPA's Preventative Strategies and Programs in Section 5.A. These risks include:

- **Equipment/structure/facilities:** Inherent risk of facilities, primarily open wire transmission and distribution ignition events. This risk is also elevated by adjacent facilities (CALPINE, PG&E) that could act as sources of ignition.
- **Object to wire or equipment contact:** Trees, birds, balloons, downed conductors, lightning strikes, or high wind events resulting in contact of equipment
- **Wire to wire contact:** Wires touching one another, and dropping molten metal to the ground
- **Vehicle operations:** Maintenance, inspection, or vegetation clearing crew vehicles causing fires (i.e., catalytic converters contacting dry brush)
- **Vegetation clearing:** Chain saws and other mechanized equipment use
- **Hot Work:** Welding or other activity that could cause ignition in the work area

4.C. CHANGES TO CPUC FIRE THREAT MAP

A key concern for NCPA is the historical risk of wildfires in the vicinity of the agency's facilities, particularly within potential fire hazard zones. Both CAL FIRE and the CPUC have developed maps to identify potential fire hazard zones, originally published in 2007 and 2018, respectively. The CPUC released an updated version of their Fire-Threat Map in August 2021. CAL FIRE's Statewide Responsibility Map was updated in September 2023. NCPA reviewed current CAL FIRE Hazard Severity Zone and CPUC Fire-Threat Maps with respect to agency facilities, as shown in Appendix 1.

CPUC Fire Threat Maps are static until new updates are released, based on data available at the time they were created. As noted below, wildfire risks evolve over time in response to the risk drivers listed above. NCPA will review available data and adjust fire threat hazard zones when applicable to NCPA facilities.

4.C.1. MAP COMPARISONS AND UPDATES

Currently published wildfire hazard maps from CAL FIRE and the CPUC show different boundaries for the risk areas delineated. They also use different terminology for hazard zones. Several factors could account for these boundary differences between agency maps: publication dates, study methodology, vegetation changes over time, recent wildfires, and potential climate change effects. The zones delineated by the CAL FIRE and CPUC maps are discussed below.

CAL FIRE CALIFORNIA FIRE HAZARD SEVERITY ZONE MAP

CAL FIRE generated and published Fire Hazard Severity Zone Maps for the entire state of California in 2007, including separate maps for each county. The California Department of Forestry and Fire Protection's Fire and Resource Assessment Program and the Office of the State Fire Marshal updated Fire Hazard Severity Zones. The Statewide Responsibility Area Map was updated in September 2023. The final regulation and map for the State Responsibility Area were adopted on January 31, 2024, effective April 1, 2024. These maps delineate three hazard zone levels: moderate, high, and very high. The figures in Appendix 1 illustrate these Fire Hazard Severity Zones. There has been no new information or changes to the environment identified to warrant an expansion of the high-fire threat district.

CPUC FIRE-THREAT MAPS

The CPUC developed and published Fire-Threat Maps. These updated 2021 maps include Tier 2 (elevated fire risk) and Tier 3 (extreme fire risk) zones. Additionally, the CPUC uses a Tier 1 (zero to moderate fire risk) category, which includes a High-Hazard Zone (HHZ) designation based on a 2018 USFS-CAL FIRE joint map of tree mortality HHZs. This Tier 1 information addresses the hazard areas with large expanses of dead trees and associated fire risks.

4.C.2. FIRE ZONE REVIEW PROCESS

The existing fire zone review process, set forth by regulatory agencies such as CAL FIRE and CPUC, is an important tool for reducing wildfire risks and hazards. Preparing and executing adequate vegetation management plans is a critical component of this process. The current fire zone process incorporates lessons learned from past major wildfire events, with each new occurrence adding knowledge and forming the basis for improving the process.

Since differences exist between currently published CAL FIRE and CPUC wildfire hazard zone maps, NCPA uses the most conservative approach to vegetation management and asset protection, assuming the highest risk factor from the combined datasets.

5. WILDFIRE PREVENTATIVE STRATEGIES

5.A. PREVENTATIVE STRATEGIES AND PROGRAMS

NCPA's strategies to reduce wildfire risk involve continuous evaluation and improvement of its programs and procedures, including NCPA's: (1) facility maintenance program, (2) emergency operating procedures, (3) vegetation management programs, and (4) asset documentation programs. These programs include all details, such as goals, objective, or percentage; monitor ongoing work; accomplishments; internal and external audits; and detailed reports. There are no constraints such as budgets, availability of equipment, knowledge to effectively deploy, or qualified personnel to install and monitor effectively.

(1) Facility Maintenance Program: NCPA has a robust preventive maintenance program to maintain the safe and reliable operation of its transmission and distribution lines. Given the growing risk of wildfires, opportunities for improvement have been identified and are incorporated into each facility's improvement plan. Additionally, NCPA utilizes risk factors as identified in Section 4.B. during improvement plan evaluations. Improvements such as those listed below may be implemented based on workable solutions and relative priorities:

- **The Collierville-Bellota (CB) 230-kV Gen-Tie Line:** In 2020, NCPA made improvements on its longest transmission line. More than half of the line is within a Tier 2 fire threat zone. NCPA prioritized the safe and reliable operation of the line. The line is over 30 years old. Following a thorough review of the line and its attendant facilities, major improvements, including upgrading insulators, hardware, and conductor damping, were completed in 2020. This project was considered a major capital improvement and was prioritized for wildfire prevention. Avian deterrents and anti-nesting cones were also added in 2020.
- **McKay's Point 17-kV Service Line:** The three-span overhead section of distribution line is in a Tier 3 fire threat zone. This short line segment is maintained and is monitored consistently. Fire-hardening improvements were analyzed in 2023, with construction anticipated to be complete by Q4 2024.
- **Geothermal 230-kV Gen-Tie Transmission Line:** This nine-span line connects with PG&E's 230-kV system. The line is characterized by long dead-ended spans and thick vegetation. Vegetation is cleared to a 300-foot width across the right-of-way (ROW) following CAL FIRE recommendations. The line is consistently inspected and maintained.
- **PG&E/NCPA/Santa Clara/Department of Water Resources Cotenancy 230-kV line:** This line is operated and maintained by PG&E on behalf of the co-owners. It connects NCPA and adjacent CALPINE geothermal plant sites to PG&E's Fulton and Lakeville substations. Annual maintenance practices on this line were enhanced by implementing extended visual inspection techniques. These enhanced inspection techniques significantly reduce ignition hazards from potential line or connector failures. These practices are now subject to an annual coordination meeting between PG&E and NCPA on behalf of the other co-tenants.

- **Geothermal Effluent Pump System 21-kV Line:** This 6-mile distribution line is in a Tier 3 fire threat zone. This line was largely rebuilt following damage caused by the 2017 Valley Fire. The wood pole line has construction framing typical to distribution construction. In addition to typical maintenance and monitoring of the structural and foundational health, NCPA works with Cal Fire and Calpine to coordinate vegetation removal and clearance work, in excess of the requirements for rural distribution circuits. This activity includes clearing fire breaks along routes within the NCPA steam fields, resulting in reduced risk of fire spread.

(2) Emergency Operating Procedures: NCPA uses emergency operating procedures to safely react to wildfire events and help guide employees. In addition to annually evaluating training procedure effectiveness, NCPA improves its operational awareness and ability to respond to fire events by ensuring that Hydro and Geothermal plant personnel working adjacent to NCPA line facilities can communicate with plant operations personnel and coordinate emergency wildfire response.

(3) Vegetation Management Program: NCPA developed and implemented a Transmission Vegetation Management Program (TVMP) that establishes vegetation maintenance requirements for each facility to maintain generation interconnection system reliability. The NCPA document, Generation Services Common Procedure GS-305: Transmission Vegetation Management Program, defines NCPA procedures for vegetation management. The full description of this program is described in Section 5.E.

(4) Wind Monitoring: Live data regarding prevailing winds is used with the fire maps located in Appendix 1. PG&E's Weather Awareness website is a resource for real-time conditions: <https://www.pge.com/en/outages-and-safety/safety/wildfire-preparedness-support/weather-and-fire-detection.html>. This information is used in communication and aids to analyze wildfire situations. In addition, prevailing wind patterns and their effect on transmission conductors due to cyclic loading are taken into account during annual transmission asset inspections conducted in accordance with NCPA's NERC FAC-003 compliance procedure GS-305.

(5) Asset documentation: Current NCPA facility documentation includes geographically referenced facility locations (Appendix 1) and current facility drawings, materials lists, and design criteria. This documentation has been coordinated with adjacent asset owners (PG&E and Calpine) to ensure completeness of maintenance actions and track design features (lightning arrestors) that minimize risks of the lines causing an ignition.

NCPA directly participated in the development of the CPUC's Fire-Threat Map,¹ which designates a High Fire-Threat District. In the map development process, NCPA served as a territory lead and worked with utility staff and local fire and government officials to identify the areas of NCPA's service territory that are at an elevated or extreme risk of power line-ignited wildfire. NCPA incorporated the High Fire-Threat District into its construction, inspection, maintenance, repair, and clearance practices, where applicable.

¹ Adopted by CPUC Decision 17-12-024.

The CPUC defines a High Fire-Threat District consisting of three areas:

- Tier 1 HHZs from the USFS and CAL FIRE joint map of Tree Mortality HHZs
- Tier 2 consists of areas on the CPUC Fire-Threat Map where there is an elevated risk for utility-associated wildfires
- Tier 3 of the CPUC Fire-Threat Map where there is an extreme risk for utility-associated wildfires

NCPA facilities in relation to CPUC and CAL FIRE threat maps are shown in Appendix 1 of this report.

5.B. POTENTIAL CLIMATE CHANGE EFFECTS

Climate change affects vegetation in many ways. Droughts are longer and more severe. Large storm events are more common and intense. Summers are hotter and may include more thunderstorms. These climate change factors affect vegetation and the associated wildfire risks:

- Vegetation adapts, with plant migration into different areas
- Vegetation dries out during droughts, presenting increased fire danger
- Stressed vegetation is more susceptible to insect infestations, damaging trees, or accelerating mortality
- Thunderstorms present lightning strike risks along with strong wind events

Extended periods of intense rainfall also typically increase landslide risks. In turn, landslides could damage or topple structures, limit access, create safety hazards by damaging roads, or cause localized tree mortality by severing root systems. Note that heavy rainfall is not the only landslide trigger mechanism, but it is the one most closely associated with climate change.

5.C. POTENTIAL CLIMATE CHANGE RISK MANAGEMENT IMPACTS

Climate change affects the risks associated with wildfires, especially in fire hazard zones. Some specific climate change impacts that affect wildfire risks include:

- Tree and underbrush growth rates
- Vegetation type changes
- Vegetation migration from existing habitats
- Stress and disease contributing to higher tree mortality

As potential impacts shift over time, fire hazard management practices will evolve and adapt to changing risk management requirements.

5.D. TREE MORTALITY

It is estimated that over 100 million trees in California died from drought-related stress between 2012 and 2017. The extended drought period left millions of acres of forestland highly susceptible to insect attacks. Drought stress is aggravated in forests with high competition for limited water resources.

Dead, dying, and diseased trees represent potential wildfire risks for NCPA. Trees adjacent to power line ROW represent a hazard due to falling branches or potential toppling. This threat increases substantially with tall snags or trees with dead tops. Dead or highly stressed trees are also an easily ignitable fuel source. They ignite quicker and generally burn faster than healthy trees. NCPA's internal Transmission Vegetation Management Program specifies tree and snag clearances.

5.E. VEGETATION MANAGEMENT

NCPA developed and implemented a Transmission Vegetation Management Program (TVMP), establishing vegetation maintenance requirements for each facility to achieve generation interconnection system reliability. The NCPA document, Generation Services Common Procedure GS-305: Transmission Vegetation Management Program, defines NCPA procedures for managing all types of vegetation associated with utility infrastructure, including vegetation above and below electrical lines.

NCPA meets or exceeds the minimum industry standard vegetation management practices. For transmission-level facilities, NCPA complies with North American Electric Reliability Corporation (NERC) FAC-003-4. For both transmission and distribution-level facilities, NCPA meets: (1) Public Resources Code section 4292, (2) Public Resources Code section 4293, (3) General Order 95 Rule 35, and (4) General Order 95 Appendix E Guidelines to Rule 35.

The TVMP enhances reliability by preventing vegetation-related outages, maintaining required clearances between power lines and vegetation within or adjacent to the ROW, reporting vegetation-related system outages to the Western Electricity Coordinating Council, and documenting the process for an annual vegetation work plan. This program satisfies requirements for vegetation management specified in NERC FAC-003-4, which requires a Generator Owner to have documented maintenance strategies, procedures, processes, or specifications to prevent the encroachment of vegetation into the Minimum Vegetation Clearance Distance of applicable lines as specified in requirement R3.

NCPA uses a combination of its own staff and qualified consultants (such as scientific experts in ecology, fire ecology, fire behavior, geology, and meteorology) with experience in line design, line construction, NERC Standards compliance, and vegetation management to develop and maintain the TVMP.

The TVMP specifies technical requirements for staff and contractors to comply with or verify compliance with California Division of Occupational Safety and Health (Cal/OSHA) standards, and NCPA Electrical Safety Procedure GS-103 ensures Cal/OSHA and Minimum Approach Distances.

Objectives of the TVMP are:

- Adhere to the Power Line Fire Prevention Field Guide published by CAL FIRE in November 2008 and used by California power utilities for the care and maintenance of trees, shrubs, and other woody plants when pruning vegetation near electric facilities.
- Maintain defined clearance distances between the generation interconnection facilities and all trees, brush, and other vegetation that could grow too close to electrical facilities, including conductors, poles, guy wires, and other structures. Since the clearances specified in the Power Line Fire Prevention Field Guide published by Cal FIRE in November 2008 are more stringent than the MVCD described in FAC-003-4, NCPA adheres to the CAL FIRE field guide.
- Where appropriate and necessary, develop site-specific, environmentally sensitive, cost-effective, and socially responsible solutions to vegetation control near the NCPA generation interconnection facilities. Document the process in NCPA's computerized maintenance management system's annual Preventive Maintenance process for the annual vegetation work plan for applicable power lines and other facility infrastructure (steam lines, switchyards, firebreaks).
- Maintain public and worker safety, maintain compliance with NERC standards and other regulatory and legal requirements, provide reliable electric service that allows for operational flexibility, and promote environmental stewardship and habitat enhancement.

Potential improvements to its programs include increasing the frequency and scope of aerial lidar surveys on its transmission and distribution facilities and a continued emphasis on identification and timely removal of danger and hazard trees that threaten overhead lines. NCPA's asset management system allows evaluating potential improvements as observations are recorded.

5.F. INSPECTIONS

NCPA performs annual inspections of its transmission and distribution facilities, in accordance with General Order 95 and General Order 165. The following additional inspections have been performed on the Collierville-Bellota 230-kV line:

- Lidar vegetation flights
- Corona scans of insulators
- Infrared "hot-spot" inspections of conductor, conductor splices, and dead-end hardware.

In addition to its annual ground-based inspection, NCPA may augment inspections with aerial drone and/or helicopter surveys.

These inspections are documented and issued by NCPA's computerized maintenance management system, and records of those inspections are maintained.

Strategic improvements to the inspection program are listed below.

- Increasing inspection frequency and scope
- Using drone-based visual inspections

- Considering new technology
- Improving inspection methodology approach
- Considering fire threat zones in inspection programs

NCPA's asset management system also allows these improvements to be evaluated as observations and comments are made when work orders for maintenance items are executed.

The TVMP establishes requirements for the type and schedule of ROW vegetation inspections. Specific hazards addressed in the TVMP include identifying encroachments into the clearance area (Section 6.3.7) and additional inspection activities to identify deadfall and brush in the ROW that could provide fuel for wildfire spread (Section 6.3.9). The TVMP also provides explicit direction to treat emergent conditions associated with a potential hazard as an immediate mitigation priority and address extent of condition without delay (Section 6.4.4).

5.G. FIRE PREVENTION, SAFETY, EMERGENCY RESPONSE TRAINING

Section 4.B. of this WMP outlines the unique risks for which NCPA performs inspections.

NCPA implemented work rules and complementary training programs for its workforce to help reduce the likelihood of fire ignition. Trainings for employees to cover fire hazards and NCPA's Fire Prevention Plan cover the following topics.

- Fire extinguisher use
- Fire prevention
- Hazardous materials handling
- Emergency response

These trainings are conducted by an outside vendor and/or NCPA supervisors or environmental health and safety specialists.

NCPA employees also receive training on emergency response plans when the employee is assigned initially to the job, when the plan changes, and when the employee's responsibilities or designated actions under the plans change.

Each facility manager is responsible for conducting site-specific training to ensure that the purpose and function of NCPA safety procedures are understood by employees, and that knowledge and skills required for safe operation are acquired by employees. Refresher training is performed and documented on an annual basis and retraining is conducted when:

- An annual audit reveals there are deviations from or inadequacies in the employee's knowledge of the procedure or changes in the regulations
- There is a new or revised control method of a system or piece of equipment

The following procedures provide additional guidance for employee training specific to the areas described in these NCPA documents:

- Generation Services Common Procedure GS-101: Lock Out Tag Out Try Procedure
- Generation Services Common Procedure GS-103: Electrical Safety Procedure

- Generation Services Common Procedure GS-107: Proper Handling of Hazardous Waste
- Generation Services Common Procedure GS-111: Hot Work Procedure
- Generation Services Common Procedure GS-115: Welding Safety Procedure
- Generation Services Common Procedure GS-126: Fire Protection and Prevention Plan
- Power Management Common Procedure PM-108: Operating Instructions and Emergency Assistance
- Power Management Common Procedure PM-201: Emergency Operating Guidelines, Collierville Power House Bellota-Collierville 230-kV Lines

5.H. RECLOSING POLICY

NCPA does not own or use automatic reclosers on its 230-kV transmission lines. Relaying equipment on the 21-kV Bear Canyon line at the Geothermal facility is also set to a “zero-reclose to lockout”, requiring physical inspection of the line prior to restoration. This is a typical approach for utility operations in remote terrain, for both personnel and fire hazard safety reasons.

In the event of a planned or emergency line trip, close coordination with NCPA generation services and dispatch, as well as with PG&E's grid control center, is mandatory. Lines are only re-energized after extensive line patrol visual confirmation. If the lines are tripped due to a forecasted or imminent wildfire or if a wildfire is believed to be caused by downed lines, close coordination with CAL FIRE's onsite representative and control center are required before NCPA's generation services attempts to energize the line.

5.I. DE-ENERGIZATION

NCPA plant managers are responsible for determining de-energizations. NCPA's Geothermal plant manager relies on PG&E to determine de-energization. NCPA's Hydro plant manager has the authority to preemptively shut off power due to fire-threat conditions; however, this option will only be used in extraordinary circumstances. Step-by-step PSPS procedures for both the Hydro and Geothermal facilities are provided in Attachment D.

NCPA also maintains transmission line trip procedures to significantly reduce fire risk, including requiring patrols prior to restoring transmission lines. Requiring patrols during high fire risk scenarios is typical and recommended of California utilities.

5.J.1. IMPACTS TO PUBLIC SAFETY

NCPA does not service retail customers and de-energizing agency facilities will not directly affect retail customers, who will be notified of PSPS by their specific utility providers.

5.J.2. CUSTOMER NOTIFICATION PROTOCOLS

NCPA provides wholesale power to cities and utilities, typically known as NCPA members, only via the utility grid. Since NCPA does not have retail customers, no customer notification protocols are in place. However, NCPA is the primary point of contact between PG&E PSPS and its member utilities. Formal procedures are currently in place, NCPA-PM-501, to notify NCPA member utilities of de-energization activities. The primary and backup points of contact for each NCPA member utility are contacted by phone.

6. LEFT BLANK

7. RESTORATION OF SERVICE

After a de-energization event, NCPA will restore service in coordination with PG&E's restoration efforts. NCPA will follow steps to restore service, such as inspecting, repairing, testing, and finally restoring.

7.A. METRICS AND ASSUMPTIONS FOR MEASURING PLAN PERFORMANCE

NCPA tracks three metrics to measure performance of this WMP. Metrics are evaluated yearly: (1) number of fire ignitions, (2) number of NCPA wires down, and (3) hazard tree fall ignitions.

METRIC 1: FIRE IGNITIONS

NCPA tracks fire ignitions in their territory as follows:

- Self-ignited or human-caused
- An NCPA facility failure was associated with the fire
- An NCPA electrical facility wire-to-wire contact was associated with the fire
- The ignition was a result of an extreme weather event

2020 Metric Summary: GEO – 0 ignitions, Hydro – 0 ignitions

2021 Metric Summary: GEO – 0 ignitions, Hydro – 0 ignitions

2022 Metric Summary: GEO – 0 ignitions, Hydro – 0 ignitions

2023 Metric Summary: GEO – 0 ignitions, Hydro – 0 ignitions

METRIC 2: WIRES DOWN

The second metric is the number of NCPA distribution and transmission wires downed. A wire down event includes any instance where an electric transmission or primary distribution conductor falls to the ground or onto a foreign object. NCPA divides the wires down metric between wires down inside and outside of High Fire Threat Districts. All wires down events are documented.

2020 Metric Summary: GEO – 0 Wire Down, Hydro – 0 Wire Down

2021 Metric Summary: GEO – 0 Wire Down, Hydro – 0 Wire Down

2022 Metric Summary: GEO – 0 Wire Down, Hydro – 0 Wire Down

2023 Metric Summary: GEO – 0 Wire Down, Hydro – 0 Wire Down

METRIC 3: FALL IN HAZARD TREES IGNITIONS

NCPA added a metric that measures an element that could lead to a wildfire ignition:

- Fall in trees (trees of height sufficient to represent a contact hazard to the Distribution Line if destabilized due to soil instability at the tree base) without adequate clearance to the ROW in areas previously affected by fire.

2023 Metric Summary: GEO – 10 Locations, 0 Fall Ins; Hydro – 2 Locations, 0 Fall Ins.

7.B. IMPACT OF METRICS ON PLAN

NCPA continues to track these metrics and document overall WMP success at identifying and containing risk. Additional metrics may be added to the WMP, as warranted, to identify which lines are most susceptible to risk factors from unexpected outages (human, animal, or vegetation induced), time-of-year risks (drought or excessive rainfall), shifting fire threat district risks, or impact of maintenance deferral on existing lines. Through this metric review, NCPA will identify lines and other facility assets that are disproportionately impacted and could benefit by focused risk reduction measures that represent potential improvements to the plan.

2020 through 2023 WMP Impact Due to Metrics – The metrics above show zero incidents and indicate success.

Within the context of California's exposure to wildfire ignition risk resulting from "wires down" or "wire/tree interaction", NCPA operates an asset base in high fire risk territory that consists of roughly 35 miles of 230-kV transmission and 6 miles of 21-kV distribution. By contrast, PG&E operates in excess of 99,000 miles of transmission and distribution circuits within its service territory, experiencing an incident rate of 308 "wires down" or "wire/tree interaction" during 2022, for a rate of 0.3 percent per mile year (PG&E 2023-2025 WMP Revision 1 Figure PG&E-6.1.1-2, page 136). Assuming NCPA's incident rate is equivalent to PG&E, NCPA should expect to experience 0.12 incident per mile year, or about one incident in 8.5 years. A "zero" metric would be indicative of success under NCPA's WMP program metrics and should be sustainable for a period in excess of 10 years.

The Agency considered adding a metric to track total inspection observations for each overhead line asset but determined this would not add value as a new metric. Instead, NCPA will continue to perform inspections through its maintenance program.

7.C. MONITORING AND AUDITING THE PLAN

This WMP is presented to the NCPA Commission on an annual basis along with metrics and a summary of updates. Additionally, a qualified independent evaluator will present a report on this plan to the NCPA Commission. See Section 8.

7.D. IDENTIFYING AND CORRECTING DEFICIENCIES IN THE PLAN

NCPA may correct deficiencies and implement plan improvements as needed. Some of these activities and their alignment to the Agency's Strategic Priorities are defined in Section 2.C. In support of these priorities, the annual WMP review provides a framework for evaluating the effectiveness of the Agency's plan, both in terms of the internal results achieved and the potential for shifting hazards resulting from ongoing drought (e.g., additional areas being designated as high fire threat) and weather-induced changes (e.g., increased fire load as a result of higher than historic rainfall totals). The Agency's strategy involves an ongoing process of assessing risk and developing cost-effective means to address those risks within the WMP (e.g., cooperative effort with Calpine to maintain fire breaks, use of WAPA for transmission line conductor repair and replacement). Improvements will be documented in the annual report to the NCPA Commission.

7.E. MONITORING THE EFFECTIVENESS OF INSPECTIONS

Line inspections for NCPA fall into two categories:

1. Line patrol and evaluation of line facilities on a structure-by-structure basis. This is either ground or aerial (drone or helicopter) based.
2. Vegetation monitoring and evaluation, either ground based on a structure-by-structure and span-by-span basis or by lidar aerial methods.

Measuring the effectiveness of these inspections can be performed by professionals independent of the inspection documentation and analysis. Baseline comparison of results from adjacent drought and excessive rainfall years will inform earlier inspection timing and/or enhanced scope of the inspections. Developing metrics surrounding identified and mitigated risks will help reinforce a "zero-tolerance" approach for vegetation management and equipment failure-induced outages. Baseline of inspection practices with adjacent owners (PG&E and Calpine) will also be used to evaluate effectiveness. An NCPA representative will ride along with inspection personnel to review their methodology and reporting. Lastly, an independent review of similar facilities can be performed and compared with inspection personnel. NCPA currently conducts ride alongs with both Cal-Fire staff and internal NCPA staff. Additional objectives are stated in Section 2.C. above.

8. INDEPENDENT AUDITOR

In 2019, NCPA anticipated that the CPUC would provide a list of qualified independent evaluators. In lieu of such a list, NCPA drew from a list it compiled following a Request for Qualifications issued in June 2019. The selection was based on competitive bid.

In 2020, NCPA competitively bid and contracted with a qualified independent evaluator, Dudek, with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of this WMP. The independent evaluator issued a report (Appendix 2) and posted to the NCPA website. The independent evaluation and report were completed on April 30, 2020.


In 2021, 2022, and 2023, NCPA competitively bid and contracted with a qualified independent evaluator, Dudek, to review this WMP using the recommendations provided by the Wildfire Safety Advisory Board's (WSAB) "Guidance Advisory Opinion for the 2021 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Cooperatives". Per the WSAB, "The guidance document should be viewed as offering an efficient way to meet the WMP requirements in Public Utilities Code Section 8387(b)(2), not as adding to the statutory requirements." The independent evaluator issued reports for each year (Appendices 3, 4, and 5) and posted to the NCPA website.


In 2024, NCPA competitively bid and contracted with a qualified independent evaluator, POWER Engineers, Inc., to review this WMP using the recommendations provided by the WSAB's "Guidance Advisory Opinion for the 2021 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Cooperatives". Per the WSAB, "The guidance document should be viewed as offering an efficient way to meet the WMP requirements in Public Utilities Code Section 8387(b)(2), not as adding to the statutory requirements." The independent evaluator issued a report for 2024 (Appendix 6) and posted to the NCPA website.

9. REFERENCES

- California Department of Forestry and Fire Protection. 2023. Fire Hazard Severity Zones. <https://osfm.fire.ca.gov/what-we-do/community-wildfire-preparedness-and-mitigation/fire-hazard-severity-zones>. Accessed March 2024.
- California Public Utilities Commission. 2021. Fire-Threat Maps and Fire-Safety Rulemaking. <https://www.cpuc.ca.gov/industries-and-topics/wildfires/fire-threat-maps-and-fire-safety-rulemaking>. Accessed March 2024.

APPENDIX 1 – FIRE RISK ASSESSMENT MAPS





APPENDIX 2 – INDEPENDENT EVALUATOR REPORT 2020

853 LINCOLN WAY, SUITE 208
AUBURN, CALIFORNIA 95603
T 530.887.8500 F 530.887.1250

April 30, 2020

12108.02

Mr. Jeremy Lawson
Northern California Power Agency
651 Commerce Drive
Roseville, CA 95678

Subject: *Evaluation of Northern California Power Agency Wildfire Prevention and Mitigation Plan*

Dear Mr. Lawson:

Dudek conducted an evaluation of the City of Northern California Power Agency (NCPA) Wildfire Mitigation Plan (WMP), as required under California Public Utilities Code (CPUC) Section 8387(b). CPUC Section 8387(b), as modified by Senate Bill (SB) 901, and the Administrative Law Judge's Ruling issued on January 17, 2019 in CPUC Docket No. R.18-10-007 (ALJ Ruling), applies to publicly-owned electric utilities and requires preparation of a Wildfire Mitigation Plan before January 1, 2020. CPUC Section 8387(c) requires that an independent evaluator review and assess the comprehensiveness of a publicly-owned utility's WMP and issue a summary report.

Dudek, as an independent plan evaluator, conducted an initial review of NCPA's Draft WMP (version 1.0). On April 21, 2020, Dudek provided a summary matrix with recommendations for Draft WMP modifications. The focus of the evaluation was to determine whether the Draft WMP addressed all required elements under CPUC Section 8387(b)(2) (included in Attachment A). The following summarizes the recommended clarifications/modifications identified during the initial review of the Draft WMP (version 1.0), by required element:

- 8387(b)(A): Provide clarification and detail regarding plan implementation responsibility.
- 8387(b)(E): Identify previous plan metrics, as available.
- 8387(b)(L): Provide details regarding risk drivers, risk impacts, and how NCPA will identify, monitor, analyze, plan/evaluate and respond to risks.
- 8387(b)(N)(i): Clarify monitoring efforts associated with WMP implementation and clearly identify performance monitoring details in the plan. Clarify plan auditing and review procedures.
- 8387(b)(N)(ii): Provide clarification and detail regarding plan implementation, review, and plan deficiency correction responsibility.
- 8387(b)(N)(iii): Clarify line/equipment inspection responsibility, timeframes, work plan approach, and target inspection goals, and performance metrics.

Subsequently, NCPA elected to modify its Draft WMP that incorporated Dudek's recommended modifications. The Revised WMP (version 1.1) was provided to Dudek on April 29, 2020. Dudek reviewed the Revised WMP and determined that it appropriately addressed all elements required under CPUC Section 8387(b)(2).

DUDEK

1


12108.02
April 2020

Mr. Jeremy Lawson

Subject: Evaluation of Northern California Power Agency Wildfire Prevention Mitigation Plan

Should you have any questions or require additional information, please do not hesitate to contact me at (530) 863-4650.

Sincerely,



Scott Eckardt, RPF
Project Manager

Att.: A. Required WMP Elements under PUC Section 8387(b)
cc: Michael Huff, Dudek
Jason Neuman, Dudek

Required WMP Elements under PUC Section 8387(b)

PUC 8387(b)(2) Section	Description
A	An accounting of the responsibilities of the persons responsible for executing the plan.
B	The objectives of the wildfire mitigation plan.
C	Description of the preventative strategies and programs to be adopted by the publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.
D	A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan's performance and the assumptions made that underlie the use of those metrics.
E	A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.
F	Protocols for disabling reclosers and de-energizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure
G	Appropriate and feasible procedures for notifying a customer who may be impacted by the de-energizing of electric lines. The procedures shall consider the need to notify, as a priority, critical first responders, health care facilities, and operators of telecommunications infrastructure.
H	Plans for vegetation management.
I	Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.
J	A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility's or electrical cooperative's service territory. The list shall include, but not be limited to, both of the following:
J(i)	Risks and risk drivers associated with design, construction, operations, and maintenance of the local publicly owned electric utility or electrical cooperative's equipment and facilities.
J(ii)	Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned utility's or electrical cooperative's service territory.
K	Identification of any geographic area in the local publicly owned electric utility's or electrical cooperative's service territory that is a higher wildfire threat than is currently identified in a commission fire threat map, and identification of where the commission should expand the high fire threat district based on new information or changes to the environment.
L	A methodology for identifying and presenting enterprise-wide safety risk and wildfire-related risk.
M	A statement of how the local publicly owned electric utility will restore service after a wildfire.
N	A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following:
N(i)	Monitor and audit the wildfire mitigation plan.
N(ii)	Identify any deficiencies in the wildfire mitigation plan or its implementation, and correct those deficiencies.
N(iii)	Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the plan, and other applicable statutes, or commission rules.

APPENDIX 3 – INDEPENDENT EVALUATOR REPORT 2021

853 LINCOLN WAY, SUITE 208
AUBURN, CALIFORNIA 95603
T 530.887.8500 F 530.887.1250

May 3, 2021

Mr. Jeremy Lawson
Northern California Power Agency
651 Commerce Drive
Roseville, CA 95678

Subject: Independent Evaluation Report of Northern California Power Agency's Wildfire Mitigation Plan Ver. 1.2

I. INTRODUCTION

Northern California Power Agency (NCPA) contracted with Dudek to engage in an independent evaluation of its Wildfire Mitigation Plan (WMP). This independent evaluation report (Report) describes the technical review and evaluation of the WMP prepared by Dudek, performed in April 2021 and completed on April 26, 2021.

Dudek conducted an evaluation of NCPA's WMP, as required under California Public Utilities Code (PUC) §8387(b). PUC §8387(b), as modified by Senate Bill (SB) 901, and the Administrative Law Judge's Ruling issued on January 17, 2019 in California Public Utilities Commission (CPUC) Docket No. R.18-10-007 (ALJ Ruling), applies to local publicly owned electric utilities and required preparation of a WMP before January 1, 2020, and revising/updating the WMP in 2020 and annually thereafter.

The WMP requirements are codified in PUC §8387(b)(2) for local publicly owned electric utilities (POUs). PUC §8387(c) requires that an independent evaluator review and assess the comprehensiveness of a POU's WMP and issue a summary report.

Dudek conducted an initial review of NCPA's WMP (version 1.2) and provided recommendations for clarifications/modifications on April 8, 2021. The focus of the evaluation was to determine whether the WMP included all elements required under PUC §8387(b)(2) (listed in Attachment A). The following summarizes the recommended clarifications/modifications identified during the initial review, by required element. Required elements not identified below were determined to satisfactorily meet code requirements in the WMP.

- 8387(b)(2)(A): While the organizational structure, responsible department and responsible position are identified, it is not clear what the responsible position's responsibilities are for executing the WMP.
- 8387(b)(2)(C): Add description of programs. Reference is made to the line maintenance program. No definitive description is provided for the proposed programs.
- 8387(b)(2)(E): Include discussion of application of previous metrics. No reference is included regarding the impacts on the WMP from past metrics.
- 8387(b)(2)(F): Enhance section to clarify role as wholesaler vs. retailer. Reclosers are not employed. Impacts to Public Safety is addressed; any impacts would be addressed by providers of Public Safety Power Shutoffs (PSPS). Any de-energization is coordinated with CAL FIRE and PG&E.

DUDEK

1

12108.04
May 2021

- 8387(b)(2)(G): Enhance section to clarify role as wholesaler vs. retailer. As a wholesale provider NCPA has no retail customers; any impacts would be addressed by providers of PSPS.
- 8387(b)(2)(J): Add list of risks and risk drivers related to design, construction, operation and maintenance; they currently are not addressed.
- 8387(b)(2)(K): Not addressed. Rather than referring solely to the High Fire-Threat District, include description of the local geography, any specific areas of concern and identification of any changes to be made.
- 8387(b)(2)(M): Needs clarification and details. Statement is very limited with no details, only that restoration will occur in coordination with PG&E and General Order (GO)-646 procedures. The section should be enhanced to include details on PG&Es restoration efforts and the GO-646 procedure.
- 8387(b)(2)(N): The section should be enhanced to include details on how the monitoring will occur throughout the year. It is not clear how deficiencies are identified. Clarification is needed whether or not the proposed effectiveness inspection methods are actually taking place, and if so, by whom.

Following updates to all of the above, the WMP was found to meet all the requirements of PUC §8387(b)(2).

In addition, though not required to do so, NCPA requested Dudek to conduct an evaluation of the WMP for compliance with the Wildfire Safety Advisory Board 2020 WMP guidance recommendations. Following updates, the WMP was found to meet all the recommendations of the Guidance Advisory Opinion for 2021 WMPs (See Attachment B for Compliance Matrix).

II. WILDFIRE MITIGATION PLAN REQUIREMENTS

A. Senate Bill 901

Per Senate Bill (SB) 901, all Publicly Owned Utilities (POUs) are required to adopt a Wildfire Mitigation Plan (WMP), which shall be reviewed by an independent third-party evaluator. SB 901 requires the governing board to determine whether any portion of the geographical area where the utility's overhead electrical lines and equipment are located has a significant risk of catastrophic wildfire resulting from those electrical lines and equipment. The bill directs electrical utilities to annually prepare WMPs that include several mitigation and response elements in each utility's strategies, protocols, and programs. Each electric utility is to prepare and adopt a comprehensive WMP before January 1, 2020. The requirements for POUs are presented in PUC §8387. In addition, the WMP shall be reviewed by an approved, independent, third-party evaluator to review and assess the comprehensiveness of, and the POU's compliance with, this Plan.

B. AB 1054 & AB 111

Per Assembly Bill (AB) 1054, POUs must annually submit a WMP to the California Wildfire Safety Advisory Board, which will review the WMP and provide recommendations on mitigating wildfire risk. AB 1054 contains similar WMP requirements to SB 901 but allows WMPs of a three-year, rather than one-year duration.

AB 111 establishes the Wildfire Safety Division within the Public Utilities Commission.

C. Northern California Power Agency WMP Requirements

PUC §8387(b)(2) lists the statutory requirements for WMPs. These are the specific elements that the independent evaluator must review in order to make its determination for this report. The specific elements that must be addressed in NCPA's WMP are included in Table A (see Attachment A) and are summarized here for reference.

- The responsibilities of persons responsible for executing the plan.
- The objectives of the wildfire mitigation plan.
- The preventive strategies and programs to be adopted to minimize the risk of its electrical lines and equipment causing catastrophic wildfires.
- The metrics to use to evaluate the wildfire mitigation plan's performance.
- How the application of previously identified metrics has informed the wildfire mitigation plan.
- Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts.
- Procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. Plans for vegetation management.
- Plans for inspections of the electrical infrastructure.
- Description of all wildfire risks, and drivers for those risks, throughout the service territory, including design, construction, operation, and maintenance of equipment and facilities, and topographic and climatological risk factors.
- Identification of any geographic area in the service territory that is a higher wildfire threat than is identified in a commission fire threat map.
- Identification of enterprise-wide safety risk and wildfire-related risks.
- How the service will be restored after a wildfire.
- The processes and procedures used to monitor and audit the implementation of the wildfire mitigation plan, identify any deficiencies, and the effectiveness of electrical line and equipment inspections.

III. DESCRIPTION OF NORTHERN CALIFORNIA POWER AGENCY

NCPA is a Joint Powers Agency, which owns and operates electrical generation facilities. NCPA is governed by a Commission comprised of one representative for each of its public power utility members.

The WMP applies to a geothermal facility and a hydro facility that are located in two different geographical areas. These two facilities contain electrical equipment in high fire threat locations. The geothermal plant is located around the Geyser territory in Lake County and the Hydro Electric Facility is located in the North Fork Stanislaus River watershed (Calaveras County).

NCPA electrical infrastructure consists of facilities that are in Moderate to Very High Fire Hazard Severity Zones (CAL FIRE) and/or Tier 2/3 CPUC Fire Threat Zones.

NCPA has taken appropriate actions to help prevent and respond to the increasing risk of devastating wildfires by following all applicable design, construction, operation, and maintenance requirements that reduce safety risks associated with its electric system.

IV. INDEPENDENT EVALUATION

A. Independent Evaluator Requirement

PUC §8387 requires each POU to “contract with a qualified independent evaluator with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan.” Additionally, the independent evaluator’s assessment of the comprehensiveness of the POU’s WMP must be issued in a report that is both posted to the POU’s website and presented at a public meeting of the POU’s governing board.

B. Dudek’s Qualifications

According to PUC §8387(c), the qualified independent evaluator that performs the assessment of NCPA’s WMP must have “experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan.” NCPA has determined that Dudek is the independent evaluator who adequately understands the local conditions and fire risks of the service area.

C. Evaluation Methodology

Dudek evaluated the comprehensiveness the NCPA WMP on the following measures:

- **Statutory Compliance:** Dudek ensured that each required element specified in PUC §8387 is either addressed in NCPA’s WMP or that NCPA has sufficiently described why that element is not applicable due to NCPA’s size, geography, system or other relevant factor.
- **Industry Comparison:** Dudek is familiar with existing industry practices and has reviewed the local POU WMPs previously filed with the CPUC. Dudek has compared NCPA’s WMP against existing practices and any comparable actions planned by the POU’s.

D. Metrics

The NCPA WMP uses the following metrics to measure performance of its wildfire mitigation measures: (1) number of fire ignitions, and (2) wires down events. Dudek has determined that these are appropriate metrics for this WMP. Dudek will continue to monitor the metrics selected in the CPUC’s current Wildfire Mitigation Plan rulemaking for utilities (per R.18-10-007) and determine if any additional metrics are applicable to POU’s and should be incorporated into future WMPs.

V. EVALUATION OF THE NORTHERN CALIFORNIA POWER AGENCY WILDFIRE MITIGATION PLAN

A. Minimizing Wildfire Risks

PUC §8387(a) requires the following: Each local publicly owned electric utility and electrical cooperative shall construct, maintain, and operate its electrical lines and equipment in a manner that will minimize the risk of wildfire posed by those electrical lines and equipment.

The WMP describes the safety-related measures that NCPA follows to reduce its risk of causing wildfires. Dudek has determined that NCPA complies with this standard due to the construction of NCPA’s equipment and resources.

B. Evaluation of WMP Elements

Dudek found that NCPA's WMP meets the statutory requirements of comprehensiveness per PUC §8387. The review of the WMP's elements is summarized relative to the application of the WMP. The table in Attachment A lists each required element for NCPA's WMP and provides Dudek's assessment of the comprehensiveness of that element within the WMP.

Below is a brief summary of WMP elements as required by PUC §8387, including restating sections of the WMP where applicable.

8387(b)(2)(A): Responsibilities of Persons Responsible for Executing the Plan.

Under the direction of the Assistant General Manager for Generation Services, the plant managers are responsible for implementation and execution of the WMP with respect to their facilities.

8387(b)(2)(B): Objectives of the Wildfire Mitigation Plan

The objective of the WMP is to reduce the risk of wildfires that could be ignited or propagated by NCPA electrical equipment or facilities in high fire threat locations.

8387(b)(2)(C): Prevention Strategies and Programs

NCPA's strategies to reduce wildfire risk include continuous evaluation and improvement of its programs and procedures: including NCPA's (1) facility maintenance program, (2) emergency operating procedures, (3) vegetation management programs, and (4) asset documentation programs. These programs include all details such as goals, objective or percentage, monitor ongoing work, accomplishments, internal and external audits, and detailed reports.

8387(b)(2)(D): Metrics and Assumptions for Measuring WMP Performance

The NCPA WMP uses two metrics to measure performance of its wildfire mitigation measures: (1) number of fire ignitions, and (2) wires down events. Dudek has determined that these are appropriate metrics for this WMP.

8387(b)(2)(E): Impact of Previous Metrics on WMP

The metrics show zero incidents and indicate success; no WMP changes due to metrics.

8387(b)(2)(F): Reclosing Protocols

NCPA does not own or use automatic reclosers on its 230 kV within the scope defined in this WMP.

8387(b)(2)(G): De-energization Notification Procedures

In the event of active fire situations, NCPA may be directed by CAL FIRE to de-energize the lines for firefighter and/or aircraft protection. If CAL FIRE requests de-energizing both of the lines, the NCPA Dispatch Center will shut down units before de-energizing these lines.

8387(b)(2)(H): Vegetation Management

NCPA has developed and implemented a Transmission Vegetation Management Program (TVMP) to establish the vegetation maintenance requirements for each facility to achieve reliability of its generation interconnection system. The NCPA document defines procedures for vegetation management. NCPA's

TVMP is the plan for all types of vegetation associated with utility infrastructure, from the ground to the sky, which includes vegetation above and below electrical lines.

8387(b)(2)(I): Inspections

NCPA performs annual inspections of its transmission and distribution facilities in accordance with General Order 95 and General Order 165. In addition to its annual ground-based inspection, NCPA may augment inspections with aerial drone and/or helicopter surveys.

8387(b)(2)(J)(i): Risks and Risk Drivers Associated with Design and Construction Standards

Risks and risk drivers related to design, construction, operation and maintenance include equipment/structure/facilities, object to wire or equipment contact, wire to wire contact, vehicle operations, vegetation clearing, and hot work.

8387(b)(2)(J)(ii): Risks and Risk Drivers Associated with Topographic and Climatological Risk Factors

Risks and risk drivers related to Topographic and Climatological Risk Factors include extended drought, vegetation type, vegetation density, weather, high winds, prevailing winds, terrain, changing weather patterns and communities at risk.

8387(b)(2)(K): Geographical Area of Higher Wildfire Threat

To identify the areas of NCPA's service territory that are at an elevated or extreme risk of power line-ignited wildfire, NCPA has incorporated the High Fire-Threat District into its construction, inspection, maintenance, repair, and clearance practices, where applicable.

8387(b)(2)(L): Enterprise-wide Safety Risks

NCPA regularly evaluates enterprise safety risks, which include severe operating conditions and contingencies. NCPA also performs regular analysis of risks to improve the ability to manage the risks effectively.

8387(b)(2)(M): Restoration of Service

After a de-energization event, NCPA will restore service in coordination with PG&E's restoration efforts. NCPA will follow PM-201 and Geothermal Facilities Maintenance Procedure (GEO-646) which specifically address restoration for Hydro and Geothermal facilities respectively.

8387(b)(2)(N)(i): Monitoring and Auditing WMP Implementation

The WMP is presented to the NCPA Commission on an annual basis along with metrics and a summary of updates.

8387(b)(2)(N)(ii): Identifying and correcting WMP deficiencies

NCPA may correct deficiencies and implement plan improvements as needed. Improvements will be documented in the annual report to the NCPA Commission.

8387(b)(2)(N)(iii): Monitoring and Auditing the effectiveness of inspections

NCPA uses General Orders 95 and 165 as guides to inspect its electric supply system.

CONCLUSION

Dudek concludes that the Northern California Power Agency Wildfire Mitigation Plan comprehensively addresses all of the applicable statutorily required elements for a Publicly Owned Utilities' WMP as specified in California

DUDEK

Public Utilities Code Section 8387, and has been updated to include modifications from the previous year's WMP. Dudek further finds that NCPA has taken reasonable actions to minimize the risk that its lines or equipment will cause a wildfire.

Prepared by,



Douglas V. Nickles, RPF
Fire Protection Specialist

Att.: A. *WMP Required Element Compliance Matrix under PUC Section 8387*
B. *Wildfire Safety Advisory Board 2020 Guidance Recommendations Compliance Matrix*
cc: Scott Eckardt, Dudek

WMP Required Element per PUC Sec 8387(b)(2)	NCPA WMP Section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions	IE's 2nd Assessment of WMP
(A): An accounting of the responsibilities of persons responsible for executing the plan.	Sec. 3.A Utility Governance Structure. Generation Services Assistant General Manager.	Needs clarification of responsibilities. While the organizational structure, responsible department and responsible position are identified, it is not clear what the responsible position's responsibilities are for executing the WMP.	NCPA - Complete. Added "and responsible for executing the WMP"	Meets requirements as modified.
(B): The objectives of the wildfire mitigation plan.	Executive Summary and Sec. 1.B. Purpose of the WMP. 2. Goals.	Meets requirements.	NA	Meets requirements.
(C): A description of the preventive strategies and programs to be adopted by the local publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.	Sec. 5.A. Preventative Strategies and Programs. Sec. 5.C. Potential Climate Change Effects. Sec. 5.D. Potential Climate Change Risk Management Impacts.	Add description of programs. Reference is made to the line maintenance program. No definitive description is provided for the proposed programs.	NCPA - Complete. Revised NCPA's (1) facility maintenance program, (2) emergency operating procedures, (3) vegetation management programs, and (4) asset documentation programs.	Meets requirements as modified.
(D): A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan's performance and the assumptions that underlie the use of those metrics.	Sec. 7.A. Metrics and Assumptions for Measuring Plan Performance.	Meets requirements.	NA	Meets requirements.

WMP Required Element per PUC Sec 8387(b)(2)	NCPA WMP Section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions	IE's 2nd Assessment of WMP
(E): A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.	Sec. 7.B. Impact of Metrics on Plan.	Include discussion of application of previous metrics. No reference is included regarding the impacts on the WMP from past metrics.	NCPA - Complete. Added "2020 WMP Impact Due to Metrics" along with establishing metric summaries to review.	Meets requirements as modified.
(F): Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure.	Sec. 5.I. Reclosing Policy. Sec. 5.J. De-Energization. Sec. 5.J.1. Impacts to Public Safety.	Enhance section to clarify role as wholesaler vs. retailer. Reclosers are not employed. Impacts to Public Safety is addressed; any impacts would be addressed by providers of PSPS. Any de-energization is coordinated with Cal Fire and PG&E.	NCPA - Complete. Changed "employ" to "own."	Meets requirements as modified.
(G): Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. The procedures shall direct notification to all public safety offices, critical first responders, health care facilities, and operators of telecommunications infrastructure with premises within the footprint of potential deenergization for a given event.	Sec. 5.J.2. Customer Notification Protocols.	Enhance section to clarify role as wholesaler vs. retailer. As a wholesale provider NCPA has no retail customers; any impacts would be addressed by providers of PSPS.	NCPA - Complete. Added wholesaler vs retailer clarification.	Meets requirements as modified.
(H): Plans for vegetation management.	Sec. 5.F. Vegetation Management.	Meets requirements.	NA	Meets requirements.

WMP Required Element per PUC Sec 8387(b)(2)	NCPA WMP Section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions	IE's 2nd Assessment of WMP
(I): Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.	Sec. 5.G. Inspections.	Meets requirements.	NA	Meets requirements.
(J): A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility's or electrical cooperative's service territory. The list shall include, but not be limited to, both of the following: (i) Risks and risk drivers associated with design, construction, operation, and maintenance of the local publicly owned electric utility's or electrical cooperative's equipment and facilities. (ii) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned electric utility's or electrical cooperative's service territory.	Sec. 4. Wildfire Risks and Drivers. Sec. 4.A. Risks Associated with Topographical and Climatological Factors.	Add list of risks and risk drivers related to design, construction, operation and maintenance; they currently are not addressed.	NCPA - Complete. Clarified 4.B. are Risks and risk drivers related to design, construction, operation and maintenance that could create fire ignition sources.	Meets requirements as modified.

WMP Required Element per PUC Sec 8387(b)(2)	NCPA WMP Section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions	IE's 2nd Assessment of WMP
(K): Identification of any geographic area in the local publicly owned electric utility's or electrical cooperative's service territory that is a higher wildfire threat than is identified in a commission fire threat map, and identification of where the commission should expand a high-fire threat district based on new information or changes to the environment.		Not addressed. Rather than referring solely to the High Fire-Threat District, include description of the local geography, any specific areas of concern and identification of any changes to be made.	NCPA - Complete. Addressed in 4.c. "NCPA has reviewed current CAL FIRE hazard severity zone and CPUC fire-threat maps with respect to agency facilities, as shown in Appendix 1. These maps have not been adjusted since the noted publication dates nor have any local agencies imposed any expansions to the maps."	Meets requirements as modified.
(L): A methodology for identifying and presenting enterprise-wide safety risk and wildfire-related risk.	Sec. 4.B. Enterprise-wide Safety Risks.	Meets requirements.	NA	Meets requirements.
(M): A statement of how the local publicly owned electric utility or electrical cooperative will restore service after a wildfire.	Sec. 7. Restoration of Service.	Needs clarification and details. Statement is very limited with no details, only that restoration will occur in coordination with PG&E and GO-646 procedures. The section should be enhanced to include details on PG&Es restoration efforts and the GO-646 procedure.	NCPA - Complete. Revised this plan to include the statement NCPA will follow PM-201 and Geothermal Facilities Maintenance Procedure (GO-646) specifically address restoration for Hydro and Geothermal facilities respectively. These procedures contain the steps that must be taken to restore such as inspecting, repairing, testing, and finally restoring.	Meets requirements as modified.

WMP Required Element per PUC Sec 8387(b)(2)	NCPA WMP Section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions	IE's 2nd Assessment of WMP
<p>(N): A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following: (i) Monitor and audit the implementation of the wildfire mitigation plan. (ii) Identify any deficiencies in the wildfire mitigation plan or its implementation, and correct those deficiencies. (iii) Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the plan, other applicable statutes, or commission rules.</p>	<p>Sec. 7.C. Monitoring and Auditing the Plan. Sec. 7.D. Identifying and Correcting Deficiencies in the Plan. Sec. 7.E. Monitoring the Effectiveness of Inspections.</p>	<p>The section should be enhanced to include details on how the monitoring will occur throughout the year. It is not clear how deficiencies are identified. Clarification is needed whether or not the proposed effectiveness inspection methods are actually taking place, and if so, by whom.</p>	<p>NCPA - Complete. Added yearly metrics summary including impact to the plan from the metrics summary.</p>	<p>Meets requirements as modified.</p>

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
1. Plan Structure – risk profile				
a) The WMP and Independent Evaluator Reports should be prominently displayed and easily located on the POU websites.	NA	Reports are displayed on POU website.	NCPA - Complete. http://www.ncpa.com/bidding-opportunities-and-public-notifications/environmental-documents/	Meets WSAB recommendation.
b) Include an index or table that shows where each section of the statute is addressed in the WMP.	Not included.	Include the statute compliance spreadsheet developed by Dudek as Appendix.	Dudek	Meets WSAB recommendation.
c) Include context-setting information at the beginning of each POU plan about each POU's risk profile in accordance with the statutory requirements Public Utilities Code Section 8387(b)(2)	Not included.	Prepare the requested context-setting information and include in Section 1.	NCPA - Complete. Added "NCPA is a Joint Powers Agency, which owns and operates electrical generation. The scope of this plan applies the Geothermal Facility and the Hydro Facility that are located in two different geological areas. These two facilities contain electrical equipment in high fire threat locations. The Geothermal Plant is located around the Geyser territory in Lake County and the Hydro Electric Facility is located in around North Fork Stanislaus."	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
d) Apply the Board developed template for review of POU WMPs	Not included.	Prepare the requested template and include in Section 1 (attached below).	NCPA. Complete created new table section 1.	Meets WSAB recommendation.
2. Plan Structure – approval process				
a) Provide a paragraph describing the public review process of the plan and how it is approved, if required	Not included.	Prepare the requested paragraph and include in Section 1.	NCPA. Completed. Added to the purpose of the plan to help fill in the overall story. Very ending paragraph to the appending process. "In 2020, This WMP was presented and recorded at a public Brown Act Meeting and is posted on a public website domain..."	Meets WSAB recommendation.
b) Include additional data on monitoring and auditing and how that information is presented	Not included.	Prepare the requested additional data regarding how the information is presented and include in Section 7.C.	NCPA. Complete. Revised to "This WMP is presented to the NCPA Commission on an annual basis along with metrics and a summary of updates."	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
c) Provide a brief explanation on each funding mechanism to be used to perform wildfire mitigation	Not included.	Prepare the requested explanation for each wildfire mitigation funding mechanism and include in the respective section (i.e., 3.B., 3.C., 5.A., 5.F, 5.G, 5.H).	NCPA - Complete. The following statement applies to all funding authority "NCPA is governed by a Commission comprised of one representative for each member. The Commission is responsible for the general management of the affairs, property, and business of the Agency. Under the direction of the General Manager, the staff of the Agency is responsible for providing various administrative, operating and planning services for the Agency. This establishes all funding and is applied to all wildfire funding mechanisms in this plan (i.e., 3.B., 3.C., 5.A., 5.F, 5.G, 5.H)."	Meets WSAB recommendation.
3. Plan Structure – independent evaluations				
a) IEs should perform a robust evaluation of the contents and substance of the POUs WMP	NA	Dudek to perform the requested evaluation.	Dudek	Meets WSAB recommendation.
b) Include evaluations of how each POU compares to the IE's assessment of industry standards	NA	Dudek to perform the requested evaluation.	Dudek	Meets WSAB recommendation.
4. Plan structure – Utility groupings				

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
a) 2021 POU WMPs and/or updates should be based on the guidelines		WMP to be updated in accordance with the recommended guidelines.	NCPA - Complete. This evaluation serves as a WMP updated based on Dudek's and WSAB recommendations.	Meets WSAB recommendation.
b) The industry should create a revised template that reflects the learnings from the 2020 initial effort	NA	NA	NA	NA
5. Customer Impacts – PSPS shutoffs				
a) Utilities should provide the context-setting information	Sec. 5.J.2. Customer Notification Protocols	The context-setting information should be enhanced in this section to reference customer impacts as well as customer notification (re-emphasize role as wholesaler vs. retail provider). Consider adding a separate Customer Impacts section.	NCPA - Complete. Revised as "NCPA provides wholesale power to City's and utilities typically known as NCPA members. Since NCPA does not have retail customers, like commercial or private residences, no customer notification protocols are in place."	Meets WSAB recommendation.
b) Include a detailed protocol to address these concerns to understand the strategic direction and effectiveness of each POU	Sec. 5.J.2. Customer Notification Protocols	See 5.a) above.	NCPA - Complete. Revised as "NCPA provides wholesale power to City's and utilities typically known as NCPA members. Since NCPA does not have retail customers, like commercial or private residences, no customer notification protocols are in place."	Meets WSAB recommendation.
6. Customer impacts – communication plans				

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
a) Describe the specific methods, content, and timing used to communicate with customers	Sec. 5.J.2. Customer Notification Protocols	The communication information should be enhanced in this section to reflect the context-setting information requested as noted above in 5.a).	NCPA - Complete. Revised as "NCPA provides wholesale power to City's and utilities typically known as NCPA members. Since NCPA does not have retail customers, like commercial or private residences, no customer notification protocols are in place."	Meets WSAB recommendation.
b) Provide an evaluation of whether the current method of emergency communication appears sufficient and, if not, what can be done to improve it, especially protocols for notifying customers, essential service providers, and other critical facilities of IOU or self-triggered PSPS events	Sec. 5.J.2. Customer Notification Protocols	See 5.a) above.	NCPA & Dudek - Complete. "Complete. Revised as "NCPA provides wholesale power to City's and utilities typically known as NCPA members. Since NCPA does not have retail customers, like commercial or private residences, no customer notification protocols are in place."	Meets WSAB recommendation.
7. The Grid – hardening				
a) Provide information on existing and planned system upgrades	Sec. 2.B. Resiliency of the Electric Grid	Enhance this section to provide specific examples of upgrades as requested.	NCPA - Complete. NCPA is a relatively smaller utility with a small asset count. The list is updated and on 5.A. (1)	Meets WSAB recommendation.
b) Provide details of each utility's system hardening and grid design programs described in the WMP filing	Sec. 2.A. Minimizing Sources of Ignition	Enhance this section to provide details of programs as requested.	NCPA - Complete. Organized programs and procedures 5.A.	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
c) Indicate the goals of the programs and the risk any particular program is designed to mitigate	Sec. 2 Goals	Enhance this section to show nexus between goals, programs and mitigation as requested.	NCPA - Complete. Revised and organized programs and procedure in Section 5.	Meets WSAB recommendation.
d) Provide the approach to PSPS mitigation and prevention	Sec. 3.C. Wildfire Response and Recovery; Sec. 5.J.1. Impacts to Public Safety; Sec. 5.J.2. Customer Notification Protocols	The PSPS information should be enhanced to reference mitigation and prevention as requested (re-emphasize role as wholesaler vs. retail provider). Consider adding a separate "PSPS" section.	NCPA - Complete. Added NCPA's wholesaler information to first paragraph for clarification.	Meets WSAB recommendation.
e) Identify any supply shortages	NA	Identify any supply shortages as requested. See 7.d) above.	NCPA - Complete. Updates to include "no supply shortages" in relation to PSPS.	Meets WSAB recommendation.
8. The Grid – inspections				
a) Describe the unique risks a utility is inspecting for, such as insect, wildfire incursion, wood split, woodpeckers, purposeful insulator destruction, termites, etc., to be included in the WMP	Sec. 5.G. Inspections	Enhance this section to describe the unique risks as requested.	NCPA - Complete. Added "Section 4.B. of this WMP outlines the unique risks NCPA inspects for. "	Meets WSAB recommendation.
b) Describe whether and how system inspections lead to system improvements	Sec. 5.G. Inspections	Enhance this section to describe the resulting system improvements as requested.	NCPA - Complete. Added "NCPA's asset management system also allows these improvements to be evaluated as observations and comments are made when work orders for	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
			maintenance items are executed."	
9. The Grid – risks				
a) Consider different options for surfacing, for further consideration and remediation, previously unidentified risks that could lead to catastrophic wildfires	Sec. 4 Wildfire Risks and Drivers	Enhance this section to describe the different options considered as requested.	NCPA - Updated Section 5.A. (1) to add "NCPA's aggressive approach to reduce transmission tie-line risk by completely upgrading insulators on this asset, NCPA's longest line, of 40 Miles. This project was considered a major cost in capital and prioritized for wildfire prevention."	Meets WSAB recommendation.
10. Risk assessment – construction				
a) State the particular wildfire risks associated with system design and construction such as topography and location near a HFTD of another utility	Not included. Wildfire risks are identified in Sec. 4.A., but there is no reference to design and construction.	Include risks associated with design and construction as requested.	NCPA - Complete. Added "There are no new wildfire risks associated to design and construction of new assets. NCPA is currently Operating and Maintain original generating facilities. No new construction in the immediate future."	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
b) Provide information about G.O. 95 exempt assets, and possible updates to G.O. 95, that could facilitate more resilient utility transmission and distribution assets	Not included.	Include information about exempt assets and updates as requested, possibly in Sec. 2. B.	NCPA - Complete. Leave as stated in Section 5.E.. "NCPA meets: (1) Public Resources Code section 4292; (2) Public Resources Code section 4293; (3) General Order 95 Rule 35; and (4) General Order 95 Appendix E Guidelines to Rule 35."	Meets WSAB recommendation.
11. Risk assessment – situational awareness				
a) Include context setting information in the WMPs including information about the prevailing wind directions and speeds, differentiated by season, along with average weather conditions by season	Sec. 4.A. Risks Associated with Topographical and Climatological Factors.	Enhance this section with context setting information as requested, including the detailed wind information.	NCPA - Complete. "Prevailing Winds: Using live data, NCPA monitors prevailing winds directions and speeds, differentiated by season, along with average weather conditions by season using NCPA real-time observations noting disturbing local weather. Live data is used with the fire maps located in Appendix 1. PG&E's Weather Awareness website is a resource for real-time conditions: https://www.pge.com/en_US/safety/emergency-preparedness/natural-disaster/wildfires/psps-weather-	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
			map.page?WT.mc_id=Vanity_weather"	
b) Include information on how and why situational awareness technology is installed, and where on the system	Sec. 5.A. Preventative Strategies and Programs.	Enhance this section with information on technology installation as requested.	NCPA - Complete. Added for clarity. "This information is used in communication and aids to analyze wildfire situations."	Meets WSAB recommendation.
c) Provide insight into decisions that are made not to install situational awareness technology	Sec. 5.A. Preventative Strategies and Programs.	See 11.c) above.	NCPA	Meets WSAB recommendation.
d) Are there constraints such as budgets, availability of equipment, knowledge to effectively deploy, or qualified personnel to install and monitor effectively?	Sec. 5.A. Preventative Strategies and Programs.	Enhance this section to address the constraints listed as requested.	NCPA - Complete. Added to 5.A. "There are no constraints such as budgets, availability of equipment, knowledge to effectively deploy, or qualified personnel to install and monitor effectively."	Meets WSAB recommendation.
e) Provide information about whether this modeling data is received from or	Sec. 5.A. Preventative	Enhance this section to provide information regarding modeling data as requested.	NCPA - Complete. Data source is shared and comes from PGE.	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
shared with other agencies, utilities, or fire professionals	Strategies and Programs.			
12. Vegetation Management – utility requirements				
a) Describe treatment plans for all types of vegetation associated with utility infrastructure, from the ground to the sky, which includes vegetation above and below electrical lines	Sec. 5.F. Vegetation Management	Enhance this section to describe the treatment plans as requested (reference is made to the TVMP - provide details).	NCPA - Added clarity that section 5.E. is "NCPA's plan for all types of vegetation associated with utility infrastructure, from the ground to the sky, which includes vegetation above and below electrical lines. "	Meets WSAB recommendation.
13. Vegetation management – personnel qualifications				
a) List the qualifications of any experts relied upon, such as scientific experts in ecology, fire ecology, fire behavior, geology, and meteorology	Sec. 5.F. Vegetation Management	Enhance this section to list the qualifications as requested.	NCPA - Complete added to section 5.E. "NCPA uses a combination of its own staff (manager, supervisor or competent designee) and the retention of qualified consultants (such as scientific experts in ecology, fire ecology, fire behavior, geology, and meteorology) with experience in line design, line construction, NERC Standards compliance, and vegetation management to develop and maintain the TVMP."	Meets WSAB recommendation.

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
b) Specify the level of expertise of the POU staff that manages the contractors performing vegetation management	Sec. 5.F. Vegetation Management	Enhance this section to specify the level of expertise as requested.	NCPA - Complete. "NCPA uses a combination of its own staff (manager, supervisor or competent designee) and the retention of qualified consultants (such as scientific experts in ecology, fire ecology, fire behavior, geology, and meteorology) with experience in line design, line construction, NERC Standards compliance, and vegetation management to develop and maintain the TVMP."	Meets WSAB recommendation.
c) Describe measures taken to ensure that POU staff and contractors comply with or verify compliance with Cal/OSHA standards on Minimum Approach Distances (MAD)	Sec. 5.F. Vegetation Management	Enhance this section to describe the measures as requested.	NCPA - Complete. The TVMP specifies technical requirements for staff and contractors to comply with or verify compliance with Cal/OSHA standards and NCPA Electrical Safety Procedure GS-103 ensures Cal/Osha and Minimum Approach Distances (MAD).	Meets WSAB recommendation.
14. Vegetation management - innovation				

WSAB 2020 WMP Guidance Recommendations	NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
a) Describe whether the POU has considered innovative and alternative approaches to vegetation management such as, but not limited to, requiring property owners to manage vegetation a certain distance from structures or utility lines, and pilot programs in home hardening	Sec. 5.F. Vegetation Management	Enhance this section to describe the approaches considered as requested.	NCPA - No innovative ideas to note.	Meets WSAB recommendation.

APPENDIX 4 – INDEPENDENT EVALUATOR REPORT 2022

DUDEK

1630 SAN PABLO AVENUE, SUITE 300
OAKLAND, CALIFORNIA 94612
T 510.601.2500 F 510.601.2501

April 14, 2022

12108.07

Mr. Jeremy Lawson
Northern California Power Agency
651 Commerce Drive
Roseville, CA 95678

Subject: Independent Evaluation Report of Northern California Power Agency's 2022 Wildfire Mitigation Plan

1 Introduction

The Northern California Power Agency (NCPA) contracted with Dudek to engage in an independent evaluation of its Wildfire Mitigation Plan (WMP). This independent evaluation report (Report) describes the technical review and evaluation of the WMP prepared by Dudek, performed in February through April 2022, and completed on April 14, 2022.

Dudek conducted an evaluation of NCPA's WMP, as required under California Public Utilities Code (PUC) §8387(b). PUC §8387(b), as modified by Senate Bill (SB) 901, and the Administrative Law Judge's Ruling issued on January 17, 2019 in California Public Utilities Commission (CPUC) Docket No. R.18-10-007 (ALJ Ruling), applies to publicly owned electric utilities and required preparation of a WMP before January 1, 2020, and revising/updating the WMP in 2020 and annually thereafter.

The WMP requirements are codified in PUC §8387(b)(2) for local publicly owned electric utilities (POUs). PUC §8387(c) requires that an independent evaluator review and assess the comprehensiveness of a POU's WMP and issue a summary report.

Dudek conducted an initial review of NCPA's WMP (version 1.3) and provided recommendations for clarifications/modifications on March 3, 2022. The focus of the evaluation was to determine whether the WMP included all elements required under PUC §8387(b)(2) (listed in Attachment A). The evaluation determined that the NCPA's 2022 Wildfire Mitigation Plan does include all the PUC §8387(b)(2) requirements.

In addition to evaluating the elements required by the Public Utility Code, Dudek evaluated the WMP for compliance with the Wildfire Safety Advisory Board (WSAB) Publicly Owned Utilities (POUs) WMP guidance recommendations and to address any deficiencies in the WSAB review of the 2022 WMP that was published on their website. Dudek worked NCPA staff to revise the WMP to meet the recommendations of the Guidance Advisory Opinion for 2022 WMPs that are relevant to the NCPA's service territory (See Attachment B for Compliance Matrix). This included more detailed explanations of the wildfire risks in the utility's service territory and the wildfire prevention programs that are designed to address these risks.

DUDEK.COM

2 Wildfire Mitigation Plan Requirements

A. Senate Bill 901

Per Senate Bill (SB) 901, all Publicly Owned Utilities are required to adopt a Wildfire Mitigation Plan (WMP), which shall be reviewed by an independent third-party evaluator. SB 901 requires the governing board to determine whether any portion of the geographical area where the utility's overhead electrical lines and equipment are located has a significant risk of catastrophic wildfire resulting from those electrical lines and equipment. The bill directs electrical utilities to annually prepare WMPs that include several mitigation and response elements in each utility's strategies, protocols, and programs. Each electric utility is to prepare and adopt a comprehensive WMP before January 1, 2020. The requirements for POU's are presented in PUC §8387. In addition, the WMP shall be reviewed by an approved, independent, third-party evaluator to review and assess the comprehensiveness of, and the POU's compliance with, this Plan.

B. AB 1054 & AB 111

Per Assembly Bill (AB) 1054, POUs must annually submit a WMP to the California Wildfire Safety Advisory Board, which will review the WMP and provide recommendations on mitigating wildfire risk. AB 1054 contains similar WMP requirements to SB 901 but allows WMPs of a three-year, rather than one-year duration. AB 111 establishes the Wildfire Safety Division within the Public Utilities Commission.

C. Northern California Power Agency WMP Requirements

PUC §8387(b)(2) lists the statutory requirements for WMPs. These are the specific elements that the independent evaluator must review to make its determination for this report. The specific elements that must be addressed in NCPA's WMP are included in Table A (see Attachment A) and are summarized here for reference.

- The responsibilities of persons responsible for executing the plan.
- The objectives of the wildfire mitigation plan.
- The preventive strategies and programs to be adopted to minimize the risk of its electrical lines and equipment causing catastrophic wildfires.
- The metrics to use to evaluate the wildfire mitigation plan's performance.
- How the application of previously identified metrics has informed the wildfire mitigation plan.
- Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts.
- Procedures for notifying a customer who may be impacted by the deenergizing of electrical lines.
- Plans for vegetation management.
- Plans for inspections of the electrical infrastructure.
- Description of wildfire risks, and drivers for those risks, throughout the service territory.
- Identification of any geographic area in the service territory that is a higher wildfire threat than is identified in a commission fire threat map.
- Identification of enterprise-wide safety risk and wildfire-related risks.
- How the service will be restored after a wildfire.
- The processes and procedures used to monitor and audit the implementation of the wildfire mitigation plan, identify any deficiencies, and the effectiveness of electrical line and equipment inspections.

3 Description of the Northern California Power Agency

NCPA is a Joint Powers Agency, which owns and operates electrical generation facilities. NCPA is governed by a Commission comprised of one representative for each of its public power utility members.

The WMP applies to the NCPA's geothermal facility and a hydro facility plus transmission and distribution lines. These two facilities contain electrical equipment in high fire threat locations and power lines that traverse high fire threat areas. The geothermal facility is located around the Geysers territory in Lake County and consists of five geothermal facilities spread over 30 square miles. The Hydro Electric facility is in the North Fork Stanislaus River watershed (Calaveras County) and consists of eight generator/water diversion stations and an office located along the river. There are approximately 40 miles of power lines between the generation facilities and their tie-in points with PG&E transmission wires. NCPA electrical infrastructure consists of facilities that are in Moderate to Very High Fire Hazard Severity Zones (CAL FIRE) and/or Tier 2/3 CPUC Fire Threat Zones.

NCPA has taken appropriate actions to help prevent and respond to the increasing risk of devastating wildfires by following all applicable design, construction, operation, and maintenance requirements that reduce safety risks associated with its electric system.

4 Independent Evaluation

A. Independent Evaluator Requirement

PUC §8387 requires each POU to "contract with a qualified independent evaluator with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan." Additionally, the independent evaluator's assessment of the comprehensiveness of the POU's WMP must be issued in a report that is both posted to the POU's website and presented at a public meeting of the POU's governing board.

B. Dudek's Qualifications

According to PUC §8387(c), the qualified independent evaluator that performs the assessment of NCPA's WMP must have "experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan." NCPA has determined that Dudek is the independent evaluator who adequately understands the local conditions and fire risks of the service area.

C. Evaluation Methodology

Dudek evaluated the comprehensiveness of the NCPA's 2022 WMP on the following measures:

- **Statutory Compliance:** Dudek ensured that each required element specified in PUC §8387 is either addressed in NCPA's WMP or that NCPA has sufficiently described why that element is not applicable due to NCPA's size, geography, system, or other relevant factor.
- **Fulfillment of Wildfire Safety Advisory Board Guidance:** Dudek reviewed WSAB guidance publications for Publicly Owned Utilities for recommendations that were relevant to the NCPA's WMP and then compared the Board's recommendation to the content of the WMP.

- **Industry Comparison:** While the NCPA differs from many nearby utilities in that they provide power to other utility agencies and not consumers, they do use similar equipment and operational procedures as nearby POUs that serve consumers. Dudek compared the elements of the NCPA's WMP, their operations, and the equipment to those used by other agencies to minimize wildfire ignition and spread. Where there was no other agency(s) to compare to (e.g., geothermal plants), Dudek used industry standards.

D. Metrics

The NCPA's Wildfire Mitigation Plan uses the following metrics to measure performance of its wildfire mitigation measures: (1) number of fire ignitions, and (2) wires down events. Dudek has determined that these are appropriate metrics for this WMP and that the WSAB has concluded that these two metrics, are generally acceptable metrics for a WMP.

Dudek recommended that the NCPA consider adding a new metric or revising one of the current metrics to integrate a metric that shows the actions NCPA is taking in their service territory to reduce wildfire ignition risk. NCPA staff acted on Dudek's recommendation, evaluating their current operations and their service territory for other useful indicators of wildfire risk. Fire weakened trees and slopes are hazard to NCPA's transmission wires where they pass through fire scars. NCPA is incorporating a third metric into their WMP that measures fall in trees, trees of height sufficient to represent a contact hazard to the Distribution Line if destabilized due to soil instability at the tree base,

5 Evaluation of the Northern California Power Agency Wildfire Mitigation Plan

A. Minimizing Wildfire Risks

PUC §8387(a) requires the following: "Each local publicly owned electric utility and electrical cooperative shall construct, maintain, and operate its electrical lines and equipment in a manner that will minimize the risk of wildfire posed by those electrical lines and equipment."

The WMP describes the safety-related measures that NCPA follows to reduce its risk of causing wildfires. Dudek has determined that NCPA complies with this standard through the design of its system and the construction of its equipment and resources.

B. Evaluation of WMP Elements

Dudek found that NCPA's WMP meets the statutory requirements of comprehensiveness per PUC §8387. The review of the WMP's elements is summarized relative to the application of the WMP. The table in Attachment A lists each required element for NCPA's WMP and provides Dudek's assessment of the comprehensiveness of that element within the WMP.

Below is a summary of the WMP elements as required by PUC §8387, including restating sections of the WMP where applicable.

8387(b)(2)(A): Responsibilities of Persons Responsible for Executing the Plan.

Under the direction of the Assistant General Manager for Generation Services, the plant managers are responsible for implementation and execution of the WMP with respect to their facilities. The NCPA dispatch center in Roseville has responsibility for the generator tie-in lines.

8387(b)(2)(B): Objectives of the Wildfire Mitigation Plan

The objectives of the WMP are to: minimize the probability that NCPA's system is the origin or contributing source for a wildfire ignition, improve the resiliency of the electric grid, specifically to reduce the likelihood of an interruption of service and an improvement in the restoration of service after an interruption, and to improve the effectiveness of their wildfire prevention strategies by modifying or replacing elements of their wildfire prevention program that are ineffective

8387(b)(2)(C): Prevention Strategies and Programs

NCPA's strategies to reduce wildfire risk include continuous evaluation and improvement of its programs and procedures: including NCPA's (1) facility maintenance program, (2) emergency operating procedures, (3) vegetation management programs, and (4) asset documentation programs. These programs include all details such as goals, objective, or percentage, monitor ongoing work, accomplishments, internal and external audits, and detailed reports. Additional programs such as coordination with CAL FIRE and wildfire prevention training for NCPA staff complement their core fire prevention programs. Attachment C in the WMP contains a table which describes identified risk drivers within NCPA service territory and preventative strategies implemented by the utility. The table includes controls NCPA has implemented to address each risk or risk driver listed.

8387(b)(2)(D): Metrics and Assumptions for Measuring WMP Performance

The NCPA WMP uses two metrics to measure performance of its wildfire mitigation measures: (1) number of fire ignitions, and (2) wires down events. Dudek has determined that these are appropriate metrics for this WMP.

8387(b)(2)(E): Impact of Previous Metrics on WMP

The metrics show zero incidents and indicate success; no WMP changes due to metrics.

8387(b)(2)(F): Reclosing Protocols

NCPA does not own or use automatic reclosers on its 230 kV within the scope defined in this WMP. This is a typical industry standard for distribution and transmission wires in rugged and remote terrain.

8387(b)(2)(G): De-energization Notification Procedures

In the event of active fire situations, NCPA may be directed by CAL FIRE to de-energize the lines for firefighter and/or aircraft protection. NCPA de-energization notification procedures depend on which lines and facilities are being de-energized. If the Hydro facilities and 230 kV lines are de-energized then NCPA personnel will work with CAL FIRE and their dispatch center in Roseville to notify fire fighters, NCPA facility

staff, PG&E, and NCPA members. For the geothermal facilities relies on PG&E to make the determination whether these facilities and their lines are to be de-energized. NCPA dispatch would communicate PG&E direction to NCPA personnel and NCPA members.

8387(b)(2)(H): Vegetation Management

NCPA has developed and implemented a Transmission Vegetation Management Program (TVMP) to establish the vegetation maintenance requirements for each facility to achieve reliability of its generation interconnection system. The NCPA document defines procedures for vegetation management. NCPA's TVMP is the plan for all types of vegetation associated with utility infrastructure, from the ground to the sky, which includes vegetation above and below electrical lines.

8387(b)(2)(I): Inspections

NCPA performs annual inspections of its transmission and distribution facilities in accordance with General Order 95 and General Order 165. Enhanced inspections are performed on the Collierville-Bellota 230 kV line including lidar vegetation flights, corona scans of insulators, infrared inspections of lines and equipment. In addition to its annual ground-based inspection, NCPA may augment inspections with aerial drone and/or helicopter surveys.

8387(b)(2)(J)(i): Risks and Risk Drivers Associated with Design and Construction Standards

Risks and risk drivers related to design, construction, operation, and maintenance include equipment/structure/facilities, object to wire or equipment contact, wire to wire contact, vehicle operations, vegetation clearing, and hot work. Attachment C in the WMP contains a table which describes identified risk drivers within NCPA service territory and preventative strategies implemented by the utility. The list includes risk drivers and risks related to design and construction standards.

8387(b)(2)(J)(ii): Risks and Risk Drivers Associated with Topographic and Climatological Risk Factors

Risks and risk drivers related to Topographic and Climatological Risk Factors include extended drought, vegetation type, vegetation density, weather, high winds, prevailing winds, terrain, changing weather patterns and communities at risk. Communities at risk is a design and construction standard and it is recommended that it is moved to that section. The plan discussed prevailing wind patterns in the service territory and the impact the winds have on the conductors. Also discussed is the impact that previous large fires in their service territory have on risks associated with topographic and climatological factors. Attachment C in the WMP contains a table which describes identified risk drivers within NCPA service territory and preventative strategies implemented by the utility. The list includes risk drivers and risks related to topographic factors within NCPA's service territory.

8387(b)(2)(K): Geographical Area of Higher Wildfire Threat

To identify the areas of NCPA's service territory that are at an elevated or extreme risk of power line-ignited wildfire, NCPA has incorporated the High Fire-Threat District into its construction, inspection, maintenance, repair, and clearance practices, where applicable.

8387(b)(2)(L): Enterprise-wide Safety Risks

NCPA regularly evaluates enterprise safety risks, which include severe operating conditions and contingencies. NCPA also performs regular analysis of risks to improve the ability to manage these risks effectively.

8387(b)(2)(M): Restoration of Service

After a de-energization event, NCPA will restore service in coordination with PG&E's restoration efforts. NCPA will follow PM-201 and Geothermal Facilities Maintenance Procedure (GEO-646) which specifically address restoration for Hydro and Geothermal facilities respectively.

8387(b)(2)(N)(i): Monitoring and Auditing WMP Implementation

The WMP is presented to the NCPA Commission on an annual basis along with the metrics and a summary of updates.

8387(b)(2)(N)(ii): Identifying and correcting WMP deficiencies

NCPA may correct deficiencies and implement plan improvements as needed. Improvements will be documented in the annual report to the NCPA Commission.

8387(b)(2)(N)(iii): Monitoring and Auditing the effectiveness of inspections

NCPA uses General Orders 95 and 165 as guides to inspect its electric supply system. The effectiveness of ground inspections is typically monitored by 'ride-a-longs' performed by NCPA staff and CAL FIRE staff with inspection personnel. Independent professionals are contracted to review lidar data and other inspection data that is collected remotely.

6 Wildfire Safety Advisory Board Recommendations

The Wildfire Safety Advisory Board produces guidance documents for publicly owned utilities annually. These documents describe elements that should be revised or expanded in future WMPs to better organize the plan, clarify where PUC required information can be found, and to provide a more comprehensive description of the utility's wildfire prevention programs. Dudek reviewed the WSAB most recent guidance document and compared contents of the NCPA's 2022 WMP to each recommended element.

1. Plan Structure, Staffing, and Evaluations

A. Context Setting Information: The WSAB recommended that POU's use an upfront table that contains information about the utility including number of customers, the size of its service areas, the service area within a high fire threat area, asset mix, and more. The intent was to provide a reviewer of the plan with a plain and accessible summary of the utility. The WSAB provided a template for this table in 2021. **NCPA's WMP uses the WSAB template and has the completed table in the Overview section of their plan.**

B. General WMP Objectives: Many POU's use two general objectives; 1. Minimizing sources of ignition and 2. Improving the resiliency of the grid. These are valid objectives but the WSAB believes that they may lead

to limited approach by a utility to wildfire prevention. The WSAB recommends that POU's take a broader approach to their objectives and consider objectives that mitigate other risks associated with wildfire such as minimizing wildfire spread. **NCPA's WMP objectives include these two general objectives; however, their WMP does describe wildfire prevention programs that go beyond minimizing new ignitions and hardening their equipment against wildfire. For example, their vegetation management program TVMP inspects and manages surface vegetation near their assets as well as trees near their power lines.**

C. Staff Responsibilities and Approval Protocols: The WSAB requested that future WMPs include additional context information regarding the public input and approval processes for the WMP of each POU. **The WMP contains a description in the Overview section of the NCPA's WMP approval process that begins with a presentation of the WMP to the NCPA Facilities Committee for comment, then is routed for final approval to the NCPA Commission. public meeting and NCPA commission meeting. Past WMP's are available on the NCPA website.**

D. Metric Development and Evaluation: Many POU's use two basic metrics; 1. New ignitions and 2. Wires down. These are valid metrics but the WSAB recommends that POU's consider adding or replacing these metrics with ones that better apply to their service territory and metrics that show progress towards an outcome as opposed to a metric that shows the outcome. **The WMP contains the two-basic metrics, and these are relevant metrics to the NCPA's assets. NCPA is evaluating adding a third metric to evaluate the effectiveness of their plan in reducing the risk posed to their wires by fire weakened trees and slopes. The NCPA does track their two current metrics and the results are published in the WMP.**

2. Grid Design, System Hardening, Operations and Inspections:

A. In 2021 the WSAB requested POUs answer several questions about their system design and construction. The questions: 1. Are there design or construction issues related to the utility's specific topography or geographic location that the Board should be aware of? 2. How will the utility address risks associated with facilities requiring power that about a Tier 2 or Tier 3 HFTD? 3. How does the utility assess its risks associated with system design and construction? 4. In what areas does the utility consider going above and beyond G.O. 95 or other General Order standards related to design and construction? **Chapter 5 Section A of the WMP provides general overview to these four questions, followed by a description of several example programs NCPA has incorporated on their transmission and generation assets.**

B. The WSAB observed that the many POU WMPs state that they meet or exceed the CPUC GO 95 standards for their inspections. The WSAB comment is that the WMPs do not state if the POU are meeting the minimum standards of GO 95 or exceeding it where circumstances merit it. The WSAB is recommending that WMPs include a description of whether their inspection programs go beyond the GO 95 standards, why they do, and how they do. **The NCPA's WMP does not use the statement "meet or exceed" and the plan does describe the inspections it performs on its assets that exceed the requirements of GO 95 including how they exceed the standard. The reasons for the inspections that go beyond the CPUC standards are summarized in the WMP with references to the NCPA documents or policies with more detailed explanations**

C. The WSAB would like POUs to include in their WMPs a description of the new ideas or enhanced protocols the utility is considering in the design, building, and maintaining their system to mitigate the wildfire risk in the future. **The WMP includes descriptions of the ongoing improvements to NCPA assets (upgrading**

equipment on their power lines) and enhancements they are making to their inspection process by upgrading frequency or the scope of inspections or where they are incorporating new techniques, such as using UAVs.

3. Vegetation Management and Inspections:

The WSAB requested that POUs describe their vegetation management practices and evaluate their impact on reducing wildfire related risk as well as the ecological impacts of the treatment options chosen. **The NCPA's WMP provides a general description of their vegetation management program and references their TVMP. The TVMP contains a detailed description of the utility's vegetation practices including what types of vegetation are treated, where they treated, and how often. The WMP also describes how their vegetation management standards exceed the GO 95 and which standard they use as their guidelines for their enhanced vegetation management program (CAL FIRE Power Line Fire Prevention Field Guide).**

7 Comparison of Industry Standards to the Operations and Equipment in use by the Northern California Power Agency

Dudek compared operational procedures and equipment used by the NCPA to mitigate wildfire risk in their service territory with mitigation measures in approved Wildfire Mitigation Plans from a similar utilities and electrical industry standards.

Avian Deterrents

The NCPA has installed avian deterrents and anti-nesting cones on its 230 kV Collierville-Bellota line, a 40-mile-long transmission line that traverses remote and mountainous terrain. Large birds are a common hazard for power line poles and towers, installing these devices on the towers along this line prevents large birds from using the towers as perches and nesting sites. This is a typical industry practice and a CALFIRE recommended practice to prevent equipment failure and wildfire ignitions due to electrocuted birds or the accumulation of bird droppings on electrical equipment.

Insulator Replacement

The NCPA has upgraded the insulators on its 230 kV Collierville-Bellota line, a 40-mile-long transmission line that traverses remote and mountainous terrain. The line is over 30 years old, and the insulators were replaced as part of a larger program to improve the safety and reliability of the line. This is a typical industry practice and replacing aging insulators reduces the risk of equipment failure, flash-over or arcing, or electrical current discharging into the ground through the pole.

Conductor Damping

The NCPA has installed mass dampers on its 230 kV Collierville-Bellota line, a 40-mile-long transmission line that traverses remote and mountainous terrain. Conductor damping is a typical industry practice to minimize wear or conductor fatigue near the hardware attachments. While this upgrade is not specific to preventing wildfire ignition it does reduce the risk of conductor or equipment failure, an event which could ignite a wildfire.

Disabling Reclosing Operations

The NCPA does not use automatic reclosers on its 230kV transmission line due to its location in rugged and remote terrain. This is a typical industry practice for both life safety and fire hazard reasons. In place of an automatic reclosers, NCPA coordinates re-energization of a tripped line with their dispatch office in Roseville, NCPA generation services, and PG&E. Lines are not re-energized until they have been visually inspected.

8 Conclusion

Dudek concludes that the Northern California Power Agency Wildfire Mitigation Plan comprehensively addresses all the applicable statutorily required elements for a Publicly Owned Utilities' WMP as specified in California Public Utilities Code Section 8387. Dudek finds that NCPA has taken reasonable actions to minimize the risk that its lines or equipment will cause a wildfire. Finally, Dudek finds that the NCPA has reviewed the guidance documentation provided by the WSAB and is incorporating recommended improvements to their WMP and their wildfire prevention programs.

Sincerely,



Jeremy Cawn
Fire Protection Planner/Urban Forestry Specialist

Attachment A: CPUC 8387(b)(2) Requirement Chart

2022			
2022 WMP Required Element per PUC Sec 8387(b)(2)	2022 NCPA WMP section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions
(A): An accounting of the responsibilities of persons responsible for executing the plan.	Sec. 3.A Utility Governance Structure. Generation Services Assistant General Manager.	Acceptable	
(B): The objectives of the wildfire mitigation plan.	Executive Summary and Sec. 1.B. Purpose of the WMP. 2. Goals.	Acceptable	
(C): A description of the preventive strategies and programs to be adopted by the local publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.	Sec. 5.A. Preventative Strategies and Programs. Sec. 5.C. Potential Climate Change Effects. Sec. 5.D. Potential Climate Change Risk Management Impacts.	Acceptable. Section 5 provides a comprehensive overview of the different wildfire prevention programs.	Section 5A. Any changes or updates to the maintenance projects and programs? Moved from 2021 to 2023 due to PGE... Section 5F. Any aerial drone or helicopter surveys worth noting? Geothermal Drone. NCPA works with Cal Fire to manage and phase maintenance work to the line. NCPA Update: Metrics reflect up to date. Good performance.
(D): A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan's performance and the assumptions that underlie the use of those metrics.	Sec. 7.A. Metrics and Assumptions for Measuring Plan Performance.	Acceptable	NCPA Update: Metrics reflect up to date. Good performance.
(E): A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.	Sec. 7.B. Impact of Metrics on Plan.	Acceptable. Consider selecting a new metric that measures an element that could lead to a wildfire ignition, such as trees without adequate clearance or equipment malfunctions detected.	NCPA has implemented enhanced inspection processes for its distribution lines that include identification of hazard trees that although outside of the normal radius of VMP clearing, still may represent a fall in hazard to wildfire ignition if toppled. NCPA has added this metric to both the WMP and to the VMP.

2022			
2022 WMP Required Element per PUC Sec 8387(b)(2)	2022 NCPA WMP section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions
(F): Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure.	Sec. 5.I. Reclosing Policy. Sec. 5.J. De-Energization. Sec. 5.J.1. Impacts to Public Safety.	Acceptable	
(G): Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. The procedures shall direct notification to all public safety offices, critical first responders, health care facilities, and operators of telecommunications infrastructure with premises within the footprint of potential de-energization for a given event.	Sec. 5.J.2. Customer Notification Protocols.	Acceptable.	
(H): Plans for vegetation management.	Sec. 5.F. Vegetation Management.	Section 5E. Any changes or updates to the Generation Services Common Procedure GS-305? Link. Acceptable. The WMP does a good job at describing general Veg Mgmt. The TVMP plan provides most of the required details to meet this sections requirements, consider adding elements of the TVMP to the WMP	NCPA added the following to Section 5.F: "Specific hazards addressed in the TVMP include identification of encroachment into the Clearance area (section 6.3.7), and additional inspection activities to identify deadfall and brush in the ROW that could provide fuel for wildfire spread (section 6.3.9). The TVMP also provides explicit direction to treat emergent conditions of a potential hazard as an immediate mitigation priority (section 6.4.4), including addressing extent of condition."
(I): Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.	Sec. 5.G. Inspections.	Acceptable. The WMP does a good job of describing general inspection process. Details regarding the types of	

2022			
2022 WMP Required Element per PUC Sec 8387(b)(2)	2022 NCPA WMP section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions
(J): A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility's or electrical cooperative's service territory. The list shall include, but not be limited to, both of the following: (i) Risks and risk drivers associated with design, construction, operation, and maintenance of the local publicly owned electric utility's or electrical cooperative's equipment and facilities. (ii) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned electric utility's or electrical cooperative's service territory.	Sec. 4. Wildfire Risks and Drivers. Sec. 4.A. Risks Associated with Topographical and Climatological Factors.	inspections performed and when they are performed would be beneficial. Acceptable. The WMP does a good job of describing general risks to the service territory both climate and terrain as well as operational and equipment. The risks specific to NCPA service territory are not described and it would be beneficial to add some NCPA specific risk drivers	NCPA has added to Section 4.A: "Risks specific to NCPA's generation facilities are tied to both residual fuel load (snags) from previous fires and potential soil instability caused by previous damage to area vegetation. These hazards are addressed by enhanced inspection techniques described in Section 5.F".
(K): Identification of any geographic area in the local publicly owned electric utility's or electrical cooperative's service territory that is a higher wildfire threat than is identified in a commission fire threat map, and identification of where the commission should expand a high-fire threat district based on new information or changes to the environment.	Sec. 4.C. Changes to CPUC Fire Threat Map	Acceptable	
(L): A methodology for identifying and presenting enterprise wide safety risk and wildfire-related risk.	Sec. 4.B. Enterprise-wide Safety Risks.	Acceptable. Consider creating a section in the WMP that collects the enterprise wide safety elements described throughout the plan.	Attachment C has been added to provide an index of risks and their associated controls evaluations within the sections of the WMP.
(M): A statement of how the local publicly owned electric utility or electrical cooperative will restore service after a wildfire.	Sec. 7. Restoration of Service.	Acceptable	

2022			
2022 WMP Required Element per PUC Sec 8387(b)(2)	2022 NCPA WMP section	IE's Assessment of WMP based on PUC Sec. 8387 Requirements	Responsible Party Revisions
(N): A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following: (i) Monitor and audit the implementation of the wildfire mitigation plan. (ii) Identify any deficiencies in the wildfire mitigation plan or its implementation, and correct those deficiencies. (iii) Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the plan, other applicable statutes, or commission rules.	Sec. 7.C. Monitoring and Auditing the Plan. Sec. 7.D. Identifying and Correcting Deficiencies in the Plan. Sec. 7.E. Monitoring the Effectiveness of Inspections.	Acceptable	Updated: NCPA currently conducts ride-alongs with both Cal-Fire staff and internal NCPA staff.

Attachment B: WSAB Guidance Recommendations Chart

WSAB 2022 WMP Guidance Recommendations	2022 NCPA WMP section	2022		
		IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
the Board recommended use of an upfront template containing key information about a utility's service area, including size, number of customers, type of customers, basic topography and weather data, asset mix (in terms of underground versus overhead lines), and interaction with High Fire Threat Districts (HFTD) and Public Safety Power Shutoffs (PSPS).	Section 1	Fully completed.	n/a	Complete
An index that showed where each of the statutory requirements were addressed in the WMP	N/A	Add index table to WMP in suggested location	See Attachment A	Complete
The WSAB is encouraging POU's to <u>re-evaluate</u> their WMP objectives to take a broader approach beyond the typical minimizing sources of ignition and improving resiliency of the grid.	N/A	The NCPA's describes the typical objectives of minimizing ignitions and improving resiliency of the grid in their WMP.	See Attachment B	Complete
Describe the vegetation management practices and evaluate their impact on reducing wildfire related risk, as well as the ecological impact of the treatment options chosen	Section 5	The WMP provides a general overview of the NCPA's program. The details the WSAB is looking for are found in the TVMP plan.	See Attachment B	Complete

2022				
WSAB 2022 WMP Guidance Recommendations	2022 NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
Information about the installation of and use of situational awareness technologies to better understand wildfire risk drivers, particularly through collaborative activities and shared data.	N/A	There is no description in the WMP about the installation or use of situational awareness technology in NCPA's service territory.	See Attachment B	Complete
Information about facilities that would not be directly subject to the protocols of the CPUC's G.O. 95 due to their construction prior to the G.O. first being adopted.	Section 5	The WMP does not specifically identify facilities that are not subject to GO 95. NCPA applies wildfire prevention strategies to all their assets in high fire threat areas	See Attachment B	Complete
The WSAB would also like information about any circumstances where the G.O. 95 standards are not followed, and what replaces them and why.	Section 5	NCPA vegetation management program follows the stricter CAL FIRE guidelines for vegetation maintenance along the interconnects between generation facilities.	See Attachment B	Complete
Are there design or construction issues related to the utility's specific topography or geographic location that the Board should be aware of?	N/A	Section 4 contains a general overview of risk drivers present but no specific terrain or location issues are discussed.	See Attachment B	Complete
How will the utility address risks associated with facilities requiring power that abut a Tier 2 or Tier 3 HFTD?	N/A	Not specifically addressed in the WMP	See Attachment B	Complete

2022				
WSAB 2022 WMP Guidance Recommendations	2022 NCPA WMP section	IE's Initial Assessment of WMP based on WSAB Guidance Recommendations	Responsible Party - revisions	IE's 2nd Assessment of WMP
How does the utility assess its risks associated with system design and construction?	Section 4 & 5	The WMP has a general overview of how NCPA evaluates its assets based on the identified wildfire risk drivers.	See Attachment B	Complete
In what areas does the utility consider going above and beyond G.O. 95 or other General Order standards related to design and construction?	Section 5	In the Facility Maintenance Program of section 5 the WMP describes the upgrades under consideration to the tie-in and transmission	See Attachment B	Complete
WMP Metrics measure something that is helpful for progress when met as expected, and when not meeting the metric creates tension for improvement.	Section 7	The WMP uses the basic metrics of new ignitions and wires down. These metrics are appropriate to NCPA's service territory. It is recommended that NCPA choose a new metric or replace one of the existing metrics that shows the utility's progress toward reducing wildfire risk.	See Attachment B	Complete
the WSAB requested that WMPs include a small amount of additional context information regarding public input and approval processes for each utility.	Section 1	The WMP includes a short description of who approves the plan and that the plan is open for public review. A description of the approval process is not included in this WMP.	See Attachment B	Complete

DUDEK

1630 SAN PABLO AVENUE, SUITE 300
OAKLAND, CALIFORNIA 94612
T 510.601.2500 F 510.601.2501

May 17, 2023,

12108.11

James D. "Jay" Mearns, PE
Supervising Engineer / Engineer V
Generation Services
651 Commerce Drive
Roseville, CA 95678

Subject: Independent Evaluator's Report of the Northern California Power Agency 2023 Wildfire Mitigation Plan

1 Introduction

The Northern California Power Agency (NCPA) contracted with Dudek to engage in an independent evaluation of its 2023 Wildfire Mitigation Plan (WMP). This independent evaluation report describes the technical review and evaluation of the WMP prepared by the NCPA. The WMP requirements are codified in California Public Utilities Code (PUC) Section 8387(b)(2) for local publicly owned electric utilities (POUs). PUC Section 8387(c) requires that an independent evaluator review and assess the comprehensiveness of a POU's WMP and issue a summary report. The year 2023 is important for POU's because they are required by PUC Section 8387(b)(1) to comprehensively revise their WMPs "at least once every three years."

Dudek conducted a review of NCPA 's 2023 WMP from February 27 to May 5, 2023. The focus of the evaluation was to determine the comprehensiveness of WMP and ensure it included all elements required under PUC Section 8387(b)(2) (listed in Attachment A).

In addition to evaluating the elements required by the PUC, Dudek reviewed the Wildfire Safety Advisory Board's (WSAB's) specific guidance for the NCPA published in their Guidance Advisory Opinion for the 2023 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electrical Cooperatives (WSAB 2022).

This Independent Evaluator's report contains the following elements: (1) an overview of the NCPA , (2) A review of the statutory requirements in PUC Section 8387(b)(2) for local POU's, (3) A review of the specific recommendations published by the WSAB for the NCPA 2022 WMP, (4) 2022 wildfire mitigation and prevention accomplishments of the NCPA , (5) an overview of the metrics used the NCPA 's WMP, and (6) a comparison of wildfire risk reduction strategies used by the NCPA with those used by similar utilities and municipal utility industry standards.

2 An Overview of the Northern California Power Agency

The NCPA's service territory consists of several geothermal and hydroelectric generating stations plus the tie-in lines that connect the NCPA facilities to their customers. NCPA's geothermal generating facilities are in the Coastal

Ranges, specifically the Mayacamas Mountains in Lake County, California. There are four facilities plus two 230 kV tie-in lines; one that is operated by the NCPA and that connects the NCPA's geothermal generating facilities to PG&E lines to the west, and a second that is not operated by the NCPA and connects to the CALPINE facilities and extends PG&E substations to the east. The lands surrounding the geothermal facilities are undeveloped except for access roads and are covered with continuous areas of forest, brush, and mixed forest-shrubland cover. It is worth noting that CALPINE's facilities, a group of geothermal generating plants, are also situated on the same geyser field as NCPA's. These two facilities have similar wildfire risks in terms of surrounding vegetation, terrain, and firefighter access. All NCPA's geothermal facilities and the related tie-in lines are in a tier 3 High Fire Threat District.

The NCPA's hydroelectric facilities are situated on the west facing slopes of the Sierra Nevada Mountains with the generating stations located in drainages at the near the bases of several dams in Calaveras and Tuolumne Counties. There are four facilities plus one 230 kV tie-in line and a 17kV service line. The lands surrounding the hydroelectric facilities are undeveloped except for access roads and the related water infrastructure (e.g., dams, spillways, etc.). Surrounding lands are covered with continuous areas of grasslands, brush, and mixed forest-shrubland cover. NCPA's hydroelectric facilities are located both inside and outside of the High Fire Threat Districts. Two facilities plus the 17kV service line are located within a Tier 3 area, one facility is located within a Tier 2 area, and one facility is not located in a High Fire Threat District. The 230 kV tie-in line extends from Collierville powerhouse to the east through Tier 3 and Tier 2 areas as well as passing through areas outside of the High Fire Threat districts in the Central Valley near Linden, CA.

Including all facilities, tie-in lines, and service lines, 46% NCPA's service territory lies within a Tier 2 area and 26% lies within a Tier 3 area. Since NCPA is a generator of electrical power not a distributor and their facilities are in remote areas away from urban or developed areas, none of their service territory is classified as Wildland Urban Interface (WUI).

The NCPA 's service territory experiences a fire season that lasts from May to October during a typical year. During exceptionally dry years, the fire season can begin in April and extend into November. Both the hydroelectric facilities and the geothermal facilities have a fire history that includes several wildfire perimeters burning within 1 mile of NCPA facilities or lines. The 2004 Geysers fire perimeter includes NCPA's geothermal generating facilities (CAL FIRE 2020).

3 Statutory Requirements for Wildfire Mitigation Plans

PUC Section 8387(b)(2) lists the statutory requirements for WMPs. These are the specific elements that the independent evaluator must review to make its determination for this report. The specific elements that must be addressed in NCPA 's WMP are included in Attachment A and are summarized here for reference.

- Staff responsibilities
- General objectives
- Wildfire risk reduction program descriptions
- The metrics used to evaluate the WMP's performance.
- How the application of previously identified metrics has informed the WMP.
- Protocols for reclosers, de-energization, and public safety power shut-off.

- Procedures for community notification and outreach
- Vegetation management plans
- Electrical equipment and infrastructure inspection plans
- Description of wildfire risks and drivers for those risks throughout the service territory, including design, construction, operation, and maintenance of equipment and facilities and topographic and climatological risk factors
- Identification of any geographic area in the service territory that is a higher wildfire threat than is identified in a commission fire threat map.
- Identification of enterprise-wide safety risk and wildfire-related risks
- How the service will be restored after a wildfire
- The processes and procedures used to monitor and audit the implementation of the WMP and identify any deficiencies, and the effectiveness of electrical line and equipment inspections.

4 Public Utility Code Requirements

Dudek found that NCPA 's WMP meets the statutory requirements of comprehensiveness per PUC Section 8387. The review of the WMP's elements is summarized relative to the application of the WMP. Dudek's assessment is in **bold text** beneath the description of the requirement. The table in Attachment A lists each PUC required element for the NCPA 's WMP and provides Dudek's initial and final assessments of the comprehensiveness of that element.

Minimizing Wildfire Risks

PUC Section 8387(a) requires the following: "Each local publicly owned electric utility and electrical cooperative shall construct, maintain, and operate its electrical lines and equipment in a manner that will minimize the risk of wildfire posed by those electrical lines and equipment."

The NCPA 's WMP and the appendices referenced in the WMP comprehensively describe the safety-related measures that the NCPA follows to reduce its risk of causing wildfires. Dudek has determined that NCPA complies with this requirement through the design of its system, its operations, and the implementation of wildfire risk reduction and wildfire response strategies.

Evaluation of WMP Elements

Below is a summary of the WMP elements as required by PUC Section 8387, including restating sections of the WMP where applicable.

8387(b)(2)(A): Responsibilities of Persons Responsible for Executing the Plan.

Chapter 3 of the NCPA WMP comprehensively describes staff responsibilities and functions in the implementation of their WMP.

8387(b)(2)(B): Objectives of the Wildfire Mitigation Plan

Chapter 2 of the NCPA WMP comprehensively describes the utility's WMP three objectives.

8387(b)(2)(C): Prevention Strategies and Programs

Chapter 5 in the NCPA WMP describes the utility's wildfire prevention strategies. It is very comprehensive, covering existing programs. System hardening/facilities upgrade information provided by facility.

8387(b)(2)(D): Metrics and Assumptions for Measuring WMP Performance

Chapter 7 section A contains a description of the three metrics used by the NCPA in their WMP. Also included is 2020-2021 data for each metric.

8387(b)(2)(E): Impact of Previous Metrics on WMP

Chapter 7 section B describes the NCPA's plans to continue tracking the three metrics described in in section A. Section B also provides a frame of reference for 'O' event metrics by comparing the NCPA's incident rate for wires down to PG&E's (NCPA's tie-in lines connect to PG&E lines).

8387(b)(2)(F): Reclosing Protocols

Chapter 5 section H states that the NCPA does not use automatic reclosers on 230 kV lines (their tie-in lines).

8387(b)(2)(G): De-energization Notification Procedures

Chapter 5 section J.2 describes the NCPAs customer notification protocols. This section contains an explanation of the notification methods and referenced NCPA policies (PM-501). Attachment D in the WMP has PM-501.

8387(b)(2)(H): Vegetation Management

Chapter 5 section E contains a comprehensive description of the NCPAs vegetation management program including fuel breaks installed around their geothermal facilities. Appendix 5 in the WMP an example of the firebreaks NCPA has installed at their geothermal facilities. Based on conversations with NCPA staff, NCPA does not install fuel breaks at their hydroelectric sites because the hydroelectric sites are located on smaller, less accessible sites.

8387(b)(2)(I): Inspections

Chapter 5 section F of the NCPA WMP comprehensively describes the utility's inspection program including the type and frequency of inspections.

8387(b)(2)(J)(i): Risks and Risk Drivers Associated with Design and Construction Standards

Chapter 4 section B in the NCPA WMP provides an overview of wildfire risk drivers in of risk drivers associated with design and construction standards.

8387(b)(2)(J)(ii): Risks and Risk Drivers Associated with Topographic and Climatological Risk Factors

Chapter 4 Section A in the NCPA WMP provides a comprehensive description of the geographic and climatological factors present across the NCPA service territory.

8387(b)(2)(K): Geographical Area of Higher Wildfire Threat

Chapter 4 Section C in the NCPA WMP describes the utility's review of the CPUC fire threat map and their conclusions about the geographical area of the high fire threat areas.

8387(b)(2)(L): Enterprise-wide Safety Risks

The introduction to chapter 4 describes that the NCPA does not have an agency-wide enterprise-risk identification and presentation. In its place is a safety policy for each type of generation asset (e.g., geothermal plant) that includes a risk-assessment process specific to that asset.

8387(b)(2)(M): Restoration of Service

Chapter 7 of the NCPA WMP has a general overview of how the utility will restore service after an outage. Two NCPA policies are referenced PM-201 and GEO-646 that specifically address restoration of service.

8387(b)(2)(N)(i): Monitoring and Auditing WMP Implementation, 8387(b)(2)(N)(ii): Identifying and correcting WMP deficiencies, 8387(b)(2)(N)(iii): Monitoring and Auditing the effectiveness of inspections.

Chapter 7 section C, D, and E of the NCPA WMP describes the utility's processes for monitoring and auditing WMP implementation, correcting WMP deficiencies, and monitoring the effectiveness of inspections. NCPA uses an ongoing process to identify risks and inefficiencies, and to develop means to address the identified issues.

5 Wildfire Safety Advisory Board Guidance Advisory Opinions

In November 2022, the WSAB published a report with a description of general recommendations for improving the WMPs for POUs and rural electrical cooperatives. At the end of the report the WSAB provided specific recommendations for each utility that submitted a WMP for review by the board. Dudek reviewed the WSAB's report, and the section below contains a summary of each recommendation the WSAB had for the NCPA 's 2022 WMP and whether the 2023 WMP has addressed the WSAB's recommendation (WSAB 2022). The materials published by the WSAB and the recommendations within are for guidance and are not statutory requirements.

1. The text on page 6 that indicates that the current WMP was initiated in 2019 and on page 7 a statement that this WMP was presented at an NCPA committee meeting – this is confusing as the 2022 updated is a complete WMP in itself. In the comprehensive revision in 2023, the WSAB expects that text like this will be resolved.

The dates on page 6 & 7 have updated to 2022 and the current version of the WMP.

6 Northern California Power Agency 2022 Progress in Implementing Wildfire Mitigation Plan Wildfire Prevention Strategies

This section describes the NCPA's accomplishments in 2022 for the wildfire prevention program and strategies described in the WMP.

Vegetation Management

Geothermal

- Completed annual maintenance of BLM firebreaks around Plant # 1 & # 2 in March 2022.
- Completed vegetation management and line clearance work along 230 kV tie-in lines and around all nine tower bases in June 2022.
- Completed annual maintenance of vegetation around Plant #1 & #2 perimeters plus along access roads in 2022.

Hydroelectric

- Completed annual maintenance of vegetation around powerhouses and substations in 2022.
- Completed vegetation management and line clearance work along 230 kV tie-in lines and around tower bases in April 2022.

Inspections

Geothermal

- 230 kV transmission line inspection completed July 21, 2022.
- 21 kV line inspection completed July 21, 2022.
- 230 kV Drone line inspection completed October 24, 2022. Conducted by PG&E, damaged conductor found by PG&E and repaired by WAPA.
- 230 kV Physical Inspections completed October 24, 2022

Hydroelectric

- 230 kV transmission line inspection completed March 15, 2022

- 17 kV line Wood pole inspections completed June 15, 2022
- 230 kV line daycore corona and IR inspection completed June 1, 2022
- 230 kV LiDAR transmission line inspection completed August 1, 2022
- NSM-Cabbage Patch 21 kV cable tests completed September 16, 2022

7 Wildfire Mitigation Plan Metric Overview

Metrics help POUs determine if their wildfire prevention strategies are effective for reducing the risk of a wildfire ignited by their electrical equipment. In 2020 the California Municipal Utilities Association published a WMP template for POUs to use in the preparation of their WMPs. This template included two metrics: number of fire ignition events and wires down events.

The NCPA adopted the two metrics suggested by the CMUA in the first and second iterations of their WMP. In 2022 the NCPA adopted an additional metric, Fall in Hazard Trees Ignitions. These three metrics: fire ignitions, wires down, and fall in hazard tree ignitions are utilized in the 2023 WMP.

The NCPA records metric data in monthly outage reports. For each event NCPA records date and time of the event, a description of the event and the cause of the event (if known), if the event was the result of an external cause, whether the outage was forced or planned, and how long the event lasted. If the event occurred along one the tie-in lines, then the location of the event along the line is described.

For the three metrics the NCPA recorded the following data in table 1 from 2020 to April 2023.

Table 1 Metric Event Record in 2020-2023

Metric	Geothermal	Hydroelectric
Fire Ignitions	0	0
Wire Down	0	0
Fall in Hazard Tree Ignitions	10 locations, 0 fall-ins	2 locations, 0 fall-ins

These three metrics with the supplemental data regarding date and time of the event, and cause of the event are useful for informing the NCPA about the effectiveness of their wildfire prevention strategies. Comparing their outage event rate on their transmission lines to PG&E's outage event rate for their transmission lines provides a good perspective on why the "0" metric events for the wire down metric is indicative of success and not an indicator of an ineffective metric.

The NCPA is considering adding metrics in future versions of the WMP including a performance-based metric that tracks overhead line inspection and includes location plus date & time data.

8 Comparison of Industry Standards and Similar Utility Wildfire Prevention Strategies

As part of this review of the NCPA's 2023 WMP, Dudek compared the wildfire prevention strategies described in the WMP to the strategies being implemented by POU's and accepted electrical industry practices for reducing wildfire risk. The NCPA is unique in that they are primarily a producer of electrical power whose transmission lines are limited to tie-ins with electrical utilities who provide the distribution of electrical power to retail customers. NCPA's service territory is unique in that their facilities including generators and tie-lines are dispersed in areas with no development save for infrastructure related to their operations. This is particularly important in that places a greater risk to their facilities from wildfire and greater responsibility for vegetation management/defensible space to protect their facilities. Therefore, there are no comparable POU's in the state and it is more appropriate to compare their wildfire prevention programs to a relevant industry standard such as the National American Electric Reliability Corporation (NERC), California Public Utility Code General Order 95 (GO 95), Public Resource Code 4292-4293, and CAL FIRE's California Power Line Fire Prevention Field Guide

8.1 Vegetation Management

The NCPA's vegetation management can be categorized as the vegetation management work done along their tie-in lines and the vegetation management work done around their facilities. For their transmission tie-ins the NCPA maintains the vegetation within the right-of-way of its transmission tie-in lines to NERC FAC-003-4. There is at least 30 feet of vertical clearance between the trees and vegetation along the tie-in lines and the wires. The corridors containing the transmission wires are typically one hundred feet in width except where terrain makes it unsafe to maintain the full 100-foot width. For their generation facilities the NCPA meets PRC 4292 & 4293 requirements as well as PUC GO 95 requirements, typically maintains a 50- to 100-foot-wide perimeter around structures.

8.2 System Hardening

Equipment Maintenance and Upgrades

All NCPA transmission line towers are entirely constructed of lattice or tubular steel and so are inherently noncombustible. Conductors and other electrical equipment attached to NCPA towers are also constructed of metal or other non-combustible materials. Transformers, circuits, and other types of electrical equipment located at substations are also constructed entirely of non-combustible materials and surrounded by a large area of bare ground. No system hardening or equipment upgrades would result in significant improvements to fire resistance of NCPA equipment. The NCPA inspects its transmission towers on a regular basis, issues with towers or tower equipment that is discovered during the inspection is repaired at the same time.

The NCPA utilizes wood poles for the 17kV distribution line at the McKay's point facility and a 21 kV lines at the NCPA's geothermal facilities. The NCPA recently rebuilt the 21 kV line and is in the process of upgrading the equipment on the 17kV.

Construction Standards

The NCPA has construction standards designed to reduce the risk of fire ignited by the failure of their electrical equipment, which include the use of animal deterrents, lightning arresters, and arc suppression fusing. The NCPA does not use explosive fuses on any of its lines that pass over areas of vegetation.

Recloser Policy

The NCPA does not have reclosers on its 230 kV transmission lines. Relaying equipment on their 21kV Bear Canyon line is set to a zero-reclose to lockout scheme.

8.3 Situational Awareness

Patrols and Visual Inspections


The NCPA has a Transmission Maintenance and Inspection Program (TMIP) that meets the standards described in NERC FAC-501-WECC-3. NCPA regularly performs visual inspections of its equipment and lines including those in remote areas. Regular and thorough inspections particularly for transmission lines is a nationally accepted best practice for early equipment fault detection and hazardous vegetation identification.

9 Conclusion

The NCPA has prepared a comprehensive WMP for 2023. The plan meets all statutory requirements described in PUC Section 8387(b)(2) for a POU. The NCPA has also considered the recommendations of the Wildfire Safety Advisory Board and revised their WMP appropriately. The NCPA 's WMP with the provided appendices describes a wildfire mitigation program that accurately assesses the risks and risk drivers present in their service territory and implements preventative strategies that are effective at reducing the wildfire risk of these risks and risk drivers.

Based on the wildfire prevention programs described in the WMP and the progress the NCPA has made in its wildfire prevention programs, the NCPA is taking an active role in minimizing the risk its equipment starts a wildfire and minimizing the risk a wildfire near their facilities can impact their operations.

Sincerely,



Jeremy Cawn
Fire Protection Planner

10 References

- Carlson, A.R., Helmers, D.P., Hawbaker, T.J., Mockrin, M.H., and Radeloff, V.C., 2022, Wildland-urban interface maps for the conterminous U.S. based on 125 million building locations: U.S. Geological Survey data release, <https://doi.org/10.5066/P94BT6Q7>.
- CAL FIRE. (2022, October 1). *Fire Perimeters through 2021*. Retrieved from Fire and Resource Assessment Program: <https://frap.fire.ca.gov/mapping/gis-data/>
- WSAB (California Wildfire Safety Advisory Board). 2022. Guidance Advisory Opinion for the 2023 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electric Cooperatives Draft. Office of Energy Infrastructure Safety. October 17, 2022. Sacramento, California. Retrieved from: Wildfire Safety Advisory Board | Office of Energy Infrastructure Safety ([ca.gov](https://www.ca.gov))

Attachment A

Northern California Power Agency WMP Review Summary Tables

CPUC Requirement

Public Utility Code 8387(b)(2)	Description of Required Element	Final Review Comment	Initial Review Comment
A	Staff Responsibilities	Good. Describes WMP responsibilities down to oversight of prevention strategies	Good.
B	General Objectives	Good.	Good.
C	Program Descriptions	Good.	Good.
D	Evaluation Metrics	Good.	Good.
E	Lessons learned, metrics application	Need to update text. WSAB expects that utilities will have a good understanding of whether their metrics are useful. Elaborate why '0' events means success.	Updated with a description of the use of metric data and plans to incorporate new metrics. Good.
F	Protocols for reclosers, de-energization, and PSPS mitigation	No reclosers. De-energization & PSPS-good.	Good.
G	Community Notification	Good. Either attached NCPA-PM-501 or briefly describe how NCPA communicates with PG&E and member agencies.	Updated with an explanation of notification methods. Good.
H	Vegetation Management	Good.	Good.
I	Infrastructure Inspections	Good.	Good.
J(i)	Grid Design, construction, and operation risks	Good. Include CALPINE facilities as a risk driver for your GEO operations.	Updated, added risk drivers for adjacent facilities. Good.
J(ii)	Vegetation, topographic, and climate risks	Comprehensive. Add in NCPA territory specific details. For example: Where do Diablo winds impact NCPA equipment or facilities? IS there a specific vegetation cover type that is high risk to the NCPA?	Updated, added detail about site or area specific risk drivers related to vegetation cover for geothermal and hydroelectric operations.

TO: JAMES MEANS

SUBJECT: INDEPENDENT EVALUATOR'S REPORT OF THE NORTHERN CALIFORNIA POWER AGENCY'S 2023 WILDFIRE MITIGATION PLAN

K	Identification and expansion of higher wildfire threat areas	Good.	Good.
L	Identify enterprise-wide risk	Missing	Resolved. NCPA does not utilize an enterprise-wide risk assessment process. Instead relies on location specific safety plans. Provides an equivalent level of safety
M	Restoration of Service	Good. Attach PM-201 and GE-646 to WMP if relevant.	Good.
N(i)	Monitoring and auditing of WMPs	Good. If NCPA evaluates the accomplishments or progress made with wildfire prevention strategies during the year, describe them here.	Good. NCPA staff provided spreadsheets with inspection and Veg. mgmt. accomplishments
N(ii)	Identifying and correcting deficiencies	Good. If NCPA adjusts wildfire prevention strategies during the year, describe them here.	Good. Detail added that NCPA use an ongoing process to review program accomplishments and changes in program priorities or goals due to changing conditions (e.g., weather)
N(iii)	Monitoring asset inspections	Good.	Good.

NCPA Specific WSAB Recommendations

WSAB 2023 POU WMP Guidance Advisory Opinion	Description of the WSAB Recommendation	Final Review Comment	Initial Review Comment
A3-40	The text on page 6 that indicates that the current WMP was initiated in 2019 and on page 7 a statement that this WMP was presented at an NCPA committee meeting – this is confusing as the 2022 updated is a complete WMP in itself. In the comprehensive revision in 2023, the WSAB expects that text like this will be resolved.	Update the text on page 6 that states " <i>In 2019, NCPA initiated the development of this current WMP</i> ". NCPA completed the development of the initial WMP in 2020. It would be more accurate to state when you began your internal review and revision of the 2022 WMP. For example, " <i>In November of 2022, NCPA initiated the development of this current WMP</i> ". Update the text on page 7 that states " <i>In 2019, this WMP was presented at the NCPA Commission Meeting, a public meeting, and is posted on NCPA's public website domain</i> " to state that the " <i>2023 WMP will be adopted by the NCPA Commission and presented at the NCPA Commission Meeting, a public meeting, and after adoption by the commission this 2023 WMP will be posted on NCPA's public website domain.</i> "	Dates have been updated. Good.

NCPA WMP Comments

Location	Page	Initial Review Comment	Final Review Comment
5.A	20	Consider removing the 2020 accomplishments from this section or shortening the statement to "Major improvements and system hardening upgrades were made to this line in 2020".	Updated. Good.
5.H	25	This sentence is missing the word 'line' "... or use automatic reclosers on its 230 kV within the scope...."	Corrected.

APPENDIX 6 – Independent Evaluator Report 2024



POWER ENGINEERS, INC.
333 CITY BOULEVARD WEST
SUITE 1700
ORANGE, CA 92668 USA

PHONE 714-507-2700
FAX 714-507-2799

May 28, 2024

Jeremy Lawson, P.E.
Generation Services Director of Engineering
Northern California Power Agency
651 Commerce Drive
Roseville, CA 95678

Subject: Independent Evaluator's Report of the
Northern California Power Agency's 2024 Wildfire Mitigation Plan

1. Introduction

POWER Engineers, Inc. (POWER) conducted an independent review of Northern California Power Agency's (NCPA) 2024 Wildfire Mitigation Plan (WMP). This independent evaluator's report describes the technical review of the 2024 WMP and its compliance with Public Utilities Code §8387 (PUC §8387). This independent evaluator's report contains the following elements: (1) an overview of NCPA, (2) a review of the statutory requirements in PUC §8387(b)(2) for WMPs, (3) an evaluation of the WMP for compliance with PUC §8387(b)(2), (4) a review of the specific recommendations published by the Wildfire Safety Advisory Board (WSAB) for the NCPA's 2024 WMP, (5) a discussion of NCPA's progress in implementing wildfire prevention strategies, (6) an overview of the metrics used in the WMP, and (7) a comparison of wildfire prevention industry standards.

Pursuant to California Senate Bill 901 enacted September 21, 2018, and Assembly Bill 1054 enacted July 12, 2019, a WMP must be updated annually and comprehensively every three years to comply with PUC §8387. The WMP requirements are codified in PUC §8387(b)(2) for local publicly owned electric utilities (POUs). PUC §8387(c) requires that an independent evaluator review and assess the comprehensiveness of a POU's WMP and issue a summary report.

In response to this legislation, POWER conducted this independent evaluation of NCPA's 2024 WMP to determine compliance with the comprehensive requirements established by PUC §8387(c) and ensure it includes all of the elements required under PUC §8387(b)(2).

In addition to evaluating the elements required by the PUC, POWER evaluated the WMP for compliance with the WSAB's guidance for POU's published in WSAB's *Guidance Advisory Opinion for the 2024 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electrical Cooperatives* (WSAB 2023).

2. Overview of Northern California Power Agency

NCPA is a Joint Powers Agency, which owns and operates electrical generation facilities. NCPA is governed by a Commission comprised of one representative for each of its public power utility members.

LAX (2024-05-28) KC

WWW.POWERENG.COM

May 28, 2024

The WMP applies to NCPA’s Geothermal Facility and Hydroelectric Facility, including transmission and distribution lines. The Geothermal and Hydroelectric facilities contain electrical equipment in high fire threat locations and power lines that traverse high fire threat areas. The Geothermal Facility is located near the Geysers in Lake County and consists of five Geothermal facilities spread over 30 square miles. The Hydroelectric Facility is located in the North Fork Stanislaus River watershed (Calaveras County) and consists of eight generator/water diversion stations and an office located along the river. There are approximately 40 miles of power lines between the generation facilities and their tie-in points with Pacific Gas and Electric (PG&E) transmission lines. NCPA’s electrical infrastructure consists of facilities that are in the California Department of Forestry and Fire Protection’s (CAL FIRE’s) Moderate to Very High Fire Hazard Severity Zones and/or the California Public Utilities Commission’s (CPUC’s) Tier 2 or 3 Fire Threat Zones.

NCPA has taken appropriate actions to help prevent and respond to the increasing risk of devastating wildfires by following all applicable design, construction, operation, and maintenance requirements that reduce safety risks associated with its electrical system.

3. Wildfire Mitigation Plan Statutory Requirements

PUC §8387(b)(2) lists the statutory requirements for WMPs. These are the specific elements that the independent evaluator must review to make its determination for this report. The specific elements that must be addressed in NCPA’s WMP are listed in Table 1.

Table 1 Statutorily Required Contents for WMPs Pursuant to Public Utilities Code §8387(b)(2)

PUC §8387(b)(2)	Required Contents of WMPs
(A)	Staff responsibilities
(B)	General objectives
(C)	Program descriptions
(D)	Evaluation of metrics
(E)	Lessons learned, metrics
(F)	Protocols for disabling reclosers and de-energizing electrical distribution system
(G)	Community de-energization notification
(H)	Vegetation management
(I)	Inspections
(J)	Risks and risk drivers
(K)	Identification of higher wildfire threat areas
(L)	Identify enterprise-wide risk
(M)	How service will be restored after a wildfire or shutdown event
(N)	The processes and procedures used to 1) monitor and audit the implementation of the WMP, 2) identify any deficiencies, and 3) monitor asset application & inspections

May 28, 2024

4. Public Utility Code Requirements Evaluation

4.1 Minimizing Wildfire Risks

PUC §8387(a) requires the following: “Each local publicly owned electric utility and electrical cooperative shall construct, maintain, and operate its electrical lines and equipment in a manner that will minimize the risk of wildfire posed by those electrical lines and equipment.”

POWER has determined that NCPA complies with this standard through the design of its system, its operational procedures, and the implementation of wildfire risk reduction and wildfire response strategies.

4.2 Evaluation of WMP Elements

POWER found that NCPA’s WMP is comprehensive and meets the statutory requirements of PUC §8387. The review of the WMP’s elements is summarized below relative to the application of the WMP. POWER’s assessment is in bold text beneath the description of the requirement.

8387(b)(2)(A): Responsibilities of Persons Responsible for Executing the Plan

- **Chapter 3 describes staff responsibility and functions in the implementation of the WMP.**

8387(b)(2)(B) Objectives of the Wildfire Mitigation Plan

- **Chapter 2 describes the WMP goals and objectives. Chapter 1 describes the purpose of the plan.**

8387(b)(2)(C): Prevention Strategies and Programs

- **Chapter 5 describes NCPA’s comprehensive wildfire prevention strategies and programs, including its 1) facility maintenance program, (2) emergency operating procedures, (3) vegetation management programs, and (4) asset documentation programs.**

8387(b)(2)(D): Metrics and Assumptions for Measuring WMP Performance

- **Chapter 7 Section A contains a description of the three metrics used by the NCPA in their WMP. These metrics are evaluated yearly: (1) number of fire ignitions, (2) number of NCPA wires down, and (3) fall in hazard tree ignitions. Data for the years 2020 through 2023 are included for each metric.**

8387(b)(2)(E): Impact of Previous Metrics on WMP

- **Chapter 7 Section B describes NCPA’s plans to continue tracking the three metrics described in Section A. Section B also describes 2020 through 2023 impact due to metrics.**

WWW.POWERENG.COM

LAX (2024-05-28) KC

PAGE 3 OF 10

May 28, 2024

8387(b)(2)(F): Reclosing Protocols

- Chapter 5 Section H describes NCPA's reclosing policy. NCPA does not own or use automatic reclosers on their 230-kilvolt (kV) transmission lines.

8387(b)(2)(G): De-energization Notification Procedures

- Chapter 5 Section J.2 describes NCPA's customer notification protocols. This section contains an explanation of the notification methods. Policies are currently in place, NCPA-PM-501, to notify NCPA member utilities of de-energization activities.

8387(b)(2)(H): Vegetation Management

- Chapter 5 Section E contains a comprehensive description of NCPA's vegetation management program. NCPA developed and implemented a Transmission Vegetation Management Program establishing vegetation maintenance requirements for each facility to achieve generation interconnection system reliability.

8387(b)(2)(I): Inspections

- Chapter 5 Section E describes NCPA's inspection program, including the type and frequency of inspections.

8387(b)(2)(J): Risks and Risk Drivers

- Chapter 4 provides a comprehensive description of wildfire risk and risk drivers associated with topographic and climatological factors and design and construction standards.

8387(b)(2)(K): Geographical Area of Higher Wildfire Threat

- Chapter 4 Section C describes NCPA's review of the CPUC's fire threat map and CAL FIRE's Fire Zones and conclusions about the geographical area of the high fire threat areas.

8387(b)(2)(L): Enterprise-wide Safety Risks

- Chapter 4 describes that NCPA does not have enterprise-wide safety risks as NCPA does not possess general responsibility over assets and geography except for locations tied to its specific generation assets, as defined in the table in Chapter 4.

8387(b)(2)(M): Restoration of Service

- Chapter 7 describes how NCPA will restore service after a de-energization event in coordination with PG&E's restoration efforts.

WWW.POWERENG.COM

May 28, 2024

8387(b)(2)(N)(i) Monitoring and Auditing WMP implementation, (ii) identifying and correcting WMP deficiencies, (iii) Monitoring and Auditing the effectiveness of inspections.

- **Chapter 7 describes NCPA's processes for monitoring and auditing WMP implementation, correcting WMP deficiencies, and monitoring the effectiveness of inspections. NCPA uses an ongoing process to identify risks and inefficiencies, and to develop means to address the identified issues.**

5. Wildfire Safety Advisory Board Guidance Advisory Opinions

The WSAB published the California Safety Advisory Boards *Guidance Advisory Opinion for the 2024 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electrical Cooperatives* (WSAB 2023), which provides guidance for development of the POU's 2024 WMP updates and future comprehensive WMPs. The WSAB provided specific recommendations for each utility that submitted a WMP for review by the board.

POWER reviewed the WSAB's report and the recommendations; these recommendations provide guidance and are not statutory requirements. Based on review of the 2024 WPM and WSAB's report, POWER has determined that NCPA complies with the recommendations below through the design of its system, its operational procedures, and the implementation of wildfire risk reduction and wildfire response strategies outlined in the WMP.

WSAB's 2024 Recommendations

Based on WSAB's evaluation of the POU's 2023 WMPs, the WSAB's advisory opinion is that each POU initiate a collaborative approach to improve POU reporting on its wildfire prevention efforts and WSAB's ability to comprehend and advise on those reports.

The WSAB recommends POU's and the Joint Associations participate in meetings or workshops as requested by the WSAB to engage with the WSAB and to exchange information and ideas through discussions on topics, including:

1. POU progress and achievements by including more detailed information for each project in the following WMPs
2. Performance metrics
3. QA/QC program
4. Independent evaluator reports
5. Executive summaries
6. Late WMP submissions
7. Revision log
8. Digital accessibility
9. Other items that come up through meetings or workshops

6. Northern California Power Agency 2023 Progress in Implementing Wildfire Mitigation Plan Wildfire Prevention Strategies

This section describes NCPA's accomplishments in 2023 for the wildfire prevention program and strategies described in the WMP.

WWW.POWERENG.COM

LAX (2024-05-28) KC

PAGE 5 OF 10

May 28, 2024

6.1 Vegetation Management

Geothermal

- Completed annual maintenance of firebreaks around Plants #1 and #2 in February 2023.
- Completed vegetation management and line clearance work along the 230-kV tie-in lines and around all nine tower bases in June 2023.
- Completed annual maintenance of vegetation around Plants #1 and #2 perimeters plus along access roads in August 2023.

Hydroelectric

- Completed annual maintenance of vegetation around powerhouses and substation in May 9, 2023.
- Completed vegetation management and line clearance work along 230-kV tie-in lines and around tower bases in September 1, 2023.
- McKay's Point 17-kV Service Line: Fire-hardening improvements were analyzed in 2023, with construction anticipated to be complete by Q4 2024.

6.2 Annual Inspections

Geothermal

- 230-kV physical transmission line inspections and insulation and hardware replacement in March 2024 (this superseded a drone inspection).
- 21-kV line inspection completed in August 2023.

Hydroelectric

- 230-kV transmission line inspection completed July 10, 2023.
- 17-kV line wood pole inspections completed November 29, 2023.
- 230-kV line daycore corona and IR inspection completed June 12, 2023.
- 230-kV LiDAR transmission line inspection completed December 28, 2023.
- NSM-Cabbage Patch 21-kV cable tests completed June 18, 2022.

7. Wildfire Mitigation Plan Metric Overview

In 2020 the California Municipal Utilities Association (CMUA) published a WMP template for POU's to use in the preparation of their WMPs. Metrics help POU's determine if their wildfire prevention strategies are effective for reducing the risk of a wildfire ignited by their electrical equipment. This template included two metrics: number of fire ignition events and wires down events.

NCPA adopted the two metrics suggested by the CMUA in the first and second iterations of their WMP. In 2023, NCPA adopted an additional metric: "Fall in Hazard Trees Ignitions." These three metrics: fire ignitions, wires down, and fall in hazard tree ignitions are included in the 2024 WMP.

NCPA records metric data in monthly outage reports. For each event, NCPA records date and time, an event description, and the cause (if known). This information includes if the event was the result of an external cause, whether the outage was forced or planned, and how long the event lasted. If the event occurred along one of the tie-in lines, then the location of the event along the line is described.

WWW.POWERENG.COM

May 28, 2024

NCPA recorded the following data for the three metrics in Table 2 for the years 2020 to 2023.

Table 2 Metric Event Record in 2020-2023

Metric	Geothermal	Hydroelectric
Fire Ignitions	0	0
Wire Down	0	0
Fall in Hazard Tree Ignitions*	10 Locations, 0 Fall Ins	2 Locations, 0 Fall Ins

*2023 metric summary only.

These three metrics, with the supplemental data regarding the event date and time and event cause, are useful for apprising NCPA about the effectiveness of their wildfire prevention strategies. Comparing their outage event rate on their transmission lines to PG&E's outage event rate for their transmission lines provides a good perspective on why the "0" metric events for the wire down metric is indicative of success and not an indicator of an ineffective metric.

Additional metrics may be added to the WMP, as needed, to identify which lines are most susceptible to risk factors from unexpected outages (human, animal, or vegetation induced), time-of-year risks (drought or excessive rainfall), shifting fire threat districts, or impact of maintenance deferment on existing lines.

8. Comparison of Industry Standards and Similar Utility Wildfire Prevention Strategies

As part of this review, POWER compared the wildfire prevention strategies described in the WMP to the strategies being implemented by POU's and accepted electrical industry practices for reducing wildfire risk. NCPA is unique in that they are primarily a producer of electrical power whose transmission lines are limited to tie-ins to the electrical utilities who provide the distribution of electrical power to retail customers. NCPA's service territory is also unique in that their facilities, including generators and tie-lines, are dispersed in areas with no development except for infrastructure related to their operations. This is particularly important in that they have a greater responsibility for vegetation management/defensible space to protect their facilities than other POU's. Therefore, there are no comparable POU's in the state and it is more appropriate to compare their wildfire prevention programs to a relevant industry standard such as the National American Electric Reliability Corporation (NERC), California Public Utility Code General Order 95 (GO 95), Public Resource Code (PRC) 4292 and 4293, and CAL FIRE's California Power Line Fire Prevention Field Guide.

8.1 Vegetation Management

NCPA performs vegetation management work along their tie-in lines and around their facilities. NCPA maintains the vegetation within the right-of-way of its transmission tie-in lines to NERC FAC-003-4. There is at least 30 feet of vertical clearance between the trees and vegetation and the wires. The corridors containing the transmission wires are typically 100 feet wide except where terrain makes it unsafe to maintain the full 100 feet. For the generation facilities, NCPA meets PRC 4292 and 4293 requirements as well as PUC GO 95 requirements, typically maintaining a 50- to 100-foot perimeter around structures.

WWW.POWERENG.COM

LAX (2024-05-28) KC

PAGE 7 OF 10

May 28, 2024

8.2 System Hardening

Equipment Maintenance and Upgrades

All NCPA transmission line towers are entirely constructed of lattice or tubular steel and so are inherently noncombustible. Conductors and other electrical equipment attached to NCPA towers are also constructed of metal or other non-combustible materials. Transformers, circuits, and other types of electrical equipment located at substations are constructed entirely of non-combustible materials and surrounded by a large area of bare ground. No system hardening or equipment upgrades would result in significant improvements to fire resistance of NCPA equipment. NCPA inspects its transmission towers on a regular basis and issues with towers or tower equipment discovered during the inspection are repaired immediately.

NCPA utilizes wood poles for the 17-kV distribution line at the McKay's Point facility and the 21-kV line at NCPA's Geothermal Facility. NCPA recently rebuilt the 21-kV line and is in the process of fire hardening the McKay's Point 17-kV distribution line.

Construction Standards

NCPA construction standards are designed to reduce the risk of fire ignited by the failure of electrical equipment, which includes the use of animal deterrents, lightning arresters, and arc suppression fusing. NCPA does not use explosive fuses on any of its lines that pass over areas of vegetation.

Recloser Policy

NCPA does not have reclosers on their 230-kV transmission lines. Relaying equipment on their 21-kV Bear Canyon line is set to a zero-reclose to lockout scheme.

8.3 Situational Awareness

NCPA has a Transmission Maintenance and Inspection Program that meets the standards described in NERC FAC-501-WECC-3. NCPA regularly performs visual inspections of their equipment and lines, including those in remote areas. Regular and thorough inspections, particularly for transmission lines, is a nationally accepted best practice for early equipment fault detection and hazardous vegetation identification.

9. Conclusion and Recommendations

NCPA prepared a comprehensive 2024 WMP. The plan meets all statutory requirements described in PUC §8387(b)(2). NCPA also considered WSAB recommendations. NCPA's WMP, with appendices, describes a wildfire mitigation program that accurately assesses the risks and risk drivers present in their service territory and implements preventative strategies that are effective at reducing wildfire risks.

NCPA may consider creating a prevailing wind map. Maps are useful to illustrate wind direction in relation to NCPA's facilities within high fire threat zones.

NCPA may also consider reviewing and updating the Public Safety Power Shutoff plan for the Hydroelectric Facility.

WWW.POWERENG.COM

LAX (2024-05-28) KC


PAGE 8 OF 10

May 28, 2024

NCPA may consider updating the amount of the Geothermal effluent pump system and 21-kV service line and steam field and delivery that are within the CAL FIRE Fire Hazard Severity Zones and CPUC Tier 2/3 Threat Zones based on the updated CAL FIRE and CPUC fire hazard maps.

Based on the wildfire prevention programs described in the WMP and the progress NCPA has made in its wildfire prevention programs, NCPA is taking an active role in minimizing the risk of its equipment starting a wildfire and minimizing the risk of a wildfire near their facilities that could impact their operations.

Sincerely,



Kathleen Cooney
Project Manager
Phone: 512-735-1823
kathleen.cooney@powereng.com



Brent Miyazaki, PG, CHG
Senior Project Manager
Phone: 714-507-2722
brent.miyazaki@powereng.com

cc: Kim Quinn, POWER Engineers, Inc.

WWW.POWERENG.COM

LAX (2024-05-28) KC

PAGE 9 OF 10

May 28, 2024

References

WSAB. 2023. *Guidance Advisory Opinion for the 2024 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electrical Cooperatives*. December 4, 2023. Sacramento, CA. Accessed online: [wsab-2024-wmp-pou-advisory-opinion.pdf \(ca.gov\)](#)

REVISION HISTORY

Version 1.0 - NCPA Commission approved on December 5, 2019 per Resolution 19-100

Version 1.1 – NCPA Commission approved on May 29, 2020 per Resolution 20-43. This WMP includes the qualified Independent Evaluators (IE) report in Appendix 2.

Version 1.2 – NCPA Commission approved on May 27, 2021 per Resolution 21-56. This WMP includes the qualified Independent Evaluators (IE) report in Appendix 3.

Version 1.3 – NCPA Commission approved on May 26 2022 per Resolution 22-58. This WMP includes the qualified Independent Evaluators (IE) report in Appendix 4.

Version 2.0 - NCPA Commission approved on May 25, 2023 per Resolution 23-46. This WMP includes the Qualified Independent Evaluators (IE) report in Appendix 5.

ATTACHMENT A - PUC 8387 (B) REQUIREMENTS TABLE

Attachment A: Index of Required Element Location in WMP

2024 WMP Required Element per PUC Sec 8387(b)(2)	2024 NCPA WMP section
(A): An accounting of the responsibilities of persons responsible for executing the plan.	3.B., 3.C.
(B): The objectives of the wildfire mitigation plan.	1.B.
(C): A description of the preventive strategies and programs to be adopted by the local publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.	5.A., 5.B., 5.C.
(D): A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan’s performance and the assumptions that underlie the use of those metrics.	7.A.
(E): A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.	7.B.
(F): Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure.	N/A – NCPA does not own or use automatic reclosers on its 230 kV lines (5.H.)
(G): Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. The procedures shall direct notification to all public safety offices, critical first responders, health care facilities, and operators of telecommunications infrastructure with premises within the footprint of potential deenergization for a given event.	5.J.2.

(H): Plans for vegetation management .	5.E.
(I): Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.	7.E.
(J): A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility's or electrical cooperative's service territory. The list shall include, but not be limited to, both of the following: (i) Risks and risk drivers associated with design, construction, operation, and maintenance of the local publicly owned electric utility's or electrical cooperative's equipment and facilities. (ii) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned electric utility's or electrical cooperative's service territory.	(J) : 4 (i) : 4.B. (ii) : 4.A.
(K): Identification of any geographic area in the local publicly owned electric utility's or electrical cooperative's service territory that is a higher wildfire threat than is identified in a commission fire threat map, and identification of where the commission should expand a high-fire threat district based on new information or changes to the environment.	N/A – At this time, NCPA does not identify any needed changes to the current boundaries as identified in current maps included in Appendix 1 – Fire Risk Assessment Maps.
(L): A methodology for identifying and presenting enterprise wide safety risk and wildfire-related risk.	4.B.
(M): A statement of how the local publicly owned electric utility or electrical cooperative will restore service after a wildfire.	7.
(N): A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following: (i) Monitor and audit the implementation of the wildfire mitigation plan. (ii) Identify any deficiencies in the wildfire mitigation plan or its implementation and correct those deficiencies. (iii) Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the plan, other applicable statutes, or commission rules.	(i) : 7.C. (ii) : 7.D. (iii) : 7.E

ATTACHMENT B – WSAB RECOMMENDED ELEMENTS TABLE

Table 2: Index of WSAB Recommended Element Location in WMP

2023 WSAB Recommended Elements	2023 NCPA WMP section
<p>(A): The WSAB has requested that public owned utilities include a table that describes each of the PUC requirements and where each requirement can be found in the WMP. This table should be incorporated into the WMP as Attachment A.</p>	<p>The table describing how each of the PUC requirements have been addressed by NCPA’s WMP has been added as Attachment A</p>
<p>(B):The WSAB has requested that publicly-owned utilities re-evaluate their general WMP objectives to take on a broader approach that goes beyond minimizing ignitions. It is recommended that NCPA re-evaluate their objectives for the following strategies: objectives that minimize the risk of fire spread or intensity and objectives that allow NCPA to restore services/return to full capacity after a wildfire spreads impacts their assets.</p>	<p>NCPA has evaluated and updated its strategies in section 5.A. of the WMP to address methods of minimizing the risk of fire spread. The strategies for restoration of services contained in section 5.H. of the WMP have been evaluated and will not be revised at this time based on the minimal impact to customers related to potentially delayed restoration of service.</p>
<p>(C): The WSAB has requested that future WMP’s contain a description of the public input and approval process for the WMP. It is recommended that NCPA add a small paragraph describing the utility’s public approval process for their plan and where the WMP is posted for review by the public.</p>	<p>A paragraph describing NCPA’s public document accessibility, review and approval process, and method for incorporation of public comments into the WMP plan has been added to section 3.B. of the WMP.</p>
<p>(D): The board has recommended that public owned utilities re-evaluate their metrics to determine if they are useful for informing them on the effectiveness of the plan. It is recommended that NCPA consider adding a new metric or replacing an existing metric with a performance-based metric like equipment inspections or trees trimmed as well as another leading metric such as number of vegetation contacts with wires discovered or equipment faults detected.</p>	<p>NCPA has considered the recommendation to consider adding a new metric or replacing an existing metric with a performance-based metric. A residual risk is related to the potential for soil instability in areas previously affected by wildfire to result in a “fall in” by trees of sufficient height to contact Distribution lines. Section 7.A. has been updated to add this new metric.</p>

<p>(E): The WSAB recommends that the Independent Evaluators report contain a comparison of the utility’s operations and equipment to relevant industry standards. It is requested that NCPA provide a list of specific operational practices and equipment that NCPA employs to reduce the risk of wildfire within the service territory.</p>	<p>NCPA has addressed specific equipment and operational practices to reduce the risk of wildfire within the service territory in section 5.A.of the WMP.</p>
--	---

ATTACHMENT C – WILDFIRE RISK ELEMENTS AND CONTROLS

Table 3 – Index of Wildfire Risks and Controls Evaluations within the WMP

Identify and Assess Wildfire Event Elements Fuel Ignition	Design Controls	Implement Controls	Evaluate Controls (WMP Section)
Free contact or downed conductor along wind centered events	X	Design and maintain Distribution and Transmission facilities in accordance with FGLE approved practices for wildland fire prevention. De-energize facilities when needed during high winded flag conditions.	3.C. Wildfire Response Communication and Recovery and 5.A.(4) Asset Recovery and 5.A.(4) Asset documentation.
Dead limbs or trees contacting Distribution lines	X	Identify and remove dead and dying trees from areas adjacent to lines.	5.E. Vegetation Management
Increased tree mortality	X	Identify and remove dead and dying trees from areas adjacent to Transmission facilities.	5.D. Tree Mortality
Trees encroaching on right-of-way distances to Transmission facilities	X	Identify and remove encroaching trees. De-energize facilities upon CAL FIRE request.	5.1. De-Energization
Faulty trees resulting from landslides or trunk failures	X	Routine inspections and non-routine incidental observations.	5.B. Potential Climate Change Effects
Fuses or conductor drooping molten metal	X	Use of non-expulsion type fuses in high fire risk areas (HFA), protection of Transmission and Distribution circuits in accordance with design standards, abating of lines prior to re-energization.	3.C. Wildfire Response Communication and Recovery; 5.A.(4) Asset documentation; 5.H. Restorer Policy and 7. Restoration of Service.
Untimely fire department response	X	Emergency Action Plan (EAP) training and coordination with local agencies.	1.B.1. Coordination with local Agencies
Undetected equipment damage or failures	X	Routine inspections and non-routine incidental observations.	5.A.(1) Facility Maintenance Program and 5.A.(2) Emergency Operating Procedures
Uncoordinated wildfire response	X	Personnel training and notification to Dispatch center for coordinated response.	Communication and Recovery
Staff unaware of wildfire risk or response	X	Personnel training and seasonal awareness reminders.	5.G. Fire Prevention, Safety, Emergency Response Training
Extended timeframe for fire event recovery	X	Leverage additional line personnel and resources via mutual aid agreements.	3.F. Mutual Aid Agreements
Extended drought conditions	X	Routine inspections and non-routine incidental observation.	5.C. Potential Climate Change Risk Management Practices
Underbrush damage from fire	X	Awareness and response.	5.B. Potential Climate Change Effects
Vegetation stress or species changes	X	Awareness and periodic personnel training.	5.A.(3) Vegetation Management Program
Lightening strikes	X	Awareness and periodic personnel training.	5.G. Fire Prevention, Safety, Emergency Response Training
Vehicles operating in dry vegetation areas	X	Periodic review of the risk categories.	5.C. Identifying Unnecessary or Ineffective Actions; 4.C. Changes to CIRC Fire Threat Map and 7.C. Monitoring and Auditing the Plan.
Vegetation clearing operations	X	Annual review of protective equipment calibration and testing records. Periodic (every 5 years) verification of protective device operating time IAW NERC RIC-005.	5.A.(1) Facility Maintenance Program
Hot Work	X	Periodic review of the risk categories.	
Undetected fire risk change	X	Annual review of protective equipment calibration and testing records. Periodic (every 5 years) verification of protective device operating time IAW NERC RIC-005.	
Protective device delayed clearing	X	Annual review of protective equipment calibration and testing records. Periodic (every 5 years) verification of protective device operating time IAW NERC RIC-005.	

