

July 11, 2024

VIA ELECTRONIC FILING

Docket # 2023 NOV

Patrick Doherty Program Manager Compliance Assurance Division Office of Energy Infrastructure Safety 715 P Street, 20th Floor Sacramento, CA 95814

RE: PacifiCorp's Response to Notice of Violation NOV_CAD_PC_CAC17_20240501_1051

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding(s) identified in the "Notice of Violation NOV_CAD_PC_CAC17_20240501_1051" (Notice of Violation or NOV) issued by the Office of Energy Infrastructure Safety (Energy Safety) on June 11, 2024. On May 1, 2024, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of the city of Weed, California. The inspection report is enclosed herewith.

Energy Safety found the following violations:

Violation 1. Energy Safety observed that in implementing 2023 WMP initiative 8.1.2.3 - Distribution Pole Replacements and Reinforcements, PacifiCorp failed to replace distribution pole ID 06242005.0177461 at coordinates 41.4857664462249, -122.442510294584. Energy Safety considers this completeness violation to be in the Minor risk category.

PacifiCorp Response:

In response to the notice of violation, the company conducted a field inspection on June 26, 2024. PacifiCorp may have provided inaccurate information. Sequence 6470 on Work Order #8077681 and Work Order #8077682 does not call for a Replace and Install of pole ID 06242005.0177461. The existing pole was evaluated and found to be adequate for the final design. PacifiCorp has no plans to replace this pole under Wildfire Mitigation.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's NOV_CAD_PC_CAC17_20240501_1051. Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or <u>californiadockets@pacificorp.com</u>.

Office of Energy Infrastructure Safety July 11, 2024 Page 2

Sincerely,

H 64

Allen Berreth Vice President of Transmission & Distribution Operations PacifiCorp 825 NE Multnomah Street, Suite 2000 Portland, OR 97232