

PORT OF STOCKTON

2024-26

UTILITY

WILDFIRE

MITIGATION

PLAN

Approved by the Board of Port Commissioners on August 19, 2024

Resolution #8517

TABLE OF CONTENTS

I.	Overview	4
A.	Policy Statement	4
B.	Purpose of the UTILITY Wildfire Mitigation Plan	4
C.	Process for Utility Adoption and Opportunity for Public Comment	4
D.	Description of Where the WMP Can Be Found on the Port's Website	4
E.	Context Setting Information	4
F.	Statutory cross reference table.....	5
G.	Organization of the UTILITY Wildfire Mitigation Plan.....	9
II.	Objectives of the UTILITY Wildfire Mitigation Plan	9
III.	Roles and Responsibilities	10
A.	Utility Governance Structure	10
B.	WILDFIRE PREVENTION	11
C.	WILDFIRE RESPONSE AND RECOVERY	11
D.	Standardized Emergency Management System	12
IV.	Wildfire Risks and Drivers associated with design, construction, operation, and maint	13
A.	Particular Risks and Risk Drivers Associated With Topographic and Climatological Risk Factors	13
B.	Enterprisewide Safety Risks	13
V.	Wildfire Preventative Strategies	14
A.	High fire threat district	14
B.	Design and Construction Standards	14
C.	Vegetation Management	14
D.	Inspections.....	15
E.	Reclosing Policy	16

F.	Deenergization.....	16
VI.	Restoration of Service	16
VII.	Evaluation of the Plan	17
A.	Metrics and Assumptions for Measuring Plan Performance	17
	Metric 1: Performance Metrics.....	17
	Metric 2: Outcome Metrics.....	17
B.	Impact of Metrics on Plan.....	18
C.	Monitoring and Auditing the Plan	18
D.	Identifying and correcting Deficiencies in the Plan	18
E.	Monitoring the effectiveness of inspections	19
F.	Climate change.....	19
VIII.	Independent Auditor	19
	Metric 1: Fire Ignitions	20
	Metric 2: Wires Down.....	20
	Conclusions.....	20

I. OVERVIEW

A. POLICY STATEMENT

The Port of Stockton's (Port) overarching goal is to provide safe, reliable, and economic electric service to its local community. In order to meet this goal, the Port constructs, maintains, and operates its electrical lines and equipment in a manner that minimizes the risk of catastrophic wildfire posed by its electrical lines and equipment.

B. PURPOSE OF THE UTILITY WILDFIRE MITIGATION PLAN

The Port is located in a region of the state with a very low wildfire risk. No part of the Port's service territory is located in or near the High Fire Threat District designed in the California Public Utilities Commission's (CPUC) Fire Threat Map. The entirety of the Port's service territory is designated as "non-fuel" or "moderate" in the California Department of Forestry and Fire Protection's (CALFIRE) Fire and Resource Assessment Program (FRAP) Fire Threat Map. Based on a review of local conditions and historical fires, the Port has determined that its electrical lines and equipment do not pose a significant risk of catastrophic wildfire.

Despite this low risk, the Port takes appropriate actions to help its region prevent and respond to the increasing risk of wildfires. In its role as a public agency, the Port closely coordinates with other local safety and emergency officials to help protect against fires and respond to emergencies. In its role as a utility, the Port follows all applicable design, construction, operation, and maintenance requirements that reduce safety risks associated with its system. This Utility Wildfire Mitigation Plan (WMP) describes the safety-related measures that the Port follows to reduce its risk of causing wildfires.

C. PROCESS FOR UTILITY ADOPTION AND OPPORTUNITY FOR PUBLIC COMMENT

Once Port staff has prepared the WMP, it is placed on the Agenda for the Board of Port Commissioners, where the WMP will be presented in a public meeting before the Board and the public will be afforded an opportunity to comment.

D. DESCRIPTION OF WHERE THE WMP CAN BE FOUND ON THE PORT'S WEBSITE

The currently effective WMP and any associated approvals are available for public review on the website for the Port of Stockton, [located www.portofstockton.com](http://www.portofstockton.com) and selecting "Electric Utility" tab.

E. CONTEXT SETTING INFORMATION

The following informational table is provided to assist the Wildfire Safety Advisory Board (WSAB) members and staff in understanding the unique characteristics of the Port.

Table 1: Context-Setting Information

Utility Name	Port of Stockton	
Service Territory Size	[2.19] square miles (1,400 acres)	
Owned Assets	<input type="checkbox"/> Transmission <input checked="" type="checkbox"/> Distribution <input type="checkbox"/> Generation	
Number of Customers Served	[43] customer accounts	
Population Within Service Territory	[0] people	
Customer Class Makeup	<i>Number of Accounts</i>	<i>Share of Total Load (MWh)</i>
	[]% Residential; []% Government; []% Agricultural; []% Small/Medium Business; [100]% Commercial/Industrial	[]% Residential; []% Government; []% Agricultural; []% Small/Medium Business; [100]% Commercial/Industrial
Service Territory Location/Topography¹	[3]% Agriculture [10]% Barren/Other []% Conifer Forest []% Conifer Woodland []% Desert []% Hardwood Forest []% Hardwood Woodland []% Herbaceous [3]% Shrub [84]% Urban []% Water	
Service Territory Wildland Urban Interface² (based on total area)	[0]% Wildland Urban Interface; [0]% Wildland Urban Intermix;	
Percent of Service Territory in CPUC High Fire Threat Districts (based on total area)	<input checked="" type="checkbox"/> Includes maps Tier 2: [0]% Tier 3: [0]%	
Prevailing Wind Directions & Speeds by Season	<input checked="" type="checkbox"/> Includes maps NE direction Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec Wind Speed (mph) 6.1 6.6 6.9 7.5 8.4 9.0 8.9 8.3 7.1 6.1 6.1 6.4	

¹ This data shall be based on the California Department of Forestry and Fire Protection, California Multi-Source Vegetation Layer Map, depicting WHR13 Types (Wildlife Habitat Relationship classes grouped into 13 major land cover types) available at: <https://www.arcgis.com/home/item.html?id=b7ec5d68d8114b1fb2bfbf4665989eb3>.

² This data shall be based on the definitions and maps maintained by the United States Department of Agriculture, as most recently assembled in *The 2010 Wildland-Urban Interface of the Conterminous United States*, available at https://www.fs.fed.us/nrs/pubs/rmap/rmap_nrs8.pdf.

Miles of Owned Lines Underground and/or Overhead	Overhead Dist.: [11] miles Overhead Trans.: [0] miles Underground Dist.: [1] miles Underground Trans.: [0] miles
	Explanatory Note 1 - Methodology for Measuring "Miles": [e.g., circuit miles, line miles.] Line Miles
	Explanatory Note 2 – Description of Unique Ownership Circumstances: [____]
	Explanatory Note 3 – Additional Relevant Context: [e.g., percentage of lines located outside service territory] None
Percent of Owned Lines in CPUC High Fire Threat Districts	<i>Overhead Distribution Lines as % of Total Distribution System (Inside and Outside Service Territory)</i>
	Tier 2: [0]% Tier 3: [0]%
	<i>Overhead Transmission Lines as % of Total Transmission System (Inside and Outside Service Territory)</i>
	Tier 2: [0]% Tier 3: [0]%
	Explanatory Note 4 – Additional Relevant Context: [e.g., explain any difference from data reported in WMP due to different numerator used for this form]
Customers have ever lost service due to an IOU PSPS event?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Customers have ever been notified of a potential loss of service to due to a forecasted IOU PSPS event?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (Notifications issued by PG&E as owners of the affected infrastructure)
Has developed protocols to pre-emptively shut off electricity in response to elevated wildfire risks?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Has previously pre-emptively shut off electricity in response to elevated wildfire risk?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, then provide the following data for calendar year 2022 <i>Number of shut-off events:</i> [____] <i>Customer Accounts that lost service for >10 minutes:</i> [____] <i>For prior response, average duration before service restored:</i> [____]

F. STATUTORY CROSS REFERENCE TABLE

The following table provides a clear roadmap as to where each statutory requirement is addressed within the Port's WMP.

Table 2: Cross References to Statutory Requirements

Requirement	Statutory Language	Location in WMP
Persons Responsible	PUC § 8387(b)(2)(A): An accounting of the responsibilities of persons responsible for executing the plan.	Section [III] Page [9]
Objectives of the Plan	PUC § 8387(b)(2)(B): The objectives of the wildfire mitigation plan.	Section [II] Page: [9]
Preventive Strategies	PUC § 8387(b)(2)(C): A description of the preventive strategies and programs to be adopted by the local publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.	Section [V] Page [13]
Evaluation Metrics	PUC § 8387(b)(2)(D): A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan's performance and the assumptions that underlie the use of those metrics.	Section [VII] Page [16]
Impact of Metrics	PUC § 8387(b)(2)(E): A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.	Section [VII] Page [16]
Deenergization Protocols	PUC § 8387(b)(2)(F): Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure.	Section [V] Page [15]
Customer Notification Procedures	PUC § 8387(b)(2)(G): Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. The procedures shall consider the need to notify, as a priority, critical first responders, health care facilities, and operators of telecommunications infrastructure.	Section [III] Page [11]
Vegetation Management	PUC § 8387(b)(2)(H): Plans for vegetation management.	Section [V] Page [13]
Inspections	PUC § 8387(b)(2)(I): Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.	Section [V] Page [15]

<p>Prioritization of Wildfire Risks</p>	<p>PUC § 8387(b)(2)(J): A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility’s or electrical cooperative’s service territory. The list shall include, but not be limited to, both of the following:</p> <p>(i) Risks and risk drivers associated with design, construction, operation, and maintenance of the local publicly owned electric utility’s or electrical cooperative’s equipment and facilities.</p> <p>(ii) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned electric utility’s or electrical cooperative’s service territory.</p>	<p>Section [IV] Page [12]</p>
<p>CPUC Fire Threat Map Adjustments</p>	<p>PUC § 8387(b)(2)(K): Identification of any geographic area in the local publicly owned electric utility’s or electrical cooperative’s service territory that is a higher wildfire threat than is identified in a commission fire threat map, and identification of where the commission should expand a high fire threat district based on new information or changes to the environment.</p>	<p>Section [V] Page [13]</p>
<p>Enterprisewide Risks</p>	<p>PUC § 8387(b)(2)(L): A methodology for identifying and presenting enterprisewide safety risk and wildfire-related risk.</p>	<p>Section [IV-B] Page [12]</p>
<p>Restoration of Service</p>	<p>PUC § 8387(b)(2)(M): A statement of how the local publicly owned electric utility or electrical cooperative will restore service after a wildfire.</p>	<p>Section [VI] Page [15]</p>
<p>Monitor and Audit</p>	<p>PUC § 8387(b)(2)(N): A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following</p> <p>(i) Monitor and audit the implementation of the wildfire mitigation plan.</p> <p>(ii) Identify any deficiencies in the wildfire mitigation plan or its implementation, and correct those deficiencies.</p> <p>(iii) Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the plan, other applicable statutes, or commission rules.</p>	<p>Section [IV] Page [12]</p>

<p style="text-align: center;">Qualified Independent Evaluator</p>	<p>PUC § 8387(c): The local publicly owned electric utility or electrical cooperative shall contract with a qualified independent evaluator with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan. The independent evaluator shall issue a report that shall be made available on the Internet Web site of the local publicly owned electric utility or electrical cooperative, and shall present the report at a public meeting of the local publicly owned electric utility’s or electrical cooperative’s governing board.</p>	<p style="text-align: center;">Section [VI] Page [17]</p>
---	---	---

G. ORGANIZATION OF THE UTILITY WILDFIRE MITIGATION PLAN

This Utility Wildfire Mitigation Plan includes the following elements:

- Objectives of the plan;
- Roles and responsibilities for carrying out the plan;
- Identification of key wildfire risks and risk drivers;
- Description of wildfire prevention, mitigation, and response strategies and programs;
- Metrics for evaluating the performance of the plan and identifying areas for improvement;
- Review and validation of the plan; and
- Timelines.


II. OBJECTIVES OF THE UTILITY WILDFIRE MITIGATION PLAN

The primary goal of this Utility Wildfire Mitigation Plan is to describe the Port's existing programs, practices, and measures that effectively reduce the probability that the Port's electric supply system could be the origin or contributing source for the ignition of a wildfire. To support this goal, the Port regularly evaluates prudent and cost-effective improvements to its physical assets, operations, and training that can help reduce the risk of equipment-related fires.

The secondary goal of this Utility Wildfire Mitigation Plan is to improve the resiliency of the electric grid. As part of the development of this plan, the Port assesses new industry practices and technologies that will reduce the likelihood of an interruption (frequency) in service and improve the restoration (duration) of service.

III. ROLES AND RESPONSIBILITIES

A. UTILITY GOVERNANCE STRUCTURE



POU / Municipal Governance Structure:

The Stockton Port District (Port) is a public corporation created for municipal purposes pursuant to Section 6290 of the California Harbors and Navigation Code. The Board of Port Commissioners is the Publicly Owned Utility governing body and the Port Director is the Publicly Owned Utility Chief Executive Officer.

The Port owns and maintains the utility system infrastructure, including power lines and poles, located on Rough & Ready Island, which is also known as the West Complex. Pacific Gas and Electric Company (PG&E) provides electricity to the West Complex pursuant to an industrial tariff.

Through a recently amended/extended Interconnection Agreement, PG&E provides the Port with wholesale electric transmission service from the California Independent System Operator's (CAISO) electric grid. The point of interconnection between the two electric systems is the high voltage (60kV) side of the Port's Rough & Ready substation. The Port provides low voltage (12kV) retail electric distribution service to its tenants within the West Complex.

B. WILDFIRE PREVENTION

This section provides a description of Port Staff roles and responsibilities relating to: (1) electric facility design, maintenance, and inspection; and (2) vegetation management.

Director of Facilities & Procurement:

The Director of Facilities & Procurement is responsible for the day-to-day operation of the Port of Stockton's Electric Utility. The Director of Facilities & Procurement will prepare reports and advise the Deputy Port Director, Maritime & Real Estate of operational circumstances and items that may impact the Port relative to wildfire prevention and implement the following best management practices:

- Operate system in a manner that will minimize potential wildfire risks.
- Take all reasonable and practicable actions to minimize the risk of a catastrophic wildfire caused by Port electric facilities.
- Coordinate with federal, state, and local fire management personnel as necessary or appropriate to implement Port Utility Wildfire Mitigation Plan.
- Immediately report fires, pursuant to the Port's Emergency Operations Plan and the requirements of this Utility Wildfire Mitigation Plan.
- Take corrective action when the staff witnesses or is notified that fire protection measures have not been properly installed or maintained.
- Comply with relevant federal, state, and industry standard requirements, including the industry standards established by the California Public Utilities Commission.

Deputy Port Director, Maritime & Real Estate:

The Deputy Port Director, Maritime & Real Estate, has the overall responsibility for executing and ensuring compliance with the Utility Wildfire Mitigation Plan. The Deputy Port Director, Maritime & Real Estate reports to the Port Director regarding wildfire risk management activities and will advise him and/or the Board of Port Commissioners of the status of the program on an annual basis.

C. WILDFIRE RESPONSE AND RECOVERY

During any emergency (including a fire) that occurs at or near the Port, certain Port staff and Port contractors are designated as points of contact with relevant local governmental and emergency officials:

- **Ricardo Navarro:** Primary Contact
- **Kevin Spagnola:** Secondary Contact, and first on site during an emergency. Kevin Spagnola would be the contact for Tesla and Grid Operations for outage and load restoration.
- **Richard Smith:** Response and investigation.

After an emergency has occurred, the Port Administration oversees any necessary response and recovery efforts of the Port of Stockton Electrical Utilities. The following Port Administration Staff have the following oversight roles:

- **Jason Katindoy:** Administrator and Contracts, Rate Schedules
- **Juan G. Villanueva:** Project Administration and Construction Project Manager
- **Ricardo Navarro:** Electrical Utilities operations
- **Richard Smith, PE:** Electrical engineering consultant from HCS Engineering
- **Kevin Spagnola:** Troubleshooter for substation and Rough and Ready Island power outages; outside contractor with Bockmon and Woody Electric.

D. STANDARDIZED EMERGENCY MANAGEMENT SYSTEM

As a local governmental agency,³ the Port has planning, communication, and coordination obligations pursuant to the California Office of Emergency Services' Standardized Emergency Management System ("SEMS") Regulations,⁴ adopted in accordance with Government Code section 8607. The SEMS Regulations specify roles, responsibilities, and structures of communications at five different levels: field response, local government, operational area, regional, and state.⁵ Pursuant to this structure, the Port annually coordinates and communicates with the relevant safety agencies as well as other relevant local and state agencies.

Under the SEMS structure, a significant amount of preparation is done through advanced planning at the county level, including the coordination of effort of public, private, and nonprofit organizations. San Joaquin County serves as the Operational Area (OA) and is guided by the San Joaquin County Office of Emergency Services. The Operational Area includes local and regional organizations that bring relevant expertise to the wildfire prevention and recovery planning process. San Joaquin County is charged with taking the lead coordination role within the OA and with being the primary point of contact for the region and state. As an OA lead entity, the County manages and/or coordinates information, resources, and priorities among local governments and serves as the link between the local government and the regional level. At this level, the governing bodies are required in SEMS to reach a consensus on how resources will be allocated in a major crisis affecting multiple jurisdictions or agencies. Pursuant to the SEMS structure, the Port participates in annual training exercises. The Port includes the Stockton Fire Department, Stockton Police Department, San Joaquin County Sheriff's Office, California Highway Patrol, San Joaquin County OES, and several other local and federal partners in annual exercises testing SEMS.

³ As defined in Cal. Gov. Code § 8680.2.

⁴ 19 CCR § 2407.

⁵ Cal. Gov. Code § 2403(b):

- (1) "Field response level" commands emergency response personnel and resources to carry out tactical decisions and activities in direct response to an incident or threat.
- (2) "Local government level" manages and coordinates the overall emergency response and recovery activities within their jurisdiction.
- (3) "Operational area level" manages and/or coordinates information, resources, and priorities among local governments within the operational area and serves as the coordination and communication link between the local government level and the regional level.
- (4) "Regional level" manages and coordinates information and resources among operational areas within the mutual aid region designated pursuant to Government Code §8600 and between the operational areas and the state level. This level along with the state level coordinates overall state agency support for emergency response activities.
- (5) "State level" manages state resources in response to the emergency needs of the other levels, manages and coordinates mutual aid among the mutual aid regions and between the regional level and state level, and serves as the coordination and communication link with the federal disaster response system.

The Port is a member of the California Utility Emergency Association, which plays a key role in ensuring communications between utilities during emergencies. The Port also participates in the Western Energy Institute's Western Region Mutual Assistance Agreement, which is a mutual assistance agreement covering utilities across a number of western states.

IV. WILDFIRE RISKS AND DRIVERS ASSOCIATED WITH DESIGN, CONSTRUCTION, OPERATION, AND MAINTENANCE

A. PARTICULAR RISKS AND RISK DRIVERS ASSOCIATED WITH TOPOGRAPHIC AND CLIMATOLOGICAL RISK FACTORS

Within the Port's service territory and the surrounding areas, the primary risk drivers for wildfire are the following:

- Extended drought;
- Vegetation type;
- Vegetation Density;
- Weather;
- High winds;
- Terrain;
- Changing Weather Patterns (Climate Change);
- Communities at Risk;
- Fire History.

B. ENTERPRISEWIDE SAFETY RISKS

A number of known threats and hazards affect the State of California, the County of San Joaquin, the City of Stockton, and the Port of Stockton. The following threats and hazards are specific to the San Joaquin Operational Area:

- Hazardous materials release – aboard a product carrier or at a facility
- Fire or explosion – aboard a product carrier or at a facility
- Flood or levee break – impending or actual
- Severe storm – impending or actual
- Earthquake – impending or actual
- Threat, incident, or attack – terrorist or other
- Civil unrest

The following threats and hazards are of specific concern within the Port of Stockton:

- Anhydrous ammonia release – aboard a product carrier or at a facility
- Fire – building, grass, or petroleum
- Chemical, biological, radiological, nuclear, explosive (CBRNE) incident involving cargo (aboard a product carrier or at a facility)
- CBRNE incident at a major public event – waterside

- Cyber attacks

V. WILDFIRE PREVENTATIVE STRATEGIES

A. HIGH FIRE THREAT DISTRICT

The Port participated in the development of the CPUC's Fire-Threat Map,⁶ which designates a High-Fire Threat District. In the map development process, the Port reviewed the proposed boundaries of the High Fire Threat District and confirmed that, based on local conditions and historical fire data, the entirety of the Port's service territory was properly excluded. While no part of the Port's service territory is located within the High Fire Threat District, the Port has incorporated the High Fire Threat District into its construction, inspection, maintenance, repair, and clearance practices. The Port will continue to evaluate its service territory and will determine if, based on changed environmental circumstances, any of the increased construction, inspection, maintenance, repair, and clearance requirements applicable in the High Fire Threat District should apply to any of the Port's facilities.

B. DESIGN AND CONSTRUCTION STANDARDS

The Port's electric facilities are designed and constructed to meet or exceed the relevant federal, state, or industry standard. The Port treats CPUC General Orders (GO) 95 and 128 as key industry standards for design and construction of overhead and underground electrical facilities. The Port meets or exceeds all standards in GO 95 and GO 128. Additionally, the Port monitors and follows, as appropriate, the National Electric Safety Code.

C. VEGETATION MANAGEMENT

The Port meets or exceeds the minimum industry standard vegetation management practices. For transmission-level facilities, the Port complies with NERC FAC-003-4, where applicable. For both transmission and distribution level facilities, the Port meets: (1) Public Resources Code section 4292; (2) Public Resources Code section 4293; (3) GO 95 Rule 35; and (4) the GO 95 Appendix E Guidelines to Rule 35. These standards require significantly increased clearances in the High Fire Threat District. The recommended time-of-trim guidelines do not establish a mandatory standard, but instead provide useful guidance to utilities. The Port will use specific knowledge of growing conditions and tree species to determine the appropriate time of trim clearance in each circumstance.

GO 95, Rule 35, Table 1					
Case	Type of Clearance	Trolley Contact, Feeder and Span Wires, 0-5kv	Supply Conductors and Supply Cables, 750 - 22,500 Volts	Supply Conductors and Supply Cables, 22.5 - 300 kV	Supply Conductors and Supply Cables, 300 - 550 kV (mm)

⁶ Adopted by CPUC Decision 17-12-024.

13	Radial clearance of bare line conductors from tree branches or foliage	18 inches	18 inches	¼ Pin Spacing	½ Pin Spacing
14	Radial clearance of bare line conductors from vegetation in the Fire-Threat District	18 inches	48 inches	48 inches	120 inches

Appendix E Guidelines to Rule 35

The radial clearances shown below are recommended minimum clearances that should be established, at time of trimming, between the vegetation and the energized conductors and associated live parts where practicable. Reasonable vegetation management practices may make it advantageous for the purposes of public safety or service reliability to obtain greater clearances than those listed below to ensure compliance until the next scheduled maintenance. Each utility may determine and apply additional appropriate clearances beyond clearances listed below, which take into consideration various factors, including: line operating voltage, length of span, line sag, planned maintenance cycles, location of vegetation within the span, species type, experience with particular species, vegetation growth rate and characteristics, vegetation management standards and best practices, local climate, elevation, fire risk, and vegetation trimming requirements that are applicable to State Responsibility Area lands pursuant to Public Resource Code Sections 4102 and 4293.

Voltage of Lines	Case 13	Case 14
Radial clearances for any conductor of a line operating at 2,400 or more volts, but less than 72,000 volts	4 feet	12 feet
Radial clearances for any conductor of a line operating at 72,000 or more volts, but less than 110,000 volts	6 feet	20 feet
Radial clearances for any conductor of a line operating at 110,000 or more volts, but less than 300,000 volts	10 feet	30 feet
Radial clearances for any conductor of a line operating at 300,000 or more volts	15 feet	30 feet

D. INSPECTIONS

The Port meets or exceeds the minimum inspection requirements provided in CPUC GO 165 and CPUC GO 95, Rule 18. Pursuant to these rules, utilities inspect electric facilities in the High Fire Threat District more frequently than the other areas of its service territory. As described above, the Port currently does not have any overhead powerlines located within or near the High-Fire Threat District within the CPUC's Fire Threat Map. However, the Port staff uses their knowledge of the

specific environmental and geographical conditions of the Port's service territory to determine if any particular areas require more frequent inspections.

If the Port staff discovers a facility in need of repair that is owned by an entity other than the Port, the Port will issue a notice to repair to the facility owner and work to ensure that necessary repairs are completed promptly.

E. RECLOSING POLICY

When an outage occurs, the first step is the Troubleman is dispatched to the site to determine a source of the outage.

For on-site related outages (as indicated by the protective relay system), the Troubleman visually inspects the system. The Port Troubleman visually inspects the power the distribution system for issues, and then manually recloses the onsite circuits. Then Operations bring Port load back online. The Port has not implemented automatic reclosures.

For off-site related outages, the Troubleman shuts down the individual circuits of Distribution system within the Port. Then electrical operations call's Tesla and coordinate re-instating loads with the network operations centers. After power is restored to the substation, the Troubleman re-energizes up the Port distribution system circuits one at a time. The Port does not have a policy to change relay settings during emergency conditions.

F. DEENERGIZATION

The Port has the authority to preemptively shut off power due to fire-threat conditions; however, this option will only be used in extraordinary circumstances. Due to the minimal risk of the Port's electrical supply facilities causing a power-line ignited wildfire, the Port is not adopting specific protocols for de-energizing any portions of its electric distribution system. The Port will reevaluate this determination in future updates to this Utility Wildfire Mitigation Plan.

VI. RESTORATION OF SERVICE

See Reclosing Policy Above.

VII. EVALUATION OF THE PLAN

A. METRICS AND ASSUMPTIONS FOR MEASURING PLAN PERFORMANCE

The Port is a low-risk utility with minimal above-ground assets. The Port will track two metrics to measure and evaluate the performance of this Utility Wildfire Mitigation Plan: (1) performance metrics; and (2) outcome metrics. The Port has made these changes to its metrics tracking efforts in order to better reflect its system and assets and to better monitor its efforts over time. These metrics will provide an evaluation of mitigation strategies and help determine effectiveness of the Plan and thus identify any areas where improvements may be warranted.

METRIC 1: PERFORMANCE METRICS

This section outlines the more programmatic work that occurs. For the purposes of performance metrics, the Port will perform the following:

- Routine and detailed Inspections of above-ground utility-owned distribution facilities in conformance with utility standards;
- Routine and necessary vegetation management associated with the Port's distribution facilities;

The Port will continue to track metrics relevant to its Wildfire Mitigation Plan, and will to continue to monitor the effectiveness of mitigation measures employed. . The Port will include information related to work performed.

METRIC 2: OUTCOME METRICS

The second metric the Port will track is outcome metrics. For purposes of this metric, the Port will track outage events on its distribution system along with ignitions, which are deemed to occur when (1) a utility owned or controlled facility was associated with the fire; (2) the fire was self-propagating and of a material other than electrical and/or communication facilities; (3) the resulting fire traveled greater than one linear meter from the ignition point; and (4) the utility has knowledge that the fire occurred.

The Port will not normalize this metric by excluding unusual events, such as severe storms. Instead, the Port will supplement this metric with a qualitative description of any such unusual events.

WMP Metrics [No Risk or Minimal Risk POU's and Co-ops]

Performance Metrics

Metric type	Progress metric name	(Actual)	(Actual)	(Forecast)	(Forecast)	(Forecast)	Unit(s)	Comments
		2021	2022	2023	2024	2025		
1. Above-Ground, Utility-Owned Distribution System Components	Routine Inspections	12	12	12			#inspections	
2. Distribution Inspections	Patrol Inspections	4	4	4			# circuit miles	
[Delete for fully undergrounded POU]	Detailed Inspections	2	2	2			# circuit miles	
	Routine Vegetation Management	2	2	2			# circuit miles	
3. Transmission Inspections	Patrol Inspections	2	2	2			# circuit miles	
[Delete for fully undergrounded POU]	Detailed Inspections	0	0	0			# circuit miles	
	Routine Vegetation Management	0	0	0			# circuit miles	

Outcome Metrics

Event Category	Cause category	(Actual)	(Actual)	(Actual)	(Actual)	(To Date)	Unit(s)	Comments
		2019	2020	2021	2022	2023		
Outage Event	Distribution	0	0	0	0	0	# outages	
	Transmission	0	0	0	0	0	# outages	
Ignitions*	Distribution	0	0	0	0	0	# ignitions	
	Transmission	0	0	0	0	0	# ignitions	
[Level 1] Safety Hazards**	Distribution	0	0	0	0	0	# hazards discovered	
[Note: rename based in highest level track]	Transmission	0	0	0	0	0	# hazards discovered	

Notes:

* An "ignition" is deemed to occur if each of the following conditions is met: (1) a utility owned or controlled facility was associated with the fire; (2) the fire was self-propagating and of a material other than electrical and/or communication facilities; (3) the resulting fire traveled greater than one linear meter from the ignition point; and (4) the utility has knowledge that the fire occurred.

** A [Level 1] Safety Hazard is defined as _____.

B. IMPACT OF METRICS ON PLAN

As the Port is adjusting to the employment of a revised set of metrics, limited data may be available. The Port will analyze the data it collects and make revisions to any areas of its program that become evident.

C. MONITORING AND AUDITING THE PLAN

The Utility Wildfire Mitigation Plan will be presented to the Port's governing authority, the Board of Port Commissioners at a properly noticed public hearing. Additionally, the Port will continue to monitor the effectiveness of its plan and will make necessary changes when warranted by changed circumstances with its equipment or territory.

D. IDENTIFYING AND CORRECTING DEFICIENCIES IN THE PLAN

Based on the recommendations of its Board of Commissioners, the Port will correct any identified deficiencies.

E. MONITORING THE EFFECTIVENESS OF INSPECTIONS

The Port has implemented a tiered approach to inspections and verifications for projects, outages and connections. Electrical plans are created by the Port's Electrical Engineer and constructed by the Port's electrical construction contractor. Construction issues are brought to the attention of the Engineer and issues are resolved.

Biannually, the Port protective relay system is tested by a third party testing agency to ensure relays and the distribution system is operating within specifications and safety.

F. CLIMATE CHANGE

The Port recognizes the challenges associated with climate change and the importance of adapting to the evolving risks associated with climate change. The Port has evaluated the impacts of climate change and has found that, as the Port's service territory is not within Tier 2 or Tier 3 of the HFTD, no changes to its Plan were necessary. The Port will continue to monitor the effects of climate change on its service territory and will make adjustments to its Plan where it finds revised mitigation efforts are necessary.

VIII. INDEPENDENT AUDITOR

Public Utilities Code section 8387(c) requires the Port to contract with a qualified independent evaluator with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of this Utility Wildfire Mitigation Plan. The independent evaluator must issue a report that is posted to the Port's website. This report must also be presented to the Port's Board of Commissioners at a public meeting.

The Port's Fire Marshal (also serving as the City of Stockton's Assistant Fire Marshal) will serve as the independent auditor for the Utility Wildfire Mitigation Plan. As the Port's Fire Marshal, this individual has specific knowledge of Port operations and is active in patrolling the Port providing inspections and safety recommendations to tenants. The physical presence of this individual allows for the constant monitoring of the necessary wildfire mitigation measures to ensure continuing compliance.

The Port Fire Marshal has prepared a report evaluating the completeness of this WMP. The report has been submitted for review, consideration, and potential adoption by the Board of Port Commissioners at a noticed public hearing.

In conclusion, the Port Fire Marshal did prepare a report for the Port of Stockton 2023 Utility Wildfire Mitigation Plan. Port staff did review the ongoing outage/tree trimming reports with regard to the two Metrics and found the following:

METRIC 1: FIRE IGNITIONS

The Port recorded no fires starts in 2023 associated with the Port's distribution system.

METRIC 2: WIRES DOWN

The Port recorded no distribution wires down in 2023.

Therefore, the Port will implement this Utility Wildfire Mitigation Plan with no significant changes from previous years.