

LOG BEGINS JULY 8th, 2024.

LOG BEGINS JULY 8th, 2024.

Liberty 2025 WMP Update Discovery Log

Table with columns: Count, Party Name, DR #, Date Request, Question No., Question ID, Question, Responses, Requestor, Date Received, Final Date Due, Date Sent, Links, Number of Attachments, Attachment Links, NDA Required?, WMP Section, Category, Subcategory. Contains detailed data for various questions and responses.

CalAdvocates	2	CalAdvocates-Liberty-2025WMP-02	3	CalAdv-02-2.3	Liberty has provided an update on initiative "WMP-GDOM-GH-01: Covered conductor installation." in Table 1 of the Excel file attachment titled "Liberty_2024_Q2_Table115_80.xlsx". Table 1 states Liberty has completed zero circuit miles of covered conductor installation as of the second quarter 2024 Quarterly Data Report Filing. a) Please explain why Liberty has not completed any circuit miles of covered conductor installation in 2024. b) Please provide a list of all covered conductor projects that were planned for 2024-2025 and that have been delayed due to permitting issues. c) Please provide an Excel document that lists each covered conductor project identified in your response to part (b), which should include the following information in separate columns, at a minimum: 1. Circuit ID number 2. Name of circuit, if applicable 3. Designation of WPD area 4. The expected or actual start date of the covered conductor project 5. The expected completion date of the covered conductor project, when Liberty submitted its 2023-2025 WMP 6. The expected completion date of the covered conductor project, as of now. d) Liberty has experienced permitting delays and construction delays with its planned projects due to limited operating periods imposed by the US Forest Service. Liberty has also experienced material delays in 2024. e) Angora Ridge and Fallen Leaf C covered conductor projects. f) See response for table.	Aaron Louie	8/23/2024	8/28/2024	8/28/2024	Data Request CalAdvocates-Liberty-2025WMP-02_Liberty_Response_08282024.pdf (libertyutilities.com)
CalAdvocates	2	CalAdvocates-Liberty-2025WMP-02	4	CalAdv-02-2.4	Liberty has provided an update on initiative "WMP-GDOM-GH-02: Undergrounding of electric lines and/or equipment." in Table 1 of the Excel file attachment titled "Liberty_2024_Q2_Table115_80.xlsx". Table 1 states Liberty has completed zero circuit miles of undergrounding of electric lines and/or equipment as of the second quarter 2024 Quarterly Data Report Filing. Please explain why Liberty has not completed any circuit miles related to the undergrounding of electric lines and/or equipment in 2024. a) Liberty has replaced 184 expulsion fuses through July 2024. Liberty plans to meet its target of 500 expulsion fuse replacements in 2024. b) Liberty does not have an expulsion fuse replacement quarterly target for Quarter 3 of 2024.	Aaron Louie	8/23/2024	8/28/2024	8/28/2024	Data Request CalAdvocates-Liberty-2025WMP-02_Liberty_Response_08282024.pdf (libertyutilities.com)
CalAdvocates	2	CalAdvocates-Liberty-2025WMP-02	5	CalAdv-02-2.5	Liberty has provided an update on initiative "WMP-GDOM-GH-12b: Expulsion fuse replacement." in Table 1 of the Excel file attachment titled "Liberty_2024_Q2_Table115_80.xlsx". Table 1 states Liberty has completed eight expulsion fuse replacements as of the second quarter 2024 Quarterly Data Report Filing. a) Please provide a brief description of Liberty's plan to replace the remaining 492 expulsion fuses to achieve its targeted goal of 500 expulsion fuse replacements in 2024. b) Does Liberty have an estimated number of expulsion fuse replacements that it will complete by the end of quarter 3? Regarding Liberty's initiative "WMP-GDOM-AI-05: Quality assurance/quality control of inspection," as part of Liberty's presentation during the 2025 Wildfire Mitigation Plan Update Group 2 Workshop, Liberty stated that by the end of 2025 Liberty will achieve a target of 12% of detailed asset inspections, while achieving a 90% pass rate. a) Will Liberty conduct any QA/QC of detailed inspections during 2024? b) If the answer to part (a) above is yes, what percentage of detailed inspections will Liberty target? c) If the answer to part (a) above is yes, does Liberty have a target pass rate for 2024? a) Yes. b) 12%. c) Yes. Refer to Section 6.11 of Liberty's 2025 WMP Update.	Aaron Louie	8/23/2024	8/28/2024	8/28/2024	Data Request CalAdvocates-Liberty-2025WMP-02_Liberty_Response_08282024.pdf (libertyutilities.com)
CalAdvocates	2	CalAdvocates-Liberty-2025WMP-02	6	CalAdv-02-2.6						Data Request CalAdvocates-Liberty-2025WMP-02_Liberty_Response_08282024.pdf (libertyutilities.com)