

January 24, 2025

***VIA ELECTRONIC FILING***

Docket # 2024 NOV

Patrick Doherty  
Program Manager  
Compliance Assurance Division  
Office of Energy Infrastructure Safety  
715 P Street, 20th Floor  
Sacramento, CA 95814

**RE: PacifiCorp's Response to Notice of Violation – CAD\_PC\_CAC17\_20240905\_1356**

Dear Patrick Doherty:

PacifiCorp provides the following response to the finding(s) identified in the “Notice of Violation CAD\_PC\_CAC17\_20240905\_1356” (Notice of Violation or NOV) issued by the Office of Energy Infrastructure Safety (Energy Safety) on December 24, 2024. On September 5, 2024, Energy Safety conducted an inspection of PacifiCorp's WMP initiatives in the vicinity of Seiad Valley, California.

Energy Safety found the following violation:

**Violation 1.** Energy Safety observed that in implementing 2024 WMP initiative 8.1.2.1 - Line Rebuild Program - Covered Conductor Installation, PC failed to provide accurate data in reporting that covered conductor was installed on Pole ID 06246012.0121101, Grid Hardening ID 8236604a, at coordinates 41.8407836260049, -123.191359417292.

**PacifiCorp's Response:**

In response to the NOV, PacifiCorp conducted a field inspection on January 2, 2025. PacifiCorp found that the pole in question was built as designed. One side of the pole has been completed and the other side of the pole will have covered conductor installed as part of a future work order.

The contractor correctly completed the work associated with 8236604a. The calls for covered conductor starting at Pole ID 06246012.012101. The reported miles completed for the period were counted from Pole ID 06246012.012101 and therefore do not require updating.

Office of Energy Infrastructure Safety


January 24, 2025

Page 2

The attached 8236604a.kmz file which was provided with the Q1 2024 QDR incorrectly included the span between Pole ID 06246012.0121101 and 06246012.0121161 that runs across the road to the southwest.

PacifiCorp appreciates the opportunity to provide this response to Energy Safety's CAD\_PC\_CAC17\_20240905\_1356. Please refer any questions to Pooja Kishore, Regulatory Affairs Manager at 503-813-7314 or via email at [pooja.kishore@pacificorp.com](mailto:pooja.kishore@pacificorp.com) and [californiadockets@pacificorp.com](mailto:californiadockets@pacificorp.com).

Sincerely,

A handwritten signature in black ink, appearing to read "Josh Jones", is positioned above the printed name.

Josh Jones

Vice President, Asset Management and Wildfire Strategy

PacifiCorp

1407 West North Temple, Suite 275

Salt Lake City, UT 84116