



Wildfire Mitigation Plan

May 9th, 2025

Table of Contents

I.	Utility Context Summary.....	3
II.	Overview	7
A.	Policy Statement.....	7
B.	Purpose of the Wildfire Mitigation Plan.....	7
C.	Organization of the Wildfire Mitigation Plan.....	7
III.	Objectives of the Wildfire Mitigation Plan	7
IV.	Roles and Responsibilities	8
A.	Utility Governance Structure	8
B.	Wildfire Prevention.....	9
C.	Wildfire Response and Recovery	9
D.	Standardized Emergency Management System	11
V.	Wildfire Risks and Drivers Associated with Design, Construction, Operation, and Maintenance.....	13
A.	Particular Risks and Risk Drivers Associated with Topographic and Climatological Risk Factors	13
B.	Enterprise-wide Safety Risks	13
VI.	Wildfire Preventative Strategies	14
A.	High Fire Threat District	14
B.	Design and Construction Standards	14
C.	Vegetation Management.....	14
D.	Inspections	15
E.	California Public Utility Commission Wildfire Threat Map.....	16
F.	CalFire Fire Threat Map	17
G.	Reclosing Policy	17
H.	De-energization	17
VII.	Restoration of Service.....	17
VIII.	Evaluation of the Plan	18
A.	Metrics and Assumptions for Measuring Plan Performance	18
B.	Impact of Metrics on Plan	20
C.	Monitoring and Auditing the Plan	20
D.	Identifying and Correcting Deficiencies in the Plan	20
E.	Monitoring the Effectiveness of Inspections	20

I. Utility Context Summary

Requirement	Statutory Language	Location in WMP
Persons Responsible	PUC § 8387(b)(2)(A): An accounting of the responsibilities of persons responsible for executing the plan.	Section 4 Page 8
Objectives of the Plan	PUC § 8387(b)(2)(B): The objectives of the wildfire mitigation plan.	Section 3 Page 7
Preventive Strategies	PUC § 8387(b)(2)(C): A description of the preventive strategies and programs to be adopted by the local publicly owned electric utility or electrical cooperative to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.	Section 6 Page 14-17
Evaluation Metrics	PUC § 8387(b)(2)(D): A description of the metrics the local publicly owned electric utility or electrical cooperative plans to use to evaluate the wildfire mitigation plan's performance and the assumptions that underlie the use of those metrics.	Section 8 Page 18-20
Impact of Metrics	PUC § 8387(b)(2)(E): A discussion of how the application of previously identified metrics to previous wildfire mitigation plan performances has informed the wildfire mitigation plan.	Section 8 Page 20
Deenergization Protocols	PUC § 8387(b)(2)(F): Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety, as well as protocols related to mitigating the public safety impacts of those protocols, including impacts on critical first responders and on health and communication infrastructure.	Section 6 Page 17
Customer Notification Procedures	PUC § 8387(b)(2)(G): Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines. The procedures shall consider the need to notify, as a priority, critical first responders, health care facilities, and operators of telecommunications infrastructure.	Section 4, 7 Page 9-11, 17-18
Vegetation Management	PUC § 8387(b)(2)(H): Plans for vegetation management.	Section 6 Page 14-15
Inspections	PUC § 8387(b)(2)(I): Plans for inspections of the local publicly owned electric utility's or electrical cooperative's electrical infrastructure.	Section 6 Page 15

Prioritization of Wildfire Risks	<p>PUC § 8387(b)(2)(J): A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the local publicly owned electric utility's or electrical cooperative's service territory. The list shall include, but not be limited to, both of the following:</p> <p>(i) Risks and risk drivers associated with design, construction, operation, and maintenance of the local publicly owned electric utility's or electrical cooperative's equipment and facilities.</p> <p>(ii) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the local publicly owned electric utility's or electrical cooperative's service territory.</p>	<p>Section 5 Page 13-14</p>
CPUC Fire Threat Map Adjustments	<p>PUC § 8387(b)(2)(K): Identification of any geographic area in the local publicly owned electric utility's or electrical cooperative's service territory that is a higher wildfire threat than is identified in a commission fire threat map, and identification of where the commission should expand a high fire threat district based on new information or changes to the environment.</p>	<p>Section 6 Page 16-17</p>
Enterprisewide Risks	<p>PUC § 8387(b)(2)(L): A methodology for identifying and presenting enterprisewide safety risk and wildfire-related risk.</p>	<p>Section 5 Page 13-14</p>
Restoration of Service	<p>PUC § 8387(b)(2)(M): A statement of how the local publicly owned electric utility or electrical cooperative will restore service after a wildfire.</p>	<p>Section 7 Page 17-18</p>
Monitor and Audit	<p>PUC § 8387(b)(2)(N): A description of the processes and procedures the local publicly owned electric utility or electrical cooperative shall use to do all of the following:</p> <ul style="list-style-type: none"> (i) Monitor and audit the implementation of the wildfire mitigation plan. (ii) Identify any deficiencies in the wildfire mitigation plan or its implementation and correct those deficiencies. <p>Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, that are carried out under the (iii) plan, other applicable statutes, or commission rules.</p>	<p>Section 8 Page 20</p>

Qualified Independent Evaluator	PUC § 8387(c): The local publicly owned electric utility or electrical cooperative shall contract with a qualified independent evaluator with experience in assessing the safe operation of electrical infrastructure to review and assess the comprehensiveness of its wildfire mitigation plan. The independent evaluator shall issue a report that shall be made available on the Internet Web site of the local publicly owned electric utility or electrical cooperative and shall present the report at a public meeting of the local publicly owned electric utility's or electrical cooperative's governing board.	https://moval.gov/mvu/reports.html
--	--	---

Table 1: Context-Setting Information

Utility Name	Moreno Valley Utility	
Service Territory Size	33.48 square miles	
Owned Assets	<input type="checkbox"/> Transmission <input checked="" type="checkbox"/> Distribution <input checked="" type="checkbox"/> Generation	
Number of Customers Served	8,944 customer accounts as of Jan 2025	
Population Within Service Territory	214,982 [estimate]	
Customer Class Makeup	Number of Accounts	Share of Total Load (MWh)
	88.84% Residential; 2.28% Government; 0.03% Agricultural [pumping]; 8.85% Commercial/Industrial	20.52% Residential; 2.39% Government; 0.51% Agricultural [pumping]; 76.69% Commercial/Industrial
Service Territory Location/Topograph ¹	<input type="checkbox"/> % Agriculture <input type="checkbox"/> % Barren/Other <input type="checkbox"/> % Conifer Forest <input type="checkbox"/> % Conifer Woodland <input type="checkbox"/> % Desert <input type="checkbox"/> % Hardwood Forest <input type="checkbox"/> % Hardwood Woodland <input type="checkbox"/> % Herbaceous <input type="checkbox"/> % Shrub 100% Urban <input type="checkbox"/> % Water	

¹ This data shall be based on the California Department of Forestry and Fire Protection, California Multi-Source Vegetation Layer Map, depicting WHR13 Types (Wildlife Habitat Relationship classes grouped into 13 major land cover types) available at: <https://www.arcgis.com/home/item.html?id=b7ec5d68d8114b1fb2bfbf4665989eb3>.

Service Territory Wildland Urban Interface² (based on total area)	100% Wildland Urban Interface; [] % Wildland Urban Intermix
Percent of Service Territory in CPUC High Fire Threat Districts (based on total area)	Includes maps - Yes Tier 2: 30% Tier 3: 10%
Prevailing Wind Directions & Speeds by Season	<input type="checkbox"/> Includes maps MVU is 100% underground and does not collect prevailing wind data.
Miles of Owned Lines Underground and/or Overhead	Overhead Dist.: 0 miles Overhead Trans.: 0 miles Underground Dist.: 156.4 miles Underground Trans.: 0 miles
	Explanatory Note 1 - Methodology for Measuring "Miles": [circuit miles]
	Explanatory Note 2 – Description of Unique Ownership Circumstances: [NA]
	Explanatory Note 3 – Additional Relevant Context: [summarizing primary voltage cable circuit miles]
Percent of Owned Lines in CPUC High Fire Threat Districts	<i>Overhead Distribution Lines as % of Total Distribution System (Inside and Outside Service Territory)</i>
	Tier 2: 0% Tier 3: 0%
	<i>Overhead Transmission Lines as % of Total Transmission System (Inside and Outside Service Territory)</i>
	Tier 2: 0% Tier 3: 0%
	Explanatory Note 4 – Additional Relevant Context: [MVU is an entirely UG system]
Customers have ever lost service due to an IOU PSPS event?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Customers have ever been notified of a potential loss of service to due to a forecasted IOU PSPS event?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Has developed protocols to pre-emptively shut off electricity in response to elevated wildfire risks?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Has previously pre-emptively shut off electricity in response to elevated wildfire risk?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, then provide the following data for calendar year 2020: Number of shut-off events: [] Customer Accounts that lost service for >10 minutes: [] For prior response, average duration before service restored: []

² This data shall be based on the definitions and maps maintained by the United States Department of Agriculture, as most recently assembled in *The 2010 Wildland-Urban Interface of the Conterminous United States*, available at https://www.fs.fed.us/nrs/pubs/rmap/rmap_nrs8.pdf.

II. Overview

A. Policy Statement

Moreno Valley Utility's overarching goal is to provide safe, reliable, and economic electric service to its local community. In order to meet this goal, Moreno Valley Utility constructs, maintains, and operates its electrical lines and equipment in a manner that minimizes the risk of catastrophic wildfire posed by its electrical lines and equipment.

B. Purpose of the Wildfire Mitigation Plan

Moreno Valley Utility's (MVU) entire electric supply system is located underground in conduit and vaults. Historically, undergrounded electric lines have not been associated with catastrophic wildfires. The undergrounding of electric lines serves as an effective mitigation measure to reduce the potential of power-line ignited wildfires. Based on a review of local conditions and historical fires, MVU has determined that its electrical lines and equipment do not pose a significant risk of catastrophic wildfire.

Despite this low risk, MVU takes appropriate actions to help its region prevent and respond to the increasing risk of devastating wildfires. In its role as a public agency, MVU closely coordinates with other local safety and emergency officials to help protect against fires and respond to emergencies. In its role as a utility, MVU follows all applicable design, construction, operation, and maintenance requirements that reduce safety risks associated with its system. This Wildfire Mitigation Plan describes the safety-related measures that MVU follows to reduce its risk of causing wildfires.

C. Organization of the Wildfire Mitigation Plan

This Wildfire Mitigation Plan included the following elements:

- Objectives of the plan;
- Roles and responsibilities for carrying out the plan;
- Identification of key wildfire risks and risk drivers;
- Description of wildfire prevention, mitigation, and response strategies and programs;
- Metrics for evaluating the performance of the plan and identifying areas for improvement;
- Review and validation of the plan; and
- Timelines.

III. Objectives of the Wildfire Mitigation Plan


The primary goal of this Wildfire Mitigation Plan is to describe MVU's existing programs, practices, and measures that effectively reduce the probability that MVU's electric supply system could be the origin or contributing source for the ignition of a wildfire. To support this goal, MVU regularly evaluates the prudent and cost-effective improvements to its physical assets, operations, and training that can help reduce the risk of equipment-related fires.

The secondary goal of this Wildfire Mitigation Plan is to improve the resiliency of the electric grid. As part of the development of this plan, MVU assesses new industry practices and technologies that will reduce the likelihood of an interruption (frequency) in service and improve the restoration (duration) of service.

IV. Roles and Responsibilities

A. Utility Governance Structure

City of Moreno Valley Organization Chart



The City of Moreno Valley is a general law city that operates under a Council-Manager form of government. MVU is governed by a five-member City Council. Four Council Members are elected by district to staggered, four-year terms, while the Mayor is directly elected. The council appoints the City Manager, who oversees the daily operations of the City. Volunteer Commissions and Boards, as well as several Citizen Advisory Committees help guide the Council in its decisions. The City Council formed a five-member Utilities Commission, whose purpose is to provide additional review for all matters pertaining to MVU. Commissioners are citizen volunteers, appointed by the City Council for three-year terms.

MVU's Wildfire Mitigation Plan is developed by staff and then reviewed by the Division Manager, Public Works Director, Assistant City Manager, City Manager, Utilities Commission, and the five-member City Council. City Council votes on approval and the plan is approved with a majority vote.

MVU funds wildfire mitigation activities through current rate payer revenues. These funds are augmented by grant awards. Mitigation projects typically take the form of revised equipment design standards and system hardening Capital Improvement Projects.

This document is intended to include, as appropriate, responses to the recommendations in the WSAB's Guidance Advisory Opinion for the 2024 Wildfire Mitigation Plans of Electric Publicly Owned Utilities and Rural Electric Cooperatives. This document also represents the combined effort of the POU industry associations to further the

development of a template to respond to the WSAB's Guidance Advisory Opinion in future WMP reporting cycles. MVU has posted the most recent Independent Evaluation (IE) at: <https://moval.gov/mvu/reports.html>.

B. Wildfire Prevention

MVU staff, in partnership with its maintenance and operations provider, is responsible for electric facility design, maintenance, and inspection, including vegetation management. Although MVU's electrical distribution system is 100% underground, MVU follows best practices to prevent ignition of wildfires from its equipment. These items include:

- MVU performs routine maintenance of all distribution facilities.
- MVU adheres to a seasonal weed abatement and vegetation management schedule to maintain at-risk sites.
- MVU contracts for seasonal weed abatement services. Standard clearances as defined by General Orders 95, 128, 165, and 174, are maintained as part of routine maintenance cycles. All electric distribution facility equipment requiring repair and maintenance are addressed and corrected as they are identified. Annual inspections and maintenances of MVU substation facilities identified no deficiencies for 2024.
- MVU abides by Municipal Code 6.40 to abate trees, shrubs, weeds, and grass at all MVU facilities. Including Landscaping, vegetation, or improved or unimproved property in any of the following conditions: containing weeds, dry grasses, dead trees, dead shrubs, or any other material which bears seeds of a wingy or downy nature or which by reason of their size, manner of growth or location, constitute a fire hazard or a threat to public health, or containing weeds, vegetation, grasses, trees or shrubs, including, but not limited to sagebrush, chaparral, and Russian Thistle (tumbleweed) which, when dry, will in reasonable probability constitute a fire hazard or be blown onto adjoining property by prevailing winds; trees and shrubs containing dead or fallen limbs or branches that may present a safety hazard; trees or shrubs which are overgrown or contain limbs or branches that restrict, impede or obstruct the use of or obscure the visibility of pedestrians or drivers using the public rights-of-way, easements, sidewalks or roadways; overgrown vegetation likely to harbor vermin, insects or rodents of any kind.
- Electric system operates in a manner that will minimize potential wildfire risks.
- Take all reasonable and practicable actions to minimize the risk of a catastrophic wildfire caused by MVU electric facilities.
- Coordinate with federal, state, and local fire management personnel as necessary or appropriate to implement MVU's Wildfire Mitigation Plan.
- Immediately report fires to local fire department, Emergency Management Program Manager, MVU administration, and other City Officials, pursuant to existing MVU practices and the requirements of this Wildfire Mitigation Plan.
- Coordinate with City Emergency Operations Center to disseminate safety warnings, emergency public information, and evacuation notices to local residents.
- MVU adheres to City of Moreno Valley personnel policy 5.11 for Employee Disaster Notification and Reporting.
- Take corrective action when the staff witnesses or is notified that fire protection measures have not been properly installed and maintained.
- Comply with relevant federal, state, and industry standard requirements, including the industry standards established by the California Public Utilities Commission.

C. Wildfire Response and Recovery

Internally, MVU's distribution system is controllable remotely through a Supervisory Control and Data Acquisition (SCADA) system networked to all substations and circuits. MVU field staff utilize hard line telephones, cellular telephones, and portable radios to communicate with internal and external stakeholders during an outage or

emergency. MVU's Outage Management System, Utility Maintenance Management System, and Dispatching System all auto-generate notifications to field, office, and administrative staff. MVU is enrolled in several mutual aid networks (APPA, CA Disaster & Civil Defense, CA Utilities Emergency Association) to facilitate expedited response and recovery from severe storms, natural disasters, or mass outages.

The City of Moreno Valley maintains a two-way (LF, HF, VHF, and UHF) mobile and base stations for communications enhanced by repeater system to extend the coverage area. This includes three repeater channels and three unit-to-unit/talk-around channels in the 800 MHz Public Safety band. The City of Moreno Valley owns ten iridium satellite phones that are issued to key personnel in the city during an emergency. Mobile radio communications are available utilizing the Moreno Valley Police Mobile Command Center (MCC). The command center has the capability of patching Sheriff, California Highway Patrol (CHP), Riverside Police, CALFIRE, March Air Reserve Base and Moreno Valley Park Rangers all on the same frequency at the same time. Moreno Valley has an Amateur Civil Emergency Services/Radio Amateur Civil Emergency Services (MV ACES/RACES) group, which operates on ham radio frequencies in support of governmental emergency communications. MV ACES/RACES can augment existing systems and establish communication links with otherwise inaccessible areas. They are also capable of sending live video and audio from an incident site to our City's emergency operations center via the ham radio.

At the county level, a Riverside County Emergency Operations Center (EOC) talk group is programmed into the Omniquest radio and is used to communicate with EOCs within Riverside County during a disaster or emergency. The City of Moreno Valley also has low-band disaster net radios to communicate with all EOCs within Riverside County during a disaster or emergency. This system uses low frequency bands and has several back up channels in case of an outage. Additionally, the City has a portable disaster case radio system. This system allows communications with other agencies such as County Emergency Services, County Fire, County Police, Hospitals, Cities within Riverside County, Moreno Valley Unified School District and Valley View Unified School District.

MVU adheres to California Public Utility Commission GO 95, 128, 165, and 174 for all system infrastructure inspection, maintenance, and reporting.

City of Moreno Valley Office of Emergency Management maintains a city-wide Hazard Mitigation Plan identifying potential fire hazards and mitigation strategies.

City of Moreno Valley also maintains a reporting hotline for all employees to properly notify the city for code violations, hazards, safety concerns, and overgrown landscaping and weeds.

MVU is impacted by Southern California Edison (SCE) Public Safety Power Shutoff (PSPS) events. MVU is an active partner in minimizing the impacts of SCE-initiated PSPS events. Additionally, MVU utilizes circuit-level PSPS details from SCE to notify potentially impacted MVU customers. MVU receives potential PSPS event communications from SCE beginning one week prior to the forecasted event. SCE-initiated PSPS events affect MVU at the sub-transmission level. MVU receives advanced notification from SCE when impacted circuits are being monitored against weather projections for a potential PSPS event. SCE provides the names of circuits being monitored as well as the impacted City accounts, along with the projected period of concern for the PSPS event. As the situation develops, MVU receives updated data from SCE on weather, circuits and accounts being monitored, and if a PSPS is triggered. MVU monitors the SCE status reports and stages mitigation assets appropriately in advance of a SCE triggered PSPS event. If the PSPS event affects any MVU facilities, MVU customers are notified as early as possible of pending power shutoffs.

When a SCE PSPS event is triggered that impacts MVU facilities, MVU notifies its customers of potential service interruption in a variety of ways. Alert notices are pushed out to customers via the MyMVU mobile application, email blasts, direct telephone communication with critical customers, as well as public messaging available on the MVU web site and through MVU's 24/7 call center. PSPS and outage notices are translated into Spanish for non-English speakers.

With all of MVU's distribution lines undergrounded, the utility does not de-energize its system during severe weather events. As MVU expands its distribution system, redundant circuitry is installed to sectionalize and isolate PSPS outages and reduce the number of affected customers. In the event MVU is impacted by an SCE PSPS, MVU does have backup generation assets to keep critical infrastructure operational, including a portable back-up generator that can be distributed to impacted MVU customers.

D. Standardized Emergency Management System

As a local governmental agency,¹ MVU has planning, communication, and coordination obligations pursuant to the California Office of Emergency Services' Standardized Emergency Management System ("SEMS") Regulations,² adopted in accordance with Government Code section 8607. The SEMS Regulations specify roles, responsibilities, and structures of communications at five different levels: field response, local government, operational area, regional, and state.³ Pursuant to this structure, MVU annually coordinates and communicates with the relevant safety agencies as well as other relevant local and state agencies. When activated, MVU serves as the Utilities Unit Leader under the Operations Section Chief as part of the City of Moreno Valley's Emergency Operations Center. In the event that the incident centered on MVU facilities, MVU would serve as the Operations Section Chief.

Under the SEMS structure, a significant amount of preparation is done through advanced planning at the county level, including the coordination of effort of public, private, and nonprofit organizations. Riverside County serves as the Operational Area and is guided by the California Office of Emergency Services, Southern Region. The Operational Area includes local and regional organizations that bring relevant expertise to the wildfire prevention and recovery planning process. These participants include:

¹ As defined in Cal. Gov. Code § 8680.2.

² 19 CCR § 2407.

³ Cal. Gov. Code § 2403(b):

- 1) "Field response level" commands emergency response personnel and resources to carry out tactical decisions and activities in direct response to an incident or threat.
- 2) "Local government level" manages and coordinates the overall emergency response and recovery activities within their jurisdiction.
- 3) "Operational area level" manages and/or coordinates information, resources, and priorities among local governments within the operational area and serves as the coordination and communication link between the local government level and the regional level.
- 4) "Regional level" manages and coordinates information and resources among operational areas within the mutual aid region designated pursuant to Government Code §8600 and between the operational areas and the state level. This level along with the state level coordinates overall state agency support for emergency response activities.
- 5) "State level" manages state resources in response to the emergency needs of the other levels, manages and coordinates mutual aid among the mutual aid regions and between the regional level and state level, and serves as the coordination and communication link with the federal disaster response system.

Agency/ Dept.	Mailing Address	Contact	Phone	Fax
AMR American Medical Response	879 Marlborough Ave. Riverside, CA. 92507		951.782.5234	951.782.5617
AMR American Medical Response	879 Marlborough Ave. Riverside, CA. 92507	Dispatch	877.267.6622	951.782.5605
Kaiser Permanente: Medical Center	12815 Heacock Moreno Valley, CA. 92552	Administration	951.601.6327	951.601.6181
Kaiser Foundation Moreno Valley: Community Hospital	27300 Iris Ave. Moreno Valley, CA. 92555	Facilities Services Manager	951.251.6594	951.251.6601
Moreno Valley Fire/Office of Emergency Management	14177 Frederic St. Moreno Valley, CA 92553	Emergency Management Program Manager	951.413.3800	951-413-3801
Moreno Valley: Special Districts	14331 Frederick Street Moreno Valley, CA 92253	Division Manager	951.413.3480	
Moreno Valley: Fire Dept.	14177 Frederick Street Moreno Valley, CA. 92553	Fire Marshal	951.413.3370	
Moreno Valley: Fire Dept.	22850 Calle San Juan De Los Lagos Moreno Valley, CA 92553	Fire Chief	951.486.6780	951.486.6790
Moreno Valley: Operations & Maintenance	14177 Frederick Street Moreno Valley, CA. 92553	Manager	951.413.3160	951.413.3141
Moreno Valley: Police Dept.	22850 San Juan De Los Lagos Moreno Valley, CA. 92552	Police Chief	951.486.6700	
Moreno Valley: Public Works	14177 Frederick Street Moreno Valley, CA. 92553	Public Works Director	951.413.3100	951.413.3141
Moreno Valley Traffic & Transportation	14177 Frederick Street Moreno Valley, CA. 92553	City Traffic Engineer	951.413.3140	951.413.3140
Moreno Valley: City Management	14177 Frederick Street Moreno Valley, CA. 92553	City Manager	951.413.3020	
Moreno Valley: Facilities Management	14177 Frederick Street Moreno Valley, CA. 92553	Division Manager	951.413.3740	
Moreno Valley: TV3	14177 Frederick Street Moreno Valley, CA. 92553	Media & Production Supervisor	951.413.3056	951.413.3053
Moreno Valley: Unified School District	25634 Alessandro Blvd. Moreno Valley, CA. 92553	Maintenance Supervisor	951.571.7865	951.571.7811
Riverside Medical Clinic: Canyon Springs Plaza	6405 Day Street Moreno Valley, CA. 92552	Facilities	951.321.6331	951.248.6703
Riverside County: Dept. of Environmental Health	4065 County Circle Riverside, CA.	Deputy Director	951.358.5172	951.358.5017
Riverside County: Dept. of Environmental Health	4065 County Circle Riverside, CA.	Supervising Environmental Health Specialist	951.358.5172	951.358.5017
Riverside County: Dept. of Environmental Health	800 S. Sanderson Ave. #200 Hemet, CA. 92545	Supervising Environmental Health Specialist	951.766.2824	
Riverside County: Dept. of Environmental Health	800 S. Sanderson Ave. #200 Hemet, CA. 92545	Supervising Environmental Health Specialist	951.766.2824	
Riverside Regional: Medical Center	26520 Cactus Ave. Moreno Valley, CA. 92552	Deputy Director	951.955.4878	951.955.8405
Riverside Regional: Medical Center	26520 Cactus Ave. Moreno Valley, CA. 92555	Chief of Hospital Plant Op.	951.486.4066	951.486.4105
Val Verde: Unified School District	975 W. Morgan Street Perris, CA. 92581	Emergency Services	951.940.6100 ext. 10672	951.940.6118
Val Verde: Unified School District - March Middle School	15800 Indian Ave	Director of Facilities, Maintenance, & Purchasing	951.940.6136 ext. 10652	
Verizon Public Relations		Director of Public Relations	(213) 800-3184	
Eastern Municipal Water District	Central Control 2270 Trumble Road Perris, CA 92572-8300		951.928.3777 ext. 6265	951.928.6170
Davita Canyon Springs Dialysis	22555 Alessandro Blvd Bldg. 5		951.653.6400	
Kaiser Permanente	27200 Iris Ave Medical Bldg.		951.353.4359	
United States Postal Services	23800 Cactus Ave	Facility Manager	951.697.4661	
Waste Management	17700 Indian St	Fleet Manager - Fleet Maintenance	951.601.1129 951.339.6681	

Pursuant to the SEMS structure, MVU participates in annual training exercises. Training exercises include workshops, tabletop exercises, and field drills. A sample of topics covered include earthquake safety, disaster response & management, active shooter, crisis leadership, and NIMS/SEMS/ICS compliance.

MVU is a member of the California Utility Emergency Association, which plays a key role in ensuring communications between utilities during emergencies and provides mutual aid. MVU also participates in the American Public Power Association Mutual Assistance Agreement, which covers public utilities across the United States. The City of Moreno Valley is a participant in the California Disaster and Civil Defense Mutual Aid Agreement which allocates state resources to cope with any type of disaster.

V. Wildfire Risks and Drivers Associated with Design, Construction, Operation, and Maintenance

A. Particular Risks and Risk Drivers Associated with Topographic and Climatological Risk Factors

Due to MVU's distribution system being 100% underground, there is limited risk specific to wildfires. As an undergrounded utility, MVU does not monitor prevailing wind speed or direction. Weather intelligence monitoring assets have not been installed on the MVU distribution system due to the associated costs and limited benefit the utility would gain from collecting such data. As a 100% underground utility, MVU does not collect wind/weather data. MVU shares service territory with SCE who maintains a robust meteorology division. Relevant weather data should be sourced from SCE.

B. Enterprise-wide Safety Risks

The safety risks discussed below apply to the City of Moreno Valley as a municipal jurisdiction and include both Moreno Valley Utility and Southern California Edison service territories.

Earthquake profile - There are three major faults/fault zones that directly affect Moreno Valley. They are the southern section of the San Andreas Fault, the San Jacinto Fault Zone, and the Elsinore Fault Zone. The San Jacinto Fault Zone is the most active fault in Southern California. It is the closest fault to Moreno Valley and runs through the eastern portion of the city, followed by the Elsinore Fault Zone which is located approximately 12-18 miles south of Moreno Valley. The San Andreas Fault Zone is located approximately 15-20 miles north of Moreno Valley. The largest earthquake to occur within 100 miles of Moreno Valley was the 7.4 magnitude Hector Mine earthquake in 1999.

The City of Moreno Valley could be affected by large earthquakes occurring in many parts of the Southern California region. However, the degree to which the earthquakes are felt, and the damages associated with them may vary. At risk from earthquake damage are critical facilities, buildings, bridges, highways and roads; hazardous materials facilities; sewer, water, and natural gas pipelines; earth dams; petroleum pipelines; and private property located in the city. The relative or secondary earthquake hazards, which are liquefaction, ground shaking, amplification, and earthquake-induced landslides, can be just as devastating as the earthquake. The USGS estimates that there is a greater than 99% chance of a major earthquake occurring within 31 miles of Moreno Valley within the next 50 years.

Flooding profile - There are four types flooding conditions that exist within the Moreno Valley area: flooding in defined watercourses; ponding; sheet flow; and dam inundation. Flooding within defined watercourses occurs within drainage channels and immediately adjacent floodplains. Ponding occurs when water flow is obstructed due to manmade obstacles such as the embankments of SR-60 and other roadways, where they cross-defined watercourses. Sheet flow occurs when capacities of defined watercourses are exceeded, and water flows over broad areas.

Known flood-prone areas as noted in the General Plan as well as recorded in city maintenance files, include:

- Along the Quincy Channel between Cottonwood Avenue and Cactus Avenue.
- An extensive floodplain that extends along the Oliver Street alignment from a point north of Alessandro Boulevard to John F. Kennedy Drive and extending in a southwesterly direction as far as the northeast

corner of Morrison Street and Filaree Avenue and the northeast corner of Nason Street and Iris Avenue.

- Along Heacock Street and Lateral A of the Perris Valley Channel between Cactus Avenue and a point north of the intersection of Lateral A and Indian Street (next to March Air Reserve Base).
- Along Sunnymead Boulevard between Frederick Street and Graham Street.
- Along Pigeon Pass Road, between Sunnymead Ranch Parkway and Lawless Road.
- Along Moreno Beach Boulevard, between Juniper Avenue and Locust Avenue.
- Along Highland Avenue, between Redlands Boulevard and Alessandro Boulevard.
- Along Locust Avenue, between Moreno Beach Boulevard and northerly city limits.
- Along Heacock Street, between Lake Summit Drive and Reche Vista Drive.
- Along Hubbard Street, between Skyland Drive and Ironwood Avenue.
- Along Cottonwood Avenue, between Nason St and Martha Crawford Street.
- Alessandro Boulevard, between Gilman Springs Road and Theodore Street.
- Neighborhood bounded by Alessandro Boulevard, Brodiaea Avenue, Redlands Boulevard, and Merwin Street.
- Miramontes Court, north of Via Solana Court.
- Easterly side of neighborhood east of Perris Boulevard, between Covey Road and Manzanita Avenue.

VI. Wildfire Preventative Strategies

A. High Fire Threat District

MVU directly participated in the development of the CPUC's Fire-Threat Map,⁴ which designates a High-Fire Threat District. In the map development process, MVU coordinated with Southern California Edison Company (SCE) and determined that because MVU's system is entirely undergrounded, that SCE would serve as territory lead for the region served by MVU. MVU has incorporated the High Fire Threat District into its construction, inspection, maintenance, repair, and clearance practices, where applicable.

B. Design and Construction Standards

MVU's electric facilities are designed and constructed to meet or exceed the relevant federal, state, or industry standard. MVU treats CPUC General Orders (GO) 95 and 128 as a key industry standard for design and construction standards for underground electrical facilities. MVU meets or exceeds all standards in GO 95 and 128. Additionally, MVU monitors and follows, as appropriate, the National Electric Safety Code. MVU will continue to underground all system distribution facilities, as well as employ grid-hardening measures where appropriate.

C. Vegetation Management

MVU meets or exceeds the minimum industry standard vegetation management practices. For transmission-level facilities, MVU complies with NERC FAC-003-4, where applicable. For both transmission and distribution level facilities, MVU meets: (1) Public Resources Code section 4292; (2) Public Resources Code section 4293; (3) CPUC GO 95, 128, 165, and 174.

MVU staff, in partnership with its maintenance and operations provider, is responsible for electric facility design, maintenance, and inspection, including vegetation management. Although MVU's electrical distribution system is 100% underground, MVU follows best practices to prevent ignition of wildfires from its equipment. These items include:

- MVU performs routine maintenance of all distribution facilities.
- MVU adheres to a seasonal weed abatement and vegetation management schedule to maintain at-risk sites.
- MVU contracts for seasonal weed abatement services. Standard clearances as defined by General Orders 95, 128, 165, and 174, are maintained as part of routine maintenance cycles. All electric distribution facility equipment requiring repair and maintenance are addressed and corrected as they are identified. Annual inspections and maintenances of MVU substation facilities identified no deficiencies for 2024.

- MVU abides by Municipal Code 6.40 to abate trees, shrubs, weeds, and grass at all MVU facilities. Including Landscaping, vegetation, or improved or unimproved property in any of the following conditions: containing weeds, dry grasses, dead trees, dead shrubs, or any other material which bears seeds of a wingy or downy nature or which by reason of their size, manner of growth or location, constitute a fire hazard or a threat to public health, or containing weeds, vegetation, grasses, trees or shrubs, including, but not limited to sagebrush, chaparral, and Russian Thistle (tumbleweed) which, when dry, will in reasonable probability constitute a fire hazard or be blown onto adjoining property by prevailing winds; trees and shrubs containing dead or fallen limbs or branches that may present a safety hazard; trees or shrubs which are overgrown or contain limbs or branches that restrict, impede or obstruct the use of or obscure the visibility of pedestrians or drivers using the public rights-of-way, easements, sidewalks or roadways; overgrown vegetation likely to harbor vermin, insects or rodents of any kind.

D. Inspections



MVU meets or exceeds the minimum inspection requirements provided in CPUC GO 165 and 174. Pursuant to these rules, utilities inspect electric facilities in the High Fire Threat District more frequently than the other areas of its service territory. As described above, MVU currently does not have any overhead power lines located within or near the High-Fire Threat District within the CPUC's Fire Threat Map. However, MVU staff uses their knowledge of the specific environmental and geographical conditions of MVU's service territory to determine if any particular areas require more frequent inspections.

If MVU staff discovers a facility in need of repair that is owned by an entity other than MVU, MVU will issue a notice to repair to the facility owner and work to ensure that necessary repairs are completed promptly.


MVU has conducted an analysis of all circuits to identify essential facilities and prioritize the deployment of back-up power facilities. Grant funding is also being sought to install back-up generation at additional strategic facilities throughout the service territory. MVU is fully capable of sectionalizing any outage to mitigate the number of customers impacted. This mitigation technique will also be employed during PSPS events to reduce any service interruptions to MVU customers.

⁴ Adopted by CPUC Decision 17-12-024.

E. California Public Utility Commission Wildfire Threat Map



F. CalFire Fire Threat Map



MVU service territory includes geographic areas of elevated wildfire risk. MVU operates facilities and serves customers in these elevated risk areas. All distribution facilities are underground and pose no additional wildfire risk. Moreover, all above ground facilities are serviced quarterly for vegetation management and weed abatement. This Wildfire Mitigation Plan will be updated as development encroaches further into elevated wildfire risk areas.

G. Reclosing Policy

MVU's system is 100% underground. Reclosers are not installed on underground circuits. MVU does not change substation relay settings.

H. De-energization

MVU has the authority to preemptively shut off power due to fire-threat conditions, however, this option will only be used in extraordinary circumstances. Due to the minimal risk of MVU's electrical supply facilities causing a power-line ignited wildfire, MVU is not adopting specific protocols for de-energizing any portions of its electric distribution system. MVU will re-evaluate this determination in future updates to this Wildfire Mitigation Plan.

VII. Restoration of Service

MVU's electric distribution system is completely underground. However, MVU is interconnected with SCE's transmission and distribution systems, much of which is overhead and exposed to wind, rain, and lightning. This is MVU's primary source of vulnerability to potential electrical service interruptions during rain and windstorms such as the ones that can be precipitated by El Nino.

MVU's underground electric distribution system is designed, and has been constructed, with redundant sources of feed.

These do not guarantee the elimination of outages but can facilitate service restoration and reduce the duration of such outages.

Preparation in advance of predicted storms: Since, as discussed in the introduction, the primary trouble source during storms is outages on SCE's transmission and distribution lines, many of which are overhead, MVU will patrol, to the extent practical, SCE's primary interconnect lines for any potential trouble spots including but not limited to broken tree limbs or other vulnerabilities. MVU will also double check the loading conditions of our underground lines to satisfy ourselves that alternate sources have the capacity to serve the electric load (customers) in the event that it is necessary.

MVU's underground system will be patrolled in advance of storms for any open trenches or excavations at construction sites to minimize water intrusion into the underground system. Although the underground system is designed to operate under such conditions, small pinholes in splices or cable can cause problems, including possible electrical shorts/faults, that can interrupt service to customers. Likewise, after the storm, each underground vault, manhole or other structure will be inspected for water intrusion and pumped, when necessary, in accordance proper utility practice and environmental guidelines.

All vehicular equipment, man-lifts, tools, and appurtenances will be thoroughly inspected for proper operation. All operating personnel will be placed on standby in the event of weather-related problems.

The MVU Operations and Call Center will be appropriately staffed for handling of trouble calls from customers and dispatching to field personnel.

Call Center support includes:

- Outage Management System (OMS)
- Field Dispatching
- Customer Callbacks

Response Prioritization:

- First Priority: Response to imminent threats to life and/or public property
- Second Priority: Removals of immediate hazards (fallen trees, power poles, etc.)
- Third Priority: Clearing of arterial roadway
- Fourth Priority: Maintenance of traffic control/closures to prevent potential accidents
- Fifth Priority (Post Storm Activity): Follow-up work such as addressing storm-related potholes and residual clean-up of all streets that have remained in a "passable and drivable" state

Referral Protocol:

- Flooding of structures on private property- Residents will be advised to call 911 for Fire Department assistance
- Facilities associated with other government agencies (RCFCD) or private utilities will be referred to appropriate agencies/company
- All storm related issues involving streets, curbs and gutters, sidewalks, residential trees in the right of way, catch basins, and miscellaneous drainage facilities will be referred to the City's Maintenance and Operations Division.

During EOC activation period, all routine maintenance programs and requests will be suspended and deferred.

VIII. Evaluation of the Plan

A. Metrics and Assumptions for Measuring Plan Performance

MVU will track the following metric to measure the performance of this Wildfire Mitigation Plan: (1) number of fire ignitions caused by utility equipment.

Metric 1: Fire Ignitions

For purposes of this metric, a fire ignition is defined as follows:

- MVU facility was associated with the fire;
- The fire was self-propagating and of a material other than electrical and/or communication facilities;
- The resulting fire traveled greater than one linear meter from the ignition point; and
- MVU has knowledge that the fire occurred.

In future Wildfire Mitigation Plans, MVU will provide the number of fires that occurred that were less than 10 acres in size. Any fires greater than 10 acres will be individually described.

Reporting Year	Fire Ignitions
2024	0
2023	0
2022	0
2021	0
2020	0

WMP Additional Metrics

Performance Metrics

Metric type	Progress metric name	(Actual) 2023	(Actual) 2024	(Forecast) 2025	(Forecast) 2026	(Forecast) 2027	Unit(s)	Comments
1. Above-Ground, Utility-Owned Distribution System	Routine Inspections	410	114	100	431	120	#inspections	
2. Distribution Inspections	Patrol Inspections	750	954	1036	1088	1142	#inspections	
	Routine Vegetation Management	5	3	4	4	4	#activities	all above ground facilities
3. Transmission Inspections	Patrol Inspections	NA	NA	NA	NA	NA	# circuit miles	distribution only
	Routine Vegetation Management	NA	NA	NA	NA	NA	# circuit miles	distribution only

Outcome Metrics

Event Category	Cause category	(Actual) 2021	(Actual) 2022	(Actual) 2023	(Actual) 2024	(To Date) 2025	Unit(s)	Comments
Outage Event	Distribution	31	32	23	26	5	# outages	
	Transmission	NA	NA	NA	NA	NA	# outages	distribution
Ignitions*	Distribution	0	0	0	0	0	0 # ignitions	
	Transmission	NA	NA	NA	NA	NA	# ignitions	distribution
Safety Hazards**	Distribution	0	0	0	0	0	# hazards discovered	
	Transmission	NA	NA	NA	NA	NA	# hazards discovered	distribution only

Notes:

* An "ignition" is deemed to occur if each of the following conditions is met: (1) a utility owned or controlled facility was associated with the fire; (2) the fire was self-propagating and of a material other than electrical and/or communication facilities; (3) the resulting fire traveled greater than one linear meter from the ignition point; and (4) the utility has knowledge that the fire occurred.

** A Safety Hazard is defined as any item elevating wildfire ignition risk.

B. Impact of Metrics on Plan

In the initial years, MVU anticipates that there will be relatively limited data gathered through the metric. However, as the data collection history becomes more robust, MVU will be able to identify areas of its operations and service territory that are disproportionately impacted. MVU will then evaluate potential improvements to the plan.

C. Monitoring and Auditing the Plan

This Wildfire Mitigation Plan will be presented to the MVU Utilities Commission and the Moreno Valley City Council. MVU will present updates to this plan to the MVU Utilities Commission and the City Council on an annual basis. The California Municipal Utilities Association (CMUA) held a special meeting of its Wildfire Preparedness, Response, and Recovery Working Group in fall 2022, which focused on risk drivers for power-line-caused catastrophic wildfires and innovative mitigation options. CMUA invited a broad range of utility staff, state agency staff (including the WSAB), industry experts, and academics to participate in this discussion. As part of this meeting, the working group discussed unidentified wildfire risk drivers and mitigation measures that could address these risks. Based on the input provided during this meeting, CMUA produced a publicly available, post-meeting report that summarizes the group's conclusions and recommendations. MVU's staff participated in CMUA's meeting and discussed changes that MVU made to its operations in response to the conclusions and recommendations of the working group in the 2023 WMP.

D. Identifying and Correcting Deficiencies in the Plan

Based on the recommendations of the MVU Utilities Commission and the Moreno Valley City Council, MVU will correct any identified deficiencies.

E. Monitoring the Effectiveness of Inspections

MVU reviews and evaluates its reliability indices regularly to monitor inspection and maintenance procedures. SAIDI, SAIFI, CAIDI, and MAIFI statistics show that MVU maintains an electric system that operates well below the State and National averages for outage incidents per the American Public Power Association's eReliability Tracker program. MVU's Utility Maintenance Management System (UMMS) is used to collect all data subject to GO165. The UMMS prepares monthly inspection and maintenance reports for all electric distribution facilities. Maintenance history for each piece of equipment is archived in the UMMS. Additionally, MVU's substation inspection and maintenance program complies with GO 174 guidelines as well as manufacturer specifications, standards, and recommendations. MVU performs monthly inspections of all substation components including recording and analysis of all alarms, fluid levels, meters, and Load Tap Changer settings.

Although MVU does not fall under the jurisdiction of the California Public Utilities Commission (CPUC), MVU has cooperated with the CPUC's Utilities Safety and Reliability Branch and their requests for periodic audits. The audit in October 2008 noted no GO 95 infractions and identified two GO 128 infractions to MVU Pad Mounted Electric structures. Repairs were made to correct the violation the day they were identified by the CPUC. Again, in March of 2013 the CPUC audit identified three vegetation obstructions that were immediately corrected in the field as they were identified. No additional infractions have been identified by the CPUC.