

June 9, 2025

Patrick Doherty, Compliance Program Manager
Compliance Assurance Division
Office of Energy Infrastructure Safety
California Natural Resources Agency
715 P Street 20th Floor
Sacramento, CA 95814

BY ENERGY SAFETY E-FILING

SUBJECT: Southern California Edison Company's Response to Notice of Violation
- NOV_CAD_SCE_CAC12_20250129_1300

Dear Mr. Doherty:

Southern California Edison Company (SCE) appreciates the opportunity to provide this response to the finding identified in the Notice of Violation – NOV_CAD_SCE_CAC12_20250129_1300 received on May 15, 2025 (Notice), based on Energy Safety field inspections conducted in SCE's service area on January 29, 2025. SCE appreciates the Office of Energy Infrastructure Safety's (Energy Safety) efforts to identify, communicate and work together to resolve potential wildfire risks. The enclosed response describes corrective actions taken or planned by SCE to remedy the finding identified in the above notice and to prevent recurrence.

If you have any questions, or require additional information, please contact Liz Leano at 626-302-3662 or Elizabeth.Leano@sce.com.

Sincerely,

//s//

Shinjini C Menon
Senior Vice President of System Planning & Engineering
Southern California Edison

SCE Response

While SCE is not requesting a written hearing for the finding addressed in this response, SCE reserves the right to identify these facts and further explain its position in subsequent procedural stages and/or proceedings.¹ Although Energy Safety has the right to refer certain issues to the CPUC for an enforcement action, the finding in this Notice does not support such referral.²

Finding: Completeness

Notice	Violation	Structures
NOV_CAD_SCE_CAC12_20250129_1300	1	1699190E

Summary of Findings:

Energy Safety's Notice states that in implementing 2024 WMP initiative 8.1.3.1 - Distribution Detailed Inspections and Remediations (IN-1.1), SCE failed to complete remediation of exposed conductor on Pole ID 1699190E, Grid Hardening ID 413812742-1699190E, at coordinates 35.119395, -118.533614.

Energy Safety considers this completeness violation to be in the Minor risk "risk category."³

Response: SCE confirms that the exposed conductor on structure 1699190E was remediated on September 9, 2024. During an inspection on June 3, 2025, SCE's Field Operations team found that the wildlife cover had shifted, likely due to environmental exposure or other external factors, leading to a recurrence of the condition. As of June 4, 2025, the wildlife cover was secured once again, and the exposed conductor is no longer present. Attached is photographic documentation confirming the most recent remediation.

¹ Government Code Section 15475.4 anticipates a "hearing" process, which traditionally implies an in-person hearing affording parties the right to present evidence and examine witnesses.

² In the Notice, Energy Safety states that pursuant to Public Utilities Code section 8389(g), following receipt of SCE's response to this Notice and resolution of any disputes, this matter may be referred to the California Public Utilities Commission (CPUC) for its consideration of a potential enforcement action, as the CPUC deems appropriate. Notice, p. 2. The Notice discussed herein does not meet the requirement for Energy Safety referral for enforcement action to the CPUC based on the statutory requirements that Energy Safety referral be based on substantial compliance with WMPs. Energy Safety cites Public Utilities Code Section 8389(g) in support of a potential enforcement action. However, Section 8389(g) only provides for a possible enforcement action where "an electrical corporation is not in compliance with its approved wildfire mitigation plan." Public Utilities Code Section 8386.1 further specifies that penalties shall be assessed for failure to substantially comply with a WMP.

³ Notice, p. 1.

Jun 05, 2025 07:36 AM

Network: Jun 4, 2025 at 11:18:03 AM PDT

Local: Jun 4, 2025 at 11:18:03 AM PDT

N 35° 7' 9.831", W 118° 32' 0.905"

22717-22723 CA-202

Tehachapi CA 93561

United States

Remark: 1699190E

35.119395,-118.533614 1699190e