



June 10, 2025

Lena McMillin  
Team Lead, Wildfire Mitigation Program Compliance  
San Diego Gas & Electric Company (SDG&E)  
8316 Century Park Court, CP32F  
San Diego, CA 92123

## NOTICE OF VIOLATION

Ms. McMillin:

Pursuant to Public Utilities Code section 326 and Government Code section 15475.1, the Office of Energy Infrastructure Safety (Energy Safety) has conducted an inspection of work completed by San Diego Gas & Electric Company (SDG&E) in accordance with its 2024 Wildfire Mitigation Plan (WMP) and determined the existence of a violation. Energy Safety therefore issues SDG&E a Notice of Violation (NOV), identifying noncompliance with an approved WMP or any law, regulation, or guideline within the authority of the Office.<sup>1</sup>

On March 26, 2025, Energy Safety conducted an inspection of SDG&E's WMP initiatives in the vicinity of the city of Jamul, California. The inspection report is enclosed herewith. Energy Safety found the following violation:

Violation 1. Energy Safety observed that in implementing 2024 WMP initiative 8.1.4.6 – Lightning Arrester Removal and Replacement (WMP.550), SDG&E failed to install California Department of Forestry and Fire Protection (CAL FIRE) approved lightning arresters on Pole ID P971968, Grid Hardening ID 530000353825-P971968, at coordinates 32.7219091903663, -116.880932169034. Energy Safety considers this completeness violation to be in the Minor risk category.

---

<sup>1</sup> Cal. Code Regs., tit. 14, section 29302(b)(2)

## Response Options

Energy Safety may prescribe a timeframe for resolution of a violation associated with the assigned risk category.<sup>2</sup> Within 30 days from the issuance date of this NOV, the electrical corporation must provide a response advising Energy Safety of corrective actions taken or planned to remedy the above identified violation(s) and prevent recurrence. Alternatively, the electrical corporation must advise Energy Safety that it will not correct the violation, including the reasoning or justification for inaction and all supporting documentation.<sup>3</sup>

This response shall be filed in the Energy Safety e-Filing system under the 2024 NOV Docket<sup>4</sup> and the associated file name(s) must begin with the NOV identification number provided above.

Pursuant to Government Code section 15475.4, if the electrical corporation intends to request a hearing “to take public comment or present additional information,” it must also do so within the 30-day timeframe. If a petition for hearing is not received by the deadline, then the determination and conditions set forth in this NOV become final.

Prior to its response or request for hearing, the electrical corporation may also request an informal conference with Energy Safety’s Compliance Assurance Division for the purpose of disputing any issues raised in this NOV no later than five (5) business days before the response deadline.<sup>5</sup> Requests for informal conference with Energy Safety must be e-mailed to [compliance@energysafety.ca.gov](mailto:compliance@energysafety.ca.gov), with a copy sent to all Energy Safety Compliance Assurance Division staff identified in the NOV.

Pursuant to Public Utilities Code section 8389(g), following receipt of the electrical corporation’s response to this NOV and resolution of any disputes, this matter may be referred to the California Public Utilities Commission for its consideration of potential enforcement action, as it deems appropriate.

Sincerely,



Patrick Doherty  
Program Manager | Compliance Assurance Division  
Office of Energy Infrastructure Safety  
[Patrick.doherty@energysafety.ca.gov](mailto:Patrick.doherty@energysafety.ca.gov)

Cc:

Lena McMillin, SDG&E  
[rmcmillin@sdge.com](mailto:rmcmillin@sdge.com)

---

<sup>2</sup> Energy Safety Compliance Guidelines, pp. 3

<sup>3</sup> Energy Safety Compliance Guidelines, pp. 4-5

<sup>4</sup> <https://efiling.energysafety.ca.gov/EFiling/DocketInformation.aspx?docketnumber=2024%20NOV>

<sup>5</sup> Energy Safety Compliance Guidelines, p. 4

Jonathan Woldemariam, SDG&E

[Jwoldemariam@sdge.com](mailto:Jwoldemariam@sdge.com)

Kari Kloberdanz, SDG&E

[kkloberdanz@sdge.com](mailto:kkloberdanz@sdge.com)

Shewit Woldegiorgis, SDG&E

[swoldegiorgis@sdge.com](mailto:swoldegiorgis@sdge.com)

Laura Fulton, SDG&E

[Lfulton@sdge.com](mailto:Lfulton@sdge.com)

Shannon Downey, Energy Safety

[shannon.downey@energysafety.ca.gov](mailto:shannon.downey@energysafety.ca.gov)

Yana Loginova, Energy Safety

[Yana.Loginova@energysafety.ca.gov](mailto:Yana.Loginova@energysafety.ca.gov)

Samuel Isaiah, Energy Safety

[Samuel.Isaiah@energysafety.ca.gov](mailto:Samuel.Isaiah@energysafety.ca.gov)

[Compliance@energysafety.ca.gov](mailto:Compliance@energysafety.ca.gov)



# INSPECTION REPORT

## Overview

### Inspection Categories

The Office of Energy Infrastructure Safety (Energy Safety) conducts inspections to verify the work performed by an electrical corporation as reported in an approved Wildfire Mitigation Plan (WMP) or subsequent filing, and to assess general conditions of electrical infrastructure that may adversely impact an electrical corporation's wildfire risk.

A Notice of Violation (NOV) is issued for any instances of noncompliance discovered during an inspection related to an electrical corporation's execution of its WMP initiatives.

### Correction Timelines

Violations must be corrected in a timely manner. Energy Safety may prescribe a timeframe for resolution of a violation. If Energy Safety assigns a risk category to a violation, an electrical corporation must correct the violation as required per the timelines provided in Table 1.<sup>6</sup>

**Table 1. Risk Category and Correction Timelines**

Risk Category	Violation and defect correction timeline
Severe	<ul style="list-style-type: none"><li>• Immediate resolution</li></ul>
Moderate	<ul style="list-style-type: none"><li>• 2 months (in High Fire Threat District (HFTD) Tier 3)</li><li>• 6 months (in HFTD Tier 2)</li><li>• 6 months (if relevant to worker safety; not in HFTD Tiers 2 or 3)</li></ul>
Minor	<ul style="list-style-type: none"><li>• 12 months or resolution scheduled in WMP update</li></ul>

---

<sup>6</sup> Energy Safety Compliance Guidelines, p. 3



# Inspection Summary

Table 2 provides a summary of the selection of the WMP inspection location and initiative. Table 3 provides a summary of the violation(s) found during the inspection. Details regarding the inspection that identified the violation(s) are provided in the Inspections Details Section below.

***Table 2: Inspection Location and Initiative Summary***

Electrical Corporation:	San Diego Gas & Electric Company
Report Number:	CAD_SDG_SIS_20250326_0847
Inspector:	Samuel Isaiah
WMP Year Inspected:	2024
Quarterly Data Report (QDR) Referenced:	Quarter 4 (Q4)
Inspection Selection:	Energy Safety viewed the contents of the Q4 QDR and performed an analysis that resulted in the selection of the WMP initiatives and locations referenced in this report.
Relevant WMP Initiative(s):	8.1.4.6 Lightning Arrester Removal and Replacement (WMP.550)
Date of inspection:	March 26, 2025
City and/or County of Inspection:	Jamul, San Diego County
Inspection Purpose:	Assess the accuracy of San Diego Gas & Electric Company’s QDR data, completeness of its work, compliance with WMP requirements, and compliance with its protocols.

**Table 3: WMP Inspection Violation(s)**

Violation #	Structure ID	Grid Hardening ID	Lat/Long	HFTD	Initiative Number	Violation Type	Severity	Violation Description
Violation 1	P971968	530000353825 -P971968	32.721909190 3663, - 116.88093216 9034	Tier 3	8.1.4.6 - Lightning Arrester Removal and Replacement	Completeness	Minor	Failure to install CAL FIRE approved lightning arresters

# Inspection Details

## Violation 1:

### **Relevant Requirement:**

SDG&E's WMP states the following regarding initiative number 8.1.4.6 - Lightning Arrester Removal and Replacement:

1. "The Lightning Arresters Replacement Program (WMP.550) installs CAL FIRE-approved lightning arresters to mitigate the impact of transient overvoltage on the electric system... CAL FIRE-approved lightning arresters are equipped with an external device that operates prior to the arrester overloading, dramatically reducing the potential of becoming an ignition source."<sup>7</sup>

### **Finding:**

On Pole ID P971968, Grid Hardening ID 530000353825-P971968, at 3103-3129 Vista Diego Rd, Jamul, CA, 91935, USA, 32.7219091903663, -116.880932169034, the inspector observed that CAL FIRE-approved lightning arresters were not installed. The inspector's observation is documented in Violation 1 photographs, which are attachments to this report. Photo numbers Item1IA1Img1, Item1IA1Img2 and Item1IA1Img3 depict non-CAL FIRE-approved lightning arresters where CAL FIRE-approved lightning arresters were reported as replaced. Per the 2024 4<sup>th</sup> quarter Quarterly Data Report, SDG&E indicated that lightning arrester removal and replacement work was completed on this pole.

Energy Safety concludes there is a violation because of these facts:

1. San Diego Gas & Electric Company's 2024 WMP Initiative 8.1.4.6 – Lightning Arrester Removal and Replacement work was identified as complete at this location.
2. CAL FIRE-approved lightning arresters were not installed.

---

<sup>7</sup> San Diego Gas and Electric, "SDG&E 2023-25 Approved Wildfire Mitigation Plan," October 23, 2023, p. 219. [Online]. Available: <https://efiling.energysafety.ca.gov/eFiling/Getfile.aspx?fileid=55859&shareable=true>

# Exhibits

Exhibit A: Photo Log

Structure ID: P971968

Violation 1




Item1GImg1: Overall Pole



Item1GImg2: Pole ID




Item1IA1Img1: CAL FIRE-approved lightning arresters not installed



Item1IA1Img2: CAL FIRE-approved lightning arresters not installed





**Item1IA1Img3:** CAL FIRE-approved lightning arresters not installed