



July 09, 2025

Patrick Doherty, Compliance Program Manager Compliance Assurance Division Office of Energy Infrastructure Safety California Natural Resources Agency 715 P Street 20<sup>th</sup> Floor Sacramento, CA 95814 BY ENERGY SAFETY E-FILING

**SUBJECT:** Southern California Edison Company's Response to Notice of Violation

- NOV CAD SCE ATJ 20250520 1304

Dear Mr. Doherty:

Southern California Edison Company (SCE) appreciates the opportunity to provide this response to the finding identified in the Notice of Violation – NOV\_CAD\_SCE\_ATJ\_20250520\_1304 received on 6 13, 2025 (Notice), based on Energy Safety field inspections conducted in SCE's service area on May 20,2025. SCE appreciates the Office of Energy Infrastructure Safety's (Energy Safety) efforts to identify, communicate and work together to resolve potential wildfire risks. The enclosed response describes corrective actions taken or planned by SCE to remedy the finding identified in the above notice and to prevent recurrence.

If you have any questions, or require additional information, please contact Liz Leano at 626-302-3662 or Elizabeth.Leano@sce.com.

Sincerely,

//s//
Shinjini C Menon
Senior Vice President of System Planning & Engineering
Southern California Edison

## **SCE Response**

While SCE is not requesting a written hearing for the finding addressed in this response, SCE reserves the right to identify these facts and further explain its position in subsequent procedural stages and/or proceedings.<sup>1</sup> Although Energy Safety has the right to refer certain issues to the CPUC for an enforcement action, the finding in this Notice does not support such referral.<sup>2</sup>

## **Finding: Data Accuracy**

Notice	Violation	Structures
NOV_CAD_SCE_ATJ_20250520_1304	1	4864658E

## **Summary of Findings:**

Energy Safety's Notice states that in implementing 2024 WMP initiative 8.1.3.1 - Distribution Detailed Inspections and Remediations (IN-1.1), SCE failed to complete the remediation of rotated dead-end wildlife covers on pole ID 4864658E, Grid Hardening ID 413854385-4864658E at coordinates 34.422765, -118.419019.

Energy Safety considers this completeness violation to be in the Minor "risk" category."3

## Response:

SCE confirms that the rotated wildlife dead-end covers on structure ID 4864658E were remediated on October 25, 2024 (see photo evidence below) and that Energy Safety had discovered a recurrence of the issue. During an inspection in response to this Notice, SCE identified that the rotated wildlife dead-end covers were likely due to environmental exposure or other external factors leading to the recurrence of the condition. To remediate the issue, SCE will need to schedule an outage and install different types of nuts.

2

<sup>&</sup>lt;sup>1</sup> Government Code Section 15475.4 anticipates a "hearing" process, which traditionally implies an in-person hearing affording parties the right to present evidence and examine witnesses.

<sup>&</sup>lt;sup>2</sup> In the Notice, Energy Safety states that pursuant to Public Utilities Code section 8389(g), following receipt of SCE's response to this Notice and resolution of any disputes, this matter may be referred to the California Public Utilities Commission (CPUC) for its consideration of a potential enforcement action, as the CPUC deems appropriate. Notice, p. 2. The Notice discussed herein does not meet the requirement for Energy Safety referral for enforcement action to the CPUC based on the statutory requirements that Energy Safety referral be based on substantial compliance with WMPs. Energy Safety cites Public Utilities Code Section 8389(g) in support of a potential enforcement action. However, Section 8389(g) only provides for a possible enforcement action where "an electrical corporation is not in compliance with its approved wildfire mitigation plan." Public Utilities Code Section 8386.1 further specifies that penalties shall be assessed for failure to substantially comply with a WMP.

<sup>&</sup>lt;sup>3</sup> Notice, p. 1.

and bolts to prevent recurrence of the condition. The remediation is planned to be completed by the end of September 2025, and we will provide photo evidence once it has been completed.

Remediation Photos from 10/25/24 Below





